



LRC Indoor Testing and Research
 200 Commonwealth Ct, Suite 101
 Cary, NC 27511
 (919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Avenue
Nags Head, NC

Project #: 26-1542
Project Location: Nags Head Elementary
 3100 S. Wrightsville Avenue
 Nags Head, NC
Project Type: IAQ
PO/Claim #: -

Table 1: Non-Viable Air Samples

Date Collected:	6/8/26	6/8/26	6/8/26	6/8/26	6/8/26
	1	2	3	4	5
Spore Identification	Reception/Lobby	Gym	Cafeteria Serving Area	Music 121	Media Center
<i>Cladosporium</i>	27	-	13	13	40
Ascospores	-	27	-	13	13
Basidiospores ²	27	-	-	-	40
Smuts, <i>Periconia</i> , <i>Myxomycetes</i> ⁴	13	-	13	-	-
<i>Penicillium/Aspergillus</i> Group ¹	27	-	40	13	80
Hyphal Elements ³	40	-	13	-	67
<i>Alternaria</i>	-	-	-	-	-
<i>Curvularia</i>	-	-	-	-	27
<i>Epicoccum</i>	-	-	-	-	-
<i>Cercospora</i>	-	-	-	-	-
<i>Arthrrium</i>	-	-	-	-	-
Clear Brown	-	-	-	-	-
Colorless	-	-	-	-	-
<i>Trichocladium</i>	-	-	-	-	-
Unidentified	-	-	-	-	-
<i>Ulocladium</i>	-	-	-	-	-
<i>Torula</i>	-	-	-	-	-
<i>Pithomyces</i>	-	-	-	-	-
Rust ⁵	-	-	-	-	-
<i>Drechslera/Bipolaris</i>	13	-	-	-	-
<i>Tetraploa</i>	-	-	-	-	-
<i>Chaetomium</i>	-	-	-	-	-
<i>Stachybotrys</i>	-	-	-	-	-
	-	-	-	-	-
Total Spores/m³	147	27	80	40	267
Particulate Level	moderate	low	low-moderate	moderate	moderate
Date Analyzed:	6/24/26	6/24/26	6/24/26	6/24/26	6/24/26

The results reported by LRC are a record of the microbes identified by our laboratory staff. We assume responsibility over analysis conducted in the laboratory, but cannot assume responsibility for activities completed in the field by the client, other personnel associated with the samples submitted, or other activities beyond the laboratory. Any information given other than microbial information, is provided as general reference information from published sources and is not an extension of liability to LRC.



LRC Indoor Testing and Research
 200 Commonwealth Ct, Suite 101
 Cary, NC 27511
 (919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
 Ian Adams
 3020 S. Wrightsville Avenue
 Nags Head, NC

Project #: 26-1542
Project Location: Nags Head Elementary
 3100 S. Wrightsville Avenue
 Nags Head, NC
Project Type: IAQ
PO/Claim #: —

Table 1: Non-Viable Air Samples

Date Collected:	6/8/26	6/8/26	6/8/26	6/8/26	6/8/26
	6	7	8	9	10
Spore Identification	CR 131	CR136	Hall at 132	Hall at Elevator	CR153
<i>Cladosporium</i>	13	40	80	27	-
Ascospores	27	27	-	27	-
Basidiospores ²	-	27	13	-	13
Smuts, <i>Periconia</i> , <i>Myxomycetes</i> ⁴	13	-	-	-	-
<i>Penicillium/Aspergillus</i> Group ¹	-	40	40	13	40
Hyphal Elements ³	-	-	67	40	-
<i>Alternaria</i>	-	-	13	-	-
<i>Curvularia</i>	-	-	13	-	-
<i>Epicoccum</i>	13	-	13	13	-
<i>Cercospora</i>	-	-	13	-	-
<i>Arthrinium</i>	-	-	-	-	-
Clear Brown	-	-	-	-	-
Colorless	-	-	-	-	-
<i>Trichocladium</i>	-	-	-	-	-
Unidentified	-	-	-	-	-
<i>Ulocladium</i>	-	-	-	-	-
<i>Torula</i>	-	-	-	-	-
<i>Pithomyces</i>	-	-	-	13	-
Rust ⁵	-	-	-	-	-
<i>Drechslera/Bipolaris</i>	-	-	-	-	-
<i>Tetraploa</i>	-	-	-	-	-
<i>Chaetomium</i>	-	-	-	-	-
<i>Stachybotrys</i>	-	-	-	-	-
	-	-	-	-	-
Total Spores/m³	67	133	253	133	53
Particulate Level	low-moderate	moderate	low	low-moderate	low
Date Analyzed:	6/24/26	6/24/26	6/24/26	6/24/26	6/24/26

Analyzed by: Cathy A. Richmond, B.S.

The results reported by LRC are a record of the microbes identified by our laboratory staff. We assume responsibility over analysis conducted in the laboratory, but cannot assume responsibility for activities completed in the field by the client, other personnel associated with the samples submitted, or other activities beyond the laboratory. Any information given other than microbial information, is provided as general reference information from published sources and is not an extension of liability to LRC.



LRC Indoor Testing and Research
 200 Commonwealth Ct, Suite 101
 Cary, NC 27511
 (919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
 Ian Adams
 3020 S. Wrightsville Avenue
 Nags Head, NC

Project #: 26-1542
Project Location: Nags Head Elementary
 3100 S. Wrightsville Avenue
 Nags Head, NC
Project Type: IAQ
PO/Claim #: —

Table 1: Non-Viable Air Samples

Date Collected:	6/8/26	6/8/26	6/8/26	6/8/26	6/8/26
	11	12	13	14	15
Spore Identification	CR155	hall at CR155	CR217	Hall at 208/Bathrooms	CR203
<i>Cladosporium</i>	-	13	40	373	13
Ascospores	27	-	-	1547	-
Basidiospores ²	13	13	13	427	-
Smuts, <i>Periconia</i> , <i>Myxomycetes</i> ⁴	13	-	27	53	-
<i>Penicillium/Aspergillus</i> Group ¹	-	-	-	187	27
Hyphal Elements ³	-	-	-	-	-
<i>Alternaria</i>	-	-	-	-	-
<i>Curvularia</i>	-	-	-	-	-
<i>Epicoccum</i>	-	-	-	-	-
<i>Cercospora</i>	-	-	-	27	-
<i>Arthrinium</i>	-	-	-	-	-
Clear Brown	-	-	-	-	-
Colorless	-	-	-	-	-
<i>Trichocladium</i>	-	-	-	-	-
Unidentified	-	-	-	-	-
<i>Ulocladium</i>	-	-	-	-	-
<i>Torula</i>	-	-	-	-	-
<i>Pithomyces</i>	-	-	-	-	-
Rust ⁵	-	-	-	-	-
<i>Drechslera/Bipolaris</i>	-	-	-	-	-
<i>Tetraploa</i>	-	-	-	-	-
<i>Chaetomium</i>	-	-	-	-	-
<i>Stachybotrys</i>	-	-	-	-	-
	-	-	-	-	-
Total Spores/m³	53	27	80	2613	40
Particulate Level	low-moderate	low	low	low-moderate	low
Date Analyzed:	6/24/26	6/24/26	6/24/26	6/24/26	6/24/26

Analyzed by: Cathy A. Richmond, B.S.

The results reported by LRC are a record of the microbes identified by our laboratory staff. We assume responsibility over analysis conducted in the laboratory, but cannot assume responsibility for activities completed in the field by the client, other personnel associated with the samples submitted, or other activities beyond the laboratory. Any information given other than microbial information, is provided as general reference information from published sources and is not an extension of liability to LRC.



LRC Indoor Testing and Research
 200 Commonwealth Ct, Suite 101
 Cary, NC 27511
 (919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
 Ian Adams
 3020 S. Wrightsville Avenue
 Nags Head, NC

Project #: 26-1542
Project Location: Nags Head Elementary
 3100 S. Wrightsville Avenue
 Nags Head, NC
Project Type: IAQ
PO/Claim #: -

Table 1: Non-Viable Air Samples

Date Collected:	6/8/26	6/8/26	6/8/26	6/8/26	6/8/26
	16	17	18	19	20
Spore Identification	CR234	CR233	CR239	Hall at CR239	Outdoor Air
<i>Cladosporium</i>	53	40	-	27	533
Ascospores	27	27	13	27	1093
Basidiospores ²	27	13	-	-	400
Smuts, <i>Periconia</i> , <i>Myxomycetes</i> ⁴	-	-	-	-	53
<i>Penicillium/Aspergillus</i> Group ¹	13	-	13	13	53
Hyphal Elements ³	-	53	13	13	27
<i>Alternaria</i>	-	-	-	-	-
<i>Curvularia</i>	-	-	-	-	-
<i>Epicoccum</i>	-	-	-	-	-
<i>Cercospora</i>	-	-	-	-	-
<i>Arthrimum</i>	-	-	-	-	-
Clear Brown	-	-	-	-	-
Colorless	-	-	-	-	-
<i>Trichocladium</i>	-	-	-	-	-
Unidentified	-	-	-	-	-
<i>Ulocladium</i>	-	-	-	-	-
<i>Torula</i>	-	-	-	-	-
<i>Pithomyces</i>	-	27	-	-	-
Rust ⁵	-	-	-	-	-
<i>Drechslera/Bipolaris</i>	-	-	-	-	-
<i>Tetraploa</i>	-	-	-	-	-
<i>Chaetomium</i>	-	-	-	-	-
<i>Stachybotrys</i>	-	-	-	-	-
	-	-	-	-	-
Total Spores/m³	120	160	40	80	2160
Particulate Level	low-moderate	low-moderate	low	low-moderate	low-moderate
Date Analyzed:	6/24/26	6/24/26	6/24/26	6/24/26	6/24/26

Analyzed by: Cathy A. Richmond, B.S.

The results reported by LRC are a record of the microbes identified by our laboratory staff. We assume responsibility over analysis conducted in the laboratory, but cannot assume responsibility for activities completed in the field by the client, other personnel associated with the samples submitted, or other activities beyond the laboratory. Any information given other than microbial information, is provided as general reference information from published sources and is not an extension of liability to LRC.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Avenue
Nags Head, NC

Project #: 26-1542
Project Location: Nags Head Elementary
3100 S. Wrightsville Avenue
Nags Head, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 1
Sample Location: Reception/Lobby
Date Collected: 6/8/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/24/26

Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: moderate
Notes: No Spores Seen

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	2	27	spores/m ³	18%
Ascospores		-	spores/m ³	-
Basidiospores	2	27	spores/m ³	18%
Smuts, <i>Periconia</i> , Myxomycetes	1	13	spores/m ³	9%
<i>Penicillium/Aspergillus</i> Group	2	27	spores/m ³	18%
Hyphal Elements	3	40	spores/m ³	27%
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>	1	13	spores/m ³	9%
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	11	147	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
 200 Commonwealth Ct, Suite 101
 Cary, NC 27511
 (919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Avenue
Nags Head, NC

Project #: 26-1542
Project Location: Nags Head Elementary
 3100 S. Wrightsville Avenue
 Nags Head, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 2
Sample Location: Gym
Date Collected: 6/8/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/24/26

Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>		-	spores/m ³	-
Ascospores	2	27	spores/m ³	100%
Basidiospores		-	spores/m ³	-
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group		-	spores/m ³	-
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrimum</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	2	27	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Avenue
Nags Head, NC

Project #: 26-1542
Project Location: Nags Head Elementary
3100 S. Wrightsville Avenue
Nags Head, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 3
Sample Location: Cafeteria Serving Area
Date Collected: 6/8/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/24/26

Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low-moderate
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	1	13	spores/m ³	17%
Ascospores		-	spores/m ³	-
Basidiospores		-	spores/m ³	-
Smuts, <i>Periconia</i> , Myxomycetes	1	13	spores/m ³	17%
<i>Penicillium/Aspergillus</i> Group	3	40	spores/m ³	50%
Hyphal Elements	1	13	spores/m ³	17%
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	6	80	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Avenue
Nags Head, NC

Project #: 26-1542
Project Location: Nags Head Elementary
3100 S. Wrightsville Avenue
Nags Head, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 4
Sample Location: Music 121
Date Collected: 6/8/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/24/26

Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: moderate
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	1	13	spores/m ³	33%
Ascospores	1	13	spores/m ³	33%
Basidiospores		-	spores/m ³	-
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group	1	13	spores/m ³	33%
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	3	40	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Avenue
Nags Head, NC

Project #: 26-1542
Project Location: Nags Head Elementary
3100 S. Wrightsville Avenue
Nags Head, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 5
Sample Location: Media Center
Date Collected: 6/8/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/24/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: moderate
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	3	40	spores/m ³	15%
Ascospores	1	13	spores/m ³	5%
Basidiospores	3	40	spores/m ³	15%
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group	6	80	spores/m ³	30%
Hyphal Elements	5	67	spores/m ³	25%
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>	2	27	spores/m ³	10%
<i>Epicoecum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	20	267	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
 200 Commonwealth Ct, Suite 101
 Cary, NC 27511
 (919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Avenue
Nags Head, NC

Project #: 26-1542
Project Location: Nags Head Elementary
 3100 S. Wrightsville Avenue
 Nags Head, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 6
Sample Location: CR 131
Date Collected: 6/8/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/24/26

Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low-moderate
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	1	13	spores/m ³	20%
Ascospores	2	27	spores/m ³	40%
Basidiospores		-	spores/m ³	-
Smuts, <i>Periconia</i> , Myxomycetes	1	13	spores/m ³	20%
<i>Penicillium/Aspergillus</i> Group		-	spores/m ³	-
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>	1	13	spores/m ³	20%
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	5	67	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Avenue
Nags Head, NC

Project #: 26-1542
Project Location: Nags Head Elementary
3100 S. Wrightsville Avenue
Nags Head, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 7
Sample Location: CR136
Date Collected: 6/8/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/24/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: moderate
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	3	40	spores/m ³	30%
Ascospores	2	27	spores/m ³	20%
Basidiospores	2	27	spores/m ³	20%
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group	3	40	spores/m ³	30%
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	10	133	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Avenue
Nags Head, NC

Project #: 26-1542
Project Location: Nags Head Elementary
3100 S. Wrightsville Avenue
Nags Head, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 8
Sample Location: Hall at 132
Date Collected: 6/8/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/24/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	6	80	spores/m ³	32%
Ascospores		-	spores/m ³	-
Basidiospores	1	13	spores/m ³	5%
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group	3	40	spores/m ³	16%
Hyphal Elements	5	67	spores/m ³	26%
<i>Alternaria</i>	1	13	spores/m ³	5%
<i>Curvularia</i>	1	13	spores/m ³	5%
<i>Epicoecum</i>	1	13	spores/m ³	5%
<i>Cercospora</i>	1	13	spores/m ³	5%
<i>Arthrimum</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	19	253	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Avenue
Nags Head, NC

Project #: 26-1542
Project Location: Nags Head Elementary
3100 S. Wrightsville Avenue
Nags Head, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 9
Sample Location: Hall at Elevator
Date Collected: 6/8/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/24/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low-moderate
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	2	27	spores/m ³	20%
Ascospores	2	27	spores/m ³	20%
Basidiospores		-	spores/m ³	-
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group	1	13	spores/m ³	10%
Hyphal Elements	3	40	spores/m ³	30%
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoecum</i>	1	13	spores/m ³	10%
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>	1	13	spores/m ³	10%
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	10	133	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
 200 Commonwealth Ct, Suite 101
 Cary, NC 27511
 (919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Avenue
Nags Head, NC

Project #: 26-1542
Project Location: Nags Head Elementary
 3100 S. Wrightsville Avenue
 Nags Head, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 10
Sample Location: CR153
Date Collected: 6/8/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/24/26

Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>		-	spores/m ³	-
Ascospores		-	spores/m ³	-
Basidiospores	1	13	spores/m ³	25%
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group	3	40	spores/m ³	75%
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	4	53	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Avenue
Nags Head, NC

Project #: 26-1542
Project Location: Nags Head Elementary
3100 S. Wrightsville Avenue
Nags Head, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 11
Sample Location: CR155
Date Collected: 6/8/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/24/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low-moderate
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>		-	spores/m ³	-
Ascospores	2	27	spores/m ³	50%
Basidiospores	1	13	spores/m ³	25%
Smuts, <i>Periconia</i> , Myxomycetes	1	13	spores/m ³	25%
<i>Penicillium/Aspergillus</i> Group		-	spores/m ³	-
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	4	53	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Avenue
Nags Head, NC

Project #: 26-1542
Project Location: Nags Head Elementary
3100 S. Wrightsville Avenue
Nags Head, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 12
Sample Location: hall at CR155
Date Collected: 6/8/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/24/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	1	13	spores/m ³	50%
Ascospores		-	spores/m ³	-
Basidiospores	1	13	spores/m ³	50%
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group		-	spores/m ³	-
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	2	27	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Avenue
Nags Head, NC

Project #: 26-1542
Project Location: Nags Head Elementary
3100 S. Wrightsville Avenue
Nags Head, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 13
Sample Location: CR217
Date Collected: 6/8/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/24/26

Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	3	40	spores/m ³	50%
Ascospores		-	spores/m ³	-
Basidiospores	1	13	spores/m ³	17%
Smuts, <i>Periconia</i> , Myxomycetes	2	27	spores/m ³	33%
<i>Penicillium/Aspergillus</i> Group		-	spores/m ³	-
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	6	80	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Avenue
Nags Head, NC

Project #: 26-1542
Project Location: Nags Head Elementary
3100 S. Wrightsville Avenue
Nags Head, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 14
Sample Location: Hall at 208/Bathrooms
Date Collected: 6/8/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/24/26

Volume (L): 75
Percentage of Slide Read: 50.0%
Detection Limit: 26.67
Particulate Level: low-moderate
No Spores Seen —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	14	373	spores/m ³	14%
Ascospores	58	1547	spores/m ³	59%
Basidiospores	16	427	spores/m ³	16%
Smuts, <i>Periconia</i> , Myxomycetes	2	53	spores/m ³	2%
<i>Penicillium/Aspergillus</i> Group	7	187	spores/m ³	7%
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>	1	27	spores/m ³	1%
<i>Arthrinium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	98	2613	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Avenue
Nags Head, NC

Project #: 26-1542
Project Location: Nags Head Elementary
3100 S. Wrightsville Avenue
Nags Head, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 15
Sample Location: CR203
Date Collected: 6/8/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/24/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	1	13	spores/m ³	33%
Ascospores		-	spores/m ³	-
Basidiospores		-	spores/m ³	-
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group	2	27	spores/m ³	67%
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	3	40	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Avenue
Nags Head, NC

Project #: 26-1542
Project Location: Nags Head Elementary
3100 S. Wrightsville Avenue
Nags Head, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 16
Sample Location: CR234
Date Collected: 6/8/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/24/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low-moderate
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	4	53	spores/m ³	44%
Ascospores	2	27	spores/m ³	22%
Basidiospores	2	27	spores/m ³	22%
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group	1	13	spores/m ³	11%
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	9	120	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Avenue
Nags Head, NC

Project #: 26-1542
Project Location: Nags Head Elementary
3100 S. Wrightsville Avenue
Nags Head, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 17
Sample Location: CR233
Date Collected: 6/8/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/24/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low-moderate
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	3	40	spores/m ³	25%
Ascospores	2	27	spores/m ³	17%
Basidiospores	1	13	spores/m ³	8%
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group		-	spores/m ³	-
Hyphal Elements	4	53	spores/m ³	33%
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>	2	27	spores/m ³	17%
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	12	160	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Avenue
Nags Head, NC

Project #: 26-1542
Project Location: Nags Head Elementary
3100 S. Wrightsville Avenue
Nags Head, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 18
Sample Location: CR239
Date Collected: 6/8/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/24/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>		-	spores/m ³	-
Ascospores	1	13	spores/m ³	33%
Basidiospores		-	spores/m ³	-
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group	1	13	spores/m ³	33%
Hyphal Elements	1	13	spores/m ³	33%
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	3	40	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Avenue
Nags Head, NC

Project #: 26-1542
Project Location: Nags Head Elementary
3100 S. Wrightsville Avenue
Nags Head, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 19
Sample Location: Hall at CR239
Date Collected: 6/8/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/24/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low-moderate
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	2	27	spores/m ³	33%
Ascospores	2	27	spores/m ³	33%
Basidiospores		-	spores/m ³	-
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group	1	13	spores/m ³	17%
Hyphal Elements	1	13	spores/m ³	17%
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	6	80	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Avenue
Nags Head, NC

Project #: 26-1542
Project Location: Nags Head Elementary
3100 S. Wrightsville Avenue
Nags Head, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 20
Sample Location: Outdoor Air
Date Collected: 6/8/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/24/26
Volume (L): 75
Percentage of Slide Read: 50.0%
Detection Limit: 26.67
Particulate Level: low-moderate
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	20	533	spores/m ³	25%
Ascospores	41	1093	spores/m ³	51%
Basidiospores	15	400	spores/m ³	19%
Smuts, <i>Periconia</i> , Myxomycetes	2	53	spores/m ³	2%
<i>Penicillium/Aspergillus</i> Group	2	53	spores/m ³	2%
Hyphal Elements	1	27	spores/m ³	1%
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	81	2160	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Project #: **26-1542**

Report Information:

DETECTION LIMITS (DL) for samples are the minimum number of spores or colonies forming units that can be satisfactorily identified for each sample type.

SPORE TRAP SAMPLES: Calculations based on volume of air sampled & percentage of slide counted, i.e. DL = 1000 L / 75 L if 100% of the slide is counted.

CODE 11: Fungal content and/or particulate level on slide too heavy to identify and enumerate fungal content.

Footnotes:

1. *Penicillium/Aspergillus* group spores are characterized by their small size, round to ovoid shape, being unicellular and usually colorless to lightly pigmented. There are numerous genera of fungi whose spore morphology is similar to that of the *Penicillium/Aspergillus* type. Several common examples would be *Acremonium*, *Paecilomyces*, and *Trichoderma*. Although the majority of spores placed in this group are *Penicillium*, *Aspergillus*, or a combination of both, these are not the only two possibilities.
2. Basidiospores are primarily transported indoors from outdoor sources and rarely grow indoors. A high basidiospore count indoors can be indicative of a wood decay problem or wet soil, and should be verified if and an outdoor source of the spores is not present.
3. Hyphae are the tubular filaments of fungi. Hyphae can fragment and become airborne much like spores and are potentially allergenic.
4. The Smut, *Periconia*, Myxomycete group is a group composed of three different types of organisms whose spores have similar morphologies. Smuts are plant pathogens, *Periconia* is a relatively uncommon mold indoors, and Myxomycetes are not fungi, but slime molds. Although these organisms do not typically proliferate indoors, their spores are potentially allergenic.
5. Rusts are plant pathogens. These fungi do not typically grow indoors unless an infected plant is present. Rust spores are potentially allergenic.

Direct Microscopic Exam Reporting:

We use a 400x-600x magnification microscope.

Reporting Quantification Levels are as follows:

Reporting Level	Quantitative Description
Occasional	1-10 per square inch
Few	11-100 per square inch
Moderate	101-1000 per square inch
Numerous	More than 1,000 per square inch

Submitted By Analyst:

Cathy A. Richmond, BS

6/24/2026