



LRC Indoor Testing and Research
 200 Commonwealth Ct, Suite 101
 Cary, NC 27511
 (919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S Wrightsville Ave.
Nags Head, NC

Project #: 26-1543
Project Location: Kitty Hawk Elementary
 16 S Dogwood Trail
 Kitty Hawk, NC
Project Type: IAQ
PO/Claim #: -

Table 1: Non-Viable Air Samples

Date Collected:	6/12/26	6/12/26	6/12/26	6/12/26	6/12/26
	1	2	3	4	5
Spore Identification	Reception Lobby	Media Center	D116 Art	D124	D133
<i>Cladosporium</i>	40	13	13	13	27
Ascospores	13	-	-	-	13
Basidiospores ²	13	-	-	-	-
Smuts, <i>Periconia</i> , <i>Myxomycetes</i> ⁴	53	13	-	-	-
<i>Penicillium/Aspergillus</i> Group ¹	40	27	-	27	-
Hyphal Elements ³	40	-	-	13	-
<i>Alternaria</i>	-	-	-	-	-
<i>Curvularia</i>	27	-	-	-	-
<i>Epicoccum</i>	-	-	-	-	-
<i>Cercospora</i>	13	-	-	-	-
<i>Arthrinium</i>	-	-	-	-	-
Clear Brown	-	-	-	-	-
Colorless	-	-	-	-	-
<i>Trichocladium</i>	-	-	-	-	-
Unidentified	-	-	-	-	-
<i>Ulocladium</i>	-	-	-	-	-
<i>Torula</i>	-	-	-	-	-
<i>Pithomyces</i>	13	-	-	-	-
Rust ⁵	-	-	-	-	-
<i>Drechslera/Bipolaris</i>	-	-	-	-	-
<i>Tetraploa</i>	-	-	-	-	-
<i>Chaetomium</i>	-	-	-	-	-
<i>Stachybotrys</i>	-	-	-	-	-
	-	-	-	-	-
Total Spores/m³	253	53	13	53	40
Particulate Level	moderate	low	low	low	low
Date Analyzed:	6/26/26	6/26/26	6/26/26	6/26/26	6/26/26

Analyzed by: Cathy A. Richmond, B.S.

The results reported by LRC are a record of the microbes identified by our laboratory staff. We assume responsibility over analysis conducted in the laboratory, but cannot assume responsibility for activities completed in the field by the client, other personnel associated with the samples submitted, or other activities beyond the laboratory. Any information given other than microbial information, is provided as general reference information from published sources and is not an extension of liability to LRC.



LRC Indoor Testing and Research
 200 Commonwealth Ct, Suite 101
 Cary, NC 27511
 (919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
 Ian Adams
 3020 S Wrightsville Ave.
 Nags Head, NC

Project #: 26-1543
Project Location: Kitty Hawk Elementary
 16 S Dogwood Trail
 Kitty Hawk, NC
Project Type: IAQ
PO/Claim #: —

Table 1: Non-Viable Air Samples

Date Collected:	6/12/26	6/12/26	6/12/26	6/12/26	6/12/26
	6	7	8	9	10
Spore Identification	D106	D Hall at Restrooms	E105	Hall at Gym	Cafeteria
<i>Cladosporium</i>	13	-	13	27	13
Ascospores	-	13	13	13	13
Basidiospores ²	-	13	27	-	13
Smuts, <i>Periconia</i> , <i>Myxomycetes</i> ⁴	-	-	-	-	-
<i>Penicillium/Aspergillus</i> Group ¹	-	40	27	-	40
Hyphal Elements ³	-	13	13	-	13
<i>Alternaria</i>	-	-	-	-	-
<i>Curvularia</i>	-	-	-	-	-
<i>Epicoccum</i>	-	-	-	-	13
<i>Cercospora</i>	-	-	-	-	-
<i>Arthrinium</i>	-	-	-	-	-
Clear Brown	-	-	-	-	-
Colorless	-	-	-	-	-
<i>Trichocladium</i>	-	-	-	-	-
Unidentified	-	-	-	-	-
<i>Ulocladium</i>	-	-	-	-	-
<i>Torula</i>	-	-	-	-	-
<i>Pithomyces</i>	-	27	-	-	-
Rust ⁵	-	-	-	-	-
<i>Drechslera/Bipolaris</i>	-	-	-	-	-
<i>Tetraploa</i>	-	-	-	-	-
<i>Chaetomium</i>	-	-	-	-	-
<i>Stachybotrys</i>	-	-	-	-	-
	-	-	-	-	-
Total Spores/m³	13	107	93	40	107
Particulate Level	low	low-moderate	low-moderate	low	low
Date Analyzed:	6/26/26	6/26/26	6/26/26	6/26/26	6/26/26

Analyzed by: Cathy A. Richmond, B.S.

The results reported by LRC are a record of the microbes identified by our laboratory staff. We assume responsibility over analysis conducted in the laboratory, but cannot assume responsibility for activities completed in the field by the client, other personnel associated with the samples submitted, or other activities beyond the laboratory. Any information given other than microbial information, is provided as general reference information from published sources and is not an extension of liability to LRC.



LRC Indoor Testing and Research
 200 Commonwealth Ct, Suite 101
 Cary, NC 27511
 (919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
 Ian Adams
 3020 S Wrightsville Ave.
 Nags Head, NC

Project #: 26-1543
Project Location: Kitty Hawk Elementary
 16 S Dogwood Trail
 Kitty Hawk, NC
Project Type: IAQ
PO/Claim #: —

Table 1: Non-Viable Air Samples

Date Collected:	6/12/26	6/12/26	6/12/26	6/12/26	6/12/26
	11	12	13	14	15
Spore Identification	A111	A110	Hall at A107	A102	B112
<i>Cladosporium</i>	40	-	40	-	13
Ascospores	53	-	-	-	-
Basidiospores ²	27	27	13	13	27
Smuts, <i>Periconia</i> , <i>Myxomycetes</i> ⁴	-	13	-	13	-
<i>Penicillium/Aspergillus</i> Group ¹	13	-	13	-	13
Hyphal Elements ³	27	-	-	-	-
<i>Alternaria</i>	-	-	-	-	-
<i>Curvularia</i>	-	-	-	-	-
<i>Epicoccum</i>	-	-	-	-	-
<i>Cercospora</i>	13	-	-	-	13
<i>Arthrinium</i>	-	-	-	-	-
Clear Brown	-	-	-	-	-
Colorless	-	-	-	-	-
<i>Trichocladium</i>	-	-	-	-	-
Unidentified	-	-	-	-	-
<i>Ulocladium</i>	-	-	-	-	-
<i>Torula</i>	-	-	-	-	-
<i>Pithomyces</i>	-	-	-	-	-
Rust ⁵	-	-	-	-	-
<i>Drechslera/Bipolaris</i>	-	-	-	-	-
<i>Tetraploa</i>	-	-	-	-	-
<i>Chaetomium</i>	-	-	-	-	-
<i>Stachybotrys</i>	-	-	-	-	-
	-	-	-	-	-
Total Spores/m³	173	40	67	27	67
Particulate Level	low-moderate	low	low	low-moderate	low-moderate
Date Analyzed:	6/26/26	6/26/26	6/26/26	6/26/26	6/26/26

Analyzed by: Cathy A. Richmond, B.S.

The results reported by LRC are a record of the microbes identified by our laboratory staff. We assume responsibility over analysis conducted in the laboratory, but cannot assume responsibility for activities completed in the field by the client, other personnel associated with the samples submitted, or other activities beyond the laboratory. Any information given other than microbial information, is provided as general reference information from published sources and is not an extension of liability to LRC.



LRC Indoor Testing and Research
 200 Commonwealth Ct, Suite 101
 Cary, NC 27511
 (919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
 Ian Adams
 3020 S Wrightsville Ave.
 Nags Head, NC

Project #: 26-1543
Project Location: Kitty Hawk Elementary
 16 S Dogwood Trail
 Kitty Hawk, NC
Project Type: IAQ
PO/Claim #: —

Table 1: Non-Viable Air Samples

Date Collected:	6/12/26	6/12/26	6/12/26	6/12/26
	16	17	18	19
Spore Identification	B109	Hall at B106	B101	Outdoor Air
<i>Cladosporium</i>	-	13	13	1733
Ascospores	-	27	-	667
Basidiospores ²	27	-	-	240
Smuts, <i>Periconia</i> , <i>Myxomycetes</i> ⁴	-	-	-	80
<i>Penicillium/Aspergillus</i> Group ¹	-	27	27	107
Hyphal Elements ³	-	-	13	27
<i>Alternaria</i>	-	-	13	-
<i>Curvularia</i>	-	-	-	27
<i>Epicoccum</i>	-	-	-	-
<i>Cercospora</i>	-	-	-	27
<i>Arthrimum</i>	-	-	-	-
Clear Brown	-	-	-	-
Colorless	-	-	-	-
<i>Trichocladium</i>	-	-	-	-
Unidentified	-	-	-	-
<i>Ulocladium</i>	-	-	-	-
Torula	-	-	-	-
<i>Pithomyces</i>	-	-	-	-
Rust ⁵	-	-	-	-
<i>Drechslera/Bipolaris</i>	-	-	-	27
<i>Tetraploa</i>	-	-	-	-
<i>Chaetomium</i>	-	-	-	-
<i>Stachybotrys</i>	-	-	-	-
	-	-	-	-
Total Spores/m³	27	67	67	2933
Particulate Level	low	low-moderate	low-moderate	moderate
Date Analyzed:	6/26/26	6/26/26	6/26/26	6/26/26

Analyzed by: Cathy A. Richmond, B.S.

The results reported by LRC are a record of the microbes identified by our laboratory staff. We assume responsibility over analysis conducted in the laboratory, but cannot assume responsibility for activities completed in the field by the client, other personnel associated with the samples submitted, or other activities beyond the laboratory. Any information given other than microbial information, is provided as general reference information from published sources and is not an extension of liability to LRC.



LRC Indoor Testing and Research
 200 Commonwealth Ct, Suite 101
 Cary, NC 27511
 (919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S Wrightsville Ave.
Nags Head, NC

Project #: 26-1543
Project Location: Kitty Hawk Elementary
 16 S Dogwood Trail
 Kitty Hawk, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 1
Sample Location: Reception Lobby
Date Collected: 6/12/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/26/26

Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: moderate
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	3	40	spores/m ³	16%
Ascospores	1	13	spores/m ³	5%
Basidiospores	1	13	spores/m ³	5%
Smuts, <i>Periconia</i> , Myxomycetes	4	53	spores/m ³	21%
<i>Penicillium/Aspergillus</i> Group	3	40	spores/m ³	16%
Hyphal Elements	3	40	spores/m ³	16%
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>	2	27	spores/m ³	11%
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>	1	13	spores/m ³	5%
<i>Arthrinium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>	1	13	spores/m ³	5%
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	19	253	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
 200 Commonwealth Ct, Suite 101
 Cary, NC 27511
 (919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S Wrightsville Ave.
Nags Head, NC

Project #: 26-1543
Project Location: Kitty Hawk Elementary
 16 S Dogwood Trail
 Kitty Hawk, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 2
Sample Location: Media Center
Date Collected: 6/12/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/26/26

Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	1	13	spores/m ³	25%
Ascospores		-	spores/m ³	-
Basidiospores		-	spores/m ³	-
Smuts, <i>Periconia</i> , Myxomycetes	1	13	spores/m ³	25%
<i>Penicillium/Aspergillus</i> Group	2	27	spores/m ³	50%
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	4	53	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S Wrightsville Ave.
Nags Head, NC

Project #: 26-1543
Project Location: Kitty Hawk Elementary
16 S Dogwood Trail
Kitty Hawk, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 3
Sample Location: D116 Art
Date Collected: 6/12/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/26/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	1	13	spores/m ³	100%
Ascospores		-	spores/m ³	-
Basidiospores		-	spores/m ³	-
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group		-	spores/m ³	-
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	1	13	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S Wrightsville Ave.
Nags Head, NC

Project #: 26-1543
Project Location: Kitty Hawk Elementary
16 S Dogwood Trail
Kitty Hawk, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 4
Sample Location: D124
Date Collected: 6/12/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/26/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	1	13	spores/m ³	25%
Ascospores		-	spores/m ³	-
Basidiospores		-	spores/m ³	-
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium</i> / <i>Aspergillus</i> Group	2	27	spores/m ³	50%
Hyphal Elements	1	13	spores/m ³	25%
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera</i> / <i>Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	4	53	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S Wrightsville Ave.
Nags Head, NC

Project #: 26-1543
Project Location: Kitty Hawk Elementary
16 S Dogwood Trail
Kitty Hawk, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 5
Sample Location: D133
Date Collected: 6/12/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/26/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	2	27	spores/m ³	67%
Ascospores	1	13	spores/m ³	33%
Basidiospores		-	spores/m ³	-
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group		-	spores/m ³	-
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	3	40	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
 200 Commonwealth Ct, Suite 101
 Cary, NC 27511
 (919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S Wrightsville Ave.
Nags Head, NC

Project #: 26-1543
Project Location: Kitty Hawk Elementary
 16 S Dogwood Trail
 Kitty Hawk, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 6
Sample Location: D106
Date Collected: 6/12/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/26/26

Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	1	13	spores/m ³	100%
Ascospores		-	spores/m ³	-
Basidiospores		-	spores/m ³	-
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group		-	spores/m ³	-
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	1	13	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S Wrightsville Ave.
Nags Head, NC

Project #: 26-1543
Project Location: Kitty Hawk Elementary
16 S Dogwood Trail
Kitty Hawk, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 7
Sample Location: D Hall at Restrooms
Date Collected: 6/12/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/26/26

Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low-moderate
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>		-	spores/m ³	-
Ascospores	1	13	spores/m ³	13%
Basidiospores	1	13	spores/m ³	13%
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group	3	40	spores/m ³	38%
Hyphal Elements	1	13	spores/m ³	13%
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>	2	27	spores/m ³	25%
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	8	107	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S Wrightsville Ave.
Nags Head, NC

Project #: 26-1543
Project Location: Kitty Hawk Elementary
16 S Dogwood Trail
Kitty Hawk, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 8
Sample Location: E105
Date Collected: 6/12/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/26/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low-moderate
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	1	13	spores/m ³	14%
Ascospores	1	13	spores/m ³	14%
Basidiospores	2	27	spores/m ³	29%
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group	2	27	spores/m ³	29%
Hyphal Elements	1	13	spores/m ³	14%
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	7	93	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S Wrightsville Ave.
Nags Head, NC

Project #: 26-1543
Project Location: Kitty Hawk Elementary
16 S Dogwood Trail
Kitty Hawk, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 9
Sample Location: Hall at Gym
Date Collected: 6/12/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/26/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	2	27	spores/m ³	67%
Ascospores	1	13	spores/m ³	33%
Basidiospores		-	spores/m ³	-
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group		-	spores/m ³	-
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	3	40	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S Wrightsville Ave.
Nags Head, NC

Project #: 26-1543
Project Location: Kitty Hawk Elementary
16 S Dogwood Trail
Kitty Hawk, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 10
Sample Location: Cafeteria
Date Collected: 6/12/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/26/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	1	13	spores/m ³	13%
Ascospores	1	13	spores/m ³	13%
Basidiospores	1	13	spores/m ³	13%
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group	3	40	spores/m ³	38%
Hyphal Elements	1	13	spores/m ³	13%
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>	1	13	spores/m ³	13%
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	8	107	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S Wrightsville Ave.
Nags Head, NC

Project #: 26-1543
Project Location: Kitty Hawk Elementary
16 S Dogwood Trail
Kitty Hawk, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 11
Sample Location: A111
Date Collected: 6/12/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/26/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low-moderate
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	3	40	spores/m ³	23%
Ascospores	4	53	spores/m ³	31%
Basidiospores	2	27	spores/m ³	15%
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group	1	13	spores/m ³	8%
Hyphal Elements	2	27	spores/m ³	15%
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>	1	13	spores/m ³	8%
<i>Arthrinium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	13	173	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
 200 Commonwealth Ct, Suite 101
 Cary, NC 27511
 (919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S Wrightsville Ave.
Nags Head, NC

Project #: **26-1543**
Project Location: Kitty Hawk Elementary
 16 S Dogwood Trail
 Kitty Hawk, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 12	Volume (L): 75
Sample Location: A110	Percentage of Slide Read: 100.0%
Date Collected: 6/12/26	Detection Limit: 13.33
Test Requested: Non-viable spore trap analysis	Particulate Level: low
Date Analyzed: 6/26/26	Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>		-	spores/m ³	-
Ascospores		-	spores/m ³	-
Basidiospores	2	27	spores/m ³	67%
Smuts, <i>Periconia</i> , Myxomycetes	1	13	spores/m ³	33%
<i>Penicillium/Aspergillus</i> Group		-	spores/m ³	-
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	3	40	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S Wrightsville Ave.
Nags Head, NC

Project #: 26-1543
Project Location: Kitty Hawk Elementary
16 S Dogwood Trail
Kitty Hawk, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 13
Sample Location: Hall at A107
Date Collected: 6/12/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/26/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	3	40	spores/m ³	60%
Ascospores		-	spores/m ³	-
Basidiospores	1	13	spores/m ³	20%
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group	1	13	spores/m ³	20%
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	5	67	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S Wrightsville Ave.
Nags Head, NC

Project #: 26-1543
Project Location: Kitty Hawk Elementary
16 S Dogwood Trail
Kitty Hawk, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 14
Sample Location: A102
Date Collected: 6/12/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/26/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low-moderate
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>		-	spores/m ³	-
Ascospores		-	spores/m ³	-
Basidiospores	1	13	spores/m ³	50%
Smuts, <i>Periconia</i> , Myxomycetes	1	13	spores/m ³	50%
<i>Penicillium/Aspergillus</i> Group		-	spores/m ³	-
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	2	27	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S Wrightsville Ave.
Nags Head, NC

Project #: 26-1543
Project Location: Kitty Hawk Elementary
16 S Dogwood Trail
Kitty Hawk, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 15
Sample Location: B112
Date Collected: 6/12/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/26/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low-moderate
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	1	13	spores/m ³	20%
Ascospores		-	spores/m ³	-
Basidiospores	2	27	spores/m ³	40%
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group	1	13	spores/m ³	20%
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoecum</i>		-	spores/m ³	-
<i>Cercospora</i>	1	13	spores/m ³	20%
<i>Arthrimum</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	5	67	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S Wrightsville Ave.
Nags Head, NC

Project #: 26-1543
Project Location: Kitty Hawk Elementary
16 S Dogwood Trail
Kitty Hawk, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 16
Sample Location: B109
Date Collected: 6/12/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/26/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>		-	spores/m ³	-
Ascospores		-	spores/m ³	-
Basidiospores	2	27	spores/m ³	100%
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium</i> / <i>Aspergillus</i> Group		-	spores/m ³	-
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera</i> / <i>Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	2	27	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S Wrightsville Ave.
Nags Head, NC

Project #: 26-1543
Project Location: Kitty Hawk Elementary
16 S Dogwood Trail
Kitty Hawk, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 17
Sample Location: Hall at B106
Date Collected: 6/12/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/26/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low-moderate
No Spores Seen —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	1	13	spores/m ³	20%
Ascospores	2	27	spores/m ³	40%
Basidiospores		-	spores/m ³	-
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group	2	27	spores/m ³	40%
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	5	67	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S Wrightsville Ave.
Nags Head, NC

Project #: 26-1543
Project Location: Kitty Hawk Elementary
16 S Dogwood Trail
Kitty Hawk, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 18
Sample Location: B101
Date Collected: 6/12/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/26/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low-moderate
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	1	13	spores/m ³	20%
Ascospores		-	spores/m ³	-
Basidiospores		-	spores/m ³	-
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium</i> / <i>Aspergillus</i> Group	2	27	spores/m ³	40%
Hyphal Elements	1	13	spores/m ³	20%
<i>Alternaria</i>	1	13	spores/m ³	20%
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera</i> / <i>Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	5	67	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S Wrightsville Ave.
Nags Head, NC

Project #: 26-1543
Project Location: Kitty Hawk Elementary
16 S Dogwood Trail
Kitty Hawk, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 19
Sample Location: Outdoor Air
Date Collected: 6/12/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/26/26
Volume (L): 75
Percentage of Slide Read: 50.0%
Detection Limit: 26.67
Particulate Level: moderate
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	65	1733	spores/m ³	59%
Ascospores	25	667	spores/m ³	23%
Basidiospores	9	240	spores/m ³	8%
Smuts, <i>Periconia</i> , Myxomycetes	3	80	spores/m ³	3%
<i>Penicillium/Aspergillus</i> Group	4	107	spores/m ³	4%
Hyphal Elements	1	27	spores/m ³	1%
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>	1	27	spores/m ³	1%
<i>Epicoecum</i>		-	spores/m ³	-
<i>Cercospora</i>	1	27	spores/m ³	1%
<i>Arthrimum</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>	1	27	spores/m ³	1%
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	110	2933	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Project #: **26-1543**

Report Information:

DETECTION LIMITS (DL) for samples are the minimum number of spores or colonies forming units that can be satisfactorily identified for each sample type.

SPORE TRAP SAMPLES: Calculations based on volume of air sampled & percentage of slide counted, i.e. DL = 1000 L / 75 L if 100% of the slide is counted.

CODE 11: Fungal content and/or particulate level on slide too heavy to identify and enumerate fungal content.

Footnotes:

1. *Penicillium/Aspergillus* group spores are characterized by their small size, round to ovoid shape, being unicellular and usually colorless to lightly pigmented. There are numerous genera of fungi whose spore morphology is similar to that of the *Penicillium/Aspergillus* type. Several common examples would be *Acremonium*, *Paecilomyces*, and *Trichoderma*. Although the majority of spores placed in this group are *Penicillium*, *Aspergillus*, or a combination of both, these are not the only two possibilities.
2. Basidiospores are primarily transported indoors from outdoor sources and rarely grow indoors. A high basidiospore count indoors can be indicative of a wood decay problem or wet soil, and should be verified if and an outdoor source of the spores is not present.
3. Hyphae are the tubular filaments of fungi. Hyphae can fragment and become airborne much like spores and are potentially allergenic.
4. The Smut, *Periconia*, Myxomycete group is a group composed of three different types of organisms whose spores have similar morphologies. Smuts are plant pathogens, *Periconia* is a relatively uncommon mold indoors, and Myxomycetes are not fungi, but slime molds. Although these organisms do not typically proliferate indoors, their spores are potentially allergenic.
5. Rusts are plant pathogens. These fungi do not typically grow indoors unless an infected plant is present. Rust spores are potentially allergenic.

Direct Microscopic Exam Reporting:

We use a 400x-600x magnification microscope.

Reporting Quantification Levels are as follows:

Reporting Level	Quantitative Description
Occasional	1-10 per square inch
Few	11-100 per square inch
Moderate	101-1000 per square inch
Numerous	More than 1,000 per square inch

Submitted By Analyst:

Cathy A. Richmond, BS

6/26/2026