



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Ave.
Nags Head, NC

Project #: 26-1548
Project Location: First Flight High School
100 Veterans Drive
Kill Devil Hills, NC
Project Type: IAQ
PO/Claim #:

Table 1: Non-Viable Air Samples

Date Collected:	6/11/26	6/11/26	6/11/26	6/11/26	6/11/26
	1	2	3	4	5
Spore Identification	Reception Lobby	Cafeteria	Auditorium	Band A302	Student Services
<i>Cladosporium</i>	-	-	27	-	-
Ascospores	-	-	-	-	-
Basidiospores ²	13	13	-	13	27
Smuts, <i>Periconia</i> , <i>Myxomycetes</i> ⁴	-	-	-	-	-
<i>Penicillium/Aspergillus</i> Group ¹	13	-	-	13	40
Hyphal Elements ³	-	-	-	-	-
<i>Alternaria</i>	-	-	-	-	-
<i>Curvularia</i>	-	-	-	-	-
<i>Epicoccum</i>	-	-	-	-	-
<i>Cercospora</i>	-	-	-	-	-
<i>Arthrimum</i>	-	-	-	-	-
Clear Brown	-	-	-	-	-
Colorless	-	-	-	-	-
Trichocladium	-	-	-	-	-
Unidentified	-	-	-	-	-
<i>Ulocladium</i>	-	-	-	-	-
Torula	-	-	-	-	-
Pithomyces	-	-	-	-	-
Rust ⁵	-	-	-	-	-
<i>Drechslera/Bipolaris</i>	-	-	-	13	-
<i>Tetraploa</i>	-	-	-	-	-
<i>Chaetomium</i>	-	-	-	-	-
<i>Stachybotrys</i>	-	-	-	-	-
	-	-	-	-	-
Total Spores/m³	27	13	27	40	67
Particulate Level	low	low	low	low	low
Date Analyzed:	6/25/26	6/25/26	6/25/26	6/25/26	6/25/26

Analyzed by: Cathy A. Richmond, B.S.

The results reported by LRC are a record of the microbes identified by our laboratory staff. We assume responsibility over analysis conducted in the laboratory, but cannot assume responsibility for activities completed in the field by the client, other personnel associated with the samples submitted, or other activities beyond the laboratory. Any information given other than microbial information, is provided as general reference information from published sources and is not an extension of liability to LRC.



LRC Indoor Testing and Research
 200 Commonwealth Ct, Suite 101
 Cary, NC 27511
 (919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Ave.
Nags Head, NC

Project #: 26-1548
Project Location: First Flight High School
 100 Veterans Drive
 Kill Devil Hills, NC
Project Type: IAQ
PO/Claim #:

Table 1: Non-Viable Air Samples

Date Collected:	6/11/26	6/11/26	6/11/26	6/11/26	6/11/26
	6	7	8	9	10
Spore Identification	Art B103	Hall at A501	B301	B302	Hall at B303
<i>Cladosporium</i>	13	13	13	67	13
Ascospores	-	-	-	-	-
Basidiospores ²	27	13	13	27	13
Smuts, <i>Periconia</i> , <i>Myxomycetes</i> ⁴	-	-	-	-	-
<i>Penicillium/Aspergillus</i> Group ¹	13	-	-	-	-
Hyphal Elements ³	-	-	-	-	-
<i>Alternaria</i>	-	-	-	-	-
<i>Curvularia</i>	-	-	-	-	-
<i>Epicoccum</i>	-	-	-	-	-
<i>Cercospora</i>	-	-	-	-	-
<i>Arthrimum</i>	-	-	-	-	-
Clear Brown	-	-	-	-	-
Colorless	-	-	-	-	-
<i>Trichocladium</i>	-	-	-	-	-
Unidentified	-	-	-	-	-
<i>Ulocladium</i>	-	-	-	-	-
<i>Torula</i>	-	-	-	-	-
<i>Pithomyces</i>	-	-	-	-	-
Rust ⁵	-	-	-	-	-
<i>Drechslera/Bipolaris</i>	-	-	-	-	-
<i>Tetraploa</i>	-	-	-	-	-
<i>Chaetomium</i>	-	-	-	-	-
<i>Stachybotrys</i>	-	-	-	-	-
	-	-	-	-	-
Total Spores/m³	53	27	27	93	27
Particulate Level	low-moderate	low	low	low	low
Date Analyzed:	6/25/26	6/25/26	6/25/26	6/25/26	6/25/26

Analyzed by: Cathy A. Richmond, B.S.

The results reported by LRC are a record of the microbes identified by our laboratory staff. We assume responsibility over analysis conducted in the laboratory, but cannot assume responsibility for activities completed in the field by the client, other personnel associated with the samples submitted, or other activities beyond the laboratory. Any information given other than microbial information, is provided as general reference information from published sources and is not an extension of liability to LRC.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Ave.
Nags Head, NC

Project #: 26-1548
Project Location: First Flight High School
100 Veterans Drive
Kill Devil Hills, NC
Project Type: IAQ
PO/Claim #:

Table 1: Non-Viable Air Samples

Date Collected:	6/11/26	6/11/26	6/11/26	6/11/26	6/11/26
	11	12	13	14	15
Spore Identification	B308	B310	Hall at B312	Media Center B400	B205B
<i>Cladosporium</i>	13	13	27	27	13
Ascospores	-	-	-	-	-
Basidiospores ²	13	-	13	13	13
Smuts, <i>Periconia</i> , <i>Myxomycetes</i> ⁴	-	-	-	-	-
<i>Penicillium/Aspergillus</i> Group ¹	-	13	-	-	-
Hyphal Elements ³	-	-	-	-	13
<i>Alternaria</i>	-	-	-	-	-
<i>Curvularia</i>	-	-	-	-	-
<i>Epicoccum</i>	-	-	-	-	-
<i>Cercospora</i>	-	-	-	-	-
<i>Arthrimum</i>	-	-	-	-	-
Clear Brown	-	-	-	-	-
Colorless	-	-	-	-	-
Trichocladium	-	-	-	-	-
Unidentified	-	-	-	-	-
<i>Ulocladium</i>	-	-	-	-	-
Torula	-	-	-	-	-
Pithomyces	-	-	-	-	-
Rust ⁵	-	-	-	-	-
<i>Drechslera/Bipolaris</i>	-	-	-	-	-
<i>Tetraploa</i>	-	-	-	-	-
<i>Chaetomium</i>	-	-	-	-	-
<i>Stachybotrys</i>	-	-	-	-	-
	-	-	-	-	-
Total Spores/m ³	27	27	40	40	40
Particulate Level	low	low	low	low	low
Date Analyzed:	6/25/26	6/25/26	6/25/26	6/25/26	6/25/26

Analyzed by: Cathy A. Richmond, B.S.

The results reported by LRC are a record of the microbes identified by our laboratory staff. We assume responsibility over analysis conducted in the laboratory, but cannot assume responsibility for activities completed in the field by the client, other personnel associated with the samples submitted, or other activities beyond the laboratory. Any information given other than microbial information, is provided as general reference information from published sources and is not an extension of liability to LRC.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Ave.
Nags Head, NC

Project #: 26-1548
Project Location: First Flight High School
100 Veterans Drive
Kill Devil Hills, NC
Project Type: IAQ
PO/Claim #:

Table 1: Non-Viable Air Samples

Date Collected:	6/11/26	6/11/26	6/11/26	6/11/26	6/11/26
	16	17	18	19	20
Spore Identification	B209	D108	D114	C201	C212
<i>Cladosporium</i>	13	53	13	13	-
Ascospores	-	-	-	-	-
Basidiospores ²	40	13	-	-	13
Smuts, <i>Periconia</i> , <i>Myxomycetes</i> ⁴	-	-	-	-	-
<i>Penicillium/Aspergillus</i> Group ¹	-	-	-	13	-
Hyphal Elements ³	-	-	-	13	-
<i>Alternaria</i>	-	-	-	-	-
<i>Curvularia</i>	-	-	-	-	-
<i>Epicoccum</i>	-	-	-	-	-
<i>Cercospora</i>	-	-	-	-	-
<i>Arthrinium</i>	-	-	-	-	-
Clear Brown	-	-	-	-	-
Colorless	-	-	-	-	-
<i>Trichocladium</i>	-	-	-	-	-
Unidentified	-	-	-	-	-
<i>Ulocladium</i>	-	-	-	-	-
<i>Torula</i>	-	-	-	-	-
<i>Pithomyces</i>	-	-	-	-	-
Rust ⁵	-	-	-	-	-
<i>Drechslera/Bipolaris</i>	-	-	-	-	-
<i>Tetraploa</i>	-	-	-	-	-
<i>Chaetomium</i>	-	-	-	-	-
<i>Stachybotrys</i>	-	-	-	-	-
	-	-	-	-	-
Total Spores/m³	53	67	13	40	13
Particulate Level	low	low	low	low	low
Date Analyzed:	6/25/26	6/25/26	6/25/26	6/25/26	6/25/26

Analyzed by: Cathy A. Richmond, B.S.

The results reported by LRC are a record of the microbes identified by our laboratory staff. We assume responsibility over analysis conducted in the laboratory, but cannot assume responsibility for activities completed in the field by the client, other personnel associated with the samples submitted, or other activities beyond the laboratory. Any information given other than microbial information, is provided as general reference information from published sources and is not an extension of liability to LRC.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Ave.
Nags Head, NC

Project #: 26-1548
Project Location: First Flight High School
100 Veterans Drive
Kill Devil Hills, NC
Project Type: IAQ
PO/Claim #:

Table 1: Non-Viable Air Samples

Date Collected:	6/11/26	6/11/26	6/11/26	6/11/26	6/11/26
	21	22	23	24	25
Spore Identification	Hall atC210	C216	2nd FloorAt Elevators/Restroo ms	C102	C302
<i>Cladosporium</i>	13	40	-	13	13
Ascospores	-	-	-	-	-
Basidiospores ²	-	13	27	13	13
Smuts, <i>Periconia</i> , Myxomycetes ⁴	-	-	13	-	-
<i>Penicillium/Aspergillus</i> Group ¹	-	40	-	-	-
Hyphal Elements ³	-	-	-	-	-
<i>Alternaria</i>	-	-	-	-	-
<i>Curvularia</i>	-	-	-	-	-
<i>Epicoccum</i>	-	-	-	-	-
<i>Cercospora</i>	-	-	-	-	-
<i>Arthrimum</i>	-	-	-	-	-
Clear Brown	-	-	-	-	-
Colorless	-	-	-	-	-
Trichocladium	-	-	-	-	-
Unidentified	-	-	-	-	-
<i>Ulocladium</i>	-	-	-	-	-
Torula	-	-	-	-	-
Pithomyces	-	-	-	-	-
Rust ⁵	-	-	-	-	-
<i>Drechslera/Bipolaris</i>	-	-	-	-	-
<i>Tetraploa</i>	-	-	-	-	-
<i>Chaetomium</i>	-	-	-	-	-
<i>Stachybotrys</i>	-	-	-	-	-
	-	-	-	-	-
Total Spores/m³	13	93	40	27	13
Particulate Level	low	low	low	low	low
Date Analyzed:	6/25/26	6/25/26	6/25/26	6/25/26	6/25/26

Analyzed by: Cathy A. Richmond, B.S.

The results reported by LRC are a record of the microbes identified by our laboratory staff. We assume responsibility over analysis conducted in the laboratory, but cannot assume responsibility for activities completed in the field by the client, other personnel associated with the samples submitted, or other activities beyond the laboratory. Any information given other than microbial information, is provided as general reference information from published sources and is not an extension of liability to LRC.



LRC Indoor Testing and Research
 200 Commonwealth Ct, Suite 101
 Cary, NC 27511
 (919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Ave.
Nags Head, NC

Project #: 26-1548
Project Location: First Flight High School
 100 Veterans Drive
 Kill Devil Hills, NC
Project Type: IAQ
PO/Claim #:

Table 1: Non-Viable Air Samples

Date Collected:	6/11/26	6/11/26
	26	27
Spore Identification	C310	Outdoor Air
<i>Cladosporium</i>	27	1920
Ascospores	-	960
Basidiospores ²	-	4693
Smuts, <i>Periconia</i> , Myxomycetes ⁴	-	427
<i>Penicillium/Aspergillus</i> Group ¹	-	213
Hyphal Elements ³	-	427
<i>Alternaria</i>	-	107
<i>Curvularia</i>	-	-
<i>Epicoccum</i>	-	-
<i>Cercospora</i>	-	-
<i>Arthrinium</i>	-	-
Clear Brown	-	-
Colorless	-	-
Trichocladium	-	-
Unidentified	-	-
<i>Ulocladium</i>	-	-
Torula	-	-
Pithomyces	-	-
Rust ⁵	-	-
<i>Drechslera/Bipolaris</i>	-	107
<i>Tetraploa</i>	-	-
<i>Chaetomium</i>	-	-
<i>Stachybotrys</i>	-	-
	-	-
Total Spores/m³	27	8853
Particulate Level	low	low-moderate
Date Analyzed:	6/25/26	6/25/26

Analyzed by: Cathy A. Richmond, B.S.

The results reported by LRC are a record of the microbes identified by our laboratory staff. We assume responsibility over analysis conducted in the laboratory, but cannot assume responsibility for activities completed in the field by the client, other personnel associated with the samples submitted, or other activities beyond the laboratory. Any information given other than microbial information, is provided as general reference information from published sources and is not an extension of liability to LRC.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Ave.
Nags Head, NC

Project #: 26-1548
Project Location: First Flight High School
100 Veterans Drive
Kill Devil Hills, NC
Project Type: IAQ
PO/Claim #:

Sample Number: 1
Sample Location: Reception Lobby
Date Collected: 6/11/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/25/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: -

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>		-	spores/m ³	-
Ascospores		-	spores/m ³	-
Basidiospores	1	13	spores/m ³	50%
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group	1	13	spores/m ³	50%
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	2	27	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Ave.
Nags Head, NC

Project #: 26-1548
Project Location: First Flight High School
100 Veterans Drive
Kill Devil Hills, NC
Project Type: IAQ
PO/Claim #:

Sample Number: 2
Sample Location: Cafeteria
Date Collected: 6/11/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/25/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: -

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>		-	spores/m ³	-
Ascospores		-	spores/m ³	-
Basidiospores	1	13	spores/m ³	100%
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium</i> / <i>Aspergillus</i> Group		-	spores/m ³	-
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera</i> / <i>Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	1	13	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Ave.
Nags Head, NC

Project #: 26-1548
Project Location: First Flight High School
100 Veterans Drive
Kill Devil Hills, NC
Project Type: IAQ
PO/Claim #:

Sample Number: 3
Sample Location: Auditorium
Date Collected: 6/11/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/25/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: -

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	2	27	spores/m ³	100%
Ascospores		-	spores/m ³	-
Basidiospores		-	spores/m ³	-
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group		-	spores/m ³	-
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	2	27	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Ave.
Nags Head, NC

Project #: 26-1548
Project Location: First Flight High School
100 Veterans Drive
Kill Devil Hills, NC
Project Type: IAQ
PO/Claim #:

Sample Number: 4
Sample Location: Band A302
Date Collected: 6/11/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/25/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: -

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>		-	spores/m ³	-
Ascospores		-	spores/m ³	-
Basidiospores	1	13	spores/m ³	33%
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group	1	13	spores/m ³	33%
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>	1	13	spores/m ³	33%
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	3	40	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Ave.
Nags Head, NC

Project #: 26-1548
Project Location: First Flight High School
100 Veterans Drive
Kill Devil Hills, NC
Project Type: IAQ
PO/Claim #:

Sample Number: 5
Sample Location: Student Services
Date Collected: 6/11/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/25/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: -

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>		-	spores/m ³	-
Ascospores		-	spores/m ³	-
Basidiospores	2	27	spores/m ³	40%
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium</i> / <i>Aspergillus</i> Group	3	40	spores/m ³	60%
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera</i> / <i>Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	5	67	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Ave.
Nags Head, NC

Project #: 26-1548
Project Location: First Flight High School
100 Veterans Drive
Kill Devil Hills, NC
Project Type: IAQ
PO/Claim #:

Sample Number: 6
Sample Location: Art B103
Date Collected: 6/11/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/25/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low-moderate
Notes: -

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	1	13	spores/m ³	25%
Ascospores		-	spores/m ³	-
Basidiospores	2	27	spores/m ³	50%
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group	1	13	spores/m ³	25%
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	4	53	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Ave.
Nags Head, NC

Project #: 26-1548
Project Location: First Flight High School
100 Veterans Drive
Kill Devil Hills, NC
Project Type: IAQ
PO/Claim #:

Sample Number: 7
Sample Location: Hall at A501
Date Collected: 6/11/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/25/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: -

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	1	13	spores/m ³	50%
Ascospores		-	spores/m ³	-
Basidiospores	1	13	spores/m ³	50%
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group		-	spores/m ³	-
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	2	27	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Ave.
Nags Head, NC

Project #: 26-1548
Project Location: First Flight High School
100 Veterans Drive
Kill Devil Hills, NC
Project Type: IAQ
PO/Claim #:

Sample Number: 8
Sample Location: B301
Date Collected: 6/11/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/25/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: -

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	1	13	spores/m ³	50%
Ascospores		-	spores/m ³	-
Basidiospores	1	13	spores/m ³	50%
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group		-	spores/m ³	-
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	2	27	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Ave.
Nags Head, NC

Project #: 26-1548
Project Location: First Flight High School
100 Veterans Drive
Kill Devil Hills, NC
Project Type: IAQ
PO/Claim #:

Sample Number: 9
Sample Location: B302
Date Collected: 6/11/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/25/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: -

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	5	67	spores/m ³	71%
Ascospores		-	spores/m ³	-
Basidiospores	2	27	spores/m ³	29%
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium</i> / <i>Aspergillus</i> Group		-	spores/m ³	-
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera</i> / <i>Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	7	93	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Ave.
Nags Head, NC

Project #: 26-1548
Project Location: First Flight High School
100 Veterans Drive
Kill Devil Hills, NC
Project Type: IAQ
PO/Claim #:

Sample Number: 10
Sample Location: Hall at B303
Date Collected: 6/11/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/25/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: -

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	1	13	spores/m ³	50%
Ascospores		-	spores/m ³	-
Basidiospores	1	13	spores/m ³	50%
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group		-	spores/m ³	-
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	2	27	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Ave.
Nags Head, NC

Project #: 26-1548
Project Location: First Flight High School
100 Veterans Drive
Kill Devil Hills, NC
Project Type: IAQ
PO/Claim #:

Sample Number: 11
Sample Location: B308
Date Collected: 6/11/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/25/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: -

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	1	13	spores/m ³	50%
Ascospores		-	spores/m ³	-
Basidiospores	1	13	spores/m ³	50%
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group		-	spores/m ³	-
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	2	27	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Ave.
Nags Head, NC

Project #: 26-1548
Project Location: First Flight High School
100 Veterans Drive
Kill Devil Hills, NC
Project Type: IAQ
PO/Claim #:

Sample Number: 12
Sample Location: B310
Date Collected: 6/11/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/25/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: -

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	1	13	spores/m ³	50%
Ascospores		-	spores/m ³	-
Basidiospores		-	spores/m ³	-
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group	1	13	spores/m ³	50%
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	2	27	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Ave.
Nags Head, NC

Project #: 26-1548
Project Location: First Flight High School
100 Veterans Drive
Kill Devil Hills, NC
Project Type: IAQ
PO/Claim #:

Sample Number: 13
Sample Location: Hall at B312
Date Collected: 6/11/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/25/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: -

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	2	27	spores/m ³	67%
Ascospores		-	spores/m ³	-
Basidiospores	1	13	spores/m ³	33%
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group		-	spores/m ³	-
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	3	40	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Ave.
Nags Head, NC

Project #: 26-1548
Project Location: First Flight High School
100 Veterans Drive
Kill Devil Hills, NC
Project Type: IAQ
PO/Claim #:

Sample Number: 14
Sample Location: Media Center B400
Date Collected: 6/11/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/25/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: -

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	2	27	spores/m ³	67%
Ascospores		-	spores/m ³	-
Basidiospores	1	13	spores/m ³	33%
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group		-	spores/m ³	-
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	3	40	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Ave.
Nags Head, NC

Project #: 26-1548
Project Location: First Flight High School
100 Veterans Drive
Kill Devil Hills, NC
Project Type: IAQ
PO/Claim #:

Sample Number: 15
Sample Location: B205B
Date Collected: 6/11/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/25/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: -

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	1	13	spores/m ³	33%
Ascospores		-	spores/m ³	-
Basidiospores	1	13	spores/m ³	33%
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group		-	spores/m ³	-
Hyphal Elements	1	13	spores/m ³	33%
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	3	40	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Ave.
Nags Head, NC

Project #: 26-1548
Project Location: First Flight High School
100 Veterans Drive
Kill Devil Hills, NC
Project Type: IAQ
PO/Claim #:

Sample Number: 16
Sample Location: B209
Date Collected: 6/11/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/25/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: -

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	1	13	spores/m ³	25%
Ascospores		-	spores/m ³	-
Basidiospores	3	40	spores/m ³	75%
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group		-	spores/m ³	-
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	4	53	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Ave.
Nags Head, NC

Project #: 26-1548
Project Location: First Flight High School
100 Veterans Drive
Kill Devil Hills, NC
Project Type: IAQ
PO/Claim #:

Sample Number: 17
Sample Location: D108
Date Collected: 6/11/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/25/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: -

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	4	53	spores/m ³	80%
Ascospores		-	spores/m ³	-
Basidiospores	1	13	spores/m ³	20%
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group		-	spores/m ³	-
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	5	67	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 341-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Ave.
Nags Head, NC

Project #: 26-1548
Project Location: First Flight High School
100 Veterans Drive
Kill Devil Hills, NC
Project Type: IAQ
PO/Claim #:

Sample Number: 18
Sample Location: D114
Date Collected: 6/11/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/25/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: -

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	1	13	spores/m ³	100%
Ascospores		-	spores/m ³	-
Basidiospores		-	spores/m ³	-
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group		-	spores/m ³	-
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	1	13	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Ave.
Nags Head, NC

Project #: 26-1548
Project Location: First Flight High School
100 Veterans Drive
Kill Devil Hills, NC
Project Type: IAQ
PO/Claim #:

Sample Number: 19
Sample Location: C201
Date Collected: 6/11/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/25/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: -

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	1	13	spores/m ³	33%
Ascospores		-	spores/m ³	-
Basidiospores		-	spores/m ³	-
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group	1	13	spores/m ³	33%
Hyphal Elements	1	13	spores/m ³	33%
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	3	40	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Ave.
Nags Head, NC

Project #: 26-1548
Project Location: First Flight High School
100 Veterans Drive
Kill Devil Hills, NC
Project Type: IAQ
PO/Claim #:

Sample Number: 20
Sample Location: C212
Date Collected: 6/11/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/25/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: -

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>		-	spores/m ³	-
Ascospores		-	spores/m ³	-
Basidiospores	1	13	spores/m ³	100%
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group		-	spores/m ³	-
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	1	13	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Ave.
Nags Head, NC

Project #: 26-1548
Project Location: First Flight High School
100 Veterans Drive
Kill Devil Hills, NC
Project Type: IAQ
PO/Claim #:

Sample Number: 21
Sample Location: Hall atC210
Date Collected: 6/11/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/25/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: -

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	1	13	spores/m ³	100%
Ascospores		-	spores/m ³	-
Basidiospores		-	spores/m ³	-
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group		-	spores/m ³	-
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	1	13	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Ave.
Nags Head, NC

Project #: 26-1548
Project Location: First Flight High School
100 Veterans Drive
Kill Devil Hills, NC
Project Type: IAQ
PO/Claim #:

Sample Number: 22
Sample Location: C216
Date Collected: 6/11/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/25/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: -

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	3	40	spores/m ³	43%
Ascospores		-	spores/m ³	-
Basidiospores	1	13	spores/m ³	14%
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group	3	40	spores/m ³	43%
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	7	93	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Ave.
Nags Head, NC

Project #: 26-1548
Project Location: First Flight High School
100 Veterans Drive
Kill Devil Hills, NC
Project Type: IAQ
PO/Claim #:

Sample Number: 23
Sample Location: 2nd Floor At Elevators/Restrooms
Date Collected: 6/11/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/25/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: -

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>		-	spores/m ³	-
Ascospores		-	spores/m ³	-
Basidiospores	2	27	spores/m ³	67%
Smuts, <i>Periconia</i> , Myxomycetes	1	13	spores/m ³	33%
<i>Penicillium/Aspergillus</i> Group		-	spores/m ³	-
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	3	40	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Ave.
Nags Head, NC

Project #: 26-1548
Project Location: First Flight High School
100 Veterans Drive
Kill Devil Hills, NC
Project Type: IAQ
PO/Claim #:

Sample Number: 24
Sample Location: C102
Date Collected: 6/11/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/25/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: -

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	1	13	spores/m ³	50%
Ascospores		-	spores/m ³	-
Basidiospores	1	13	spores/m ³	50%
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group		-	spores/m ³	-
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	2	27	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Ave.
Nags Head, NC

Project #: 26-1548
Project Location: First Flight High School
100 Veterans Drive
Kill Devil Hills, NC
Project Type: IAQ
PO/Claim #:

Sample Number: 25
Sample Location: C302
Date Collected: 6/11/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/25/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: -

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	1	13	spores/m ³	100%
Ascospores		-	spores/m ³	-
Basidiospores		-	spores/m ³	-
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium</i> / <i>Aspergillus</i> Group		-	spores/m ³	-
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera</i> / <i>Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	1	13	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Ave.
Nags Head, NC

Project #: 26-1548
Project Location: First Flight High School
100 Veterans Drive
Kill Devil Hills, NC
Project Type: IAQ
PO/Claim #:

Sample Number: 26
Sample Location: C310
Date Collected: 6/11/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/25/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: -

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	2	27	spores/m ³	100%
Ascospores		-	spores/m ³	-
Basidiospores		-	spores/m ³	-
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group		-	spores/m ³	-
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	2	27	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Ave.
Nags Head, NC

Project #: 26-1548
Project Location: First Flight High School
100 Veterans Drive
Kill Devil Hills, NC
Project Type: IAQ
PO/Claim #:

Sample Number: 27
Sample Location: Outdoor Air
Date Collected: 6/11/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/25/26
Volume (L): 75
Percentage of Slide Read: 12.5%
Detection Limit: 106.67
Particulate Level: low-moderate
Notes: -

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	18	1920	spores/m ³	22%
Ascospores	9	960	spores/m ³	11%
Basidiospores	44	4693	spores/m ³	53%
Smuts, <i>Periconia</i> , Myxomycetes	4	427	spores/m ³	5%
<i>Penicillium/Aspergillus</i> Group	2	213	spores/m ³	2%
Hyphal Elements	4	427	spores/m ³	5%
<i>Alternaria</i>	1	107	spores/m ³	1%
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>	1	107	spores/m ³	1%
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	83	8853	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Project #: **26-1548**

Report Information:

DETECTION LIMITS (DL) for samples are the minimum number of spores or colonies forming units that can be satisfactorily identified for each sample type.

SPORE TRAP SAMPLES: Calculations based on volume of air sampled & percentage of slide counted, i.e. DL = 1000 L / 75 L if 100% of the slide is counted.

CODE 11: Fungal content and/or particulate level on slide too heavy to identify and enumerate fungal content.

Footnotes:

1. *Penicillium/Aspergillus* group spores are characterized by their small size, round to ovoid shape, being unicellular and usually colorless to lightly pigmented. There are numerous genera of fungi whose spore morphology is similar to that of the *Penicillium/Aspergillus* type. Several common examples would be *Acremonium*, *Paecilomyces*, and *Trichoderma*. Although the majority of spores placed in this group are *Penicillium*, *Aspergillus*, or a combination of both, these are not the only two possibilities.
2. Basidiospores are primarily transported indoors from outdoor sources and rarely grow indoors. A high basidiospore count indoors can be indicative of a wood decay problem or wet soil, and should be verified if and an outdoor source of the spores is not present.
3. Hyphae are the tubular filaments of fungi. Hyphae can fragment and become airborne much like spores and are potentially allergenic.
4. The Smut, *Periconia*, Myxomycete group is a group composed of three different types of organisms whose spores have similar morphologies. Smuts are plant pathogens, *Periconia* is a relatively uncommon mold indoors, and Myxomycetes are not fungi, but slime molds. Although these organisms do not typically proliferate indoors, their spores are potentially allergenic.
5. Rusts are plant pathogens. These fungi do not typically grow indoors unless an infected plant is present. Rust spores are potentially allergenic.

Chain of Custody available on request

Direct Microscopic Exam Reporting:

We use a 400x-600x magnification microscope.

Reporting Quantification Levels are as follows:

Reporting Level	Quantitative Description
Occasional	1-10 per square inch
Few	11-100 per square inch
Moderate	101-1000 per square inch
Numerous	More than 1,000 per square inch

Submitted By Analyst:

Cathy A. Richmond, BS

6/25/2026