



LRC Indoor Testing and Research
 200 Commonwealth Ct, Suite 101
 Cary, NC 27511
 (919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Avenue
Nags Head, NC

Project #: 26-1549
Project Location: Manteo Elementary School
 701 US-64
 Manteo, NC
Project Type: IAQ
PO/Claim #: -

Table 1: Non-Viable Air Samples

Date Collected:	6/9/26	6/9/26	6/9/26	6/9/26	6/9/26
	1	2	3	4	5
Spore Identification	Entry Hall	B111	B109	Hall at B107	B103
<i>Cladosporium</i>	13	-	13	53	27
Ascospores	27	13	-	13	53
Basidiospores ²	-	-	-	13	-
Smuts, <i>Periconia</i> , <i>Myxomycetes</i> ⁴	-	13	-	-	13
<i>Penicillium/Aspergillus</i> Group ¹	27	13	-	13	27
Hyphal Elements ³	13	-	-	13	40
<i>Alternaria</i>	-	-	-	-	-
<i>Curvularia</i>	13	-	-	-	-
<i>Epicoccum</i>	27	-	-	13	-
<i>Cercospora</i>	-	-	-	-	-
<i>Arthrimum</i>	-	-	-	-	-
Clear Brown	-	-	-	-	-
Colorless	-	-	-	-	-
<i>Trichocladium</i>	-	-	-	-	-
Unidentified	-	-	-	13	-
<i>Ulocladium</i>	-	-	-	-	-
<i>Torula</i>	-	-	-	-	-
<i>Pithomyces</i>	-	-	-	-	-
Rust ⁵	-	-	-	-	-
<i>Drechslera/Bipolaris</i>	-	-	-	-	-
<i>Tetraploa</i>	-	-	-	-	-
<i>Chaetomium</i>	-	-	-	-	-
<i>Stachybotrys</i>	-	-	-	-	-
	-	-	-	-	-
Total Spores/m³	120	40	13	133	160
Particulate Level	moderate	low-moderate	low	low-moderate	low-moderate
Date Analyzed:	6/23/26	6/23/26	6/23/26	6/23/26	6/23/26

The results reported by LRC are a record of the microbes identified by our laboratory staff. We assume responsibility over analysis conducted in the laboratory, but cannot assume responsibility for activities completed in the field by the client, other personnel associated with the samples submitted, or other activities beyond the laboratory. Any information given other than microbial information, is provided as general reference information from published sources and is not an extension of liability to LRC.



LRC Indoor Testing and Research
 200 Commonwealth Ct, Suite 101
 Cary, NC 27511
 (919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
 Ian Adams
 3020 S. Wrightsville Avenue
 Nags Head, NC

Project #: 26-1549
Project Location: Manteo Elementary School
 701 US-64
 Manteo, NC
Project Type: IAQ
PO/Claim #: —

Table 1: Non-Viable Air Samples

Date Collected:	6/9/26	6/9/26	6/9/26	6/9/26	6/9/26
	6	7	8	9	10
Spore Identification	C102	Gym	C114 Technology	D111	D128
<i>Cladosporium</i>	13	13	27	40	27
Ascospores	13	13	-	-	-
Basidiospores ²	-	-	-	53	27
Smuts, <i>Periconia</i> , <i>Myxomycetes</i> ⁴	-	-	-	40	-
<i>Penicillium/Aspergillus</i> Group ¹	-	-	-	13	-
Hyphal Elements ³	-	40	27	80	-
<i>Alternaria</i>	-	-	-	-	-
<i>Curvularia</i>	-	27	27	13	-
<i>Epicoccum</i>	-	-	13	40	-
<i>Cercospora</i>	-	-	-	-	-
<i>Arthrinium</i>	-	-	-	-	-
Clear Brown	-	-	-	-	-
Colorless	-	-	-	-	-
<i>Trichocladium</i>	-	-	-	-	-
Unidentified	-	-	-	-	-
<i>Ulocladium</i>	-	-	-	-	-
<i>Torula</i>	-	-	-	-	-
<i>Pithomyces</i>	-	-	-	13	-
Rust ⁵	-	-	-	-	-
<i>Drechslera/Bipolaris</i>	-	13	-	-	-
<i>Tetraploa</i>	-	-	-	-	-
<i>Chaetomium</i>	-	-	-	-	-
<i>Stachybotrys</i>	-	-	-	-	-
	-	-	-	-	-
Total Spores/m³	27	107	93	293	53
Particulate Level	low	moderate	moderate	moderate	low
Date Analyzed:	6/23/26	6/23/26	6/23/26	6/23/26	6/23/26

Analyzed by: Cathy A. Richmond, B.S.

The results reported by LRC are a record of the microbes identified by our laboratory staff. We assume responsibility over analysis conducted in the laboratory, but cannot assume responsibility for activities completed in the field by the client, other personnel associated with the samples submitted, or other activities beyond the laboratory. Any information given other than microbial information, is provided as general reference information from published sources and is not an extension of liability to LRC.



LRC Indoor Testing and Research
 200 Commonwealth Ct, Suite 101
 Cary, NC 27511
 (919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
 Ian Adams
 3020 S. Wrightsville Avenue
 Nags Head, NC

Project #: 26-1549
Project Location: Manteo Elementary School
 701 US-64
 Manteo, NC
Project Type: IAQ
PO/Claim #: —

Table 1: Non-Viable Air Samples

Date Collected:	6/9/26	6/9/26	6/9/26	6/9/26	6/9/26
	11	12	13	14	15
Spore Identification	D130	B201	B205	B209	B214
<i>Cladosporium</i>	40	-	27	27	27
Ascospores	-	-	27	13	-
Basidiospores ²	27	13	-	13	-
Smuts, <i>Periconia</i> , <i>Myxomycetes</i> ⁴	-	-	27	-	13
<i>Penicillium/Aspergillus</i> Group ¹	13	27	13	27	13
Hyphal Elements ³	-	-	-	-	13
<i>Alternaria</i>	-	-	-	-	-
<i>Curvularia</i>	-	-	-	-	-
<i>Epicoccum</i>	-	-	-	-	-
<i>Cercospora</i>	-	-	-	-	-
<i>Arthrinium</i>	-	-	-	-	-
Clear Brown	-	-	-	-	-
Colorless	-	-	-	-	-
<i>Trichocladium</i>	-	-	-	-	-
Unidentified	-	-	-	-	-
<i>Ulocladium</i>	-	-	-	-	-
<i>Torula</i>	-	-	-	-	-
<i>Pithomyces</i>	-	-	-	-	-
Rust ⁵	-	-	-	-	-
<i>Drechslera/Bipolaris</i>	-	-	13	-	-
<i>Tetraploa</i>	-	-	-	-	-
<i>Chaetomium</i>	-	-	-	-	-
<i>Stachybotrys</i>	-	-	-	-	-
	-	-	-	-	-
Total Spores/m³	80	40	107	80	67
Particulate Level	low	low-moderate	low-moderate	low-moderate	low-moderate
Date Analyzed:	6/23/26	6/23/26	6/23/26	6/23/26	6/23/26

Analyzed by: Cathy A. Richmond, B.S.

The results reported by LRC are a record of the microbes identified by our laboratory staff. We assume responsibility over analysis conducted in the laboratory, but cannot assume responsibility for activities completed in the field by the client, other personnel associated with the samples submitted, or other activities beyond the laboratory. Any information given other than microbial information, is provided as general reference information from published sources and is not an extension of liability to LRC.



LRC Indoor Testing and Research
 200 Commonwealth Ct, Suite 101
 Cary, NC 27511
 (919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
 Ian Adams
 3020 S. Wrightsville Avenue
 Nags Head, NC

Project #: 26-1549
Project Location: Manteo Elementary School
 701 US-64
 Manteo, NC
Project Type: IAQ
PO/Claim #: -

Table 1: Non-Viable Air Samples

Date Collected:	6/9/26	6/9/26	6/9/26	6/9/26	6/9/26
	16	17	18	19	20
Spore Identification	B216	B221	B116	B120	K101 Cafeteria Serving
<i>Cladosporium</i>	-	27	13	27	27
Ascospores	27	-	13	-	-
Basidiospores ²	-	13	-	-	13
Smuts, <i>Periconia</i> , <i>Myxomycetes</i> ⁴	-	13	13	-	-
<i>Penicillium/Aspergillus</i> Group ¹	-	13	-	27	-
Hyphal Elements ³	-	13	-	-	-
<i>Alternaria</i>	-	-	-	-	-
<i>Curvularia</i>	-	-	-	27	-
<i>Epicoccum</i>	-	-	-	-	-
<i>Cercospora</i>	-	-	-	-	-
<i>Arthrimum</i>	-	-	-	-	-
Clear Brown	-	-	-	-	-
Colorless	-	-	-	-	-
<i>Trichocladium</i>	-	-	-	-	-
Unidentified	-	-	-	-	-
<i>Ulocladium</i>	-	-	-	-	-
<i>Torula</i>	-	-	-	-	-
<i>Pithomyces</i>	-	-	-	-	-
Rust ⁵	-	-	-	-	-
<i>Drechslera/Bipolaris</i>	-	-	13	-	13
<i>Tetraploa</i>	-	-	-	-	-
<i>Chaetomium</i>	-	-	-	-	-
<i>Stachybotrys</i>	-	-	-	-	-
	-	-	-	-	-
Total Spores/m³	27	80	53	80	53
Particulate Level	low	low	low	low-moderate	low
Date Analyzed:	6/23/26	6/23/26	6/23/26	6/23/26	6/23/26

Analyzed by: Cathy A. Richmond, B.S.

The results reported by LRC are a record of the microbes identified by our laboratory staff. We assume responsibility over analysis conducted in the laboratory, but cannot assume responsibility for activities completed in the field by the client, other personnel associated with the samples submitted, or other activities beyond the laboratory. Any information given other than microbial information, is provided as general reference information from published sources and is not an extension of liability to LRC.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Avenue
Nags Head, NC

Project #: 26-1549
Project Location: Manteo Elementary School
701 US-64
Manteo, NC
Project Type: IAQ
PO/Claim #: —

Table 1: Non-Viable Air Samples

Date Collected:	6/9/26
Spore Identification	21
	Outdoor Air
<i>Cladosporium</i>	1120
Ascospores	640
Basidiospores ²	2293
Smuts, <i>Periconia</i> , <i>Myxomycetes</i> ⁴	427
<i>Penicillium/Aspergillus</i> Group ¹	53
Hyphal Elements ³	-
<i>Alternaria</i>	-
<i>Curvularia</i>	213
<i>Epicoccum</i>	160
<i>Cercospora</i>	-
<i>Arthrinium</i>	-
Clear Brown	-
Colorless	-
<i>Trichocladium</i>	-
Unidentified	-
<i>Ulocladium</i>	-
<i>Torula</i>	-
<i>Pithomyces</i>	-
Rust ⁵	-
<i>Drechslera/Bipolaris</i>	53
<i>Tetraploa</i>	-
<i>Chaetomium</i>	-
<i>Stachybotrys</i>	-
	-
Total Spores/m ³	4960
Particulate Level	moderate
Date Analyzed:	6/23/26

Analyzed by: Cathy A. Richmond, B.S.

The results reported by LRC are a record of the microbes identified by our laboratory staff. We assume responsibility over analysis conducted in the laboratory, but cannot assume responsibility for activities completed in the field by the client, other personnel associated with the samples submitted, or other activities beyond the laboratory. Any information given other than microbial information, is provided as general reference information from published sources and is not an extension of liability to LRC.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Avenue
Nags Head, NC

Project #: 26-1549
Project Location: Manteo Elementary School
701 US-64
Manteo, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 1
Sample Location: Entry Hall
Date Collected: 6/9/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/23/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: moderate
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	1	13	spores/m ³	11%
Ascospores	2	27	spores/m ³	22%
Basidiospores		-	spores/m ³	-
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group	2	27	spores/m ³	22%
Hyphal Elements	1	13	spores/m ³	11%
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>	1	13	spores/m ³	11%
<i>Epicoccum</i>	2	27	spores/m ³	22%
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	9	120	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Avenue
Nags Head, NC

Project #: 26-1549
Project Location: Manteo Elementary School
701 US-64
Manteo, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 2
Sample Location: B111
Date Collected: 6/9/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/23/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low-moderate
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>		-	spores/m ³	-
Ascospores	1	13	spores/m ³	33%
Basidiospores		-	spores/m ³	-
Smuts, <i>Periconia</i> , Myxomycetes	1	13	spores/m ³	33%
<i>Penicillium/Aspergillus</i> Group	1	13	spores/m ³	33%
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	3	40	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Avenue
Nags Head, NC

Project #: 26-1549
Project Location: Manteo Elementary School
701 US-64
Manteo, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 3
Sample Location: B109
Date Collected: 6/9/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/23/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	1	13	spores/m ³	100%
Ascospores		-	spores/m ³	-
Basidiospores		-	spores/m ³	-
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group		-	spores/m ³	-
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	1	13	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Avenue
Nags Head, NC

Project #: 26-1549
Project Location: Manteo Elementary School
701 US-64
Manteo, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 4
Sample Location: Hall at B107
Date Collected: 6/9/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/23/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low-moderate
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	4	53	spores/m ³	40%
Ascospores	1	13	spores/m ³	10%
Basidiospores	1	13	spores/m ³	10%
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium</i> / <i>Aspergillus</i> Group	1	13	spores/m ³	10%
Hyphal Elements	1	13	spores/m ³	10%
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoecum</i>	1	13	spores/m ³	10%
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified	1	13	spores/m ³	10%
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera</i> / <i>Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	10	133	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Avenue
Nags Head, NC

Project #: 26-1549
Project Location: Manteo Elementary School
701 US-64
Manteo, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 5
Sample Location: B103
Date Collected: 6/9/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/23/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low-moderate
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	2	27	spores/m ³	17%
Ascospores	4	53	spores/m ³	33%
Basidiospores		-	spores/m ³	-
Smuts, <i>Periconia</i> , Myxomycetes	1	13	spores/m ³	8%
<i>Penicillium</i> / <i>Aspergillus</i> Group	2	27	spores/m ³	17%
Hyphal Elements	3	40	spores/m ³	25%
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera</i> / <i>Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	12	160	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
 200 Commonwealth Ct, Suite 101
 Cary, NC 27511
 (919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Avenue
Nags Head, NC

Project #: 26-1549
Project Location: Manteo Elementary School
 701 US-64
 Manteo, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 6
Sample Location: C102
Date Collected: 6/9/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/23/26

Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	1	13	spores/m ³	50%
Ascospores	1	13	spores/m ³	50%
Basidiospores		-	spores/m ³	-
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group		-	spores/m ³	-
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	2	27	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Avenue
Nags Head, NC

Project #: 26-1549
Project Location: Manteo Elementary School
701 US-64
Manteo, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 7
Sample Location: Gym
Date Collected: 6/9/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/23/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: moderate
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	1	13	spores/m ³	13%
Ascospores	1	13	spores/m ³	13%
Basidiospores		-	spores/m ³	-
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group		-	spores/m ³	-
Hyphal Elements	3	40	spores/m ³	38%
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>	2	27	spores/m ³	25%
<i>Epicoecum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>	1	13	spores/m ³	13%
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	8	107	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Avenue
Nags Head, NC

Project #: 26-1549
Project Location: Manteo Elementary School
701 US-64
Manteo, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 8
Sample Location: C114 Technology
Date Collected: 6/9/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/23/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: moderate
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	2	27	spores/m ³	29%
Ascospores		-	spores/m ³	-
Basidiospores		-	spores/m ³	-
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group		-	spores/m ³	-
Hyphal Elements	2	27	spores/m ³	29%
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>	2	27	spores/m ³	29%
<i>Epicoecum</i>	1	13	spores/m ³	14%
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	7	93	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Avenue
Nags Head, NC

Project #: 26-1549
Project Location: Manteo Elementary School
701 US-64
Manteo, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 9
Sample Location: D111
Date Collected: 6/9/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/23/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: moderate
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	3	40	spores/m ³	14%
Ascospores		-	spores/m ³	-
Basidiospores	4	53	spores/m ³	18%
Smuts, <i>Periconia</i> , Myxomycetes	3	40	spores/m ³	14%
<i>Penicillium/Aspergillus</i> Group	1	13	spores/m ³	5%
Hyphal Elements	6	80	spores/m ³	27%
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>	1	13	spores/m ³	5%
<i>Epicoecum</i>	3	40	spores/m ³	14%
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>	1	13	spores/m ³	5%
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	22	293	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Avenue
Nags Head, NC

Project #: 26-1549
Project Location: Manteo Elementary School
701 US-64
Manteo, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 10
Sample Location: D128
Date Collected: 6/9/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/23/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	2	27	spores/m ³	50%
Ascospores		-	spores/m ³	-
Basidiospores	2	27	spores/m ³	50%
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group		-	spores/m ³	-
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	4	53	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Avenue
Nags Head, NC

Project #: 26-1549
Project Location: Manteo Elementary School
701 US-64
Manteo, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 11
Sample Location: D130
Date Collected: 6/9/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/23/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	3	40	spores/m ³	50%
Ascospores		-	spores/m ³	-
Basidiospores	2	27	spores/m ³	33%
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group	1	13	spores/m ³	17%
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	6	80	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Avenue
Nags Head, NC

Project #: 26-1549
Project Location: Manteo Elementary School
701 US-64
Manteo, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 12
Sample Location: B201
Date Collected: 6/9/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/23/26

Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low-moderate
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>		-	spores/m ³	-
Ascospores		-	spores/m ³	-
Basidiospores	1	13	spores/m ³	33%
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group	2	27	spores/m ³	67%
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	3	40	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Avenue
Nags Head, NC

Project #: 26-1549
Project Location: Manteo Elementary School
701 US-64
Manteo, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 13
Sample Location: B205
Date Collected: 6/9/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/23/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low-moderate
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	2	27	spores/m ³	25%
Ascospores	2	27	spores/m ³	25%
Basidiospores		-	spores/m ³	-
Smuts, <i>Periconia</i> , Myxomycetes	2	27	spores/m ³	25%
<i>Penicillium/Aspergillus</i> Group	1	13	spores/m ³	13%
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>	1	13	spores/m ³	13%
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	8	107	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Avenue
Nags Head, NC

Project #: 26-1549
Project Location: Manteo Elementary School
701 US-64
Manteo, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 14
Sample Location: B209
Date Collected: 6/9/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/23/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low-moderate
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	2	27	spores/m ³	33%
Ascospores	1	13	spores/m ³	17%
Basidiospores	1	13	spores/m ³	17%
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group	2	27	spores/m ³	33%
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	6	80	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Avenue
Nags Head, NC

Project #: 26-1549
Project Location: Manteo Elementary School
701 US-64
Manteo, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 15
Sample Location: B214
Date Collected: 6/9/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/23/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low-moderate
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	2	27	spores/m ³	40%
Ascospores		-	spores/m ³	-
Basidiospores		-	spores/m ³	-
Smuts, <i>Periconia</i> , Myxomycetes	1	13	spores/m ³	20%
<i>Penicillium</i> / <i>Aspergillus</i> Group	1	13	spores/m ³	20%
Hyphal Elements	1	13	spores/m ³	20%
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera</i> / <i>Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	5	67	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Avenue
Nags Head, NC

Project #: 26-1549
Project Location: Manteo Elementary School
701 US-64
Manteo, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 16
Sample Location: B216
Date Collected: 6/9/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/23/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>		-	spores/m ³	-
Ascospores	2	27	spores/m ³	100%
Basidiospores		-	spores/m ³	-
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group		-	spores/m ³	-
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	2	27	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Avenue
Nags Head, NC

Project #: 26-1549
Project Location: Manteo Elementary School
701 US-64
Manteo, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 17
Sample Location: B221
Date Collected: 6/9/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/23/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	2	27	spores/m ³	33%
Ascospores		-	spores/m ³	-
Basidiospores	1	13	spores/m ³	17%
Smuts, <i>Periconia</i> , Myxomycetes	1	13	spores/m ³	17%
<i>Penicillium/Aspergillus</i> Group	1	13	spores/m ³	17%
Hyphal Elements	1	13	spores/m ³	17%
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	6	80	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Avenue
Nags Head, NC

Project #: 26-1549
Project Location: Manteo Elementary School
701 US-64
Manteo, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 18
Sample Location: B116
Date Collected: 6/9/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/23/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	1	13	spores/m ³	25%
Ascospores	1	13	spores/m ³	25%
Basidiospores		-	spores/m ³	-
Smuts, <i>Periconia</i> , Myxomycetes	1	13	spores/m ³	25%
<i>Penicillium/Aspergillus</i> Group		-	spores/m ³	-
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>	1	13	spores/m ³	25%
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	4	53	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Avenue
Nags Head, NC

Project #: 26-1549
Project Location: Manteo Elementary School
701 US-64
Manteo, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 19
Sample Location: B120
Date Collected: 6/9/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/23/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low-moderate
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	2	27	spores/m ³	33%
Ascospores		-	spores/m ³	-
Basidiospores		-	spores/m ³	-
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group	2	27	spores/m ³	33%
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>	2	27	spores/m ³	33%
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>		-	spores/m ³	-
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	6	80	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Avenue
Nags Head, NC

Project #: 26-1549
Project Location: Manteo Elementary School
701 US-64
Manteo, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 20
Sample Location: K101 Cafeteria Serving
Date Collected: 6/9/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/23/26
Volume (L): 75
Percentage of Slide Read: 100.0%
Detection Limit: 13.33
Particulate Level: low
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	2	27	spores/m ³	50%
Ascospores		-	spores/m ³	-
Basidiospores	1	13	spores/m ³	25%
Smuts, <i>Periconia</i> , Myxomycetes		-	spores/m ³	-
<i>Penicillium/Aspergillus</i> Group		-	spores/m ³	-
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>		-	spores/m ³	-
<i>Epicoccum</i>		-	spores/m ³	-
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>	1	13	spores/m ³	25%
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	4	53	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Dare County Schools
Ian Adams
3020 S. Wrightsville Avenue
Nags Head, NC

Project #: 26-1549
Project Location: Manteo Elementary School
701 US-64
Manteo, NC
Project Type: IAQ
PO/Claim #: —

Sample Number: 21
Sample Location: Outdoor Air
Date Collected: 6/9/26
Test Requested: Non-viable spore trap analysis
Date Analyzed: 6/23/26
Volume (L): 75
Percentage of Slide Read: 25.0%
Detection Limit: 53.33
Particulate Level: moderate
Notes: —

Spore Identification	Count	Results	Units	Percentage
<i>Cladosporium</i>	21	1120	spores/m ³	23%
Ascospores	12	640	spores/m ³	13%
Basidiospores	43	2293	spores/m ³	46%
Smuts, <i>Periconia</i> , Myxomycetes	8	427	spores/m ³	9%
<i>Penicillium/Aspergillus</i> Group	1	53	spores/m ³	1%
Hyphal Elements		-	spores/m ³	-
<i>Alternaria</i>		-	spores/m ³	-
<i>Curvularia</i>	4	213	spores/m ³	4%
<i>Epicoccum</i>	3	160	spores/m ³	3%
<i>Cercospora</i>		-	spores/m ³	-
<i>Arthrrium</i>		-	spores/m ³	-
Clear Brown		-	spores/m ³	-
Colorless		-	spores/m ³	-
<i>Trichocladium</i>		-	spores/m ³	-
Unidentified		-	spores/m ³	-
<i>Ulocladium</i>		-	spores/m ³	-
Torula		-	spores/m ³	-
<i>Pithomyces</i>		-	spores/m ³	-
Rust		-	spores/m ³	-
<i>Drechslera/Bipolaris</i>	1	53	spores/m ³	1%
<i>Tetraploa</i>		-	spores/m ³	-
<i>Chaetomium</i>		-	spores/m ³	-
<i>Stachybotrys</i>		-	spores/m ³	-
		-	spores/m ³	-
Total Spores	93	4960	spores/m³	

Analyzed by: Cathy A. Richmond, B.S.



LRC Indoor Testing and Research
200 Commonwealth Ct, Suite 101
Cary, NC 27511
(919) 342-4936

Certificate of Laboratory Analysis

Non-Viable Spore Trap Analysis

Project #: **26-1549**

Report Information:

DETECTION LIMITS (DL) for samples are the minimum number of spores or colonies forming units that can be satisfactorily identified for each sample type.

SPORE TRAP SAMPLES: Calculations based on volume of air sampled & percentage of slide counted, i.e. DL = 1000 L / 75 L if 100% of the slide is counted.

CODE 11: Fungal content and/or particulate level on slide too heavy to identify and enumerate fungal content.

Footnotes:

1. *Penicillium/Aspergillus* group spores are characterized by their small size, round to ovoid shape, being unicellular and usually colorless to lightly pigmented. There are numerous genera of fungi whose spore morphology is similar to that of the *Penicillium/Aspergillus* type. Several common examples would be *Acremonium*, *Paecilomyces*, and *Trichoderma*. Although the majority of spores placed in this group are *Penicillium*, *Aspergillus*, or a combination of both, these are not the only two possibilities.
2. Basidiospores are primarily transported indoors from outdoor sources and rarely grow indoors. A high basidiospore count indoors can be indicative of a wood decay problem or wet soil, and should be verified if and an outdoor source of the spores is not present.
3. Hyphae are the tubular filaments of fungi. Hyphae can fragment and become airborne much like spores and are potentially allergenic.
4. The Smut, *Periconia*, Myxomycete group is a group composed of three different types of organisms whose spores have similar morphologies. Smuts are plant pathogens, *Periconia* is a relatively uncommon mold indoors, and Myxomycetes are not fungi, but slime molds. Although these organisms do not typically proliferate indoors, their spores are potentially allergenic.
5. Rusts are plant pathogens. These fungi do not typically grow indoors unless an infected plant is present. Rust spores are potentially allergenic.

Direct Microscopic Exam Reporting:

We use a 400x-600x magnification microscope.

Reporting Quantification Levels are as follows:

Reporting Level	Quantitative Description
Occasional	1-10 per square inch
Few	11-100 per square inch
Moderate	101-1000 per square inch
Numerous	More than 1,000 per square inch

Submitted By Analyst:

Cathy A. Richmond, BS

6/23/2026