



Cesar Chavez PCS (Parkside - HS) - Lead in Water Test Results



FY25 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
Cesar Chavez PCS [Parkside - High School]	WS-094-001	Food Prep Sink	1	In kitchen			WF-022025-094001-10	6/3/2025	FT-FY25-022025-094001-A	<1	FT-FY25-022025-094001-B	<1
Cesar Chavez PCS [Parkside - High School]	WS-094-002	Cooler	1	In hallway across from main office	High	Left	WF-022025-094002-08	N/A	FT-FY25-022025-094002-A	Non-operational	FT-FY25-022025-094002-B	Non-operational
Cesar Chavez PCS [Parkside - High School]	WS-094-003	Cooler	1	In hallway across from main office	Low	Right	WF-022025-094003-08	N/A	FT-FY25-022025-094003-A	Non-operational	FT-FY25-022025-094003-B	Non-operational
Cesar Chavez PCS [Parkside - High School]	WS-094-004	Cooler	1	In hallway across from room 129	High	Left	WF-022025-094004-08	6/3/2025	FT-FY25-022025-094004-A	<1	FT-FY25-022025-094004-B	<1
Cesar Chavez PCS [Parkside - High School]	WS-094-005	Cooler	1	In hallway across from room 129	Low	Right	WF-022025-094005-08	6/3/2025	FT-FY25-022025-094005-A	<1	FT-FY25-022025-094005-B	<1
Cesar Chavez PCS [Parkside - High School]	WS-094-006	Health Suite	1	In nurse office 107			WF-022025-094006-07	6/3/2025	FT-FY25-022025-094006-A	<1	FT-FY25-022025-094006-B	<1
Cesar Chavez PCS [Parkside - High School]	WS-094-007	Break Room	1	In classroom 119			WF-022025-094007-08	N/A	FT-FY25-022025-094007-A	Non-operational	FT-FY25-022025-094007-B	Non-operational
Cesar Chavez PCS [Parkside - High School]	WS-094-008	Break Room	2	In teacher's workroom 233			WF-022025-094008-07	6/3/2025	FT-FY25-022025-094008-A	<1	FT-FY25-022025-094008-B	<1
Cesar Chavez PCS [Parkside - High School]	WS-094-009	Cooler	2	In hallway across from room 203	High	Left	WF-022025-094009-09	N/A	FT-FY25-022025-094009-A	Non-operational	FT-FY25-022025-094009-B	Non-operational
Cesar Chavez PCS [Parkside - High School]	WS-094-010	Cooler	2	In hallway across from room 203	Low	Right	WF-022025-094010-09	N/A	FT-FY25-022025-094010-A	Non-operational	FT-FY25-022025-094010-B	Non-operational
Cesar Chavez PCS [Parkside - High School]	WS-094-011	Cooler	2	In hallway across from room 217	High	Left	WF-022025-094011-08	N/A	FT-FY25-022025-094011-A	Non-operational	FT-FY25-022025-094011-B	Non-operational
Cesar Chavez PCS [Parkside - High School]	WS-094-012	Cooler	2	In hallway across from room 217	Low	Right	WF-022025-094012-08	N/A	FT-FY25-022025-094012-A	Non-operational	FT-FY25-022025-094012-B	Non-operational
Cesar Chavez PCS [Parkside - High School]	WS-094-013	Cooler	1	In gymnasium	High	Left	WF-022025-094013-06	6/3/2025	FT-FY25-022025-094013-A	<1	FT-FY25-022025-094013-B	<1
Cesar Chavez PCS [Parkside - High School]	WS-094-014	Cooler	1	In gymnasium	Low	Right	WF-022025-094014-06	6/3/2025	FT-FY25-022025-094014-A	<1	FT-FY25-022025-094014-B	<1