

December 19, 2024

Dear MCVSD Community,

Our school system is committed to protecting student, teacher, and staff health. To protect our community and in compliance with the Department of Education regulations, the Morris County Vocational School District tested our high school's drinking water for lead in October 2024.

Results of our Testing

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we completed a plumbing profile for each of the buildings within the Morris County Vocational School District. Through this effort, we identified and tested all drinking water and food preparation outlets. Of the forty-four (44) samples taken, all tested below the lead action level of 15 ppb.

If any drinking water or food preparation outlet had been determined to be out of compliance, in accordance with the Department of Education regulations, Morris County School of Technology would implement immediate remedial measures for any drinking water outlet with a result greater than the US Environmental Protection Agency established action level of 15 µg/l (parts per billion [ppb]) for lead. This would have included turning off the outlet unless it is determined the location must remain on for non-drinking purposes. In these cases, a "DO NOT DRINK – SAFE FOR HANDWASHING ONLY" sign would have been posted.

Health Effects of Lead

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and it can be released later in life. During pregnancy, the child receives lead from the mother's bones, which may affect brain development.

In other words, it is the fetus that is at risk because developing fetuses receive lead from the mother's bones. Children and fetuses absorb more lead into their bodies than adults and are more susceptible to its effects on brain development; however, most children with elevated blood lead levels do not exhibit any symptoms, but effects may appear later in life.

How Lead Enters our Water

Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like rivers and lakes. Lead enters drinking water primarily as a result of the corrosion, or wearing away, of materials containing lead in the water distribution system and household plumbing. These materials include lead-based solder used to join copper pipes, brass, and chrome-brass faucets, and in some cases, pipes made of or lined with lead.

When water remains in contact with lead pipes or plumbing materials containing lead over time, the lead may dissolve into your drinking water. This means the first water drawn from the tap in the morning, or later in the afternoon if the water has not been used all day, may contain elevated levels of lead.

- Homes and buildings in New Jersey built before 1987 are more likely to have lead pipes and/or lead solder.
- Service lines, which may also contain lead, are the individual pipes that run from the well to a home or building. The property owner may also be the owner of the service line. Lead service lines are not typically found in non-community systems (e.g., school, office, restaurant, or other buildings on their own well).
- Brass faucets, fittings, and valves, including those advertised as “lead-free”, may also contribute lead to drinking water. The law currently allows end-use brass fixtures, such as faucets, that contain a maximum of 0.25 percent lead to be labeled as “lead free”. However, prior to January 4, 2014, “lead free” allowed up to 8 percent lead content of the wetted surfaces of plumbing products including those labeled National Sanitation Foundation (NSF) certified. Consumers should be aware of their current fixtures and take appropriate precautions.

Lead in Drinking Water

Lead is a common metal found in the environment. Drinking water is one possible source of lead exposure. The main sources of lead exposure are lead-based paint and lead-contaminated dust or soil. In addition, lead can be found in certain types of pottery, pewter, brass fixtures, cosmetics, imported spices and other food. Other sources include exposure in the workplace and exposure from certain hobbies like shooting ranges and fishing (lead can be carried on clothing or shoes). Lead is found in some toys, some playground equipment, and some children’s metal jewelry.

EPA estimates that 10 to 20 percent of a person’s potential exposure to lead may come from drinking water. Infants who consume mostly formula mixed with lead-containing water may receive 40 to 60 percent of their exposure to lead from drinking water. When there are elevated levels of lead in your water, drinking water is likely to be a more important source of exposure.

For More Information

A copy of the test results is available in our central office for inspection by the public, including students, teachers, other school personnel, and parents, and can be viewed between the hours of 8:00 a.m. and 4:00 p.m. and are also available on our website at www.mcvts.org. For more information about water quality in our schools, contact Bill Poisseroux, Facilities Manager at (973) 627-4600 ext. 227.

For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's Web site at www.epa.gov/lead, call the National Lead Information Center at 800-424-LEAD or Safe Drinking Water Act hotline at 1-800-426-4791, or contact your health care provider.

If you are concerned about lead exposure at this facility or in your home, you may want to ask your health care providers about testing children to determine levels of lead in their blood.

Sincerely,

A handwritten signature in black ink, appearing to read "Shari Castelli". The signature is fluid and cursive, with the first name "Shari" and last name "Castelli" clearly distinguishable.

Shari Castelli
Acting Superintendent

December 18th, 2024

Morris County Vocational School
400 East Main Street
Denville NJ 07834

PROPERTY LOCATION: Morris County Vocational School
400 East Main Street - Denville

WATER ANALYSIS REPORT

*Enclosed please find the water analysis report from the lab for the above listed property. As indicated in the report, all the parameters tested **DO** comply with NJ DEP standards. Please review the reports carefully and feel free to contact our office if you have any questions.

The following parameters were tested:

Lead/Copper – 44 Locations

** indicates parameters that do not meet NJ DEP standards.

When submitting reporting forms to any organization, RAdata strongly recommends you retain a copy for your files. RAdata & the labs retain copies if something should happen to your copies.

Thank You,

Stephanie Leenstra

Stephanie Leenstra
Field Services Manager



RAdata, LLC
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: William Mickley
Morris County Vocational School
400 East Main Street
Denville, NJ 078340000

Laboratory Results

Sample Number	Sample Location	Collected By
1024-1765	400 East Main Street - Denville Twp	Jacob, Smith

Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
1024-1765	10/3/2024 6:13:00 AM Room 425 Auto Teacher Water Fountain	10/15/2024 9:11:00 AM	Lead (1st Draw)	3.24 ug/L	15 ug/L 2 ug/l	Std Method 3113B
1024-1765-1	10/3/2024 6:13:00 AM Room 425 Auto Teacher Water Fountain	10/11/2024 2:16:00 PM	Copper	0.0910 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
1024-1765-10	10/3/2024 6:27:00 AM Building 4 Pot and Pan Wash Sink	10/11/2024 2:07:00 PM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
1024-1765-10	10/3/2024 6:27:00 AM Building 4 Pot and Pan Wash Sink	10/11/2024 2:16:00 PM	Copper	0.169 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
1024-1765-11	10/3/2024 6:28:00 AM Building 4 Sanitize Sink	10/11/2024 2:07:00 PM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
1024-1765-11	10/3/2024 6:28:00 AM Building 4 Sanitize Sink	10/11/2024 2:16:00 PM	Copper	0.165 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
1024-1765-12	10/3/2024 6:29:00 AM Building 4 Handwash Sink by Exiting	10/11/2024 2:07:00 PM	Lead (1st Draw)	6.31 ug/L	15 ug/L 2 ug/l	Std Method 3113B
1024-1765-12	10/3/2024 6:29:00 AM Building 4 Handwash Sink by Exiting	10/11/2024 2:16:00 PM	Copper	0.167 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
1024-1765-13	10/3/2024 6:34:00 AM Water Fountain by Room 406	10/11/2024 2:07:00 PM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
1024-1765-13	10/3/2024 6:34:00 AM Water Fountain by Room 406	10/11/2024 2:16:00 PM	Copper	< 0.0500 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
1024-1765-14	10/3/2024 6:35:00 AM Bottle Filler by Room 406	10/15/2024 9:11:00 AM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
1024-1765-14	10/3/2024 6:35:00 AM Bottle Filler by Room 406	10/11/2024 2:16:00 PM	Copper	< 0.0500 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
1024-1765-15	10/3/2024 6:37:00 AM Room 407 Kids Hand Wash Sink	10/15/2024 9:11:00 AM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
1024-1765-15	10/3/2024 6:37:00 AM Room 407 Kids Hand Wash Sink	10/11/2024 2:16:00 PM	Copper	0.0560 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
1024-1765-16	10/3/2024 6:37:00 AM Room 407 Kitchen Sink	10/15/2024 9:11:00 AM	Lead (1st Draw)	2.72 ug/L	15 ug/L 2 ug/l	Std Method 3113B

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Tuesday, December 17, 2024

NJDEP Laboratory Certification # 14006

Page 1 of 7



RAdata, LLC
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: William Mickley
Morris County Vocational School
400 East Main Street
Denville, NJ 078340000

Laboratory Results

Sample Number	Sample Location	Collected By
1024-1765	400 East Main Street - Denville Twp	Jacob, Smith

Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
1024-1765-16	10/3/2024 6:37:00 AM Room 407 Kitchen Sink	10/11/2024 2:16:00 PM	Copper	0.148 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
1024-1765-17	10/3/2024 6:39:00 AM Handwash Sink in Biology	10/15/2024 9:11:00 AM	Lead (1st Draw)	12.6 ug/L	15 ug/L 2 ug/l	Std Method 3113B
1024-1765-17	10/3/2024 6:39:00 AM Handwash Sink in Biology	10/11/2024 2:16:00 PM	Copper	0.224 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
1024-1765-18	10/3/2024 6:41:00 AM 412 Teacher's Lounge Sink	10/15/2024 9:11:00 AM	Lead (1st Draw)	2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
1024-1765-18	10/3/2024 6:41:00 AM 412 Teacher's Lounge Sink	10/11/2024 2:16:00 PM	Copper	0.156 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
1024-1765-19	10/3/2024 6:44:00 AM Water Fountain by Room 418	10/15/2024 9:11:00 AM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
1024-1765-19	10/3/2024 6:44:00 AM Water Fountain by Room 418	10/11/2024 2:16:00 PM	Copper	< 0.0500 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
1024-1765-2	10/3/2024 6:15:00 AM Room 426 Auto Tech Water Fountain	10/11/2024 2:07:00 PM	Lead (1st Draw)	10.1 ug/L	15 ug/L 2 ug/l	Std Method 3113B
1024-1765-2	10/3/2024 6:15:00 AM Room 426 Auto Tech Water Fountain	10/11/2024 2:16:00 PM	Copper	0.0880 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
1024-1765-20	10/3/2024 6:45:00 AM Bottle Filler by Room 418	10/15/2024 9:11:00 AM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
1024-1765-20	10/3/2024 6:45:00 AM Bottle Filler by Room 418	10/11/2024 2:16:00 PM	Copper	< 0.0500 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
1024-1765-21	10/3/2024 6:46:00 AM Room 420 Handwash Sink	10/15/2024 9:11:00 AM	Lead (1st Draw)	3.84 ug/L	15 ug/L 2 ug/l	Std Method 3113B
1024-1765-21	10/3/2024 6:46:00 AM Room 420 Handwash Sink	10/11/2024 2:16:00 PM	Copper	0.0860 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
1024-1765-22	10/3/2024 6:50:00 AM Water Fountain by Room 303	10/15/2024 9:11:00 AM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
1024-1765-22	10/3/2024 6:50:00 AM Water Fountain by Room 303	10/11/2024 2:16:00 PM	Copper	0.0700 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Tuesday, December 17, 2024

NJDEP Laboratory Certification # 14006

Page 2 of 7



RAdata, LLC
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: William Mickley
Morris County Vocational School
400 East Main Street
Denville, NJ 078340000

Laboratory Results

Sample Number	Sample Location	Collected By
1024-1765	400 East Main Street - Denville Twp	Jacob, Smith

Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
1024-1765-23	10/3/2024 6:51:00 AM Bottle Filler by Room 303	10/15/2024 9:11:00 AM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
1024-1765-23	10/3/2024 6:51:00 AM Bottle Filler by Room 303	10/11/2024 2:16:00 PM	Copper	0.0600 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
1024-1765-24	10/3/2024 6:52:00 AM Room 302 Electrical Bathroom Tap	10/15/2024 9:11:00 AM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
1024-1765-24	10/3/2024 6:52:00 AM Room 302 Electrical Bathroom Tap	10/11/2024 2:16:00 PM	Copper	< 0.0500 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
1024-1765-25	10/3/2024 6:53:00 AM Water Fountain by Room 306	10/15/2024 9:11:00 AM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
1024-1765-25	10/3/2024 6:53:00 AM Water Fountain by Room 306	10/11/2024 2:16:00 PM	Copper	0.0560 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
1024-1765-26	10/3/2024 6:54:00 AM Bottle Filler by Room 306	10/15/2024 9:11:00 AM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
1024-1765-26	10/3/2024 6:54:00 AM Bottle Filler by Room 306	10/11/2024 2:16:00 PM	Copper	0.0640 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
1024-1765-27	10/3/2024 6:57:00 AM Staff Bathroom by Boiler Room	10/15/2024 9:11:00 AM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
1024-1765-27	10/3/2024 6:57:00 AM Staff Bathroom by Boiler Room	10/11/2024 2:16:00 PM	Copper	0.135 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
1024-1765-28	10/3/2024 7:01:00 AM Water Fountain by Room 201	10/15/2024 9:11:00 AM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
1024-1765-28	10/3/2024 7:01:00 AM Water Fountain by Room 201	10/11/2024 2:16:00 PM	Copper	< 0.0500 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
1024-1765-29	10/3/2024 7:02:00 AM Bottle Filler by Room 201	10/15/2024 9:11:00 AM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
1024-1765-29	10/3/2024 7:02:00 AM Bottle Filler by Room 201	10/11/2024 2:16:00 PM	Copper	< 0.0500 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
1024-1765-3	10/3/2024 6:17:00 AM Room 427 Nurses Office Tap	10/15/2024 9:11:00 AM	Lead (1st Draw)	3.73 ug/L	15 ug/L 2 ug/l	Std Method 3113B

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Tuesday, December 17, 2024

NJDEP Laboratory Certification # 14006

Page 3 of 7



RAdata, LLC
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: William Mickley
Morris County Vocational School
400 East Main Street
Denville, NJ 078340000

Laboratory Results

Sample Number 1024-1765 **Sample Location** 400 East Main Street - Denville Twp **Collected By** Jacob, Smith

Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
1024-1765-3	10/3/2024 6:17:00 AM Room 427 Nurses Office Tap	10/11/2024 2:16:00 PM	Copper	0.110 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
1024-1765-30	10/3/2024 7:04:00 AM Water Fountain by Room 629	10/15/2024 9:11:00 AM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
1024-1765-30	10/3/2024 7:04:00 AM Water Fountain by Room 629	10/11/2024 2:16:00 PM	Copper	< 0.0500 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
1024-1765-31	10/3/2024 7:05:00 AM Bottle Filler by Room 629	10/15/2024 9:11:00 AM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
1024-1765-31	10/3/2024 7:05:00 AM Bottle Filler by Room 629	10/11/2024 2:16:00 PM	Copper	< 0.0500 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
1024-1765-32	10/3/2024 7:08:00 AM Water Fountain by Building 1 Electrical	10/15/2024 9:11:00 AM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
1024-1765-32	10/3/2024 7:08:00 AM Water Fountain by Building 1 Electrical	10/11/2024 2:16:00 PM	Copper	0.0680 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
1024-1765-33	10/3/2024 7:09:00 AM Right Fountain by Building 1 Electrical	10/17/2024 11:18:00 AM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
1024-1765-33	10/3/2024 7:09:00 AM Right Fountain by Building 1 Electrical	10/11/2024 2:16:00 PM	Copper	0.0500 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
1024-1765-34	10/3/2024 7:10:00 AM Bottle Filler by Building 1 Electrical	10/17/2024 11:18:00 AM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
1024-1765-34	10/3/2024 7:10:00 AM Bottle Filler by Building 1 Electrical	10/11/2024 2:16:00 PM	Copper	< 0.0500 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
1024-1765-35	10/3/2024 7:11:00 AM Bottle Filler by Building 1 Staff BT	10/17/2024 11:18:00 AM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
1024-1765-35	10/3/2024 7:11:00 AM Bottle Filler by Building 1 Staff BT	10/11/2024 2:16:00 PM	Copper	0.0730 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
1024-1765-36	10/3/2024 7:12:00 AM Bottle Filler by Room 113	10/17/2024 11:18:00 AM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
1024-1765-36	10/3/2024 7:12:00 AM Bottle Filler by Room 113	10/11/2024 2:16:00 PM	Copper	0.0740 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Tuesday, December 17, 2024

NJDEP Laboratory Certification # 14006

Page 4 of 7



RAdata, LLC
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: William Mickley
Morris County Vocational School
400 East Main Street
Denville, NJ 078340000

Laboratory Results

Sample Number **Sample Location** **Collected By**
1024-1765 400 East Main Street - Denville Twp Jacob, Smith

Sample No.	Collected	Analyzed	Parameter	Result	MCL [#]	Method
1024-1765-37	10/3/2024 7:13:00 AM Water Fountain by Room 107	10/17/2024 11:18:00 AM	Lead (1st Draw)	5.50 ug/L	15 ug/L 2 ug/l	Std Method 3113B
1024-1765-37	10/3/2024 7:13:00 AM Water Fountain by Room 107	10/11/2024 2:16:00 PM	Copper	0.151 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
1024-1765-38	10/3/2024 7:15:00 AM Bottle Filler by Cafeteria	10/17/2024 11:18:00 AM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
1024-1765-38	10/3/2024 7:15:00 AM Bottle Filler by Cafeteria	10/11/2024 2:16:00 PM	Copper	0.139 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
1024-1765-39	10/3/2024 7:17:00 AM Building 1 Hand Wash Sink Food Services	10/17/2024 11:18:00 AM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
1024-1765-39	10/3/2024 7:17:00 AM Building 1 Hand Wash Sink Food Services	10/11/2024 2:16:00 PM	Copper	0.178 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
1024-1765-4	10/3/2024 6:21:00 AM Building 4 Kitchen Prep Sink by Spices	10/11/2024 2:07:00 PM	Lead (1st Draw)	9.16 ug/L	15 ug/L 2 ug/l	Std Method 3113B
1024-1765-4	10/3/2024 6:21:00 AM Building 4 Kitchen Prep Sink by Spices	10/11/2024 2:16:00 PM	Copper	0.0830 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
1024-1765-40	10/3/2024 7:18:00 AM Building Food Services Sink	10/17/2024 11:18:00 AM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
1024-1765-40	10/3/2024 7:18:00 AM Building Food Services Sink	10/11/2024 2:16:00 PM	Copper	0.309 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
1024-1765-41	10/3/2024 7:20:00 AM Cafeteria Left Pots and Pans Sink	10/17/2024 11:18:00 AM	Lead (1st Draw)	2.62 ug/L	15 ug/L 2 ug/l	Std Method 3113B
1024-1765-41	10/3/2024 7:20:00 AM Cafeteria Left Pots and Pans Sink	10/11/2024 2:16:00 PM	Copper	0.176 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
1024-1765-42	10/3/2024 7:21:00 AM Cafeteria Right Pots and Pans Sink	10/17/2024 11:18:00 AM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
1024-1765-42	10/3/2024 7:21:00 AM Cafeteria Right Pots and Pans Sink	10/11/2024 2:16:00 PM	Copper	0.164 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
1024-1765-43	10/3/2024 7:22:00 AM Cafeteria Dish Sprayer	10/17/2024 11:18:00 AM	Lead (1st Draw)	4.11 ug/L	15 ug/L 2 ug/l	Std Method 3113B

[#] MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.



RAdata, LLC
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: William Mickley
Morris County Vocational School
400 East Main Street
Denville, NJ 078340000

Laboratory Results

Sample Number	Sample Location	Collected By
1024-1765	400 East Main Street - Denville Twp	Jacob, Smith

Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
1024-1765-43	10/3/2024 7:22:00 AM Cafeteria Dish Sprayer	10/11/2024 2:16:00 PM	Copper	0.276 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
1024-1765-44	10/3/2024 7:23:00 AM Cafeteria Hand Wash Sink	10/17/2024 11:18:00 AM	Lead (1st Draw)	9.33 ug/L	15 ug/L 2 ug/l	Std Method 3113B
1024-1765-44	10/3/2024 7:23:00 AM Cafeteria Hand Wash Sink	10/11/2024 2:16:00 PM	Copper	0.158 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
1024-1765-5	10/3/2024 6:22:00 AM Building 4 Kitchen Prep Sink by Food Trays	10/11/2024 2:07:00 PM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
1024-1765-5	10/3/2024 6:22:00 AM Building 4 Kitchen Prep Sink by Food Trays	10/11/2024 2:16:00 PM	Copper	< 0.0500 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
1024-1765-6	10/3/2024 6:23:00 AM Kitchen Handwash Sink by Freezer	10/11/2024 2:07:00 PM	Lead (1st Draw)	2.85 ug/L	15 ug/L 2 ug/l	Std Method 3113B
1024-1765-6	10/3/2024 6:23:00 AM Kitchen Handwash Sink by Freezer	10/11/2024 2:16:00 PM	Copper	0.178 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
1024-1765-7	10/3/2024 6:24:00 AM Building 4 Kitchen Dishwashing Sink	10/11/2024 2:07:00 PM	Lead (1st Draw)	5.53 ug/L	15 ug/L 2 ug/l	Std Method 3113B
1024-1765-7	10/3/2024 6:24:00 AM Building 4 Kitchen Dishwashing Sink	10/11/2024 2:16:00 PM	Copper	0.240 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
1024-1765-8	10/3/2024 6:25:00 AM Building 4 Kitchen Island Sink	10/11/2024 2:07:00 PM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
1024-1765-8	10/3/2024 6:25:00 AM Building 4 Kitchen Island Sink	10/11/2024 2:16:00 PM	Copper	< 0.0500 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
1024-1765-9	10/3/2024 6:26:00 AM Building 4 Kitchen Cold Water Supply	10/11/2024 2:07:00 PM	Lead (1st Draw)	7.73 ug/L	15 ug/L 2 ug/l	Std Method 3113B
1024-1765-9	10/3/2024 6:26:00 AM Building 4 Kitchen Cold Water Supply	10/11/2024 2:16:00 PM	Copper	0.109 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Tuesday, December 17, 2024

NJDEP Laboratory Certification # 14006

Page 6 of 7



RAdata, LLC
27 Ironia Road, Unit 2
Flanders, NJ 07836
973-927-7303 Phone
973-927-4980 Fax

Customer: William Mickley
Morris County Vocational School
400 East Main Street
Denville, NJ 078340000

Laboratory Results

Sample Number	Sample Location	Collected By
1024-1765	400 East Main Street - Denville Twp	Jacob, Smith

Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
------------	-----------	----------	-----------	--------	-------	--------

**The parameters tested on this report PASSED NJ
Drinking Water Standards.**

This report represents results associated to the point of collection location in the structure only. It is recommended that other locations within the structure where water can be consumed, be tested to verify compliance to state and federal drinking water regulations.

Reviewed and Approved by:

Kaity March

Kaity March, Laboratory Manager Designe

MCL - Maximum Contaminant Level

ND - Not Detected

* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

** If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Tuesday, December 17, 2024

NJDEP Laboratory Certification # 14006

Page 7 of 7

RAdata, LLC

27 Ironia Road Unit 2
Flanders, New Jersey 07836
973-927-7303 Phone
973-927-8221 Fax
NJDEP LAB ID# 14006

Chain of Custody / Analysis Request Form

Project Name: Morris County Volatile Soil School RAdata Job # 1024-1765-1Project Address: 400 East Main StreetDenville NJ 07834

1024-1765-3
1024-1765-4
1024-1765-5

Report To: (Name and address)		Bill To: (Name and address)		Property Lot: _____		Number of Containers		Indicate Analysis Requested by checking appropriate boxes													
Phone: _____		Phone: _____		Property Block: _____				Total Coliform / E-coli	Nitrate, Total	Volatile Organics	Lead	Iron	Manganese	Arsenic	EPA 504.1	Gross Alpha	Uranium				
Fax: _____		Fax: _____		Municipality: <u>Denville Twp?</u>																	
				County: <u>Morris</u>																	
Sampled by: (Signature) _____			Sample Collection Date: <u>11/3/24</u>			Turnaround Time: _____															
Item No.	Sample ID Number	Sample Location	Sample Collection Time	Method Preserved						Matrix											
				Na ₂ S ₂ O ₃	HCl	HNO ₃	H ₂ SO ₄	NONE	OTHER	WATER	OTHER										
1		Room 425 North 15th St	6:13			X					X										X
2		Room 426 North 15th St	6:13			X					X										X
3		Room 427 North 15th St	6:17			X					X										X
4		Building 4 North 15th St	6:21			X					X										X
5		Building 4 North 15th St	6:22			X					X										X
Field pH _____		GPS Coordinate Origin: Well Head / Front Door / Sample Collection Point / Other _____																			
Field Temperature _____ °C		N.J. Well Permit or Well Record Number (if known) _____																			
Time _____		GPS Monitor # _____ GPS File # _____																			
Released by (Signature) _____		Date/Time Released <u>10/3/24</u>	Delivery Method <u>FR</u>	Received by (Signature) _____		Date/Time Received <u>10-4-24 6:13</u>		Temperature upon receipt, °C													

COMMENTS:

REPORT COPY

27 Ironia Road Unit 2
Flanders, New Jersey 07836
973-927-7303 Phone
973-927-8221 Fax
NJDEP LAB ID# 14006

Project Name: Monroe's County Vocational School

RAdata Job # _____

Project Address: 400 East main street

Den v. 11e ms 67834

1024-1765-6
1024-1765-7

1024-1765-5
1024-1765-9
1024-1765-10

Report To: (Name and address)		Bill To: (Name and address)		Property Lot: _____		Indicate Analysis Requested by checking appropriate boxes						
Phone: _____		Phone: _____		Property Block: _____								
Fax: _____		Fax: _____		Municipality: <u>Denville Twp</u>								
				County: <u>Morris</u>								
Sampled by: (Signature) _____			Sample Collection Date: <u>10/5/24</u>		Turnaround Time: _____		Number of Containers Total Coliform / E-coli Nitrate, Total Volatile Organics Lead Iron Manganese Arsenic EPA 504.1 Gross Alpha Uranium					
Item No.	Sample ID Number	Sample Location	Sample Collection Time	Method Preserved				Matrix				
				Na ₂ S ₂ O ₃	HCl	HNO ₃		H ₂ SO ₄	NONE	OTHER	WATER	OTHER
1		Kitchen Handwashed Sink By Decker	623			X						
2		Funk 94 Kitchen Dishwasher Sink	624			X						
3		Bunk 94 Kitchen Island Sink	625			X						
4		Building 4 Kitchen Sink	626			X						
5		Building 4 Kitchen Sink	627			X						
Field pH _____		GPS Coordinate Origin: Well Head / Front Door / Sample Collection Point / Other _____						Size of holding tank _____ gallon				
Field Temperature _____ °C		N.J. Well Permit or Well Record Number (if known) _____						Water flush time _____ minutes				
Time _____		GPS Monitor # _____ GPS File # _____										
Released by (Signature) _____		Date/Time Released	Delivery Method	Received by (Signature) _____		Date/Time Received		Temperature upon receipt, °C				
		10/3/24	HG10									

COMMENTS:

REPORT COPY

RAdata, LLC

27 Ironia Road Unit 2
Flanders, New Jersey 07836
973-927-7303 Phone
973-927-8221 Fax
NJDEP LAB ID# 14006

Chain of Custody / Analysis Request Form

Project Name:

HILLS County VOC/Heavy Metals

RAdata Job #

Project Address:

400 East Main Street

Denville NJ 07834

1024-1765-11

1024-1765-12

1024-1765-13

1024-1765-14

1024-1765-15

Report To: (Name and address)**Bill To:** (Name and address)

Property Lot: _____

Property Block: _____

Municipality: Denville TwpCounty: McCook

Phone: _____

Phone: _____

Fax: _____

Fax: _____

Indicate Analysis Requested
by checking appropriate boxes**Sampled by:** (Signature) _____**Sample Collection Date:** _____**Turnaround Time:** _____

10/3/24

Item No.	Sample ID Number	Sample Location	Sample Collection Time	Method Preserved						Matrix		Number of Containers	Total Coliform	Nitrate, Total	Volatile Organics	Lead	Iron	Manganese	Arsenic	EPA 504.1	Gross Alpha	Uranium	
				Na ₂ S ₂ O ₃	HCl	HNO ₃	H ₂ SO ₄	NONE	OTHER	WATER	OTHER												
1		Building 4 Soil 1.2m x 1.2m	10/29			X						1				X							X
2		Building 4 Soil 1.2m x 1.2m	10/29			X						1				X							X
3		Water Sample - By Room 406	10/34			X						1				X							X
4		Water Sample - By Room 406	10/35			X						1				X							X
5		Room 407 - 815 water sample	10/37			X						1				X							X

Field pH _____

Field Temperature _____ °C

Time _____

GPS Coordinate Origin: Well Head / Front Door / Sample Collection Point / Other _____

N.J. Well Permit or Well Record Number (if known) _____

GPS Monitor # _____ GPS File # _____

Size of holding tank _____ gallons

Water flush time _____ minutes

Released by (Signature) _____

Date/Time Released

Delivery Method

Received by (Signature) _____

Date/Time Received

Temperature upon receipt, °C

COMMENTS:

REPORT COPY

RAdata, LLC

27 Ironia Road Unit 2
Flanders, New Jersey 07836
973-927-7303 Phone
973-927-8221 Fax
NJDEP LAB ID# 14006

Chain of Custody / Analysis Request Form

Project Name: Metris County Vocational School

RAdata Job #

Project Address: 400 East Main StreetDenville NJ 07834

1024-1765-16

1024-1765-17

1024-1765-18

1024-1765-19

1024-1765-20

Report To: (Name and address)		Bill To: (Name and address)		Property Lot: _____		Number of Containers		Indicate Analysis Requested by checking appropriate boxes											
Phone: _____ Fax: _____		Phone: _____ Fax: _____		Property Block: _____ Municipality: <u>Denville Twp</u> County: <u>Metris</u>				Total Coliform / E-coli	Nitrate, Total	Volatile Organics	Lead	Iron	Manganese	Arsenic	EPA 504.1	Gross Alpha	Uranium	Copper	
Sampled by: (Signature) _____			Sample Collection Date: <u>10/3/24</u>			Turnaround Time: _____													
Item No.	Sample ID Number	Sample Location	Sample Collection Time	Method Preserved						Matrix									
				Na₂S₂O₃	HCl	HNO₃	H₂SO₄	NONE	OTHER	WATER	OTHER								
1		Room 407 Kitchen Sink	6:37			X						1							X
2		Handwash Sink in Room 303	6:41			X						1							X
3		412 Teachers Lounge Sink	6:41			X						1							X
4		Water Fountain in Room 418	6:44			X						1							X
5		Bottle Filling Room 418	6:45			X						1							X
Field pH _____ Field Temperature _____ °C Time _____		GPS Coordinate Origin: Well Head / Front Door / Sample Collection Point / Other _____ N.J. Well Permit or Well Record Number (if known) _____ GPS Monitor # _____ GPS File # _____										Size of holding tank _____ gallons Water flush time _____ minutes							
Released by (Signature)		Date/Time Released	Delivery Method	Received by (Signature)		Date/Time Received		Temperature upon receipt, °C											
<u>[Signature]</u>		<u>10/3/24</u>	<u>Hand</u>																

COMMENTS:

REPORT COPY

RAdata, LLC

27 Ironia Road Unit 2
 Flanders, New Jersey 07836
 973-927-7303 Phone
 973-927-8221 Fax
 NJDEP LAB ID# 14006

Chain of Custody / Analysis Request Form

Project Name: Morris County Vocational School

RAdata Job #

Project Address: 400 East Main Street

Denville NJ 07834

1024-1765-21

1024-1765-22

1024-1765-23

1024-1765-24

1024-1765-25

Report To: (Name and address)		Bill To: (Name and address)		Property Lot: _____		Property Block: _____		Municipality: <u>Denville Twp</u>		County: <u>Morris</u>		Indicate Analysis Requested by checking appropriate boxes																				
Phone: _____		Phone: _____										Number of Containers	Total Coliform / E-coli	Nitrate, Total	Volatile Organics	Lead	Iron	Manganese	Arsenic	EPA 504.1	Gross Alpha	Uranium										
Fax: _____		Fax: _____																														
Sampled by: (Signature) _____				Sample Collection Date: <u>10/3/24</u>				Turnaround Time: _____																								
Item No.	Sample ID Number	Sample Location	Sample Collection Time	Method Preserved	Matrix																											
				Na₂S₂O₃	HCl	HNO₃	H₂SO₄	NONE	OTHER	WATER	OTHER																					
1		Room 400 Hallway near 3rd	6:46			X						1				X						X										
2		Room 303	6:50			X						1				X						X										
3		Room 203	6:51			X						1				X						X										
4		Room 302 E/Kelley Bathroom	6:52			X						1				X						X										
5		Water fountain in Room 306	6:53			X						1				X						X										

Field pH _____
 Field Temperature _____ °C
 Time _____

GPS Coordinate Origin: Well Head / Front Door / Sample Collection Point / Other _____

N.J. Well Permit or Well Record Number (if known) _____

GPS Monitor # _____ GPS File # _____

Size of holding tank _____ gallons

Water flush time _____ minutes

Released by (Signature) _____

Date/Time Released 10/3/24

Delivery Method Hand

Received by (Signature) _____

Date/Time Received _____

Temperature upon receipt, °C _____

COMMENTS:

REPORT COPY

RAdata, LLC

Chain of Custody / Analysis Request Form

27 Ironia Road Unit 2
Flanders, New Jersey 07836
973-927-7303 Phone
973-927-8221 Fax
NJDEP LAB ID# 14006

Project Name: Morris County Vocational School RAdata Job # 1024-1765-26Project Address: 400 East Main Street
Denville NJ 078341024-1765-271024-1765-281024-1765-291024-1765-30

Report To: (Name and address)		Bill To: (Name and address)		Property Lot: _____		Number of Containers		Indicate Analysis Requested by checking appropriate boxes													
Phone: _____		Phone: _____		Property Block: _____				Total Coliform / E-coli	Nitrate, Total	Volatile Organics	Lead	Iron	Manganese	Arsenic	EPA 504.1	Gross Alpha	Uranium				
Fax: _____		Fax: _____		Municipality: <u>Denville Twp</u>																	
				County: <u>Morris</u>																	
Sampled by: (Signature) _____			Sample Collection Date: <u>10/3/24</u>			Turnaround Time: _____															
Item No.	Sample ID Number	Sample Location	Sample Collection Time	Method Preserved				Matrix													
				Na ₂ S ₂ O ₃	HCl	HNO ₃	H ₂ SO ₄	NONE	OTHER	WATER	OTHER										
1		Boiling Water By Room 306	654			X												X			
2		Boiling Water By Room 306	657			X												X			
3		Boiling Water By Room 201	701 701			X												X			
4		Boiling Water By Room 201	702			X												X			
5		Boiling Water By Room 624	704			X												X			
Field pH _____		GPS Coordinate Origin: Well Head / Front Door / Sample Collection Point / Other _____										Size of holding tank _____ gallons									
Field Temperature _____ °C		N.J. Well Permit or Well Record Number (if known) _____										Water flush time _____ minutes									
Time _____		GPS Monitor # _____ GPS File # _____																			
Released by (Signature) _____		Date/Time Released	Delivery Method	Received by (Signature) _____		Date/Time Received		Temperature upon receipt, °C													
_____		10/3/24	HAND	_____		_____															
_____				_____		_____															
_____				_____		_____															

COMMENTS:

REPORT COPY

RAdata, LLC

27 Ironia Road Unit 2
Flanders, New Jersey 07836
973-927-7303 Phone
973-927-8221 Fax
NJDEP LAB ID# 14006

Chain of Custody / Analysis Request Form

Project Name: Morris County Vocational School RAdata Job # 1024-1765-31Project Address: 400 East Main StreetDenville NJ 07834

1024-1765-32

1024-1765-33

1024-1765-34

1024-1765-35

Report To: (Name and address)		Bill To: (Name and address)		Property Lot: _____		Number of Containers		Indicate Analysis Requested by checking appropriate boxes													
Phone: _____		Phone: _____		Property Block: _____				Total Coliform / E-coli	Nitrate, Total	Volatile Organics	Lead	Iron	Manganese	Arsenic	EPA 504.1	Gross Alpha	Uranium				
Fax: _____		Fax: _____		Municipality: <u>Denville Twp</u>																	
				County: <u>Morris</u>																	
Sampled by: (Signature) _____			Sample Collection Date: <u>10/3/24</u>			Turnaround Time: _____															
Item No.	Sample ID Number	Sample Location	Sample Collection Time	Method Preserved						Matrix											
				Na ₂ S ₂ O ₃	HCl	HNO ₃	H ₂ SO ₄	NONE	OTHER	WATER	OTHER										
1		Denville Twp By Room 624	703			X						1					X				X
2		Denville Twp By Room 624	704			X						1					X				X
3		Denville Twp By Room 624	709			X						1					X				X
4		Denville Twp By Room 624	710			X						1					X				X
5		Denville Twp By Room 624	711			X						1					X				X
Field pH _____		GPS Coordinate Origin: Well Head / Front Door / Sample Collection Point / Other _____																			
Field Temperature _____ °C		N.J. Well Permit or Well Record Number (if known) _____																			
Time _____		GPS Monitor # _____ GPS File # _____																			
Released by (Signature) _____		Date/Time Released	Delivery Method	Received by (Signature)		Date/Time Received		Temperature upon receipt, °C													
		10/3/24	HCL18																		

COMMENTS:

REPORT COPY

27 Ironia Road Unit 2
Flanders, New Jersey 07836
973-927-7303 Phone
973-927-8221 Fax
NJDEP LAB ID# 14006

Project Name: MOTT'S COUNTY VOCATIONAL SCHOOL

RAdata Job #

Project Address: 400 East main street

DENV.11F WJ 07834

10241-1715-36

1674-1765 57

1024-1765-38

1024-1765-29

1024-1765-46

Report To: (Name and address) Phone: _____ Fax: _____		Bill To: (Name and address) Phone: _____ Fax: _____		Property Lot: _____ Property Block: _____ Municipality: <u>Denville Twp</u> County: <u>Morris</u>		Number of Containers	Indicate Analysis Requested by checking appropriate boxes										
Sampled by: (Signature) _____		Sample Collection Date: <u>10/13/24</u>		Turnaround Time: _____			Total Coliform / E-coli	Nitrate, Total	Volatile Organics	Lead	Iron	Manganese	Arsenic	EPA 504.1	Gross Alpha	Uranium	
Item No.	Sample ID Number	Sample Location	Sample Collection Time	Method Preserved													Matrix
				Na ₂ S ₂ O ₃	HCl	HNO ₃	H ₂ SO ₄	NONE	OTHER	WATER	OTHER						
1		Bottle 1 - 1st By Room 113	712			X											X
2		Water from 1st By Room 107	713			X											X
3		Bottle 1 - 1st By 1st floor	715			X											X
4		Building 1 - 1st floor 1st room	717			X											X
5		Building 1 - 1st floor 1st room	718			X											X
Field pH _____ Field Temperature _____ °C Time _____		GPS Coordinate Origin: Well Head / Front Door / Sample Collection Point / Other _____ N.J. Well Permit or Well Record Number (if known) _____ GPS Monitor # _____ GPS File # _____											Size of holding tank _____ gallon Water flush time _____ minutes				
Released by (Signature) _____		Date/Time Released _____	Delivery Method _____	Received by (Signature) _____		Date/Time Received _____		Temperature upon receipt, °C _____									

REPORT COPY

RAdata, LLC

27 Ironia Road Unit 2
 Flanders, New Jersey 07836
 973-927-7303 Phone
 973-927-8221 Fax
 NJDEP LAB ID# 14006

Chain of Custody / Analysis Request Form

Project Name: Morris County Vocational School

RAdata Job # 1024-1765-41

Project Address: 400 East main Street

Denville NJ 07834

1024-1765-43

1024-1765-44

Report To: (Name and address)		Bill To: (Name and address)		Property Lot: _____		Indicate Analysis Requested by checking appropriate boxes																	
Phone: _____		Phone: _____		Property Block: _____																			
Fax: _____		Fax: _____		Municipality: <u>Denville Twp</u>																			
				County: <u>Morris</u>																			
Sampled by: (Signature) <u>[Signature]</u>			Sample Collection Date: <u>10/13/24</u>			Turnaround Time: _____																	
Item No.	Sample ID Number	Sample Location	Sample Collection Time	Method Preserved						Matrix		Number of Containers	Total Coliform / E-coli	Nitrate, Total	Volatile Organics	Lead	Iron	Manganese	Arsenic	EPA 504.1	Gross Alpha	Uranium	Copper
				Na ₂ S ₂ O ₃	HCl	HNO ₃	H ₂ SO ₄	NONE	OTHER	WATER	OTHER												
1		Wellhead 407 Pits and Pumps	720			X						1				X							X
2		Wellhead 408 Pits and Pumps	721			X						1				X							X
3		Wellhead 409 Pits and Pumps	722			X						1				X							X
4		Wellhead 410 Pits and Pumps	723			X						1				X							X
5																							

Field pH _____	GPS Coordinate Origin: Well Head / Front Door / Sample Collection Point / Other _____	Size of holding tank _____ gallons
Field Temperature _____ °C	N.J. Well Permit or Well Record Number (if known) _____	Water flush time _____ minutes
Time _____	GPS Monitor # _____ GPS File # _____	

Released by (Signature) <u>[Signature]</u>	Date/Time Released <u>10/13/24</u>	Delivery Method <u>Hand</u>	Received by (Signature) _____	Date/Time Received _____	Temperature upon receipt, °C _____

COMMENTS: