Service Report

Byram Schools

Monday, December 15, 2025 6:13 PM EST

BYRAM TOWNSHIP BOARD OF EDUCATION
ATTENTION: Ms. Theresa Radline
12 MANSFIELD DRIVE
STANHOPE NJ 07834
(000) 000-0000

Report Number: **17652**

Recorded By: **James Meister**
(973) 219-9983
j.meister@associatedwater.com

On-Site Time: **1:57 PM EST to 2:41 PM EST**

ANNEX, BYRAM LAKES ELEMENTARY SCHOOL,BYRAM INTERMEDIATE SCHOOL - Byram Schools

Test	Intermediate School	Annex	Elementary School	
pH	9.5 8 - 9.5	9.5 8 - 9.5	8.5 8 - 9.5	
Nitrite (NaNO2)	1200 1000 - 2500	1300 1000 - 2500	1900 1000 - 2500	
Conductivity (as umhos)	2520	2860	2580	
Inhibitor Inv	25/.5	8/.15	25/1.25	

Intermediate School — Online

System is within parameters.

Annex — Online

System is within parameters.

Elementary School — Online

System is within parameters.

These water treatment reports and any other documents are believed to be true accurate copies of the actual service reports/documents and are presented solely for the convenience of our clients. AWC assumes no liability for any errors or omissions. By reading or downloading any document on this site, client agrees to above terms and conditioners.