Lead in Drinking Water
First Draw
Sampling Report

Byram Lakes School
Byram Intermediate School

Prepared For:

Byram Township Schools

12 Mansfield Drive
Stanhope, NJ 07874

Performed By:

AERO Environmental Services Inc.

275 Rt 10 East, 220-306 Succasunna, NJ 07876

Report Date

May 15, 2025

AERO ENVIRONMENTAL SERVICES, INC.
ENGINEERING • CONSULTING • TESTING

275 Route 10 East, Suite 220-306 Succasunna, NJ 07876
Telephone (973) 920-9061
Fax (973) 529-0335

May 15, 2025

Ms. Theresa Radline
Business Administrator
Byram Township School District
12 Mansfield Drive
Stanhope, NJ 07874

Re: Lead in Drinking Water Report - First Draw Sampling

Dear Ms. Radline,

Enclosed is the final report for Lead in Drinking Water Sampling & Analysis conducted for the Byram Township School District. Lead in drinking water sampling was conducted of all active drinking water locations at the following district facilities.


- Byram Intermediate School
- Byram Lakes School

A total of fifty-six (56) first draw samples, including field blanks, were collected while at each district facility. All first draw samples were analyzed. All samples were labeled with a unique identification number and transported to EMSL Analytical for analysis for lead in drinking water using EPA Method 200.8

Based on laboratory analysis of all functioning drinking water locations samples analyzed, **zero (0) samples exceeded the action limit.** No remedial action is required. All lead results were below 15 µg/L which is the New Jersey Action Level.

If you have any questions, please contact me directly at 973-920-9061.

Sincerely,



Michael Berta, CSP, CPEA
AERO Environmental Services Inc.
mberta@aeroenvironmental.net

TABLE OF CONTENTS

Byram Township School District

1.0 Introduction 1

2.0 Summary of Findings 2

3.0 Sampling & Analysis 4

4.0 Conclusion 5

Attachments

Appendix 1 - Lead Sampling Laboratory Reports – Byram Intermediate School

Appendix 2 - Lead Sampling Laboratory Reports – Byram Lakes School

1.0 INTRODUCTION

AERO Environmental Services, Inc. was contracted by the Byram Township School District to conduct Lead in Drinking Water Sampling at two (2) district facilities. The water sampling was performed by Michael Berta of AERO Environmental Services Inc. All samples were analyzed by EMSL Analytical Inc. at 200 Route 130 North, Cinnaminson, NJ 08077, a New Jersey certified Lead in Drinking Water testing facility. NJDEP Laboratory Number 03036.

The purpose of sampling was to collect first the draw drinking water samples from all active drinking water locations within the district and have them analyzed for lead concentration levels.

The initial first draw samples were taken from active drinking water outlets and food preparation outlets throughout the facilities. These samples determine the lead content of water sitting in water outlets that are used for drinking or cooking within each facility.

Lead in water can originate from the outlet fixture or plumbing upstream of the outlet fixture (e.g., pipe, joints, valves, fittings etc.). Lead can also enter a facility through the drinking water system. Sample results are then compared to assist in determining the sources of lead contamination and the appropriate corrective measures.

If initial first draw test results reveal lead concentrations greater than 15 µg/l (ppb) in a 250 mL sample for a given outlet, follow-up flush testing is required to determine if the lead contamination results are from the fixture or from interior plumbing.

All samples were collected in a 250 mL wide mouth plastic container that was provided by the analytical laboratory. At each sample location, the first draw sample was taken after it was determined that the water had been standing in the plumbing system for greater than eight hours but less than forty-eight hours.

-END OF SECTION-

2.0 SUMMARY OF FINDINGS

First Draw samples were collected and submitted for lead analysis. Table(s) 1 below shows the concentration of lead (parts per billion or microgram per liter) at each active drinking water location sampled. Sampling conducted followed NJDEP protocols, and all samples were submitted to EMSL Analytical under a completed Chain of Custody.

Table 1: Byram Intermediate School

Date	Location Description	Sample ID	Sample Location Code	First Draw Result ug/L (ppb)	Action Ug/L Ppb	Over Limit Yes/No
04/08/25	Teachers Lounge	IS-1	IS-TL-Teachers Lounge	1.40	15	No
04/08/25	Hallway Annex by Rm 209 Chiller	IS-2	IS-FCBF-by 209-01	ND	15	No
04/08/25	Hallway Annex by Rm 209 Bottle Filler	IS-3	IS-FCBF-by 209-02	ND	15	No
04/08/25	Hallway Annex by Rm 209	IS-4	IS-FB-by 209	3.30	15	No
04/08/25	Hallway by CST Chiller	IS-5	IS-FCBF-by CST-01	ND	15	No
04/08/25	Hallway by CST Bottle Filler	IS-6	IS-FCBF-by CST-02	ND	15	No
04/08/25	Boys Locker Room	IS-7	IS-FB-Boys Locker Rm -01	2.30	15	No
04/08/25	Boys Locker Room	IS-8	IS-FB-Boys Locker Rm-02	6.28	15	No
04/08/25	Girls Locker Room	IS-9	IS-FB-Girls Locker Rm-02	5.50	15	No
04/08/25	Kitchen	IS-10	IS-KO-Kitchen-01	ND	15	No
04/08/25	Kitchen	IS-11	IS-KO-Kitchen-02	ND	15	No
04/08/25	Kitchen	IS-12	IS-KO-Kitchen-03	2.80	15	No
04/08/25	Kitchen	IS-13	IS-IM-Kitchen	ND	15	No
04/08/25	All Purpose Room Chiller	IS-14	IS-FCBF-APR-01	ND	15	No
04/08/25	All Purpose Room Bottle Filler	IS-15	IS-FCBF-APR-02	ND	15	No
04/08/25	Main Office Kitchen	IS-16	IS-SO-Main Office Kitchen	3.13	15	No
04/08/25	Nurse Office	IS-17	IS-MO-Nurse	4.69	15	No
04/08/25	Hallway by Rm 114	IS-18	IS-FB-by 114-01	5.13	15	No
04/08/25	Hallway by Rm 114	IS-19	IS-FB-by 114-02	2.40	15	No
04/08/25	Hallway by Rm 114	IS-20	IS-FB-by 114-03	2.66	15	No
04/08/25	Hallway by Rm 114	IS-21	IS-FB-by 114-04	1.6	15	No
04/08/25	Hallway by Room 101	IS-22	IS-FB-by 101-01	ND	15	No
04/08/25	Hallway by Room 101	IS-23	IS-FB-by 101-02	ND	15	No
04/08/25	Hallway by Room 101 Chiller	IS-24	IS-FCBF-by 101-03	ND	15	No
04/08/25	Hallway by Room 101 Bottle Filler	IS-25	IS-FCBF-by 101-04	ND	15	No
04/08/25	Open Space by boys Rm	IS-26	IS-FB-Open Space by boys Rm-01	1.29	15	No
04/08/25	Field Blank	IS-27	IS-Field Blank	ND	15	No

Table 1: Byram Lakes School

Date	Location Description	Sample ID	Sample Location Code	First Draw Result ug/L (ppb)	Action ug/L Ppb	Over Limit Yes/No
04/08/25	Room B010 Kitchen	BL-1	BL-KO-B010-01	1.20	15	No
04/08/25	Room B010 Kitchen	BL-2	BL-KO-B010-02	ND	15	No
04/08/25	Room B010 Kitchen	BL-3	BL-KO-B010-03	2.52	15	No
04/08/25	Room B010 Kitchen	BL-4	BL-KO-B010-04	2.22	15	No
04/08/25	Room B010 Kitchen	BL-5	BL-KO-B010-05	5.12	15	No
04/08/25	Room B010 Kitchen	BL-6	BL-KO-B010-06	2.57	15	No
04/08/25	Hallway by A027	BL-7	BL-FB-by A027-01	ND	15	No
04/08/25	Hallway by A027	BL-8	BL-FB-by A027-02	ND	15	No
04/08/25	Hallway by A027	BL-9	BL-FB-by A027-03	ND	15	No
04/08/25	Room A010 Nurse	BL-10	BL-SO-A010	7.69	15	No
04/08/25	Hallway A Wing by A049 Chiller	BL-11	BL-FCBF-by A049-01	ND	15	No
04/08/25	Hallway A Wing by A049 Bottle Filler	BL-12	BL-FCBF-by A049-02	ND	15	No
04/08/25	Room A033 Faculty Room	BL-13	BL-SO-A033	ND	15	No
04/08/25	Room A037	BL-14	BL-FB-A037	2.14	15	No
04/08/25	Room A047	BL-15	BL-FB-A047	ND	15	No
04/08/25	Room A038	BL-16	BL-FB-A038	4.29	15	No
04/08/25	Room A045	BL-17	BL-FB-A045	3.39	15	No
04/08/25	Room A040	BL-18	BL-FB-A040	3.48	15	No
04/08/25	Room A043	BL-19	BL-FB-A043	ND	15	No
04/08/25	Hallway by C016 Girls	BL-20	BL-FB-by C016 Girls-01	ND	15	No
04/08/25	Hallway C Wing by C016 Girls	BL-21	BL-FB-by C016 Girls-02	1.68	15	No
04/08/25	Hallway C Wing by C016 Girls	BL-22	BL-FB-by C016 Girls-03	ND	15	No
04/08/25	Hallway C Wing by C116 Girls	BL-23	BL-FB-by C116 Girls-01	ND	15	No
04/08/25	Hallway A Wing by A108 Girls	BL-24	BL-FB-by A108 Girls -01	ND	15	No
04/08/25	Hallway A Wing by A108 Girls	BL-25	BL-FB-by A108 Girls -02	ND	15	No
04/08/25	Hallway A Wing by A108 Girls	BL-26	BL-FB-by A108 Girls -03	ND	15	No
04/08/25	Hallway C Wing by C116 Girls	BL-27	BL-FB-by C116 Girls-02	ND	15	No
04/08/25	Hallway C Wing by C116 Girls	BL-28	BL-FB-by C116 Girls-03	ND	15	No
04/08/25	Field Blank	BL-29	BL-Field Blank	ND	15	No

3.0 SAMPLING AND ANALYSES

The following guidance documents were followed for all sampling:

1. N.J.A.C. 6A:26-12.4 Safe Drinking Water

2. The EPA's Revised Technical Guidance - "3Ts for Reduced Lead in Drinking Water in Schools"

3. Guidance Document from NJDEP Division of Water Supply and Geoscience – "Lead in Drinking Water: Guidance for Schools and Child Care Facilities Served by Public Water."

Fifty-Six (56) first draw samples, including field blanks were collected while at each facility. All first draw samples were analyzed.

All samples were labeled with a unique identification number and transported to EMSL Analytical for analysis for lead in drinking water using EPA Method 200.8.

4.0 CONCLUSION

- Based on laboratory analysis of the samples analyzed, zero (0) samples exceeded the action limit.
- No remedial action is required.
- <u>All lead results were below the 15 µg/L New Jersey Action Level.</u>

APPENDIX 1

Byram Intermediate School

LABORATORY ANALYSIS WATER SAMPLING RESULTS
WITH
CHAIN OF CUSTODY

EMSL Analytical, Inc.

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012516697
LIMS Reference ID: AD16697
EMSL Customer ID: AERO50

Attention: Michael Berta
AERO Environmental Services, Inc [AERO50]
275 Route 10 East, Suite 220-306
Succasunna, NJ 07876
(973) 920-9061
mberta@aeroenvironmental.net

Project Name: Byram Intermediate School

Customer PO:
EMSL Sales Rep: David Prince
Received: 04/11/2025 10:24
Reported: 04/25/2025 18:37

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: IS-1/IS-TL-Teachers Lounge - Lims Reference ID: AD16697-01 Matrix: Drinking Water Sampled: 04/08/25 06:20:00									
Metals									
Lead	1.40		1	1.00	µg/L	04/18/25 12:28	04/21/25 14:06	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IS-2/IS-FCBF-by 209-01 - Lims Reference ID: AD16697-02 Matrix: Drinking Water Sampled: 04/08/25 06:22:00									
Metals									
Lead	ND		1	1.00	µg/L	04/18/25 12:28	04/21/25 14:13	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IS-3/IS-FCBF-by 209-02 - Lims Reference ID: AD16697-03 Matrix: Drinking Water Sampled: 04/08/25 06:23:00									
Metals									
Lead	ND		1	1.00	µg/L	04/18/25 12:28	04/21/25 14:15	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IS-4/IS-FB-by 209 - Lims Reference ID: AD16697-04 Matrix: Drinking Water Sampled: 04/08/25 06:24:00									
Metals									
Lead	3.30		1	1.00	µg/L	04/18/25 12:28	04/21/25 14:17	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IS-5/IS-FCBF-by CST-01 - Lims Reference ID: AD16697-05 Matrix: Drinking Water Sampled: 04/08/25 06:26:00									
Metals									
Lead	ND		1	1.00	µg/L	04/18/25 12:28	04/21/25 14:19	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IS-6/IS-FCBF-by CST-02 - Lims Reference ID: AD16697-06 Matrix: Drinking Water Sampled: 04/08/25 06:27:00									
Metals									
Lead	ND		1	1.00	µg/L	04/18/25 12:28	04/21/25 14:39	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IS-7/IS-FB-Boys Locker Rm -01 - Lims Reference ID: AD16697-07 Matrix: Drinking Water Sampled: 04/08/25 06:30:00									
Metals									
Lead	2.30		1	1.00	µg/L	04/18/25 12:28	04/21/25 14:41	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IS-8/IS-FB-Boys Locker Rm-02 - Lims Reference ID: AD16697-08 Matrix: Drinking Water Sampled: 04/08/25 06:31:00									
Metals									
Lead	6.28		1	1.00	µg/L	04/18/25 12:28	04/21/25 14:43	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IS-9/IS-FB-Girls Locker Rm-02 - Lims Reference ID: AD16697-09 Matrix: Drinking Water Sampled: 04/08/25 06:33:00									
Metals									
Lead	5.50		1	1.00	µg/L	04/18/25 12:28	04/21/25 14:45	PL	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012516697
LIMS Reference ID: AD16697
EMSL Customer ID: AERO50

Attention: Michael Berta
AERO Environmental Services, Inc [AERO50]
275 Route 10 East, Suite 220-306
Succasunna, NJ 07876
(973) 920-9061
mberta@aeroenvironmental.net

Project Name: Byram Intermediate School

Customer PO:
EMSL Sales Rep: David Prince
Received: 04/11/2025 10:24
Reported: 04/25/2025 18:37

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: IS-10/IS-KO-Kitchen-01 - Lims Reference ID: AD16697-10 Matrix: Drinking Water Sampled: 04/08/25 18:35:00									
Metals									
Lead	ND		1	1.00	µg/L	04/18/25 12:28	04/21/25 14:47	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IS-11/IS-KO-Kitchen-02 - Lims Reference ID: AD16697-11 Matrix: Drinking Water Sampled: 04/08/25 06:36:00									
Metals									
Lead	ND		1	1.00	µg/L	04/18/25 12:28	04/21/25 14:49	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IS-12/IS-KO-Kitchen-03 - Lims Reference ID: AD16697-12 Matrix: Drinking Water Sampled: 04/08/25 06:37:00									
Metals									
Lead	2.80		1	1.00	µg/L	04/18/25 12:28	04/21/25 14:55	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IS-13/IS-IM-Kitchen - Lims Reference ID: AD16697-13 Matrix: Drinking Water Sampled: 04/08/25 06:38:00									
Metals									
Lead	ND		1	1.00	µg/L	04/18/25 12:28	04/21/25 14:57	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IS-14/IS-FCBF-APR-01 - Lims Reference ID: AD16697-14 Matrix: Drinking Water Sampled: 04/08/25 06:41:00									
Metals									
Lead	ND		1	1.00	µg/L	04/18/25 12:28	04/21/25 15:05	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IS-15/IS-FCBF-APR-02 - Lims Reference ID: AD16697-15 Matrix: Drinking Water Sampled: 04/08/25 06:42:00									
Metals									
Lead	ND		1	1.00	µg/L	04/18/25 12:28	04/21/25 15:08	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IS-16/IS-SO-Main Office Kitchen - Lims Reference ID: AD16697-16 Matrix: Drinking Water Sampled: 04/08/25 06:44:00									
Metals									
Lead	3.13		1	1.00	µg/L	04/18/25 12:28	04/21/25 15:10	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IS-17/IS-MO-Nurse - Lims Reference ID: AD16697-17 Matrix: Drinking Water Sampled: 04/08/25 06:46:00									
Metals									
Lead	4.69		1	1.00	µg/L	04/18/25 12:28	04/21/25 15:12	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IS-18/IS-FB-by 114-01 - Lims Reference ID: AD16697-18 Matrix: Drinking Water Sampled: 04/08/25 06:47:00									
Metals									
Lead	5.13		1	1.00	µg/L	04/18/25 12:28	04/21/25 15:14	PL	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012516697
LIMS Reference ID: AD16697
EMSL Customer ID: AERO50

Attention: Michael Berta
AERO Environmental Services, Inc [AERO50]
275 Route 10 East, Suite 220-306
Succasunna, NJ 07876
(973) 920-9061
mberta@aeroenvironmental.net

Project Name: Byram Intermediate School

Customer PO:
EMSL Sales Rep: David Prince
Received: 04/11/2025 10:24
Reported: 04/25/2025 18:37

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: IS-19/IS-FB-by 114-02 -		**Lims Reference ID:**		**AD16697-19**	**Matrix: Drinking Water**				**Sampled: 04/08/25 06:48:00**
Metals									
Lead	**2.40**		1	1.00	µg/L	04/18/25 12:28	04/21/25 15:16	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IS-20/IS-FB-by 114-03 -		**Lims Reference ID:**		**AD16697-20**	**Matrix: Drinking Water**				**Sampled: 04/08/25 18:49:00**
Metals									
Lead	**2.66**		1	1.00	µg/L	04/18/25 12:28	04/21/25 15:18	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IS-21/IS-FB-by 114-04 -		**Lims Reference ID:**		**AD16697-21**	**Matrix: Drinking Water**				**Sampled: 04/08/25 06:50:00**
Metals									
Lead	**1.60**		1	1.00	µg/L	04/18/25 12:31	04/21/25 13:15	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IS-22/IS-FB-by 101-01 -		**Lims Reference ID:**		**AD16697-22**	**Matrix: Drinking Water**				**Sampled: 04/08/25 06:52:00**
Metals									
Lead	**ND**		1	1.00	µg/L	04/18/25 12:31	04/21/25 13:22	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IS-23/IS-FB-by 101-02 -		**Lims Reference ID:**		**AD16697-23**	**Matrix: Drinking Water**				**Sampled: 04/08/25 06:53:00**
Metals									
Lead	**ND**		1	1.00	µg/L	04/18/25 12:31	04/21/25 13:24	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IS-24/IS-FCBF-by 101-03 -		**Lims Reference ID:**		**AD16697-24**	**Matrix: Drinking Water**				**Sampled: 04/08/25 06:54:00**
Metals									
Lead	**ND**		1	1.00	µg/L	04/18/25 12:31	04/21/25 13:26	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IS-25/IS-FCBF-by 101-04 -		**Lims Reference ID:**		**AD16697-25**	**Matrix: Drinking Water**				**Sampled: 04/08/25 06:55:00**
Metals									
Lead	**ND**		1	1.00	µg/L	04/18/25 12:31	04/21/25 13:28	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IS-26/IS-FB-Open Space by boys Rm-01 -		**Lims Reference ID:**		**AD16697-26**	**Matrix: Drinking Water**				**Sampled: 04/08/25 06:57:00**
Metals									
Lead	**1.29**		1	1.00	µg/L	04/18/25 12:31	04/21/25 13:34	PL	EPA 200.8 (DA)/EPA 200.8
Sample: IS-27/IS-Field Blank -		**Lims Reference ID:**		**AD16697-27**	**Matrix: Drinking Water**				**Sampled: 04/08/25 07:00:00**
Metals									
Lead	**ND**		1	1.00	µg/L	04/18/25 12:31	04/21/25 13:36	PL	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012516697
LIMS Reference ID: AD16697
EMSL Customer ID: AERO50

Attention: Michael Berta
AERO Environmental Services, Inc [AERO50]
275 Route 10 East, Suite 220-306
Succasunna, NJ 07876
(973) 920-9061
mberta@aeroenvironmental.net

Project Name: Byram Intermediate School

Customer PO:
EMSL Sales Rep: David Prince
Received: 04/11/2025 10:24
Reported: 04/25/2025 18:37

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	NJDEP

List of Certifications

Code	Description	Number	Expires
PADEP	Pennsylvania Department of Environmental Protection	2845.25	11/30/2025
NYSDOH	New York State Department of Health ELAP	10872	04/01/2025
NJDEP	New Jersey Department of Environmental Protection	03036	06/30/2025
MADEP	Massachusetts Department of Environmental Protection	M-NJ337	06/30/2025
CTDPH	Connecticut Department of Public Health	PH-0270	06/23/2026
California ELAP	California Water Boards	1877	06/30/2025
AIHA LAP	EMSL Analytical, Inc. Cinnaminson, NJ AIHA-LAP, LLC-ELLAP Accredited	100194	05/01/2025
A2LA	A2LA Environmental Certificate	2845.01	07/31/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012516697
LIMS Reference ID: AD16697
EMSL Customer ID: AERO50

Attention: Michael Berta
AERO Environmental Services, Inc [AERO50]
275 Route 10 East, Suite 220-306
Succasunna, NJ 07876
(973) 920-9061
mberta@aeroenvironmental.net

Project Name: Byram Intermediate School
Customer PO:
EMSL Sales Rep: David Prince
Received: 04/11/2025 10:24
Reported: 04/25/2025 18:37

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

Owen McKenna Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

AD16697

EMSL ANALYTICAL, INC.
LABORATORY • PRODUCTS • TRAINING

JL 4/11/25 pres. HNO3 added 4/11/25 JL 0930

3E2W-WQEQ-3UDH

Client Information
AERO Environmental Services, Inc
Succasunna, NJ
AERO50

Project Overview

Client	Aero Environmental
PO Number	
Project Name	Byram Intermediate School
Project ID	
Bill To	AERO50
Report To Contact	Michael Berta
Report To Email	Mberta@aeroenvironmental.net
Special Instructions	

Project Site

Building Type	School or Day Care Center
Address	12 Mansfield Drive
City	Stanhope
State	NJ
Zip	07874

Testing Laboratory
Cinnaminson Chemistry
Cinnaminson, NJ 08077

Lead Drinking Water

Sample ID	Sample Area	Date/Time Collected	Volume	Test Method	TAT	pH	Preservative	Additional Tests	Notes
IS-1	IS-TL-Teachers Lounge	4/8/2025 6:20 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
IS-2	IS-FCBF-by 209-01	4/8/2025 6:22 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
IS-3	IS-FCBF-by 209-02	4/8/2025 6:23 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
IS-4	IS-FB-by 209	4/8/2025 6:24 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
IS-5	IS-FCBF-by CST-01	4/8/2025 6:26 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
IS-6	IS-FCBF-by CST-02	4/8/2025 6:27 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
IS-7	IS-FB-Boys Locker Rm -01	4/8/2025 6:30 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
IS-8	IS-FB-Boys Locker Rm-02	4/8/2025 6:31 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
IS-9	IS-FB-Girls Locker Rm-02	4/8/2025 6:33 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
IS-10	IS-KO-Kitchen-01	4/8/2025 6:35 PM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
IS-11	IS-KO-Kitchen-02	4/8/2025 6:36 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
IS-12	IS-KO-Kitchen-03	4/8/2025 6:37 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
IS-13	IS-IM-Kitchen	4/8/2025 6:38 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
IS-14	IS-FCBF-APR-01	4/8/2025 6:41 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
IS-15	IS-FCBF-APR-02	4/8/2025 6:42 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				

AD16697

EMSL ANALYTICAL, INC.
LABORATORY • PRODUCTS • TRAINING

3E2W-WQEQ-3UDH

Sample ID	Sample Area	Date/Time Collected	Volume	Test Method	TAT	pH	Preservative	Additional Tests	Notes
IS-16	IS-SO-Main Office Kitchen	4/8/2025 6:44 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
IS-17	IS-MO-Nurse	4/8/2025 6:46 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
IS-18	IS-FB-by 114-01	4/8/2025 6:47 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
IS-19	IS-FB-by 114-02	4/8/2025 6:48 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
IS-20	IS-FB-by 114-03	4/8/2025 6:49 PM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
IS-21	IS-FB-by 114-04	4/8/2025 6:50 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
IS-22	IS-FB-by 101-01	4/8/2025 6:52 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
IS-23	IS-FB-by 101-02	4/8/2025 6:53 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
IS-24	IS-FCBF-by 101-03	4/8/2025 6:54 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
IS-25	IS-FCBF-by 101-04	4/8/2025 6:55 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
IS-26	IS-FB-Open Space by boys Rm-01	4/8/2025 6:57 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
IS-27	IS-Field Blank	4/8/2025 7:00 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				

M Berta

Sampled By / Date 4/8/2025

M Berta

Relinquished By / Date 4/8/2025

AD166917

EMSL ANALYTICAL, INC.
LABORATORY • PRODUCTS • TRAINING

3E2W-WQEQ-3UDH

(WL) 4.10.25 @ 1211pm

Received (Lab) / Date

CPer 4/10/25 7pm

L Bonnelly (CR) 4/11/25 0900

APPENDIX 2

Byram Lakes School

LABORATORY ANALYSIS WATER SAMPLING RESULTS
WITH
CHAIN OF CUSTODY

EMSL Analytical, Inc.

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012516676
LIMS Reference ID: AD16676
EMSL Customer ID: AERO50

Attention: Michael Berta
AERO Environmental Services, Inc [AERO50]
275 Route 10 East, Suite 220-306
Succasunna, NJ 07876
(973) 920-9061
mberta@aeroenvironmental.net

Project Name: Byram Lakes School
Customer PO:
EMSL Sales Rep: David Prince
Received: 04/11/2025 09:00
Reported: 04/25/2025 18:35

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BL-1/BL-KO-B010-01 -		**Lims Reference ID:**		**AD16676-01**	**Matrix: Drinking Water**				**Sampled: 04/08/25 07:08:00**
Metals									
Lead	**1.20**		1	1.00	µg/L	04/21/25 09:00	04/22/25 09:51	PL	EPA 200.8 (DA)/EPA 200.8
Sample: BL-2/BL-KO-B010-02 -		**Lims Reference ID:**		**AD16676-02**	**Matrix: Drinking Water**				**Sampled: 04/08/25 07:09:00**
Metals									
Lead	**ND**		1	1.00	µg/L	04/21/25 09:00	04/22/25 09:57	PL	EPA 200.8 (DA)/EPA 200.8
Sample: BL-3/BL-KO-B010-03 -		**Lims Reference ID:**		**AD16676-03**	**Matrix: Drinking Water**				**Sampled: 04/08/25 07:10:00**
Metals									
Lead	**2.52**		1	1.00	µg/L	04/21/25 09:00	04/22/25 09:59	PL	EPA 200.8 (DA)/EPA 200.8
Sample: BL-4/BL-KO-B010-04 -		**Lims Reference ID:**		**AD16676-04**	**Matrix: Drinking Water**				**Sampled: 04/08/25 07:11:00**
Metals									
Lead	**2.22**		1	1.00	µg/L	04/21/25 09:00	04/22/25 10:01	PL	EPA 200.8 (DA)/EPA 200.8
Sample: BL-5/BL-KO-B010-05 -		**Lims Reference ID:**		**AD16676-05**	**Matrix: Drinking Water**				**Sampled: 04/08/25 07:12:00**
Metals									
Lead	**5.12**		1	1.00	µg/L	04/21/25 09:00	04/22/25 10:03	PL	EPA 200.8 (DA)/EPA 200.8
Sample: BL-6/BL-KO-B010-06 -		**Lims Reference ID:**		**AD16676-06**	**Matrix: Drinking Water**				**Sampled: 04/08/25 07:13:00**
Metals									
Lead	**2.57**		1	1.00	µg/L	04/21/25 09:00	04/22/25 10:10	PL	EPA 200.8 (DA)/EPA 200.8
Sample: BL-7/BL-FB-by A027-01 -		**Lims Reference ID:**		**AD16676-07**	**Matrix: Drinking Water**				**Sampled: 04/08/25 07:15:00**
Metals									
Lead	**ND**		1	1.00	µg/L	04/21/25 09:00	04/22/25 10:12	PL	EPA 200.8 (DA)/EPA 200.8
Sample: BL-8/BL-FB-by A027-02 -		**Lims Reference ID:**		**AD16676-08**	**Matrix: Drinking Water**				**Sampled: 04/08/25 07:16:00**
Metals									
Lead	**ND**		1	1.00	µg/L	04/21/25 09:00	04/22/25 10:14	PL	EPA 200.8 (DA)/EPA 200.8
Sample: BL-9/BL-FB-by A027-03 -		**Lims Reference ID:**		**AD16676-09**	**Matrix: Drinking Water**				**Sampled: 04/08/25 07:17:00**
Metals									
Lead	**ND**		1	1.00	µg/L	04/21/25 09:00	04/22/25 10:16	PL	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012516676
LIMS Reference ID: AD16676
EMSL Customer ID: AERO50

Attention: Michael Berta
AERO Environmental Services, Inc [AERO50]
275 Route 10 East, Suite 220-306
Succasunna, NJ 07876
(973) 920-9061
mberta@aeroenvironmental.net

Project Name: Byram Lakes School
Customer PO:
EMSL Sales Rep: David Prince
Received: 04/11/2025 09:00
Reported: 04/25/2025 18:35

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BL-10/BL-SO-A010 -		**Lims Reference ID:**		**AD16676-10**	**Matrix: Drinking Water**				**Sampled: 04/08/25 07:19:00**
Metals									
Lead	7.69		1	1.00	µg/L	04/21/25 09:00	04/22/25 10:18	PL	EPA 200.8 (DA)/EPA 200.8
Sample: BL-11/BL-FCBF-by A049-01 -		**Lims Reference ID:**		**AD16676-11**	**Matrix: Drinking Water**				**Sampled: 04/08/25 07:20:00**
Metals									
Lead	ND		1	1.00	µg/L	04/21/25 09:00	04/22/25 10:20	PL	EPA 200.8 (DA)/EPA 200.8
Sample: BL-12/BL-FCBF-by A049-02 -		**Lims Reference ID:**		**AD16676-12**	**Matrix: Drinking Water**				**Sampled: 04/08/25 07:21:00**
Metals									
Lead	ND		1	1.00	µg/L	04/21/25 09:00	04/22/25 10:26	PL	EPA 200.8 (DA)/EPA 200.8
Sample: BL-13/BL-SO-A033 -		**Lims Reference ID:**		**AD16676-13**	**Matrix: Drinking Water**				**Sampled: 04/08/25 07:23:00**
Metals									
Lead	ND		1	1.00	µg/L	04/21/25 09:00	04/22/25 10:29	PL	EPA 200.8 (DA)/EPA 200.8
Sample: BL-14/BL-FB-A037 -		**Lims Reference ID:**		**AD16676-14**	**Matrix: Drinking Water**				**Sampled: 04/08/25 07:24:00**
Metals									
Lead	2.14		1	1.00	µg/L	04/21/25 09:00	04/22/25 10:35	PL	EPA 200.8 (DA)/EPA 200.8
Sample: BL-15/BL-FB-A047 -		**Lims Reference ID:**		**AD16676-15**	**Matrix: Drinking Water**				**Sampled: 04/08/25 07:25:00**
Metals									
Lead	ND		1	1.00	µg/L	04/21/25 09:00	04/22/25 10:37	PL	EPA 200.8 (DA)/EPA 200.8
Sample: BL-16/BL-FB-A038 -		**Lims Reference ID:**		**AD16676-16**	**Matrix: Drinking Water**				**Sampled: 04/08/25 07:26:00**
Metals									
Lead	4.29		1	1.00	µg/L	04/21/25 09:00	04/22/25 10:39	PL	EPA 200.8 (DA)/EPA 200.8
Sample: BL-17/BL-FB-A045 -		**Lims Reference ID:**		**AD16676-17**	**Matrix: Drinking Water**				**Sampled: 04/08/25 07:27:00**
Metals									
Lead	3.39		1	1.00	µg/L	04/21/25 09:00	04/22/25 10:41	PL	EPA 200.8 (DA)/EPA 200.8
Sample: BL-18/BL-FB-A040 -		**Lims Reference ID:**		**AD16676-18**	**Matrix: Drinking Water**				**Sampled: 04/08/25 07:28:00**
Metals									
Lead	3.48		1	1.00	µg/L	04/21/25 09:00	04/22/25 10:43	PL	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012516676
LIMS Reference ID: AD16676
EMSL Customer ID: AERO50

Attention: Michael Berta
AERO Environmental Services, Inc [AERO50]
275 Route 10 East, Suite 220-306
Succasunna, NJ 07876
(973) 920-9061
mberta@aeroenvironmental.net

Project Name: Byram Lakes School
Customer PO:
EMSL Sales Rep: David Prince
Received: 04/11/2025 09:00
Reported: 04/25/2025 18:35

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BL-19/BL-FB-A043 -		**Lims Reference ID:**		**AD16676-19**	**Matrix: Drinking Water**				**Sampled: 04/08/25 07:29:00**
Metals									
Lead	ND		1	1.00	µg/L	04/21/25 09:00	04/22/25 10:45	PL	EPA 200.8 (DA)/EPA 200.8
Sample: BL-20/BL-FB-by C016 Girls-01 -		**Lims Reference ID:**		**AD16676-20**	**Matrix: Drinking Water**				**Sampled: 04/08/25 07:31:00**
Metals									
Lead	ND		1	1.00	µg/L	04/21/25 09:00	04/22/25 10:47	PL	EPA 200.8 (DA)/EPA 200.8
Sample: BL-21/BL-FB-by C016 Girls-02 -		**Lims Reference ID:**		**AD16676-21**	**Matrix: Drinking Water**				**Sampled: 04/08/25 07:32:00**
Metals									
Lead	1.68		1	1.00	µg/L	04/21/25 09:01	04/22/25 08:42	PL	EPA 200.8 (DA)/EPA 200.8
Sample: BL-22/BL-FB-by C016 Girls-03 -		**Lims Reference ID:**		**AD16676-22**	**Matrix: Drinking Water**				**Sampled: 04/08/25 07:32:00**
Metals									
Lead	ND		1	1.00	µg/L	04/21/25 09:01	04/22/25 08:48	PL	EPA 200.8 (DA)/EPA 200.8
Sample: BL-23/BL-FB-by C116 Girls-01 -		**Lims Reference ID:**		**AD16676-23**	**Matrix: Drinking Water**				**Sampled: 04/08/25 07:33:00**
Metals									
Lead	ND		1	1.00	µg/L	04/21/25 09:01	04/22/25 08:50	PL	EPA 200.8 (DA)/EPA 200.8
Sample: BL-24/BL-FB-by A108 Girls -01 -		**Lims Reference ID:**		**AD16676-24**	**Matrix: Drinking Water**				**Sampled: 04/08/25 07:34:00**
Metals									
Lead	ND		1	1.00	µg/L	04/21/25 09:01	04/22/25 08:52	PL	EPA 200.8 (DA)/EPA 200.8
Sample: BL-25/BL-FB-by A108 Girls -02 -		**Lims Reference ID:**		**AD16676-25**	**Matrix: Drinking Water**				**Sampled: 04/08/25 07:35:00**
Metals									
Lead	ND		1	1.00	µg/L	04/21/25 09:01	04/22/25 08:54	PL	EPA 200.8 (DA)/EPA 200.8
Sample: BL-26/BL-FB-by A108 Girls -03 -		**Lims Reference ID:**		**AD16676-26**	**Matrix: Drinking Water**				**Sampled: 04/08/25 07:37:00**
Metals									
Lead	ND		1	1.00	µg/L	04/21/25 09:01	04/22/25 09:00	PL	EPA 200.8 (DA)/EPA 200.8
Sample: BL-27/BL-FB-by C116 Girls-02 -		**Lims Reference ID:**		**AD16676-27**	**Matrix: Drinking Water**				**Sampled: 04/08/25 07:38:00**
Metals									
Lead	ND		1	1.00	µg/L	04/21/25 09:01	04/22/25 09:03	PL	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012516676
LIMS Reference ID: AD16676
EMSL Customer ID: AERO50

Attention: Michael Berta
AERO Environmental Services, Inc [AERO50]
275 Route 10 East, Suite 220-306
Succasunna, NJ 07876
(973) 920-9061
mberta@aeroenvironmental.net

Project Name: Byram Lakes School
Customer PO:
EMSL Sales Rep: David Prince
Received: 04/11/2025 09:00
Reported: 04/25/2025 18:35

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: BL-28/BL-FB-by C116 Girls-03 -			**Lims Reference ID:**	**AD16676-28**	**Matrix: Drinking Water**				**Sampled: 04/08/25 07:39:00**
Metals									
Lead	**ND**		1	1.00	µg/L	04/21/25 09:01	04/22/25 09:05	PL	EPA 200.8 (DA)/EPA 200.8
Sample: BL-29/BL-Field Blank -			**Lims Reference ID:**	**AD16676-29**	**Matrix: Drinking Water**				**Sampled: 04/08/25 07:41:00**
Metals									
Lead	**ND**		1	1.00	µg/L	04/21/25 09:01	04/22/25 09:07	PL	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012516676
LIMS Reference ID: AD16676
EMSL Customer ID: AERO50

Attention: Michael Berta
AERO Environmental Services, Inc [AERO50]
275 Route 10 East, Suite 220-306
Succasunna, NJ 07876
(973) 920-9061
mberta@aeroenvironmental.net

Project Name: Byram Lakes School
Customer PO:
EMSL Sales Rep: David Prince
Received: 04/11/2025 09:00
Reported: 04/25/2025 18:35

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	NJDEP

List of Certifications

Code	Description	Number	Expires
PADEP	Pennsylvania Department of Environmental Protection	2845.25	11/30/2025
NYSDOH	New York State Department of Health ELAP	10872	04/01/2025
NJDEP	New Jersey Department of Environmental Protection	03036	06/30/2025
MADEP	Massachusetts Department of Environmental Protection	M-NJ337	06/30/2025
CTDPH	Connecticut Department of Public Health	PH-0270	06/23/2026
California ELAP	California Water Boards	1877	06/30/2025
AIHA LAP	EMSL Analytical, Inc. Cinnaminson, NJ AIHA-LAP, LLC-ELLAP Accredited	100194	05/01/2025
A2LA	A2LA Environmental Certificate	2845.01	07/31/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012516676
LIMS Reference ID: AD16676
EMSL Customer ID: AERO50

Attention: Michael Berta
AERO Environmental Services, Inc [AERO50]
275 Route 10 East, Suite 220-306
Succasunna, NJ 07876
(973) 920-9061
mberta@aeroenvironmental.net

Project Name: Byram Lakes School
Customer PO:
EMSL Sales Rep: David Prince
Received: 04/11/2025 09:00
Reported: 04/25/2025 18:35

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

Owen McKenna Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

AD16676

EMSL ANALYTICAL, INC.
LABORATORY • PRODUCTS • TRAINING

UFTD-9EHW-TT6Q

Client Information
AERO Environmental Services, Inc
Succasunna, NJ
AERO50

Project Overview

Client	Aero Environmental
PO Number	
Project Name	Byram Lakes School
Project ID	
Bill To	AERO50
Report To Contact	Michael Berta
Report To Email	Mberta@aeroenvironmental.net
Special Instructions	

Project Site

Building Type	School or Day Care Center
Address	11 Mansfield Drive
City	Stanhope
State	NJ
Zip	07874

Testing Laboratory
Cinnaminson Chemistry
Cinnaminson, NJ 08077

Lead Drinking Water

Sample ID	Sample Area	Date/Time Collected	Volume	Test Method	TAT	pH	Preservative	Additional Tests	Notes
BL-1	BL-KO-B010-01	4/8/2025 7:08 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
BL-2	BL-KO-B010-02	4/8/2025 7:09 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
BL-3	BL-KO-B010-03	4/8/2025 7:10 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
BL-4	BL-KO-B010-04	4/8/2025 7:11 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
BL-5	BL-KO-B010-05	4/8/2025 7:12 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
BL-6	BL-KO-B010-06	4/8/2025 7:13 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
BL-7	BL-FB-by A027-01	4/8/2025 7:15 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
BL-8	BL-FB-by A027-02	4/8/2025 7:16 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
BL-9	BL-FB-by A027-03	4/8/2025 7:17 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
BL-10	BL-SO-A010	4/8/2025 7:19 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
BL-11	BL-FCBF-by A049-01	4/8/2025 7:20 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
BL-12	BL-FCBF-by A049-02	4/8/2025 7:21 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
BL-13	BL-SO-A033	4/8/2025 7:23 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
BL-14	BL-FB-A037	4/8/2025 7:24 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
BL-15	BL-FB-A047	4/8/2025 7:25 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				

RECEIVED
EMSL
CINNAMINSON, NJ
25 APR 10 PM 6:57

AD16676

EMSL ANALYTICAL, INC.
LABORATORY • PRODUCTS • TRAINING

UFTD-9EHW-TT6Q

Sample ID	Sample Area	Date/Time Collected	Volume	Test Method	TAT	pH	Preservative	Additional Tests	Notes
BL-16	BL-FB-A038	4/8/2025 7:26 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
BL-17	BL-FB-A045	4/8/2025 7:27 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
BL-18	BL-FB-A040	4/8/2025 7:28 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
BL-19	BL-FB-A043	4/8/2025 7:29 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
BL-20	BL-FB-by C016 Girls-01	4/8/2025 7:31 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
BL-21	BL-FB-by C016 Girls-02	4/8/2025 7:32 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
BL-22	BL-FB-by C016 Girls-03	4/8/2025 7:32 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
BL-23	BL-FB-by C116 Girls-01	4/8/2025 7:33 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
BL-24	BL-FB-by A108 Girls -01	4/8/2025 7:34 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
BL-25	BL-FB-by A108 Girls -02	4/8/2025 7:35 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
BL-26	BL-FB-by A108 Girls -03	4/8/2025 7:37 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
BL-27	BL-FB-by C116 Girls-02	4/8/2025 7:38 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
BL-28	BL-FB-by C116 Girls-03	4/8/2025 7:39 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				
BL-29	BL-Field Blank	4/8/2025 7:41 AM	250 mL	C-Lead by ICP-MS | EPA 200.8	2 Week				

AD16676

EMSL ANALYTICAL, INC.
LABORATORY • PRODUCTS • TRAINING

UFTD-9EHW-TT6Q

Sampled By / Date 4/8/2025

Relinquished By / Date 4/8/2025

(WI) 4.10.25 @ 12:11 PM

Received (Lab) / Date

4-10-25 19:02

(CR) 4/11/25 0900

HNO_3 JL added 4/11/25 0943

RECEIVED
EMSL
CINNAMINSON, NJ
25 APR 10 PM 6:57