# Service Report

**Byram Schools**

**Wednesday, March 25, 2026 4:21 PM EDT**

**BYRAM TOWNSHIP BOARD OF EDUCATION**
**ATTENTION: Ms. Theresa Radline**
**12 MANSFIELD DRIVE**
**STANHOPE NJ 07834**
**(000) 000-0000**

Report Number: **17941**

Recorded By: **James Meister**
**(973) 219-9983**
**j.meister@associatedwater.com**

On-Site Time: **10:40 AM EDT to 11:10 AM EDT**

## ANNEX, BYRAM LAKES ELEMENTARY SCHOOL,BYRAM INTERMEDIATE SCHOOL - Byram Schools

| Test | Intermediate School | Annex | Elementary School | |
|---|---|---|---|---|
| **pH** | 9.5<br>8 - 9.5 | 9.5<br>8 - 9.5 | 8.5<br>8 - 9.5 | |
| **Nitrite (NaNO2)** | 1100<br>1000 - 2500 | 1400<br>1000 - 2500 | 1900<br>1000 - 2500 | |
| **Conductivity (as umhos)** | 2550 | 2710 | 2407 | |
| **Inhibitor Inv** | 25/.5 | 8/.15 | 25/1.25 | |

### Intermediate School — Online

System is within parameters.

### Annex — Online

System is within parameters.

### Elementary School — Online

System is within parameters.

These water treatment reports and any other documents are believed to be true accurate copies of the actual service reports/documents and are presented solely for the convenience of our clients. AWC assumes no liability for any errors or omissions. By reading or downloading any document on this site, client agrees to above terms and conditioners.