Lead in School Drinking Water Report & Action Plan

School	Prairie Elementary		
Plan Adopted by School Board	July 16, 2026	**Plan Last Updated**	July 6, 2026

As part of the safeguards for public health and our commitment to the health and safety of our community, Yelm Community Schools has developed a reporting and action plan based on the Environmental Protection Agency (EPA) standards of lead concentration to not exceed 15 parts per billion (ppb) and the State of Washington standards to not exceed 5 ppb. These thresholds are not indicators of health effects but provide markers for when steps should be taken to reduce lead concentration in drinking water.

How the Testing Process Works

STEP 1	STEP 2	STEP 3	STEP 4	STEP 5
Inventory all water fixtures at the school used for drinking or cooking	Water samples are collected from fixtures by a third party and sent to accredited lab for testing	Fixtures with sample results greater than 5 ppb are removed from service and an action plan is create	Corrective action is taken to reduce lead levels through replacement or repair	Fixtures are resampled to determine if they can be returned to service

Sampling Dates & Results

Public K–12 school buildings built, or with all plumbing replaced, before 2016 are required to have drinking water tested for lead. Schools must have their drinking water tested for lead at least once between July 1, 2014, and June 30, 2026. Retesting is required at least once every five years beginning July 1, 2026.

Date of Sample	Sampling Agency	Sampling Type	# of Samples Collected	Samples > 5 ppb	Results Received
Mar 18, 2026	Water Management Laboratories	Initial	40	27	May 11, 2026

Result Calculation

Per the Department of Health, testing results are provided in milligrams per liter (mg/L). Results are converted into parts per billion (ppb) to determine the level of lead recorded. The ppb level then determines if a faucet requires remediation and/or mitigation. For example, a result of .0054 mg/L would convert to 5 ppb, which is displayed in whole numbers.

Lead in School Drinking Water Report & Action Plan

Corrective Action Plan

Follow Washington DOH guidelines and RCW 28.A.210.410 (5)(b)(i-iv), the action plan for any fixture resulting in >5 ppb must:

- Be developed in consultation with the DOH or local health jurisdiction regarding technical guidance and with the Office of the Superintendent of Public Instruction (OSPI) regarding funding for remediation activities.
- Describe mitigation measures implemented since led test results were received.
- Include a schedule of remediation activities.
- Include post-remediation retesting to confirm remediation activities reduced lead concentrations for identified fixtures.

Fixture/Sample ID	Location	Fixture Type
303	Staff Lounge	Sink Faucet
Mitigation Measures:	Isolated Fixture	Hand Washing Only
Remediation Plan:	Fixture Replace & Retesting	
Date	**Purpose of Sampling**	**Results**
Mar 18, 2026	Initial Test	7

Fixture/Sample ID	Location	Fixture Type
304	Staff Work Room	Sink Faucet
Mitigation Measures:	Isolated Fixture	Turn Off Water
Remediation Plan:	Fixture Replace & Retesting	
Date	**Purpose of Sampling**	**Results**
Mar 18, 2026	Initial Test	65

Fixture/Sample ID	Location	Fixture Type
306	Health Room	Sink Faucet
Mitigation Measures:	Isolated Fixture	Hand Washing Only
Remediation Plan:	Fixture Replace & Retesting	
Date	**Purpose of Sampling**	**Results**

Mar 18, 2026	Initial Test	7

Fixture/Sample ID	Location	Fixture Type
307	Rm 1	Sink Faucet
Mitigation Measures:	Isolated Fixture	Turn Off Water
Remediation Plan:	Fixture Replace & Retesting	
Date	**Purpose of Sampling**	**Results**
Mar 18, 2026	Initial Test	42

Fixture/Sample ID	Location	Fixture Type
308	Rm 1	Sink Faucet
Mitigation Measures:	Isolated Fixture	Turn Off Water
Remediation Plan:	Fixture Replace & Retesting	
Date	**Purpose of Sampling**	**Results**
Mar 18, 2026	Initial Test	17

Fixture/Sample ID	Location	Fixture Type
310	Pod A	Sink Faucet
Mitigation Measures:	Isolated Fixture	Turn Off Water
Remediation Plan:	Fixture Replace & Retesting	
Date	**Purpose of Sampling**	**Results**
Mar 18, 2026	Initial Test	34

Fixture/Sample ID	Location	Fixture Type
311	Rm 2	Sink Faucet
Mitigation Measures:	Isolated Fixture	Hand Washing Only

Lead in School Drinking Water Report & Action Plan

Remediation Plan:	Fixture Replace & Retesting	
Date	**Purpose of Sampling**	**Results**
Mar 18, 2026	Initial Test	6

Fixture/Sample ID	**Location**	**Fixture Type**
312	Rm 2	Sink Faucet
Mitigation Measures:	Isolated Fixture	Turn Off Water
Remediation Plan:	Fixture Replace & Retesting	
Date	**Purpose of Sampling**	**Results**
Mar 18, 2026	Initial Test	21

Fixture/Sample ID	**Location**	**Fixture Type**
313	Rm 3	Sink Faucet
Mitigation Measures:	Isolated Fixture	Turn Off Water
Remediation Plan:	Fixture Replace & Retesting	
Date	**Purpose of Sampling**	**Results**
Mar 18, 2026	Initial Test	16

Fixture/Sample ID	**Location**	**Fixture Type**
314	Rm 5	Sink Faucet
Mitigation Measures:	Isolated Fixture	Turn Off Water
Remediation Plan:	Fixture Replace & Retesting	
Date	**Purpose of Sampling**	**Results**
Mar 18, 2026	Initial Test	29

Fixture/Sample ID	**Location**	**Fixture Type**

Lead in School Drinking Water Report & Action Plan

315	Rm 4	Sink Faucet
Mitigation Measures:	Isolated Fixture	Hand Washing Only
Remediation Plan:	Fixture Replace & Retesting	
Date	**Purpose of Sampling**	**Results**
Mar 18, 2026	Initial Test	8

Fixture/Sample ID	Location	Fixture Type
316	Rm 6	Sink Faucet
Mitigation Measures:	Isolated Fixture	Hand Washing Only
Remediation Plan:	Fixture Replace & Retesting	
Date	**Purpose of Sampling**	**Results**
Mar 18, 2026	Initial Test	7

Fixture/Sample ID	Location	Fixture Type
317	Rm 8	Sink Faucet
Mitigation Measures:	Isolated Fixture	Hand Washing Only
Remediation Plan:	Fixture Replace & Retesting	
Date	**Purpose of Sampling**	**Results**
Mar 18, 2026	Initial Test	9

Fixture/Sample ID	Location	Fixture Type
318	Rm 9	Sink Faucet
Mitigation Measures:	Isolated Fixture	Hand Washing Only
Remediation Plan:	Fixture Replace & Retesting	
Date	**Purpose of Sampling**	**Results**
Mar 18, 2026	Initial Test	14

Lead in School Drinking Water Report & Action Plan

Fixture/Sample ID	Location	Fixture Type
320	STEP House	Sink Faucet
Mitigation Measures:	Isolated Fixture	Hand Washing Only
Remediation Plan:	Fixture Replace & Retesting	
Date	**Purpose of Sampling**	**Results**
Mar 18, 2026	Initial Test	8

Fixture/Sample ID	Location	Fixture Type
324	Pt 2	Sink Faucet
Mitigation Measures:	Isolated Fixture	Hand Washing Only
Remediation Plan:	Fixture Replace & Retesting	
Date	**Purpose of Sampling**	**Results**
Mar 18, 2026	Initial Test	15

Fixture/Sample ID	Location	Fixture Type
326	Rm 18	Sink Faucet
Mitigation Measures:	Isolated Fixture	Turn Off Water
Remediation Plan:	Fixture Replace & Retesting	
Date	**Purpose of Sampling**	**Results**
Mar 18, 2026	Initial Test	70

Fixture/Sample ID	Location	Fixture Type
327	Rm 19	Sink Faucet
Mitigation Measures:	Isolated Fixture	Turn Off Water
Remediation Plan:	Fixture Replace & Retesting	

Lead in School Drinking Water Report & Action Plan

Date	Purpose of Sampling	Results
Mar 18, 2026	Initial Test	19

Fixture/Sample ID	Location	Fixture Type
331	Rm 17	Sink Faucet
Mitigation Measures:	Isolated Fixture	Turn Off Water
Remediation Plan:	Fixture Replace & Retesting	
Date	**Purpose of Sampling**	**Results**
Mar 18, 2026	Initial Test	17

Fixture/Sample ID	Location	Fixture Type
332	Rm 14	Sink Faucet
Mitigation Measures:	Isolated Fixture	Turn Off Water
Remediation Plan:	Fixture Replace & Retesting	
Date	**Purpose of Sampling**	**Results**
Mar 18, 2026	Initial Test	26

Fixture/Sample ID	Location	Fixture Type
333	Rm 15	Sink Faucet
Mitigation Measures:	Isolated Fixture	Turn Off Water
Remediation Plan:	Fixture Replace & Retesting	
Date	**Purpose of Sampling**	**Results**
Mar 18, 2026	Initial Test	28

Fixture/Sample ID	Location	Fixture Type
334	Rm 16	Sink Faucet

YELM Community Schools

Lead in School Drinking Water Report & Action Plan

Mitigation Measures:	Isolated Fixture	Turn Off Water
Remediation Plan:	Fixture Replace & Retesting	
Date	**Purpose of Sampling**	**Results**
Mar 18, 2026	Initial Test	17

Fixture/Sample ID	**Location**	**Fixture Type**
335	Rm 13	Sink Faucet
Mitigation Measures:	Isolated Fixture	Turn Off Water
Remediation Plan:	Fixture Replace & Retesting	
Date	**Purpose of Sampling**	**Results**
Mar 18, 2026	Initial Test	150

Fixture/Sample ID	**Location**	**Fixture Type**
336	Rm 12	Sink Faucet
Mitigation Measures:	Isolated Fixture	Turn Off Water
Remediation Plan:	Fixture Replace & Retesting	
Date	**Purpose of Sampling**	**Results**
Mar 18, 2026	Initial Test	32

Fixture/Sample ID	**Location**	**Fixture Type**
337	Pod B	Sink Faucet
Mitigation Measures:	Isolated Fixture	Hand Washing Only
Remediation Plan:	Fixture Replace & Retesting	
Date	**Purpose of Sampling**	**Results**
Mar 18, 2026	Initial Test	9

YELM Community Schools

Lead in School Drinking Water Report & Action Plan

Fixture/Sample ID	Location	Fixture Type
339	Rm 11	Sink Faucet
Mitigation Measures:	Isolated Fixture	Turn Off Water
Remediation Plan:	Fixture Replace & Retesting	
Date	**Purpose of Sampling**	**Results**
Mar 18, 2026	Initial Test	20

Fixture/Sample ID	Location	Fixture Type
340	Rm 10	Sink Faucet
Mitigation Measures:	Isolated Fixture	Hand Washing Only
Remediation Plan:	Fixture Replace & Retesting	
Date	**Purpose of Sampling**	**Results**
Mar 18, 2026	Initial Test	9