

July 21, 2026

Mr. James May
Iroquois CSD
2111 Girdle Road
Elma, New York 14059

Re: Follow Up Lead Testing in School Drinking Water

Dear Mr. May:

Included with this letter is Stohl Environmental LLC's report for the Lead in Drinking Water Resampling analysis performed by Iroquois Central School District, including:

- **Elma Primary School – 711 Rice Road, Elma, NY**

This report is prepared to assist school districts in complying with the requirements of 10 NYCRR Subpart 67-4: *Lead Testing in School Drinking Water*, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 5 parts per billion (ppb)".

Recap of Initial Sampling and Analysis: In Compliance with NYS regulations, initial first draw water sampling was completed on December 10, 2025, and a total of 1 sample was identified as containing lead concentrations above the NYS Action Level of 5 ppb.

Mitigation by District and Follow-up Sampling by Stohl Environmental LLC:

- Following the receipt of initial sampling results on January 28, 2026, in accordance with guidance received from NYS, the District is reported to have prohibited use of the outlets analyzed as above the NYS Action Level of 5 ppb "(1) a lead remediation plan is implemented... and (2) test results indicate that the lead levels are at or below the action level".
- Subsequent to reported mitigation by the District, Iroquois Central School District performed follow-up sampling and laboratory analysis on 1 of 1 outlet identified as containing lead concentrations above the NYS action level.
- Follow-up sampling was performed by Iroquois Central School District in accordance with the requirements and protocols outlined in NYS regulations, as well as USEPA Technical Guidance Document "3-T's for Reducing Lead in Drinking Water in Schools".

- Results of Follow-up Sampling: Based upon the follow-up sampling and analysis performed, the following is reported:
 - Of the 1 outlet sampled during the post mitigation follow up on April 2, 2026:
 - 1 outlet was analyzed by a certified and independent laboratory as below the action level; thus cleared for use.

Thank you for the opportunity to be of service to Iroquois Central School District.

Sincerely,
Stohl Environmental, LLC.

A handwritten signature in dark ink, appearing to read "M. Scinta".

Michael Scinta
EPA Lead Risk Assessor

Lead Testing in School Drinking Water

Prepared for:

Iroquois Central School District

Prepared by:



**3860 California Road
Orchard Park, New York 14127**

Conditions as of April 2, 2026

Summary of Samples Collected at Iroquois High School:

Building Name	Date of Sampling	Total Samples	At or Below Action Level*	Above Action Level*
Iroquois High School	12/10/2025	13	12	1
	4/2/2026	1	1	0

**NYS Action Level is 5 parts per billion*

Listing of Outlets Requiring Remediation

The following outlets were analyzed above the NYS Action Level:

Sample #	Location	Fixture/Outlet Type	Laboratory Analysis (in ppb)	
			12/10/25	4/2/26
EP-040	A8 2 Bay Sink Left Faucet West Wall	Sink	11.2	<1.00 – Cleared

1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:

All the locations sampled were analyzed at less than the NYS Action Level of 5 ppb, therefore no further response action is required.

1.4 Laboratory Analytical Reports and Chain of Custody Documents



7469 Whitepine Rd
North Chesterfield, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: Stohl Environmental
3860 California Road
Orchard Park, NY 14127

Report Number: 26-04-02691

Received Date: 04/14/2026
Reported Date: 04/17/2026
Sampled By: James May
Tech Certification #:

Project/Test Address: 2023L-213; High School/Elma Primary

Client Number:
33-5980

Laboratory Results

Fax Number:
716-312-8092

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
26-04-02691-001	HS-087	04/02/2026	151 KITCHEN LEFT 3 BAY SINK S WALL LEFT SINK	<1.00	04/17/2026	
26-04-02691-002	HS-088	04/02/2026	151 KITCHEN LEFT 3 BAY SINK S WALL RIGHT SINK	<1.00	04/17/2026	
26-04-02691-003	HS-090	04/02/2026	151 KITCHEN RIGHT 3 BAY SINK S WALL RIGHT SINK	<1.00	04/17/2026	
26-04-02691-004	EP-040	04/02/2026	A8 2 BAY SINK LEFT FAUCET WEST WALL	<1.00	04/17/2026	

Method: EPA 200.8
Analyst: Nicole Holloway
Accreditation #: NY 11714

Reviewed By Authorized Signatory:

Melissa Kanode

Melissa Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion

1.5 Laboratory Certifications

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2027
Issued April 01, 2026

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE
Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MS. JULIE DICKERSON
ENVIRONMENTAL HAZARDS SERVICES, LLC
7469 WHITEPINE ROAD
N. CHESTERFIELD, VA 23237

NY Lab Id No: 11714

*is hereby APPROVED as an Environmental Laboratory in conformance with the
National Environmental Laboratory Accreditation Conference Standards (2016) for the category
ENVIRONMENTAL ANALYSES POTABLE WATER
All approved analytes are listed below:*

Metals I	
Arsenic, Total	EPA200.8 Rev. 5.4
Copper, Total	EPA200.8 Rev. 5.4
Lead, Total	EPA200.8 Rev. 5.4
Manganese, Total	EPA200.8 Rev. 5.4



Serial No.: 72235

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at <https://apps.health.ny.gov/pubdoh/applinks/awd/elappliweb/>, by phone (516) 485-6670 or by email to elap@health.ny.gov.

Page 1 of 1

