



SCI ENGINEERING, INC.

EARTH • SCIENCE • SOLUTIONS

GEOTECHNICAL
ENVIRONMENTAL
NATURAL RESOURCES
CULTURAL RESOURCES
CONSTRUCTION SERVICES

July 13, 2026

Patrick McCart
Rockwood School District
17146 Manchester Road
Wildwood, Missouri 63040

RE: Lead in Drinking Water Report - Resample
Rockwood South Middle School
1628 Hawkins Road
Fenton, Missouri
SCI No. 2018-0351.2A Task 200

Dear Patrick McCart:

INTRODUCTION

SCI Engineering, Inc. (SCI) is pleased to submit this report summarizing lead in drinking water testing activities performed on August 3 and October 9, 2023, and subsequent resampling conducted on November 22, 2023. The purpose of the initial sampling activities was to screen for elevated levels of lead in the drinking water at potable water sources throughout the above-referenced structure.

Following the initial testing, the school district performed remediation on fixtures which previously exceeded the action level. The remediated fixtures were then resampled, the results of which are summarized herein.

The drinking water survey is intended to satisfy the requirements for the “Get the Lead Out of School Drinking Water Act” (GTLOSDWA), Section 160.077 administered by the Missouri Department of Health and Senior Services. Potable water sources to be tested were identified by the school district prior to SCI’s field activities.

LIMITATIONS

SCI’s sampling activities were limited to locations identified by the school district. If any additional potable water sources need testing, please contact SCI, and we will make arrangements for sampling these fixtures. Potable water sources that were not sampled will need a sign placed near each fixture informing students and faculty that it is not to be used as a drinking water source.

During the course of performing the initial sampling of the fixtures within the building, SCI was able to sample all drinking water sources identified by the school district.

DRINKING WATER SURVEY

SCI collected “first draw” samples which consisted of collecting a water sample from each fixture or sample location after it remained stagnant for at least eight hours. Prior to sampling, SCI first mobilized to the site to flush the identified potable water fixtures throughout the structure. Once each fixture was flushed, a sign was placed on the fixture indicating it should not be used. SCI then revisited the site, after a minimum of eight hours, to collect water samples from the fixtures.

On August 3 and October 9, 2023, SCI initially collected 54 drinking water samples (RSMS-1 through RSMS-54) from various water fixtures located throughout the structure and submitted them for analytical testing. During this sampling event, 2 sample locations exceeded the action level (AL) of 5.0 micrograms lead per liter of water. One fixture was removed, the other was taken out of service until remediation activities could be completed.

During SCI’s resampling event on November 22, 2023, 2 drinking water samples were collected from fixtures which exceeded 5.0 micrograms lead per liter of water. In addition to first draw samples, SCI also collected second draw samples during the resampling event. The second draw samples were collected after the first draw sample and consisted of flushing the fixture for approximately 30 seconds and then collecting the sample. The purpose of the second draw sample is to aid in pinpointing any potential lead contamination and determine appropriate remediation. During this sampling event, the fixture was below the AL and was returned to service.

All drinking water samples were analyzed for total lead by U.S. EPA Method 200.8. SCI collected a minimum of 250 milliliters of water from each location. Sampled water was containerized in laboratory-provided sample containers and shipped to the accredited lab using standard chain-of-custody procedures.

The drinking water samples were analyzed for lead in accordance with the GTLOSDWA Section 160.077, which establishes an action level (AL) of 5 parts per billion (ppb). The drinking water samples which initially exceeded the AL are identified in Table 1, below. Additionally, the results of SCI’s resampling efforts are included in the right-hand columns below. If any, results in bold from SCI’s resampling indicate a result greater than the AL. A copy of the analytical test results and chain-of-custody for all samples is enclosed.

Table 1 – Lead in Drinking Water Results

Sample Number	Sample Location	Sample Description	Initial Result (ppb)	Resampling-First Draw (ppb)	Resampling-Second Draw (ppb)
RSMS-14	Serving Lines 3 and 4	Combi-Oven	43.7	NS (removed)	
RSMS-39	Room 11	Sink 5	10.6	1.0	<1.0

NS-Not Sampled

CONCLUSION AND RECOMMENDATIONS

As previously mentioned, no drinking water samples exceeded the AL of 5 ppb. Therefore, all tested fixtures are compliant per GTLOSDWA and should be tested every five years.

Within seven business days after receiving this report, the school district shall contact parents and staff via written notification which shall include the following:

- The test results and a summary that explains such results;
- A description of any remedial steps taken;
- A description of general health effects of lead contamination and community specific resources; and
- If there is not enough water to meet the drinking water needs of the students, teachers, and staff, bottled water shall be provided.

Additionally, within two weeks of receiving this report, the results and any lead remediation plans must be made available on the school's website.

This report, and subsequent annual testing reports, must be submitted to the Missouri Department of Health and Senior Services, Healthy Drinking Water Unit, PO Box 570, Jefferson City, MO 65102-0570.

SCI appreciates the opportunity to be of service to you on this project. Please contact us if you have any questions or comments regarding the information provided.

Respectfully,

SCI ENGINEERING, INC.



Ethan D. Boyer
Staff Scientist



Jessica B. Keeven, CHMM
Environmental Services Manager

EDB/GBK/bmw

Enclosures
Lead Testing Results



Pace Analytical Services, LLC

2231 W. Altorfer Drive

Peoria, IL 61615

(800)752-6651

October 25, 2023

Glenn Grissom
SCI Engineering
130 Point W. Blvd.
St. Charles, MO 63301

RE: 2018-0351.2T-Rockwood South MS

Dear Glenn Grissom:

Please find enclosed the analytical results for the **54** sample(s) the laboratory received on **8/4/23 2:30 pm** and logged in under work order **GH01158**. All testing is performed according to our current TNI accreditations unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of Pace Analytical Services, LLC.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

Pace Analytical Services appreciates the opportunity to provide you with analytical expertise. We are always trying to improve our customer service and we welcome you to contact the General Manager, Lisa Grant, with any feedback you have about your experience with our laboratory at 309-683-1764 or lisa.grant@pacelabs.com.

A handwritten signature in black ink, appearing to read 'Chenise Lambert-Sykes'.

Chenise Lambert-Sykes
Project Manager
(314)432-0550
Chenise.Lambert-Sykes@pacelabs.com

**SAMPLE RECEIPT CHECK LIST**

Items not applicable will be marked as in compliance

Work Order GH01158

YES	Samples received within temperature compliance when applicable
YES	COC present upon sample receipt
YES	COC completed & legible
YES	Sampler name & signature present
YES	Unique sample IDs assigned
YES	Sample collection location recorded
YES	Date & time collected recorded on COC
YES	Relinquished by client signature on COC
YES	COC & labels match
YES	Sample labels are legible
YES	Appropriate bottle(s) received
YES	Sufficient sample volume received
YES	Sample containers received undamaged
YES	Zero headspace, <6 mm present in VOA vials
NO	Trip blank(s) received
YES	All non-field analyses received within holding times
YES	Short hold time analysis
YES	Current PDC COC submitted
NO	Case narrative provided



Case Narrative

The drinking water lead analysis was performed at Pace-Ormond Beach, FL. Please refer to the subcontract section of the report for details.

Sample RSMS-10 (GH01158-10) arrived to the subcontract laboratory empty and analysis could not be performed.



ANALYTICAL RESULTS

Sample: GH01158-01
Name: RSMS-1
Matrix: Drinking Water - Grab

Sampled: 08/03/23 18:26
Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		08/03/23 18:26	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GH01158-02
Name: RSMS-2
Matrix: Drinking Water - Grab

Sampled: 08/03/23 18:28
Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		08/03/23 18:28	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GH01158-03
Name: RSMS-3
Matrix: Drinking Water - Grab

Sampled: 08/03/23 19:10
Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	2.2	ug/L		08/03/23 19:10	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GH01158-04
Name: RSMS-4
Matrix: Drinking Water - Grab

Sampled: 08/03/23 19:11
Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	2.1	ug/L		08/03/23 19:11	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------



ANALYTICAL RESULTS

Sample: GH01158-05
Name: RSMS-5
Matrix: Drinking Water - Grab

Sampled: 08/03/23 19:09

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	1.2	ug/L		08/03/23 19:09	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GH01158-06
Name: RSMS-6
Matrix: Drinking Water - Grab

Sampled: 08/03/23 19:08

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	2.5	ug/L		08/03/23 19:08	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GH01158-07
Name: RSMS-7
Matrix: Drinking Water - Grab

Sampled: 08/03/23 18:58

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	4.8	ug/L		08/03/23 18:58	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GH01158-08
Name: RSMS-8
Matrix: Drinking Water - Grab

Sampled: 08/03/23 18:52

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		08/03/23 18:52	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------



ANALYTICAL RESULTS

Sample: GH01158-09
Name: RSMS-9
Matrix: Drinking Water - Grab

Sampled: 08/03/23 18:45

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	1.2	ug/L		08/03/23 18:45	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GH01158-11
Name: RSMS-11
Matrix: Drinking Water - Grab

Sampled: 08/03/23 18:38

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		08/03/23 18:38	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GH01158-12
Name: RSMS-12
Matrix: Drinking Water - Grab

Sampled: 08/03/23 19:02

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		08/03/23 19:02	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GH01158-13
Name: RSMS-13
Matrix: Drinking Water - Grab

Sampled: 08/03/23 18:33

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		08/03/23 18:33	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------



ANALYTICAL RESULTS

Sample: GH01158-14
Name: RSMS-14
Matrix: Drinking Water - Grab

Sampled: 08/03/23 18:34

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	43.7	ug/L		08/03/23 18:34	1	1		PACE	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	---	--	------	-------------------

Sample: GH01158-15
Name: RSMS-15
Matrix: Drinking Water - Grab

Sampled: 08/03/23 19:20

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		08/03/23 19:20	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GH01158-16
Name: RSMS-16
Matrix: Drinking Water - Grab

Sampled: 08/03/23 19:21

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		08/03/23 19:21	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GH01158-17
Name: RSMS-17
Matrix: Drinking Water - Grab

Sampled: 08/03/23 19:16

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		08/03/23 19:16	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------



ANALYTICAL RESULTS

Sample: GH01158-18
Name: RSMS-18
Matrix: Drinking Water - Grab

Sampled: 08/03/23 19:17

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		08/03/23 19:17	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GH01158-19
Name: RSMS-19
Matrix: Drinking Water - Grab

Sampled: 08/03/23 19:27

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		08/03/23 19:27	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GH01158-20
Name: RSMS-20
Matrix: Drinking Water - Grab

Sampled: 08/03/23 19:28

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		08/03/23 19:28	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GH01158-21
Name: RSMS-21
Matrix: Drinking Water - Grab

Sampled: 08/03/23 19:29

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		08/03/23 19:29	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------



ANALYTICAL RESULTS

Sample: GH01158-22
Name: RSMS-22
Matrix: Drinking Water - Grab

Sampled: 08/03/23 19:32

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	2.7	ug/L		08/03/23 19:32	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GH01158-23
Name: RSMS-23
Matrix: Drinking Water - Grab

Sampled: 08/03/23 19:37

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		08/03/23 19:37	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GH01158-24
Name: RSMS-24
Matrix: Drinking Water - Grab

Sampled: 08/03/23 19:38

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		08/03/23 19:38	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GH01158-25
Name: RSMS-25
Matrix: Drinking Water - Grab

Sampled: 08/03/23 19:39

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		08/03/23 19:39	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------



ANALYTICAL RESULTS

Sample: GH01158-26
Name: RSMS-26
Matrix: Drinking Water - Grab

Sampled: 08/03/23 19:43

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		08/03/23 19:43	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GH01158-27
Name: RSMS-27
Matrix: Drinking Water - Grab

Sampled: 08/03/23 19:44

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	2.6	ug/L		08/03/23 19:44	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GH01158-28
Name: RSMS-28
Matrix: Drinking Water - Grab

Sampled: 08/03/23 19:45

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		08/03/23 19:45	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GH01158-29
Name: RSMS-29
Matrix: Drinking Water - Grab

Sampled: 08/03/23 19:48

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	1.4	ug/L		08/03/23 19:48	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------



ANALYTICAL RESULTS

Sample: GH01158-30
Name: RSMS-30
Matrix: Drinking Water - Grab

Sampled: 08/03/23 19:49

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		08/03/23 19:49	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GH01158-31
Name: RSMS-31
Matrix: Drinking Water - Grab

Sampled: 08/03/23 19:50

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		08/03/23 19:50	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GH01158-32
Name: RSMS-32
Matrix: Drinking Water - Grab

Sampled: 08/03/23 19:53

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		08/03/23 19:53	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GH01158-33
Name: RSMS-33
Matrix: Drinking Water - Grab

Sampled: 08/03/23 19:54

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		08/03/23 19:54	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------



ANALYTICAL RESULTS

Sample: GH01158-34
Name: RSMS-34
Matrix: Drinking Water - Grab

Sampled: 08/03/23 19:54

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	1.2	ug/L		08/03/23 19:54	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GH01158-35
Name: RSMS-35
Matrix: Drinking Water - Grab

Sampled: 08/03/23 19:59

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		08/03/23 19:59	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GH01158-36
Name: RSMS-36
Matrix: Drinking Water - Grab

Sampled: 08/03/23 20:00

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		08/03/23 20:00	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GH01158-37
Name: RSMS-37
Matrix: Drinking Water - Grab

Sampled: 08/03/23 20:01

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	1.5	ug/L		08/03/23 20:01	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------



ANALYTICAL RESULTS

Sample: GH01158-38
Name: RSMS-38
Matrix: Drinking Water - Grab

Sampled: 08/03/23 20:03

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		08/03/23 20:03	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GH01158-39
Name: RSMS-39
Matrix: Drinking Water - Grab

Sampled: 08/03/23 20:04

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	10.6	ug/L		08/03/23 20:04	1	1		PACE	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	---	--	------	-------------------

Sample: GH01158-40
Name: RSMS-40
Matrix: Drinking Water - Grab

Sampled: 08/03/23 20:05

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	2.3	ug/L		08/03/23 20:05	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GH01158-41
Name: RSMS-41
Matrix: Drinking Water - Grab

Sampled: 08/03/23 20:12

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		08/03/23 20:12	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------



ANALYTICAL RESULTS

Sample: GH01158-42
Name: RSMS-42
Matrix: Drinking Water - Grab

Sampled: 08/03/23 20:13

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		08/03/23 20:13	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GH01158-43
Name: RSMS-43
Matrix: Drinking Water - Grab

Sampled: 08/03/23 20:16

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	3.3	ug/L		08/03/23 20:16	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GH01158-44
Name: RSMS-44
Matrix: Drinking Water - Grab

Sampled: 08/03/23 20:20

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		08/03/23 20:20	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GH01158-45
Name: RSMS-45
Matrix: Drinking Water - Grab

Sampled: 08/03/23 20:21

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		08/03/23 20:21	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------



ANALYTICAL RESULTS

Sample: GH01158-46
Name: RSMS-46
Matrix: Drinking Water - Grab

Sampled: 08/03/23 20:24

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		08/03/23 20:24	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GH01158-47
Name: RSMS-47
Matrix: Drinking Water - Grab

Sampled: 08/03/23 20:27

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		08/03/23 20:27	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GH01158-48
Name: RSMS-48
Matrix: Drinking Water - Grab

Sampled: 08/03/23 20:29

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	2.4	ug/L		08/03/23 20:29	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GH01158-49
Name: RSMS-49
Matrix: Drinking Water - Grab

Sampled: 08/03/23 20:32

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		08/03/23 20:32	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------



ANALYTICAL RESULTS

Sample: GH01158-50
Name: RSMS-50
Matrix: Drinking Water - Grab

Sampled: 08/03/23 20:35

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		08/03/23 20:35	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GH01158-51
Name: RSMS-51
Matrix: Drinking Water - Grab

Sampled: 08/03/23 20:36

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		08/03/23 20:36	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GH01158-52
Name: RSMS-52
Matrix: Drinking Water - Grab

Sampled: 08/03/23 20:37

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		08/03/23 20:37	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------

Sample: GH01158-53
Name: RSMS-53
Matrix: Drinking Water - Grab

Sampled: 08/03/23 20:39

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	< 1	ug/L		08/03/23 20:39	1	1		PACE	EPA 200.8 REV 5.4
------	-----	------	--	----------------	---	---	--	------	-------------------



Pace Analytical Services, LLC

2231 W. Altorfer Drive

Peoria, IL 61615

(800)752-6651

ANALYTICAL RESULTS

Sample: GH01158-54

Name: RSMS-54

Matrix: Drinking Water - Grab

Sampled: 08/03/23 20:40

Received: 08/04/23 14:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Subcontracted Analysis - Pace Analytical - Ormond Beach

Lead	1	ug/L		08/03/23 20:40	1	1		PACE	EPA 200.8 REV 5.4
------	---	------	--	----------------	---	---	--	------	-------------------



NOTES

Specifications regarding method revisions, method modifications, and calculations used for analysis are available upon request. Please contact your project manager.

* Not a TNI accredited analyte

Certifications

CHI - McHenry, IL - 4314-A W. Crystal Lake Road, McHenry, IL 60050

TNI Accreditation for Drinking Water and Wastewater Fields of Testing through IL EPA Accreditation No. 100279

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17556

PIA - Peoria, IL - 2231 W. Altorfer Drive, Peoria, IL 61615

TNI Accreditation for Drinking Water, Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. 100230

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17553

Drinking Water Certifications/Accreditations: Iowa (240); Kansas (E-10338); Missouri (870)

Wastewater Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

Solid and Hazardous Material Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO - 1805 W Sunset Street, Springfield, MO 65807

USEPA DMR-QA Program

STL - Hazelwood, MO - 944 Anglum Rd, Hazelwood, MO 63042

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through KS KDHE Certification No. E-10389

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. - 200080

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory, Registry No. 171050

Missouri Department of Natural Resources - Certificate of Approval for Microbiological Laboratory Service - No. 1050

Certified by: Chenise Lambert-Sykes, Project Manager





October 13, 2023

Chenise Lambert-Sykes
Pace Analytical Services, Inc - IL/MO
944 Anglum Road
Hazelwood, MO 63042

RE: Project: GH01158
Pace Project No.: 35832704

Dear Chenise Lambert-Sykes:

Enclosed are the analytical results for sample(s) received by the laboratory on October 05, 2023. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Ormond Beach

Sample GH01158-10 arrived empty, unable to analyze sample due to insufficient sample volume.

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Brad Smith
brad.smith@pacelabs.com
(386) 672-5668
Project Manager

Enclosures



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



CERTIFICATIONS

Project: GH01158

Pace Project No.: 35832704

Pace Analytical Services Ormond Beach

8 East Tower Circle, Ormond Beach, FL 32174

Alaska DEC- CS/UST/LUST

Alabama Certification #: 41320

Colorado Certification: FL NELAC Reciprocity

Connecticut Certification #: PH-0216

Delaware Certification: FL NELAC Reciprocity

DoD-ANAB #: ADE-3199

Florida Certification #: E83079

Georgia Certification #: 955

Guam Certification: FL NELAC Reciprocity

Hawaii Certification: FL NELAC Reciprocity

Illinois Certification #: 200068

Indiana Certification: FL NELAC Reciprocity

Kansas Certification #: E-10383

Kentucky Certification #: 90050

Louisiana Certification #: FL NELAC Reciprocity

Louisiana Environmental Certificate #: 05007

Maine Certification #: FL01264

Maryland Certification: #346

Massachusetts Certification #: M-FL1264

Michigan Certification #: 9911

Mississippi Certification: FL NELAC Reciprocity

Missouri Certification #: 236

Montana Certification #: Cert 0074

Nebraska Certification: NE-OS-28-14

New Hampshire Certification #: 2958

New Jersey Certification #: FL022

New York Certification #: 11608

North Carolina Environmental Certificate #: 667

North Carolina Certification #: 12710

North Dakota Certification #: R-216

Ohio DEP 87780

Oklahoma Certification #: D9947

Pennsylvania Certification #: 68-00547

Puerto Rico Certification #: FL01264

South Carolina Certification: #96042001

Tennessee Certification #: TN02974

Texas Certification: FL NELAC Reciprocity

US Virgin Islands Certification: FL NELAC Reciprocity

Virginia Environmental Certification #: 460165

West Virginia Certification #: 9962C

Wisconsin Certification #: 399079670

Wyoming (EPA Region 8): FL NELAC Reciprocity

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE ANALYTE COUNT

Project: GH01158
Pace Project No.: 35832704

Lab ID	Sample ID	Method	Analysts	Analytes Reported	Laboratory
35832704001	GH01158-01	EPA 200.8	BSL	1	PASI-O
35832704002	GH01158-02	EPA 200.8	BSL	1	PASI-O
35832704003	GH01158-03	EPA 200.8	BSL	1	PASI-O
35832704004	GH01158-04	EPA 200.8	BSL	1	PASI-O
35832704005	GH01158-05	EPA 200.8	BSL	1	PASI-O
35832704006	GH01158-06	EPA 200.8	BSL	1	PASI-O
35832704007	GH01158-07	EPA 200.8	BSL	1	PASI-O
35832704008	GH01158-08	EPA 200.8	BSL	1	PASI-O
35832704009	GH01158-09	EPA 200.8	BSL	1	PASI-O
35832704011	GH01158-11	EPA 200.8	BSL	1	PASI-O
35832704012	GH01158-12	EPA 200.8	BSL	1	PASI-O
35832704013	GH01158-13	EPA 200.8	BSL	1	PASI-O
35832704014	GH01158-14	EPA 200.8	BSL	1	PASI-O
35832704015	GH01158-15	EPA 200.8	BSL	1	PASI-O
35832704016	GH01158-16	EPA 200.8	BSL	1	PASI-O
35832704017	GH01158-17	EPA 200.8	BSL	1	PASI-O
35832704018	GH01158-18	EPA 200.8	BSL	1	PASI-O
35832704019	GH01158-19	EPA 200.8	BSL	1	PASI-O
35832704020	GH01158-20	EPA 200.8	BSL	1	PASI-O
35832704021	GH01158-21	EPA 200.8	BSL	1	PASI-O
35832704022	GH01158-22	EPA 200.8	BSL	1	PASI-O
35832704023	GH01158-23	EPA 200.8	BSL	1	PASI-O
35832704024	GH01158-24	EPA 200.8	BSL	1	PASI-O
35832704025	GH01158-25	EPA 200.8	BSL	1	PASI-O
35832704026	GH01158-26	EPA 200.8	BSL	1	PASI-O
35832704027	GH01158-27	EPA 200.8	BSL	1	PASI-O
35832704028	GH01158-28	EPA 200.8	BSL	1	PASI-O
35832704029	GH01158-29	EPA 200.8	BSL	1	PASI-O
35832704030	GH01158-30	EPA 200.8	BSL	1	PASI-O
35832704031	GH01158-31	EPA 200.8	BSL	1	PASI-O
35832704032	GH01158-32	EPA 200.8	BSL	1	PASI-O
35832704033	GH01158-33	EPA 200.8	BSL	1	PASI-O
35832704034	GH01158-34	EPA 200.8	BSL	1	PASI-O
35832704035	GH01158-35	EPA 200.8	BSL	1	PASI-O
35832704036	GH01158-36	EPA 200.8	BSL	1	PASI-O
35832704037	GH01158-37	EPA 200.8	BSL	1	PASI-O
35832704038	GH01158-38	EPA 200.8	BSL	1	PASI-O

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE ANALYTE COUNT

Project: GH01158
Pace Project No.: 35832704

Lab ID	Sample ID	Method	Analysts	Analytes Reported	Laboratory
35832704039	GH01158-39	EPA 200.8	BSL	1	PASI-O
35832704040	GH01158-40	EPA 200.8	BSL	1	PASI-O
35832704041	GH01158-41	EPA 200.8	BSL	1	PASI-O
35832704042	GH01158-42	EPA 200.8	BSL	1	PASI-O
35832704043	GH01158-43	EPA 200.8	LEC	1	PASI-O
35832704044	GH01158-44	EPA 200.8	BSL	1	PASI-O
35832704045	GH01158-45	EPA 200.8	BSL	1	PASI-O
35832704046	GH01158-46	EPA 200.8	BSL	1	PASI-O
35832704047	GH01158-47	EPA 200.8	BSL	1	PASI-O
35832704048	GH01158-48	EPA 200.8	BSL	1	PASI-O
35832704049	GH01158-49	EPA 200.8	BSL	1	PASI-O
35832704050	GH01158-50	EPA 200.8	BSL	1	PASI-O
35832704051	GH01158-51	EPA 200.8	BSL	1	PASI-O
35832704052	GH01158-52	EPA 200.8	BSL	1	PASI-O
35832704053	GH01158-53	EPA 200.8	BSL	1	PASI-O
35832704054	GH01158-54	EPA 200.8	BSL	1	PASI-O

PASI-O = Pace Analytical Services - Ormond Beach

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-01		Lab ID: 35832704001		Collected: 08/03/23 18:26		Received: 10/05/23 16:30		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		10/12/23 21:17	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-02		Lab ID: 35832704002		Collected: 08/03/23 18:28		Received: 10/05/23 16:30		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		10/12/23 21:19	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-03		Lab ID: 35832704003		Collected: 08/03/23 19:10		Received: 10/05/23 16:30		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	2.2	ug/L	1.0	1		10/12/23 21:20	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-04		Lab ID: 35832704004		Collected: 08/03/23 19:11		Received: 10/05/23 16:30		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	2.1	ug/L	1.0	1		10/12/23 21:22	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-05		Lab ID: 35832704005		Collected: 08/03/23 19:09		Received: 10/05/23 16:30		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	1.2	ug/L	1.0	1		10/12/23 21:23	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-06		Lab ID: 35832704006	Collected: 08/03/23 19:08	Received: 10/05/23 16:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach						
Lead	2.5	ug/L	1.0	1		10/12/23 21:24	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-07		Lab ID: 35832704007	Collected: 08/03/23 18:58	Received: 10/05/23 16:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach						
Lead	4.8	ug/L	1.0	1		10/12/23 21:29	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GH01158

Pace Project No.: 35832704

Sample: GH01158-08		Lab ID: 35832704008		Collected: 08/03/23 18:52		Received: 10/05/23 16:30		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		10/12/23 21:30	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-09		Lab ID: 35832704009		Collected: 08/03/23 18:45		Received: 10/05/23 16:30		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	1.2	ug/L	1.0	1		10/12/23 21:32	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-11		Lab ID: 35832704011		Collected: 08/03/23 18:38		Received: 10/05/23 16:30		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		10/12/23 21:33	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-12		Lab ID: 35832704012		Collected: 08/03/23 19:02		Received: 10/05/23 16:30		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		10/12/23 21:34	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-13		Lab ID: 35832704013		Collected: 08/03/23 18:33		Received: 10/05/23 16:30		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		10/12/23 21:36	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-14		Lab ID: 35832704014		Collected: 08/03/23 18:34		Received: 10/05/23 16:30		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	43.7	ug/L	1.0	1		10/12/23 21:37	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-15		Lab ID: 35832704015		Collected: 08/03/23 19:20		Received: 10/05/23 16:30		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		10/12/23 21:47	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-16		Lab ID: 35832704016		Collected: 08/03/23 19:21		Received: 10/05/23 16:30		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		10/12/23 21:52	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-17		Lab ID: 35832704017		Collected: 08/03/23 19:16		Received: 10/05/23 16:30		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		10/12/23 21:53	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-18		Lab ID: 35832704018		Collected: 08/03/23 19:17		Received: 10/05/23 16:30		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
		Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		10/12/23 21:55	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-19		Lab ID: 35832704019		Collected: 08/03/23 19:27		Received: 10/05/23 16:30		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		10/12/23 21:56	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-20		Lab ID: 35832704020		Collected: 08/03/23 19:28		Received: 10/05/23 16:30		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		10/12/23 21:57	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-21		Lab ID: 35832704021		Collected: 08/03/23 19:29		Received: 10/05/23 16:30		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		10/12/23 22:02	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-22		Lab ID: 35832704022		Collected: 08/03/23 19:32		Received: 10/05/23 16:30		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	2.7	ug/L	1.0	1		10/12/23 22:03	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-23		Lab ID: 35832704023		Collected: 08/03/23 19:37		Received: 10/05/23 16:30		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		10/12/23 22:05	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-24		Lab ID: 35832704024		Collected: 08/03/23 19:38		Received: 10/05/23 16:30		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		10/12/23 22:06	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-25		Lab ID: 35832704025		Collected: 08/03/23 19:39		Received: 10/05/23 16:30		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		10/12/23 22:08	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-26		Lab ID: 35832704026		Collected: 08/03/23 19:43		Received: 10/05/23 16:30		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		10/12/23 22:09	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-27		Lab ID: 35832704027	Collected: 08/03/23 19:44	Received: 10/05/23 16:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach						
Lead	2.6	ug/L	1.0	1		10/12/23 22:10	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-28		Lab ID: 35832704028		Collected: 08/03/23 19:45		Received: 10/05/23 16:30		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		10/12/23 22:12	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-29		Lab ID: 35832704029	Collected: 08/03/23 19:48	Received: 10/05/23 16:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach						
Lead	1.4	ug/L	1.0	1		10/12/23 22:13	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-30		Lab ID: 35832704030		Collected: 08/03/23 19:49		Received: 10/05/23 16:30		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		10/12/23 22:15	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-31		Lab ID: 35832704031		Collected: 08/03/23 19:50		Received: 10/05/23 16:30		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		10/12/23 22:19	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-32		Lab ID: 35832704032		Collected: 08/03/23 19:53		Received: 10/05/23 16:30		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		10/12/23 22:20	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-33		Lab ID: 35832704033		Collected: 08/03/23 19:54		Received: 10/05/23 16:30		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		10/12/23 22:22	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-34		Lab ID: 35832704034		Collected: 08/03/23 19:54		Received: 10/05/23 16:30		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	1.2	ug/L	1.0	1		10/12/23 22:23	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-35		Lab ID: 35832704035		Collected: 08/03/23 19:59		Received: 10/05/23 16:30		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		10/12/23 22:30	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-36		Lab ID: 35832704036		Collected: 08/03/23 20:00		Received: 10/05/23 16:30		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		10/12/23 22:38	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-37		Lab ID: 35832704037	Collected: 08/03/23 20:01	Received: 10/05/23 16:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach						
Lead	1.5	ug/L	1.0	1		10/12/23 22:39	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-38		Lab ID: 35832704038		Collected: 08/03/23 20:03		Received: 10/05/23 16:30		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		10/12/23 22:41	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-39		Lab ID: 35832704039	Collected: 08/03/23 20:04	Received: 10/05/23 16:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach						
Lead	10.6	ug/L	1.0	1		10/12/23 22:42	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-40		Lab ID: 35832704040	Collected: 08/03/23 20:05	Received: 10/05/23 16:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach						
Lead	2.3	ug/L	1.0	1		10/12/23 22:43	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-41		Lab ID: 35832704041	Collected: 08/03/23 20:12	Received: 10/05/23 16:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach						
Lead	ND	ug/L	1.0	1		10/12/23 22:45	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-42		Lab ID: 35832704042		Collected: 08/03/23 20:13		Received: 10/05/23 16:30		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		10/12/23 22:46	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-43		Lab ID: 35832704043	Collected: 08/03/23 20:16	Received: 10/05/23 16:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Preparation Method: EPA 200.8 Pace Analytical Services - Ormond Beach						
Lead	3.3	ug/L	1.0	1	10/12/23 23:28	10/13/23 11:15	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-44		Lab ID: 35832704044		Collected: 08/03/23 20:20		Received: 10/05/23 16:30		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		10/12/23 22:48	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-45		Lab ID: 35832704045		Collected: 08/03/23 20:21		Received: 10/05/23 16:30		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		10/12/23 22:49	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-46		Lab ID: 35832704046		Collected: 08/03/23 20:24		Received: 10/05/23 16:30		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		10/12/23 22:53	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-47		Lab ID: 35832704047		Collected: 08/03/23 20:27		Received: 10/05/23 16:30		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		10/12/23 22:55	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-48		Lab ID: 35832704048		Collected: 08/03/23 20:29		Received: 10/05/23 16:30		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	2.4	ug/L	1.0	1		10/12/23 22:56	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-49		Lab ID: 35832704049		Collected: 08/03/23 20:32		Received: 10/05/23 16:30		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		10/12/23 22:58	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-50		Lab ID: 35832704050		Collected: 08/03/23 20:35		Received: 10/05/23 16:30		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		10/12/23 22:59	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-51		Lab ID: 35832704051		Collected: 08/03/23 20:36		Received: 10/05/23 16:30		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		10/12/23 23:01	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-52		Lab ID: 35832704052		Collected: 08/03/23 20:37		Received: 10/05/23 16:30		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		10/12/23 23:02	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-53		Lab ID: 35832704053		Collected: 08/03/23 20:39		Received: 10/05/23 16:30		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach							
Lead	ND	ug/L	1.0	1		10/12/23 23:04	7439-92-1		

REPORT OF LABORATORY ANALYSIS



ANALYTICAL RESULTS

Project: GH01158
Pace Project No.: 35832704

Sample: GH01158-54		Lab ID: 35832704054	Collected: 08/03/23 20:40	Received: 10/05/23 16:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Ormond Beach						
Lead	1.0	ug/L	1.0	1		10/12/23 23:05	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: GH01158
Pace Project No.: 35832704

QC Batch:	957629	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Ormond Beach
Associated Lab Samples:	35832704001, 35832704002, 35832704003, 35832704004, 35832704005, 35832704006, 35832704007, 35832704008, 35832704009, 35832704011, 35832704012, 35832704013, 35832704014		

METHOD BLANK: 5266441 Matrix: Water
Associated Lab Samples: 35832704001, 35832704002, 35832704003, 35832704004, 35832704005, 35832704006, 35832704007, 35832704008, 35832704009, 35832704011, 35832704012, 35832704013, 35832704014

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	1.0	10/12/23 21:42	

LABORATORY CONTROL SAMPLE: 5266442

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	52.1	104	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 5266437 5266438

Parameter	Units	35832657021 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Qual
Lead	ug/L	29.4	50	50	82.2	81.8	106	105	70-130	0	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 5266439 5266440

Parameter	Units	35832704014 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Qual
Lead	ug/L	43.7	50	50	94.2	94.0	101	101	70-130	0	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: GH01158
Pace Project No.: 35832704

QC Batch:	957665	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Ormond Beach
Associated Lab Samples:	35832704015, 35832704016, 35832704017, 35832704018, 35832704019, 35832704020, 35832704021, 35832704022, 35832704023, 35832704024, 35832704025, 35832704026, 35832704027, 35832704028, 35832704029, 35832704030, 35832704031, 35832704032, 35832704033, 35832704034		

METHOD BLANK:	5266743	Matrix:	Water
Associated Lab Samples:	35832704015, 35832704016, 35832704017, 35832704018, 35832704019, 35832704020, 35832704021, 35832704022, 35832704023, 35832704024, 35832704025, 35832704026, 35832704027, 35832704028, 35832704029, 35832704030, 35832704031, 35832704032, 35832704033, 35832704034		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	1.0	10/12/23 22:28	

LABORATORY CONTROL SAMPLE:	5266744					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	51.3	103	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE:	5266739			5266740							
Parameter	Units	35832704015 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Qual
Lead	ug/L	ND	50	50	52.3	51.9	105	104	70-130	1	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE:	5266741			5266742							
Parameter	Units	35832704034 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Qual
Lead	ug/L	1.2	50	50	53.5	52.4	105	102	70-130	2	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: GH01158
Pace Project No.: 35832704

QC Batch:	957666	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Ormond Beach
Associated Lab Samples:	35832704035, 35832704036, 35832704037, 35832704038, 35832704039, 35832704040, 35832704041, 35832704042, 35832704044, 35832704045, 35832704046, 35832704047, 35832704048, 35832704049, 35832704050, 35832704051, 35832704052, 35832704053, 35832704054		

METHOD BLANK:	5266753	Matrix:	Water
Associated Lab Samples:	35832704035, 35832704036, 35832704037, 35832704038, 35832704039, 35832704040, 35832704041, 35832704042, 35832704044, 35832704045, 35832704046, 35832704047, 35832704048, 35832704049, 35832704050, 35832704051, 35832704052, 35832704053, 35832704054		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	1.0	10/12/23 23:12	

LABORATORY CONTROL SAMPLE:	5266754					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	51.1	102	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE:	5266749			5266750							
Parameter	Units	35832704035 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Qual
Lead	ug/L	ND	50	50	52.1	50.7	103	100	70-130	3	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE:	5266751			5266752							
Parameter	Units	35832704054 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Qual
Lead	ug/L	1.0	50	50	52.6	52.5	103	103	70-130	0	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: GH01158

Pace Project No.: 35832704

QC Batch: 957718

Analysis Method: EPA 200.8

QC Batch Method: EPA 200.8

Analysis Description: 200.8 MET Drinking Water

Laboratory: Pace Analytical Services - Ormond Beach

Associated Lab Samples: 35832704043

METHOD BLANK: 5267127

Matrix: Water

Associated Lab Samples: 35832704043

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	1.0	10/13/23 11:09	

LABORATORY CONTROL SAMPLE: 5267128

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	49.4	99	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 5267129 5267130

Parameter	Units	35832726005 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Qual
Lead	ug/L	0.0014 mg/L	50	50	48.9	49.1	95	95	70-130	0	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 5267131 5267132

Parameter	Units	35834054001 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Qual
Lead	ug/L	0.0011 U mg/L	50	50	39.3	39.7	78	79	70-130	1	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Date: 10/13/2023 04:03 PM



QUALIFIERS

Project: GH01158
Pace Project No.: 35832704

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.
ND - Not Detected at or above adjusted reporting limit.
TNTC - Too Numerous To Count
MDL - Adjusted Method Detection Limit.
PQL - Practical Quantitation Limit.
RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.
S - Surrogate
1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.
Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.
LCS(D) - Laboratory Control Sample (Duplicate)
MS(D) - Matrix Spike (Duplicate)
DUP - Sample Duplicate
RPD - Relative Percent Difference
NC - Not Calculable.
SG - Silica Gel - Clean-Up
U - Indicates the compound was analyzed for, but not detected.
N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.
Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.
Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.
TNI - The NELAC Institute.

ANALYTE QUALIFIERS

U Compound was analyzed for but not detected.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: GH01158

Pace Project No.: 35832704

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
35832704043	GH01158-43	EPA 200.8	957718	EPA 200.8	957743
35832704001	GH01158-01	EPA 200.8	957629		
35832704002	GH01158-02	EPA 200.8	957629		
35832704003	GH01158-03	EPA 200.8	957629		
35832704004	GH01158-04	EPA 200.8	957629		
35832704005	GH01158-05	EPA 200.8	957629		
35832704006	GH01158-06	EPA 200.8	957629		
35832704007	GH01158-07	EPA 200.8	957629		
35832704008	GH01158-08	EPA 200.8	957629		
35832704009	GH01158-09	EPA 200.8	957629		
35832704011	GH01158-11	EPA 200.8	957629		
35832704012	GH01158-12	EPA 200.8	957629		
35832704013	GH01158-13	EPA 200.8	957629		
35832704014	GH01158-14	EPA 200.8	957629		
35832704015	GH01158-15	EPA 200.8	957665		
35832704016	GH01158-16	EPA 200.8	957665		
35832704017	GH01158-17	EPA 200.8	957665		
35832704018	GH01158-18	EPA 200.8	957665		
35832704019	GH01158-19	EPA 200.8	957665		
35832704020	GH01158-20	EPA 200.8	957665		
35832704021	GH01158-21	EPA 200.8	957665		
35832704022	GH01158-22	EPA 200.8	957665		
35832704023	GH01158-23	EPA 200.8	957665		
35832704024	GH01158-24	EPA 200.8	957665		
35832704025	GH01158-25	EPA 200.8	957665		
35832704026	GH01158-26	EPA 200.8	957665		
35832704027	GH01158-27	EPA 200.8	957665		
35832704028	GH01158-28	EPA 200.8	957665		
35832704029	GH01158-29	EPA 200.8	957665		
35832704030	GH01158-30	EPA 200.8	957665		
35832704031	GH01158-31	EPA 200.8	957665		
35832704032	GH01158-32	EPA 200.8	957665		
35832704033	GH01158-33	EPA 200.8	957665		
35832704034	GH01158-34	EPA 200.8	957665		
35832704035	GH01158-35	EPA 200.8	957666		
35832704036	GH01158-36	EPA 200.8	957666		
35832704037	GH01158-37	EPA 200.8	957666		
35832704038	GH01158-38	EPA 200.8	957666		
35832704039	GH01158-39	EPA 200.8	957666		
35832704040	GH01158-40	EPA 200.8	957666		
35832704041	GH01158-41	EPA 200.8	957666		
35832704042	GH01158-42	EPA 200.8	957666		
35832704044	GH01158-44	EPA 200.8	957666		
35832704045	GH01158-45	EPA 200.8	957666		
35832704046	GH01158-46	EPA 200.8	957666		
35832704047	GH01158-47	EPA 200.8	957666		
35832704048	GH01158-48	EPA 200.8	957666		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: GH01158

Pace Project No.: 35832704

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
35832704049	GH01158-49	EPA 200.8	957666		
35832704050	GH01158-50	EPA 200.8	957666		
35832704051	GH01158-51	EPA 200.8	957666		
35832704052	GH01158-52	EPA 200.8	957666		
35832704053	GH01158-53	EPA 200.8	957666		
35832704054	GH01158-54	EPA 200.8	957666		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SUBCONTRACT ORDER
Transfer Chain of Custody

Pace Analytical Services, LLC
GH01158

W0# : 35832704



SENDING LABORATORY

PDC Laboratories, Inc.
944 Anglum Road
Hazelwood, MO 63042
(800) 333-3278

RECEIVING LABORATORY

Pace Analytical - Ormond Beach
8 East Tower Circle
Ormond Beach, FL 32174
(386) 676-4842

Sample: GH01158-01
Name: RSMS-1

Sampled: 08/03/23 18:26
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 18:26	
01-Turb check	08/17/23 16:00	01/30/24 18:26	

Sample: GH01158-02
Name: RSMS-2

Sampled: 08/03/23 18:28
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 18:28	
01-Turb check	08/17/23 16:00	01/30/24 18:28	

Sample: GH01158-03
Name: RSMS-3

Sampled: 08/03/23 19:10
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 19:10	
01-Turb check	08/17/23 16:00	01/30/24 19:10	

Sample: GH01158-04
Name: RSMS-4

Sampled: 08/03/23 19:11
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 19:11	
01-Turb check	08/17/23 16:00	01/30/24 19:11	

SUBCONTRACT ORDER
Transfer Chain of Custody
Pace Analytical Services, LLC
GH01158

SENDING LABORATORY

PDC Laboratories, Inc.
944 Anglum Road
Hazelwood, MO 63042
(800) 333-3278

RECEIVING LABORATORY

Pace Analytical - Ormond Beach
8 East Tower Circle
Ormond Beach, FL 32174
(386) 676-4842

Sample: GH01158-05
Name: RSMS-5

Sampled: 08/03/23 19:09
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
----------	-----	---------	----------

01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 19:09	
01-Turb check	08/17/23 16:00	01/30/24 19:09	

Sample: GH01158-06
Name: RSMS-6

Sampled: 08/03/23 19:08
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
----------	-----	---------	----------

01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 19:08	
01-Turb check	08/17/23 16:00	01/30/24 19:08	

Sample: GH01158-07
Name: RSMS-7

Sampled: 08/03/23 18:58
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
----------	-----	---------	----------

01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 18:58	
01-Turb check	08/17/23 16:00	01/30/24 18:58	

Sample: GH01158-08
Name: RSMS-8

Sampled: 08/03/23 18:52
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
----------	-----	---------	----------

01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 18:52	
01-Turb check	08/17/23 16:00	01/30/24 18:52	

SUBCONTRACT ORDER
Transfer Chain of Custody
Pace Analytical Services, LLC
GH01158

SENDING LABORATORY

PDC Laboratories, Inc.
944 Anglum Road
Hazelwood, MO 63042
(800) 333-3278

RECEIVING LABORATORY

Pace Analytical - Ormond Beach
8 East Tower Circle
Ormond Beach, FL 32174
(386) 676-4842

Sample: GH01158-09
Name: RSMS-9

Sampled: 08/03/23 18:45
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 18:45	
01-Turb check	08/17/23 16:00	01/30/24 18:45	

Sample: GH01158-10
Name: RSMS-10

Sampled: 08/03/23 18:40
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 18:40	
01-Turb check	08/17/23 16:00	01/30/24 18:40	

Sample: GH01158-11
Name: RSMS-11

Sampled: 08/03/23 18:38
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 18:38	
01-Turb check	08/17/23 16:00	01/30/24 18:38	

Sample: GH01158-12
Name: RSMS-12

Sampled: 08/03/23 19:02
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 19:02	
01-Turb check	08/17/23 16:00	01/30/24 19:02	

SUBCONTRACT ORDER
Transfer Chain of Custody
Pace Analytical Services, LLC
GH01158

SENDING LABORATORY

PDC Laboratories, Inc.
944 Anglum Road
Hazelwood, MO 63042
(800) 333-3278

RECEIVING LABORATORY

Pace Analytical - Ormond Beach
8 East Tower Circle
Ormond Beach, FL 32174
(386) 676-4842

Sample: GH01158-13
Name: RSMS-13

Sampled: 08/03/23 18:33
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
----------	-----	---------	----------

01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 18:33	
01-Turb check	08/17/23 16:00	01/30/24 18:33	

Sample: GH01158-14
Name: RSMS-14

Sampled: 08/03/23 18:34
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
----------	-----	---------	----------

01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 18:34	
01-Turb check	08/17/23 16:00	01/30/24 18:34	

Sample: GH01158-15
Name: RSMS-15

Sampled: 08/03/23 19:20
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
----------	-----	---------	----------

01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 19:20	
01-Turb check	08/17/23 16:00	01/30/24 19:20	

Sample: GH01158-16
Name: RSMS-16

Sampled: 08/03/23 19:21
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
----------	-----	---------	----------

01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 19:21	
01-Turb check	08/17/23 16:00	01/30/24 19:21	

SUBCONTRACT ORDER
Transfer Chain of Custody
Pace Analytical Services, LLC
GH01158

SENDING LABORATORY

PDC Laboratories, Inc.
944 Anglum Road
Hazelwood, MO 63042
(800) 333-3278

RECEIVING LABORATORY

Pace Analytical - Ormond Beach
8 East Tower Circle
Ormond Beach, FL 32174
(386) 676-4842

Sample: GH01158-17
Name: RSMS-17

Sampled: 08/03/23 19:16
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
----------	-----	---------	----------

01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 19:16	
01-Turb check	08/17/23 16:00	01/30/24 19:16	

Sample: GH01158-18
Name: RSMS-18

Sampled: 08/03/23 19:17
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
----------	-----	---------	----------

01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 19:17	
01-Turb check	08/17/23 16:00	01/30/24 19:17	

Sample: GH01158-19
Name: RSMS-19

Sampled: 08/03/23 19:27
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
----------	-----	---------	----------

01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 19:27	
01-Turb check	08/17/23 16:00	01/30/24 19:27	

Sample: GH01158-20
Name: RSMS-20

Sampled: 08/03/23 19:28
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
----------	-----	---------	----------

01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 19:28	
01-Turb check	08/17/23 16:00	01/30/24 19:28	

SUBCONTRACT ORDER
Transfer Chain of Custody

Pace Analytical Services, LLC
GH01158

SENDING LABORATORY

PDC Laboratories, Inc.
944 Anglum Road
Hazelwood, MO 63042
(800) 333-3278

RECEIVING LABORATORY

Pace Analytical - Ormond Beach
8 East Tower Circle
Ormond Beach, FL 32174
(386) 676-4842

Sample: GH01158-21
Name: RSMS-21

Sampled: 08/03/23 19:29
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 19:29	
01-Turb check	08/17/23 16:00	01/30/24 19:29	

Sample: GH01158-22
Name: RSMS-22

Sampled: 08/03/23 19:32
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 19:32	
01-Turb check	08/17/23 16:00	01/30/24 19:32	

Sample: GH01158-23
Name: RSMS-23

Sampled: 08/03/23 19:37
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 19:37	
01-Turb check	08/17/23 16:00	01/30/24 19:37	

Sample: GH01158-24
Name: RSMS-24

Sampled: 08/03/23 19:38
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 19:38	
01-Turb check	08/17/23 16:00	01/30/24 19:38	

SUBCONTRACT ORDER
Transfer Chain of Custody

Pace Analytical Services, LLC
GH01158

SENDING LABORATORY

PDC Laboratories, Inc.
944 Anglum Road
Hazelwood, MO 63042
(800) 333-3278

RECEIVING LABORATORY

Pace Analytical - Ormond Beach
8 East Tower Circle
Ormond Beach, FL 32174
(386) 676-4842

Sample: GH01158-25
Name: RSMS-25

Sampled: 08/03/23 19:39
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 19:39	
01-Turb check	08/17/23 16:00	01/30/24 19:39	

Sample: GH01158-26
Name: RSMS-26

Sampled: 08/03/23 19:43
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 19:43	
01-Turb check	08/17/23 16:00	01/30/24 19:43	

Sample: GH01158-27
Name: RSMS-27

Sampled: 08/03/23 19:44
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 19:44	
01-Turb check	08/17/23 16:00	01/30/24 19:44	

Sample: GH01158-28
Name: RSMS-28

Sampled: 08/03/23 19:45
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 19:45	
01-Turb check	08/17/23 16:00	01/30/24 19:45	

SUBCONTRACT ORDER
Transfer Chain of Custody

Pace Analytical Services, LLC

GH01158

SENDING LABORATORY

PDC Laboratories, Inc.
944 Anglum Road
Hazelwood, MO 63042
(800) 333-3278

RECEIVING LABORATORY

Pace Analytical - Ormond Beach
8 East Tower Circle
Ormond Beach, FL 32174
(386) 676-4842

Sample: GH01158-29
Name: RSMS-29

Sampled: 08/03/23 19:48
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
----------	-----	---------	----------

01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 19:48	
01-Turb check	08/17/23 16:00	01/30/24 19:48	

Sample: GH01158-30
Name: RSMS-30

Sampled: 08/03/23 19:49
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
----------	-----	---------	----------

01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 19:49	
01-Turb check	08/17/23 16:00	01/30/24 19:49	

Sample: GH01158-31
Name: RSMS-31

Sampled: 08/03/23 19:50
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
----------	-----	---------	----------

01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 19:50	
01-Turb check	08/17/23 16:00	01/30/24 19:50	

Sample: GH01158-32
Name: RSMS-32

Sampled: 08/03/23 19:53
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
----------	-----	---------	----------

01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 19:53	
01-Turb check	08/17/23 16:00	01/30/24 19:53	

SUBCONTRACT ORDER
Transfer Chain of Custody
Pace Analytical Services, LLC
GH01158

SENDING LABORATORY

PDC Laboratories, Inc.
944 Anglum Road
Hazelwood, MO 63042
(800) 333-3278

RECEIVING LABORATORY

Pace Analytical - Ormond Beach
8 East Tower Circle
Ormond Beach, FL 32174
(386) 676-4842

Sample: GH01158-33
Name: RSMS-33

Sampled: 08/03/23 19:54
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
----------	-----	---------	----------

01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 19:54	
01-Turb check	08/17/23 16:00	01/30/24 19:54	

Sample: GH01158-34
Name: RSMS-34

Sampled: 08/03/23 19:54
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
----------	-----	---------	----------

01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 19:54	
01-Turb check	08/17/23 16:00	01/30/24 19:54	

Sample: GH01158-35
Name: RSMS-35

Sampled: 08/03/23 19:59
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
----------	-----	---------	----------

01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 19:59	
01-Turb check	08/17/23 16:00	01/30/24 19:59	

Sample: GH01158-36
Name: RSMS-36

Sampled: 08/03/23 20:00
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
----------	-----	---------	----------

01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 20:00	
01-Turb check	08/17/23 16:00	01/30/24 20:00	

SUBCONTRACT ORDER
Transfer Chain of Custody
Pace Analytical Services, LLC
GH01158

SENDING LABORATORY

PDC Laboratories, Inc.
944 Anglum Road
Hazelwood, MO 63042
(800) 333-3278

RECEIVING LABORATORY

Pace Analytical - Ormond Beach
8 East Tower Circle
Ormond Beach, FL 32174
(386) 676-4842

Sample: GH01158-37
Name: RSMS-37

Sampled: 08/03/23 20:01
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
----------	-----	---------	----------

01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 20:01	
01-Turb check	08/17/23 16:00	01/30/24 20:01	

Sample: GH01158-38
Name: RSMS-38

Sampled: 08/03/23 20:03
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
----------	-----	---------	----------

01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 20:03	
01-Turb check	08/17/23 16:00	01/30/24 20:03	

Sample: GH01158-39
Name: RSMS-39

Sampled: 08/03/23 20:04
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
----------	-----	---------	----------

01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 20:04	
01-Turb check	08/17/23 16:00	01/30/24 20:04	

Sample: GH01158-40
Name: RSMS-40

Sampled: 08/03/23 20:05
Matrix: Drinking Water
Preservative: HNO₃, pH <2

Analysis	Due	Expires	Comments
----------	-----	---------	----------

01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 20:05	
01-Turb check	08/17/23 16:00	01/30/24 20:05	

SUBCONTRACT ORDER
Transfer Chain of Custody
Pace Analytical Services, LLC
GH01158

SENDING LABORATORY

PDC Laboratories, Inc.
944 Anglum Road
Hazelwood, MO 63042
(800) 333-3278

RECEIVING LABORATORY

Pace Analytical - Ormond Beach
8 East Tower Circle
Ormond Beach, FL 32174
(386) 676-4842

Sample: GH01158-41
Name: RSMS-41

Sampled: 08/03/23 20:12
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 20:12	
01-Turb check	08/17/23 16:00	01/30/24 20:12	

Sample: GH01158-42
Name: RSMS-42

Sampled: 08/03/23 20:13
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 20:13	
01-Turb check	08/17/23 16:00	01/30/24 20:13	

Sample: GH01158-43
Name: RSMS-43

Sampled: 08/03/23 20:16
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 20:16	
01-Turb check	08/17/23 16:00	01/30/24 20:16	

Sample: GH01158-44
Name: RSMS-44

Sampled: 08/03/23 20:20
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 20:20	
01-Turb check	08/17/23 16:00	01/30/24 20:20	

SUBCONTRACT ORDER
Transfer Chain of Custody
Pace Analytical Services, LLC
GH01158

SENDING LABORATORY

PDC Laboratories, Inc.
944 Anglum Road
Hazelwood, MO 63042
(800) 333-3278

RECEIVING LABORATORY

Pace Analytical - Ormond Beach
8 East Tower Circle
Ormond Beach, FL 32174
(386) 676-4842

Sample: GH01158-45
Name: RSMS-45

Sampled: 08/03/23 20:21
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
----------	-----	---------	----------

01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 20:21	
01-Turb check	08/17/23 16:00	01/30/24 20:21	

Sample: GH01158-46
Name: RSMS-46

Sampled: 08/03/23 20:24
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
----------	-----	---------	----------

01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 20:24	
01-Turb check	08/17/23 16:00	01/30/24 20:24	

Sample: GH01158-47
Name: RSMS-47

Sampled: 08/03/23 20:27
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
----------	-----	---------	----------

01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 20:27	
01-Turb check	08/17/23 16:00	01/30/24 20:27	

Sample: GH01158-48
Name: RSMS-48

Sampled: 08/03/23 20:29
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
----------	-----	---------	----------

01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 20:29	
01-Turb check	08/17/23 16:00	01/30/24 20:29	

SUBCONTRACT ORDER
Transfer Chain of Custody
Pace Analytical Services, LLC
GH01158

SENDING LABORATORY

PDC Laboratories, Inc.
944 Anglum Road
Hazelwood, MO 63042
(800) 333-3278

RECEIVING LABORATORY

Pace Analytical - Ormond Beach
8 East Tower Circle
Ormond Beach, FL 32174
(386) 676-4842

Sample: GH01158-49
Name: RSMS-49

Sampled: 08/03/23 20:32
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
----------	-----	---------	----------

01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 20:32	
------------------------	----------------	----------------	--

01-Turb check	08/17/23 16:00	01/30/24 20:32	
---------------	----------------	----------------	--

Sample: GH01158-50
Name: RSMS-50

Sampled: 08/03/23 20:35
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
----------	-----	---------	----------

01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 20:35	
------------------------	----------------	----------------	--

01-Turb check	08/17/23 16:00	01/30/24 20:35	
---------------	----------------	----------------	--

Sample: GH01158-51
Name: RSMS-51

Sampled: 08/03/23 20:36
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
----------	-----	---------	----------

01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 20:36	
------------------------	----------------	----------------	--

01-Turb check	08/17/23 16:00	01/30/24 20:36	
---------------	----------------	----------------	--

Sample: GH01158-52
Name: RSMS-52

Sampled: 08/03/23 20:37
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
----------	-----	---------	----------

01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 20:37	
------------------------	----------------	----------------	--

01-Turb check	08/17/23 16:00	01/30/24 20:37	
---------------	----------------	----------------	--

SUBCONTRACT ORDER
Transfer Chain of Custody
Pace Analytical Services, LLC
GH01158

WO# : 35832704

PM: BTS

Due Date: 10/13/23

CLIENT: PACHAZ

SENDING LABORATORY

PDC Laboratories, Inc.
944 Anglum Road
Hazelwood, MO 63042
(800) 333-3278

RECEIVING LABORATORY

Pace Analytical - Ormond Beach
8 East Tower Circle
Ormond Beach, FL 32174
(386) 676-4842

Sample: GH01158-53
Name: RSMS-53

Sampled: 08/03/23 20:39
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 20:39	
01-Turb check	08/17/23 16:00	01/30/24 20:39	

Sample: GH01158-54
Name: RSMS-54

Sampled: 08/03/23 20:40
Matrix: Drinking Water
Preservative: HNO3, pH <2

Analysis	Due	Expires	Comments
01-Pb 200.8 DW Schools	08/17/23 16:00	01/30/24 20:40	
01-Turb check	08/17/23 16:00	01/30/24 20:40	

Please email results to Chenise Lambert-Sykes at Chenise.Lambert-Sykes@pacelabs.com

Date Shipped: _____ Total # of Containers: 54 Sample Origin (State): _____ PO #: _____

Turn-Around Time Requested ☐ NORMAL ☐ RUSH

Date Results Needed: _____

10/21/23		Sample Temperature Upon Receipt _____ °C	
3:30pm		Sample(s) Received on Ice Y or N	
Relinquished By <u>Chenise Lambert</u>	Date/Time	Received By	Date/Time
		Proper Bottles Received in Good Condition Y or N	
		Bottles Filled with Adequate Volume Y or N	
		Samples Received Within Hold Time Y or N	
		Date/Time Taken From Sample Bottle Y or N	
Relinquished By <u>T SI/pace</u>	Date/Time	Received By	Date/Time
		10/8/23 1630	

Pace

Project #
Project Manager:
Client:

Sample Condition Upon Receipt
WO# : 35832704

PM: BTS Due Date: 10/13/23
CLIENT: PACHAZ

Date and Initials of person:

Examining contents: _____

Label: _____

Deliver: _____

pH: _____

Initials: JRS

Thermometer Used: T 409

Date: 10-5-23

Time: 1637

State of Origin: _____

☐ For WV projects, all containers verified to $\leq 6^{\circ}\text{C}$

Cooler #1 Temp. 24.3°C (Visual) tail (Correction Factor) 24.4°C (Actual)

Cooler #2 Temp. 25.3°C (Visual) (Correction Factor) 25.4°C (Actual)

Cooler #3 Temp. 23.2°C (Visual) (Correction Factor) 23.3°C (Actual)

Cooler #4 Temp. 22.2°C (Visual) (Correction Factor) 22.3°C (Actual)

Cooler #5 Temp. 24.4°C (Visual) (Correction Factor) 24.5°C (Actual)

Cooler #6 Temp. 25.3°C (Visual) (Correction Factor) 25.4°C (Actual)

Recheck for OOT $^{\circ}\text{C}$ (Visual) (Correction Factor) (Actual)

☐ Samples on ice, cooling process has begun.

☐ Samples on ice, cooling process has begun.

☐ Samples on ice, cooling process has begun.

☐ Samples on ice, cooling process has begun.

☐ Samples on ice, cooling process has begun.

☐ Samples on ice, cooling process has begun.

Time: _____ Initials: _____

Courier: ☒ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☐ Pace ☐ Other: _____

Shipping Method: ☐ Standard Overnight ☐ First Overnight ☐ Priority Overnight ☒ Ground ☐ International Priority ☐ Other: _____

Billing: ☐ Recipient ☒ Sender ☐ Third Party ☐ Credit Card ☐ Unknown

Tracking # 7903 7806 2713

Custody Seal Present: ☐ Yes ☐ No Seal properly placed and intact: ☐ Yes ☐ No

Ice: ☐ Wet ☐ Blue ☒ Dry ☐ None ☐ Melted

Packing Material: ☒ Bubble Wrap ☐ Bubble Bags ☐ None ☐ Other: _____

Samples shorted to lab: ☐ Yes ☐ No (If yes, complete the following)

Shorted Date: _____

Shorted Time: _____

Bottle Quantity / Type: _____

Chain of Custody:	Present: ☒ Yes ☐ No Filled Out: ☒ Yes ☐ No ☐ N/A Relinquished From Pace: ☒ Yes ☐ No ☐ N/A Sampler Name: ☒ Yes ☐ No ☐ N/A	
	Relinquished To Pace: ☐ Yes ☐ No ☐ N/A Sampling Date(s): ☐ Yes ☐ No ☐ N/A Sampling Time(s): ☒ Yes ☐ No ☐ N/A	
Samples Arrived within Hold Time.	☒ Yes ☐ No ☐ N/A	Comments:
Rush Turnaround Requested on COC.	☐ Yes ☒ No ☐ N/A	Comments:
Sufficient Volume.	☐ Yes ☒ No ☐ N/A	Comments:
Correct Containers Used.	☒ Yes ☐ No ☐ N/A	Comments:
Containers Intact.	☐ Yes ☒ No ☐ N/A	Comments:
Sample Labels Match COC (Sample ID, Date/Time of Collection).	☒ Yes ☐ No ☐ N/A	Comments:
All containers needing acid / base preservation have been checked.	☒ Yes ☐ No ☐ N/A	Preservation Information Preservative: _____ Date: _____ Lot / Trace: _____ Time: _____ Amount added (mL): _____ Initials: _____
All containers needing preservation are found to be in compliance with EPA recommendation:	☒ Yes ☐ No ☐ N/A	
Exceptions: Vials, Microbiology, O&G, PFAS		
Headspace in Volatile Vials? (>6mm):	☐ Yes ☐ No ☒ N/A	
Trip Blank Present:	☐ Yes ☐ No ☒ N/A	

Comments / Resolutions (use back for additional comments):

All containers arrived in 500mL Co
Cooler #14, 23.0, Cooler #15, 25.1 Sample GHO 1158-10A arrived empty

Pace

Sample Condition Upon Receipt Form (SCUR)

Project #
Project Manager:
Client:

Date and Initials of person:

Examining contents: _____

Label: _____

Deliver: _____

pH: _____

Thermometer Used: T 409

Date: 10-5-23

Time: 1637

Initials: JRS

State of Origin: _____

☐ For WV projects, all containers verified to $\leq 6^{\circ}\text{C}$

Cooler #1 Temp. $^{\circ}\text{C}$ 24.3 (Visual) tail (Correction Factor) 24.4 (Actual)

Cooler #2 Temp. $^{\circ}\text{C}$ 25.3 (Visual) _____ (Correction Factor) 25.4 (Actual)

Cooler #3 Temp. $^{\circ}\text{C}$ 23.2 (Visual) _____ (Correction Factor) 23.3 (Actual)

Cooler #4 Temp. $^{\circ}\text{C}$ 22.2 (Visual) _____ (Correction Factor) 22.3 (Actual)

Cooler #5 Temp. $^{\circ}\text{C}$ 24.4 (Visual) _____ (Correction Factor) 24.5 (Actual)

Cooler #6 Temp. $^{\circ}\text{C}$ 25.3 (Visual) _____ (Correction Factor) 25.4 (Actual)

Recheck for OOT $^{\circ}\text{C}$ _____ (Visual) _____ (Correction Factor) _____ (Actual)

☐ Samples on ice, cooling process has begun.

☐ Samples on ice, cooling process has begun.

☐ Samples on ice, cooling process has begun.

☐ Samples on ice, cooling process has begun.

☐ Samples on ice, cooling process has begun.

☐ Samples on ice, cooling process has begun.

Time: _____ Initials: _____

Courier: ☒ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☐ Pace ☐ Other: _____

Shipping Method: ☐ Standard Overnight ☐ First Overnight ☐ Priority Overnight ☒ Ground ☐ International Priority ☐ Other: _____

Billing: ☐ Recipient ☐ Sender ☐ Third Party ☐ Credit Card ☐ Unknown

Tracking # _____

Custody Seal Present: ☐ Yes ☐ No Seal properly placed and intact: ☐ Yes ☐ No

Ice: ☐ Wet ☐ Blue ☒ Dry ☐ None ☐ Melted

Packing Material: ☒ Bubble Wrap ☐ Bubble Bags ☐ None ☐ Other: _____

Samples shorted to lab: ☐ Yes ☐ No (If yes, complete the following)

Shorted Date: _____

Shorted Time: _____

Bottle Quantity / Type: _____

Chain of Custody:	Present: ☐ Yes ☐ No Filled Out: ☐ Yes ☐ No ☐ N/A Relinquished From Pace: ☐ Yes ☐ No ☐ N/A Sampler Name: ☐ Yes ☐ No ☐ N/A		
	Relinquished To Pace: ☐ Yes ☐ No ☐ N/A Sampling Date(s): ☐ Yes ☐ No ☐ N/A Sampling Time(s): ☐ Yes ☐ No ☐ N/A		
Samples Arrived within Hold Time.	☐ Yes ☐ No ☐ N/A	Comments:	
Rush Turnaround Requested on COC	☐ Yes ☐ No ☐ N/A	Comments:	
Sufficient Volume.	☐ Yes ☐ No ☐ N/A	Comments:	
Correct Containers Used.	☐ Yes ☐ No ☐ N/A	Comments:	
Containers Intact.	☐ Yes ☐ No ☐ N/A	Comments:	
Sample Labels Match COC (Sample ID, Date/Time of Collection).	☐ Yes ☐ No ☐ N/A	Comments:	
All containers needing acid / base preservation have been checked.	☐ Yes ☐ No ☐ N/A	Preservation Information Preservative: _____ Date: _____ Lot / Trace: _____ Time: _____ Amount added (mL): _____ Initials: _____	
All containers needing preservation are found to be in compliance with EPA recommendation:	☐ Yes ☐ No ☐ N/A		
Exceptions: Vials, Microbiology, O&G, PFAS			
Headspace in Volatile Vials? (>6mm):	☐ Yes ☐ No ☐ N/A		
Trip Blank Present:	☐ Yes ☐ No ☐ N/A		

Comments / Resolutions (use back for additional comments):

All Samples Arrived in 500mL Containers
SCUR continued

Pace

Project #
Project Manager:
Client:

Condition Upon Receipt Form (SCUR)
WO# : 35832704
PM: BTS Due Date: 10/13/23
CLIENT: PACHAZ

Date and Initials of person:

Examining contents: _____

Label: _____

Deliver: _____

pH: _____

Initials: JRS

Thermometer Used: T 409

Date: 10-5-23

Time: 16:36

State of Origin: _____

☐ For WV projects, all containers verified to ≤6 °C

Cooler #1 Temp. °C 22.3 (Visual) tail (Correction Factor) 22.4 (Actual)

Cooler #2 Temp. °C 23.8 (Visual) (Correction Factor) 23.9 (Actual)

Cooler #3 Temp. °C 24.4 (Visual) (Correction Factor) 24.5 (Actual)

Cooler #4 Temp. °C 22.3 (Visual) (Correction Factor) 22.4 (Actual)

Cooler #5 Temp. °C 25.8 (Visual) (Correction Factor) 25.9 (Actual)

Cooler #6 Temp. °C 21.2 (Visual) (Correction Factor) 21.3 (Actual)

Recheck for OOT °C _____ (Visual) _____ (Correction Factor) _____ (Actual)

Courier: ☒ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☐ Pace ☐ Other: _____

Shipping Method: ☐ Standard Overnight ☐ First Overnight ☐ Priority Overnight ☒ Ground ☐ International Priority ☐ Other: _____

Billing: ☐ Recipient ☐ Sender ☐ Third Party ☐ Credit Card ☐ Unknown

Tracking # _____

Custody Seal Present: ☐ Yes ☐ No Seal properly placed and intact: ☐ Yes ☐ No

Packing Material: ☒ Bubble Wrap ☐ Bubble Bags ☐ None ☐ Other: _____

Ice: ☐ Wet ☐ Blue ☒ Dry ☐ None ☐ Melted

Samples shorted to lab: ☐ Yes ☐ No (If yes, complete the following)

Shorted Date: _____

Shorted Time: _____

Bottle Quantity / Type: _____

Chain of Custody:	Present: ☐ Yes ☐ No Filled Out: ☐ Yes ☐ No ☐ N/A Relinquished From Pace: ☐ Yes ☐ No ☐ N/A Sampler Name: ☐ Yes ☐ No ☐ N/A
	Relinquished To Pace: ☐ Yes ☐ No ☐ N/A Sampling Date(s): ☐ Yes ☐ No ☐ N/A Sampling Time(s): ☐ Yes ☐ No ☐ N/A
Samples Arrived within Hold Time.	☐ Yes ☐ No ☐ N/A Comments: _____
Rush Turnaround Requested on COC.	☐ Yes ☐ No ☐ N/A Comments: _____
Sufficient Volume.	☐ Yes ☐ No ☐ N/A Comments: _____
Correct Containers Used.	☐ Yes ☐ No ☐ N/A Comments: _____
Containers Intact.	☐ Yes ☐ No ☐ N/A Comments: _____
Sample Labels Match COC (Sample ID, Date/Time of Collection).	☐ Yes ☐ No ☐ N/A Comments: _____
All containers needing acid / base preservation have been checked.	☐ Yes ☐ No ☐ N/A
All containers needing preservation are found to be in compliance with EPA recommendation:	☐ Yes ☐ No ☐ N/A
Exceptions: Vials, Microbiology, O&G, PFAS	
Headspace in Volatile Vials? (>6mm):	☐ Yes ☐ No ☐ N/A
Trip Blank Present:	☐ Yes ☐ No ☐ N/A

Preservation Information	
Preservative: _____	Date: _____
Lot / Trace: _____	Time: _____
Amount added (mL): _____	Initials: _____

Comments / Resolutions (use back for additional comments):

Cooler #7 23.4 + 0.1 23.5

All samples arrived in 500mL containers.
SCUR continued

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD
STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)




1 CLIENT SCI Engineering		PROJECT NUMBER 2018-0351.2T		PROJECT LOCATION Rockwood South MS		PURCHASE ORDER #		3 ANALYSIS REQUESTED		4 (FOR LAB USE ONLY) GND1158	
ADDRESS 130 Point West Blvd		PHONE NUMBER (314) 581-7570		E-MAIL ggrissom@sciengineering.com		DATE SHIPPED		+		+	
CITY St. Charles, MO 63301		SAMPLER (PLEASE PRINT) Doug Ell		MATRIX TYPES: WW- WASTEWATER DW- DRINKING WATER GW- GROUND WATER WWSL- SLUDGE NAS- NON AQUEOUS SOLID LCHL- LEACHATE OIL- OIL SO- SOIL SOL- SOLID							
CONTACT PERSON Glen Grissom		SAMPLER'S SIGNATURE <i>Doug Ell</i>									
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB	COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	DW	Pb	Turb Check
RSMS-1	8/3/23	1826	X		DW	1	6	X	X		
RSMS-2	8/3/23	1828	X		DW	1	6	X	X		
RSMS-3	8/3/23	1910	X		DW	1	6	X	X		
RSMS-4	8/3/23	1911	X		DW	1	6	X	X		
RSMS-5	8/3/23	1909	X		DW	1	6	X	X		
RSMS-6	8/3/23	1908	X		DW	1	6	X	X		
RSMS-7	8/3/23	1858	X		DW	1	6	X	X		
RSMS-8	8/3/23	1852	X		DW	1	6	X	X		
RSMS-9	8/3/23	1845	X		DW	1	6	X	X		
RSMS-10	8/3/23	1840	X		DW	1	6	X	X		
RSMS-11	8/3/23	1838	X		DW	1	6	X	X		
CHEMICAL PRESERVATION CODES:		1 - HCL	2 - H2SO4	3 - HNO3	4 - NAOH	5 - NA2S2O3	6 - UNPRESERVED	7 - OTHER			
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) NORMAL RUSH (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE)		DATE RESULTS NEEDED		6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.							
RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE				PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS)							
7 RELINQUISHED BY: (SIGNATURE) <i>Doug Ell</i>		DATE 8/4/23 TIME 1300		RECEIVED BY: (SIGNATURE) <i>Dawn Williams</i>		DATE 8-4-23 TIME 14:30		8 COMMENTS: (FOR LAB USE ONLY)			
RELINQUISHED BY: (SIGNATURE)		DATE		RECEIVED BY: (SIGNATURE)		DATE		SAMPLE TEMPERATURE UPON RECEIPT			
RELINQUISHED BY: (SIGNATURE)		TIME		RECEIVED BY: (SIGNATURE)		TIME		CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N			
RELINQUISHED BY: (SIGNATURE)		DATE		RECEIVED BY: (SIGNATURE)		DATE		SAMPLE(S) RECEIVED ON ICE Y OR N			
RELINQUISHED BY: (SIGNATURE)		TIME		RECEIVED BY: (SIGNATURE)		TIME		SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N			
								DATE AND TIME TAKEN FROM SAMPLE BOTTLE			

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)



1 CLIENT SCI Engineering		PROJECT NUMBER 2018-0351.2T		PROJECT LOCATION Rockwood South MS		PURCHASE ORDER #		3 ANALYSIS REQUESTED				4 (FOR LAB USE ONLY) LOGIN # <u>G4H0158</u> LOGGED BY: _____ CLIENT: <u>SCI Engineering</u> PROJECT: <u>Drinking Water Lead</u> PROJ. MGR.: <u>Chenise Lambert-Sykes</u> CUSTODY SEAL #: _____	
ADDRESS 130 Point West Blvd		PHONE NUMBER (314) 581-7570		E-MAIL ggrissom@sciengineering.com		DATE SHIPPED		DW Pb Turb Check				REMARKS	
CITY STATE ZIP St. Charles, MO 63301		SAMPLER (PLEASE PRINT) Doug Ell		SAMPLER'S SIGNATURE 		MATRIX TYPES: WW-WASTEWATER DW-DRINKING WATER GW-GROUND WATER WWSL-SLUDGE NAS-NON AQUEOUS SOLID LCHT-LEACHATE OIL-OIL SO-SOIL SOL-SOLID							
CONTACT PERSON Glen Grissom													
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED						
RSMS-12		8/3/23	1902	X	DW	1	6	X	X				
RSMS-13		8/3/23	1833	X	DW	1	6	X	X				
RSMS-14		8/3/23	1834	X	DW	1	6	X	X				
RSMS-15		8/3/23	1920	X	DW	1	6	X	X				
RSMS-16		8/3/23	1921	X	DW	1	6	X	X				
RSMS-17		8/3/23	1916	X	DW	1	6	X	X				
RSMS-18		8/3/23	1917	X	DW	1	6	X	X				
RSMS-19		8/3/23	1927	X	DW	1	6	X	X				
RSMS-20		8/3/23	1928	X	DW	1	6	X	X				
RSMS-21		8/3/23	1929	X	DW	1	6	X	X				
RSMS-22		8/3/23	1932	X	DW	1	6	X	X				
CHEMICAL PRESERVATION CODES:		1 - HCL	2 - H2SO4	3 - HNO3	4 - NAOH	5 - NA2S2O3	6 - UNPRESERVED	7 - OTHER					
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE)		NORMAL RUSH (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE)		DATE RESULTS NEEDED		6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.							
RUSH RESULTS VIA (PLEASE CIRCLE)		EMAIL PHONE				PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) _____							
7 RELINQUISHED BY: (SIGNATURE) 		DATE 8/4/23		RECEIVED BY: (SIGNATURE) 		DATE 8-4-23		8 COMMENTS: (FOR LAB USE ONLY)					
RELINQUISHED BY: (SIGNATURE)		TIME 1300		RECEIVED BY: (SIGNATURE)		TIME 14:30		SAMPLE TEMPERATURE UPON RECEIPT _____ °C					
RELINQUISHED BY: (SIGNATURE)		DATE		RECEIVED BY: (SIGNATURE)		DATE		CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N SAMPLE(S) RECEIVED ON ICE Y OR N SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N					
RELINQUISHED BY: (SIGNATURE)		TIME		RECEIVED BY: (SIGNATURE)		TIME		DATE AND TIME TAKEN FROM SAMPLE BOTTLE _____					

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT SCI Engineering		PROJECT NUMBER 2018-0351.2T		PROJECT LOCATION Rockwood South MS		PURCHASE ORDER #		3 ANALYSIS REQUESTED				4 (FOR LAB USE ONLY) LOGIN # <u>GND1158</u> LOGGED BY: _____ CLIENT: <u>SCI Engineering</u> PROJECT: <u>Drinking Water Lead</u> PROJ. MGR.: <u>Chenise Lambert-Sykes</u> CUSTODY SEAL #: _____	
ADDRESS 130 Point West Blvd		PHONE NUMBER (314) 581-7570		E-MAIL ggriissom@sciengineering.com		DATE SHIPPED		+ DW Pb + Turb Check					
CITY STATE ZIP St. Charles, MO 63301		SAMPLER (PLEASE PRINT) Doug Ell		SAMPLER'S SIGNATURE 		MATRIX TYPES: WW-WASTEWATER DW-DRINKING WATER GW-GROUND WATER WWSL-SLUDGE NAS-NON AQUEOUS SOLID LCHT-LEACHATE OIL-OIL SO-SOIL SOL-SOLID							
CONTACT PERSON Glen Grissom													
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED					REMARKS	
RSMS-23		8/3/23	1937	X	DW	1	6	X	X				
RSMS-24		8/3/23	1938	X	DW	1	6	X	X				
RSMS-25		8/3/23	1939	X	DW	1	6	X	X				
RSMS-26		8/3/23	1943	X	DW	1	6	X	X				
RSMS-27		8/3/23	1944	X	DW	1	6	X	X				
RSMS-28		8/3/23	1945	X	DW	1	6	X	X				
RSMS-29		8/3/23	1948	X	DW	1	6	X	X				
RSMS-30		8/3/23	1949	X	DW	1	6	X	X				
RSMS-31		8/3/23	1950	X	DW	1	6	X	X				
RSMS-32		8/3/23	1953	X	DW	1	6	X	X				
RSMS-33		8/3/23	1954	X	DW	1	6	X	X				
CHEMICAL PRESERVATION CODES:		1-HCL	2-H2SO4	3-HNO3	4-NAOH	5-NA2S2O3	6-UNPRESERVED	7-OTHER					
5		TURNAROUND TIME REQUESTED (PLEASE CIRCLE) NORMAL RUSH (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE)			DATE RESULTS NEEDED		6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may <u>NOT</u> be acceptable to report to all regulatory authorities.						
RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE		EMAIL IF DIFFERENT FROM ABOVE:			PHONE # IF DIFFERENT FROM ABOVE:		PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) _____						
7		RELINQUISHED BY: (SIGNATURE) 		DATE 8/4/23	RECEIVED BY: (SIGNATURE) 		DATE 8-4-23	8					
RELINQUISHED BY: (SIGNATURE)		DATE	RECEIVED BY: (SIGNATURE)		DATE	COMMENTS: (FOR LAB USE ONLY)							
RELINQUISHED BY: (SIGNATURE)		DATE	RECEIVED BY: (SIGNATURE)		DATE	SAMPLE TEMPERATURE UPON RECEIPT _____ °C							
RELINQUISHED BY: (SIGNATURE)		DATE	RECEIVED BY: (SIGNATURE)		DATE	CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N SAMPLE(S) RECEIVED ON ICE Y OR N SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N							
RELINQUISHED BY: (SIGNATURE)		DATE	RECEIVED BY: (SIGNATURE)		DATE	DATE AND TIME TAKEN FROM SAMPLE BOTTLE _____							

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT SCI Engineering ADDRESS 130 Point West Blvd CITY STATE ZIP St. Charles, MO 63301 CONTACT PERSON Glen Grissom		PROJECT NUMBER 2018-0351.2T PHONE NUMBER (314) 581-7570 PROJECT LOCATION Rockwood South MS E-MAIL ggriissom@sciengineering.com		PURCHASE ORDER # DATE SHIPPED MATRIX TYPES: WW-WASTEWATER DW-DRINKING WATER GW-GROUND WATER WWSL-SLUDGE NAS-NON AQUEOUS SOLID LGHT-LEACHATE OIL-OIL SO-SOIL SOL-SOLID		3 ANALYSIS REQUESTED DW Pb Turb Check		4 (FOR LAB USE ONLY) LOGIN # <u>CH0158</u> LOGGED BY: _____ CLIENT: SCI Engineering PROJECT: Drinking Water Lead PROJ. MGR.: Chenise Lambert-Sykes CUSTODY SEAL #: _____	
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED	REMARKS	
RSMS-34		8/3/23	1954	X	DW	1	6	X	X
RSMS-35		8/3/23	1959	X	DW	1	6	X	X
RSMS-36		8/3/23	2000	X	DW	1	6	X	X
RSMS-37		8/3/23	2001	X	DW	1	6	X	X
RSMS-38		8/3/23	2003	X	DW	1	6	X	X
RSMS-39		8/3/23	2004	X	DW	1	6	X	X
RSMS-40		8/3/23	2005	X	DW	1	6	X	X
RSMS-41		8/3/23	2012	X	DW	1	6	X	X
RSMS-42		8/3/23	2013	X	DW	1	6	X	X
RSMS-43		8/3/23	2016	X	DW	1	6	X	X
RSMS-44		8/3/23	2020	X	DW	1	6	X	X
CHEMICAL PRESERVATION CODES: 1-HCL 2-H2SO4 3-HNO3 4-NAOH 5-NA2S2O3 6-UNPRESERVED 7-OTHER									
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) NORMAL RUSH (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:				6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may <u>NOT</u> be acceptable to report to all regulatory authorities. PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) _____		7 RELINQUISHED BY: (SIGNATURE) DATE 8/4/23 TIME 1300 RECEIVED BY: (SIGNATURE) DATE 8-4-23 TIME 14:30			
RELINQUISHED BY: (SIGNATURE)		DATE		RECEIVED BY: (SIGNATURE)		DATE		COMMENTS: (FOR LAB USE ONLY)	
RELINQUISHED BY: (SIGNATURE)		DATE		RECEIVED BY: (SIGNATURE)		DATE		SAMPLE TEMPERATURE UPON RECEIPT _____ °C	
RELINQUISHED BY: (SIGNATURE)		DATE		RECEIVED BY: (SIGNATURE)		DATE		CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N	
RELINQUISHED BY: (SIGNATURE)		DATE		RECEIVED BY: (SIGNATURE)		DATE		SAMPLE(S) RECEIVED ON ICE Y OR N	
RELINQUISHED BY: (SIGNATURE)		DATE		RECEIVED BY: (SIGNATURE)		DATE		SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N	
RELINQUISHED BY: (SIGNATURE)		DATE		RECEIVED BY: (SIGNATURE)		DATE		DATE AND TIME TAKEN FROM SAMPLE BOTTLE _____	

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD

STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT SCI Engineering ADDRESS 130 Point West Blvd CITY STATE ZIP St. Charles, MO 63301 CONTACT PERSON Glen Grissom		PROJECT NUMBER 2018-0351.2T PHONE NUMBER (314) 581-7570 PROJECT LOCATION Rockwood South MS E-MAIL ggrissom@sciengineering.com MATRICES: WW-WASTEWATER DW-DRINKING WATER GW-GROUND WATER WWSL-SLUDGE NAS-NON AQUEOUS SOLID LCHT-LEACHATE OIL-OIL SO-SOIL SOL-SOLID		3 ANALYSIS REQUESTED DW Pb Turb Check		4 (FOR LAB USE ONLY) LOGIN # <u>GHO158</u> LOGGED BY: CLIENT: <u>SCI Engineering</u> PROJECT: <u>Drinking Water Lead</u> PROJ. MGR.: <u>Chenise Lambert-Sykes</u> CUSTODY SEAL #: REMARKS					
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT)		DATE COLLECTED	TIME COLLECTED	SAMPLE TYPE GRAB COMP	MATRIX TYPE	BOTTLE COUNT	PRES CODE CLIENT PROVIDED				
RSMS-45		8/3/23	2021	X		DW	1	6	X	X	
RSMS-46		8/3/23	2024	X		DW	1	6	X	X	
RSMS-47		8/3/23	2027	X		DW	1	6	X	X	
RSMS-48		8/3/23	2029	X		DW	1	6	X	X	
RSMS-49		8/3/23	2032	X		DW	1	6	X	X	
RSMS-50		8/3/23	2035	X		DW	1	6	X	X	
RSMS-51		8/3/23	2036	X		DW	1	6	X	X	
RSMS-52		8/3/23	2037	X		DW	1	6	X	X	
RSMS-53		8/3/23	2039	X		DW	1	6	X	X	
RSMS-54		8/3/23	2040	X		DW	1	6	X	X	
CHEMICAL PRESERVATION CODES:		1 - HCL	2 - H2SO4	3 - HNO3	4 - NAOH	5 - NA2S2O3	6 - UNPRESERVED	7 - OTHER			
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) NORMAL RUSH (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:		DATE RESULTS NEEDED		6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities. PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS)							
7 RELINQUISHED BY: (SIGNATURE) DATE 8/4/23 TIME 1:30D RELINQUISHED BY: (SIGNATURE) DATE TIME RELINQUISHED BY: (SIGNATURE) DATE TIME		RECEIVED BY: (SIGNATURE) DATE TIME RECEIVED BY: (SIGNATURE) DATE TIME RECEIVED BY: (SIGNATURE) DATE TIME		8 COMMENTS: (FOR LAB USE ONLY) SAMPLE TEMPERATURE UPON RECEIPT °C CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N SAMPLE(S) RECEIVED ON ICE Y OR N SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N DATE AND TIME TAKEN FROM SAMPLE BOTTLE							



Pace Analytical Services, LLC

2231 W. Altorfer Drive

Peoria, IL 61615

(800)752-6651

October 24, 2023

Glenn Grissom
SCI Engineering
130 Point W. Blvd.
St. Charles, MO 63301

RE: 2010-5012.2T- RSMS

Dear Glenn Grissom:

Please find enclosed the analytical results for the **1** sample(s) the laboratory received on **10/11/23 4:30 pm** and logged in under work order **GJ01926**. All testing is performed according to our current TNI accreditations unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of Pace Analytical Services, LLC.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

Pace Analytical Services appreciates the opportunity to provide you with analytical expertise . We are always trying to improve our customer service and we welcome you to contact the General Manager, Lisa Grant, with any feedback you have about your experience with our laboratory at 309-683-1764 or lisa.grant@pacelabs.com.

A handwritten signature in black ink, appearing to read 'Chenise Lambert-Sykes'.

Chenise Lambert-Sykes
Project Manager
(314)432-0550
Chenise.Lambert-Sykes@pacelabs.com

**SAMPLE RECEIPT CHECK LIST**

Items not applicable will be marked as in compliance

Work Order GJ01926

YES	Samples received within temperature compliance when applicable
YES	COC present upon sample receipt
YES	COC completed & legible
YES	Sampler name & signature present
YES	Unique sample IDs assigned
YES	Sample collection location recorded
YES	Date & time collected recorded on COC
YES	Relinquished by client signature on COC
YES	COC & labels match
YES	Sample labels are legible
YES	Appropriate bottle(s) received
YES	Sufficient sample volume received
YES	Sample containers received undamaged
NO	Zero headspace, <6 mm present in VOA vials
NO	Trip blank(s) received
YES	All non-field analyses received within holding times
NO	Short hold time analysis
YES	Current PDC COC submitted
NO	Case narrative provided



Pace Analytical Services, LLC

2231 W. Altorfer Drive

Peoria, IL 61615

(800)752-6651

ANALYTICAL RESULTS

Sample: GJ01926-01

Name: RSMS - 10

Matrix: Drinking Water - Grab

Sampled: 10/09/23 20:41

Received: 10/11/23 16:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
<u>Total Metals - PIA</u>									
Lead	2.09	ug/L		10/23/23 09:00	1	1.00	10/23/23 10:38	KMC	EPA 200.8 REV 5.4



NOTES

Specifications regarding method revisions, method modifications, and calculations used for analysis are available upon request. Please contact your project manager.

* Not a TNI accredited analyte

Certifications

CHI - McHenry, IL - 4314-A W. Crystal Lake Road, McHenry, IL 60050

TNI Accreditation for Drinking Water and Wastewater Fields of Testing through IL EPA Accreditation No. 100279

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17556

PIA - Peoria, IL - 2231 W. Altorfer Drive, Peoria, IL 61615

TNI Accreditation for Drinking Water, Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. 100230

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17553

Drinking Water Certifications/Accreditations: Iowa (240); Kansas (E-10338); Missouri (870)

Wastewater Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

Solid and Hazardous Material Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO - 1805 W Sunset Street, Springfield, MO 65807

USEPA DMR-QA Program

STL - Hazelwood, MO - 944 Anglum Rd, Hazelwood, MO 63042

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through KS KDHE Certification No. E-10389

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. - 200080

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory, Registry No. 171050

Missouri Department of Natural Resources - Certificate of Approval for Microbiological Laboratory Service - No. 1050



Certified by: Chenise Lambert-Sykes, Project Manager

December 07, 2023

Brian Lieb
SCI Engineering, Inc.
130 Point West Boulevard
St. Charles, MO 63301
TEL: (314) 956-8240
FAX: (636) 949-8269



Illinois	100226
Kansas	E-10374
Louisiana	05002
Louisiana	05003
Oklahoma	9978

RE: 2018-0351.2A T200

WorkOrder: 23111931

Dear Brian Lieb:

TEKLAB, INC received 2 samples on 11/28/2023 11:35:00 AM for the analysis presented in the following report.

Samples are analyzed on an as received basis unless otherwise requested and documented. The sample results contained in this report relate only to the requested analytes of interest as directed on the chain of custody. NELAP accredited fields of testing are indicated by the letters NELAP under the Certification column. Unless otherwise documented within this report, Teklab Inc. analyzes samples utilizing the most current methods in compliance with 40CFR. All tests are performed in the Collinsville, IL laboratory unless otherwise noted in the Case Narrative.

All quality control criteria applicable to the test methods employed for this project have been satisfactorily met and are in accordance with NELAP except where noted. The following report shall not be reproduced, except in full, without the written approval of Teklab, Inc.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,



Patrick Riley
Project Manager
(618)344-1004 ex 44
patrickriley@teklabinc.com



Report Contents

<http://www.teklabinc.com/>

Client: SCI Engineering, Inc.

Work Order: 23111931

Client Project: 2018-0351.2A T200

Report Date: 07-Dec-23

This reporting package includes the following:

Cover Letter	1
Report Contents	2
Definitions	3
Case Narrative	5
Accreditations	6
Laboratory Results	7
Receiving Check List	8
Chain of Custody	Appended

Client: SCI Engineering, Inc.

Work Order: 23111931

Client Project: 2018-0351.2A T200

Report Date: 07-Dec-23

Abbr Definition

* Analytes on report marked with an asterisk are not NELAP accredited

CCV Continuing calibration verification is a check of a standard to determine the state of calibration of an instrument between recalibration.

CRQL A Client Requested Quantitation Limit is a reporting limit that varies according to customer request. The CRQL may not be less than the MDL.

DF Dilution factor is the dilution performed during analysis only and does not take into account any dilutions made during sample preparation. The reported result is final and includes all dilution factors.

DNI Did not ignite

DUP Laboratory duplicate is a replicate aliquot prepared under the same laboratory conditions and independently analyzed to obtain a measure of precision.

ICV Initial calibration verification is a check of a standard to determine the state of calibration of an instrument before sample analysis is initiated.

IDPH IL Dept. of Public Health

LCS Laboratory control sample is a sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes and analyzed exactly like a sample to establish intra-laboratory or analyst specific precision and bias or to assess the performance of all or a portion of the measurement system.

LCS D Laboratory control sample duplicate is a replicate laboratory control sample that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MBLK Method blank is a sample of a matrix similar to the batch of associated sample (when available) that is free from the analytes of interest and is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedures, and in which no target analytes or interferences should present at concentrations that impact the analytical results for sample analyses.

MDL "The method detection limit is defined as the minimum measured concentration of a substance that can be reported with 99% confidence that the measured concentration is distinguishable from method blank results."

MS Matrix spike is an aliquot of matrix fortified (spiked) with known quantities of specific analytes that is subjected to the entire analytical procedures in order to determine the effect of the matrix on an approved test method's recovery system. The acceptable recovery range is listed in the QC Package (provided upon request).

MSD Matrix spike duplicate means a replicate matrix spike that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MW Molecular weight

NC Data is not acceptable for compliance purposes

ND Not Detected at the Reporting Limit

NELAP NELAP Accredited

PQL Practical quantitation limit means the lowest level that can be reliably achieved within specified limits of precision and accuracy during routine laboratory operation conditions.

RL The reporting limit the lowest level that the data is displayed in the final report. The reporting limit may vary according to customer request or sample dilution. The reporting limit may not be less than the MDL.

RPD Relative percent difference is a calculated difference between two recoveries (ie. MS/MSD). The acceptable recovery limit is listed in the QC Package (provided upon request).

SPK The spike is a known mass of target analyte added to a blank sample or sub-sample; used to determine recovery deficiency or for other quality control purposes.

Surr Surrogates are compounds which are similar to the analytes of interest in chemical composition and behavior in the analytical process, but which are not normally found in environmental samples.

TIC Tentatively identified compound: Analytes tentatively identified in the sample by using a library search. Only results not in the calibration standard will be reported as tentatively identified compounds. Results for tentatively identified compounds that are not present in the calibration standard, but are assigned a specific chemical name based upon the library search, are calculated using total peak areas from reconstructed ion chromatograms and a response factor of one. The nearest Internal Standard is used for the calculation. The results of any TICs must be considered estimated, and are flagged with a "T". If the estimated result is above the calibration range it is flagged "ET"

TNTC Too numerous to count (> 200 CFU)

Client: SCI Engineering, Inc.

Work Order: 23111931

Client Project: 2018-0351.2A T200

Report Date: 07-Dec-23

Qualifiers

- | | |
|---|--|
| # - Unknown hydrocarbon | B - Analyte detected in associated Method Blank |
| C - RL shown is a Client Requested Quantitation Limit | E - Value above quantitation range |
| H - Holding times exceeded | I - Associated internal standard was outside method criteria |
| J - Analyte detected below quantitation limits | M - Manual Integration used to determine area response |
| ND - Not Detected at the Reporting Limit | R - RPD outside accepted recovery limits |
| S - Spike Recovery outside recovery limits | T - TIC(Tentatively identified compound) |
| X - Value exceeds Maximum Contaminant Level | |



Case Narrative

<http://www.teklabinc.com/>

Client: SCI Engineering, Inc.

Work Order: 23111931

Client Project: 2018-0351.2A T200

Report Date: 07-Dec-23

Cooler Receipt Temp: NA °C

Locations

Collinsville

Address 5445 Horseshoe Lake Road
Collinsville, IL 62234-7425
Phone (618) 344-1004
Fax (618) 344-1005
Email jhriley@teklabinc.com

Collinsville Air

Address 5445 Horseshoe Lake Road
Collinsville, IL 62234-7425
Phone (618) 344-1004
Fax (618) 344-1005
Email EHurley@teklabinc.com

Springfield

Address 3920 Pintail Dr
Springfield, IL 62711-9415
Phone (217) 698-1004
Fax (217) 698-1005
Email KKlostermann@teklabinc.com

Chicago

Address 1319 Butterfield Rd.
Downers Grove, IL 60515
Phone (630) 324-6855
Fax
Email arenner@teklabinc.com

Kansas City

Address 8421 Nieman Road
Lenexa, KS 66214
Phone (913) 541-1998
Fax (913) 541-1998
Email jhriley@teklabinc.com

Client: SCI Engineering, Inc.**Work Order:** 23111931**Client Project:** 2018-0351.2A T200**Report Date:** 07-Dec-23

State	Dept	Cert #	NELAP	Exp Date	Lab
Illinois	IEPA	100226	NELAP	1/31/2024	Collinsville
Kansas	KDHE	E-10374	NELAP	4/30/2024	Collinsville
Louisiana	LDEQ	05002	NELAP	6/30/2024	Collinsville
Louisiana	LDEQ	05003	NELAP	6/30/2024	Collinsville
Oklahoma	ODEQ	9978	NELAP	8/31/2024	Collinsville
Arkansas	ADEQ	88-0966		3/14/2024	Collinsville
Illinois	IDPH	17584		5/31/2025	Collinsville
Iowa	IDNR	430		6/1/2024	Collinsville
Kentucky	UST	0073		1/31/2024	Collinsville
Missouri	MDNR	00930		5/31/2023	Collinsville
Missouri	MDNR	930		1/31/2025	Collinsville



Laboratory Results

<http://www.teklabinc.com/>

Client: SCI Engineering, Inc.

Work Order: 23111931

Client Project: 2018-0351.2A T200

Report Date: 07-Dec-23

Matrix: DRINKING WATER

Sample ID	Client Sample ID	Certification	Qual	RL	Result	Units	DF	Date Analyzed	Date Collected
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)									
Lead									
23111931-001A	RSMS-39R	NELAP		1.0	1.0	µg/L	1	12/04/2023 16:56	11/22/2023 21:19
23111931-002A	RSMS-39(2nd)	NELAP		1.0	< 1.0	µg/L	1	12/04/2023 17:00	11/22/2023 21:20



Receiving Check List

<http://www.teklabinc.com/>

Client: SCI Engineering, Inc.

Work Order: 23111931

Client Project: 2018-0351.2A T200

Report Date: 07-Dec-23

Carrier: Craig McKinney

Received By: HAW

Completed by:

Reviewed by:

On:

On:

28-Nov-23

28-Nov-23

Mary E Kemp

Ellie Hopkins

Pages to follow:

Chain of custody

1

Extra pages included

0

Shipping container/cooler in good condition?

Yes ☒

No ☐

Not Present ☐

Temp °C

NA

Type of thermal preservation?

None ☒

Ice ☐

Blue Ice ☐

Dry Ice

☐

Chain of custody present?

Yes ☒

No ☐

Chain of custody signed when relinquished and received?

Yes ☒

No ☐

Chain of custody agrees with sample labels?

Yes ☒

No ☐

Samples in proper container/bottle?

Yes ☒

No ☐

Sample containers intact?

Yes ☒

No ☐

Sufficient sample volume for indicated test?

Yes ☒

No ☐

All samples received within holding time?

Yes ☒

No ☐

Reported field parameters measured:

Field ☐

Lab ☐

NA ☒

Container/Temp Blank temperature in compliance?

Yes ☒

No ☐

When thermal preservation is required, samples are compliant with a temperature between 0.1°C - 6.0°C, or when samples are received on ice the same day as collected.

Water – at least one vial per sample has zero headspace?

Yes ☐

No ☐

No VOA vials ☒

Water - TOX containers have zero headspace?

Yes ☐

No ☐

No TOX containers ☒

Water - pH acceptable upon receipt?

Yes ☒

No ☐

NA ☐

NPDES/CWA TCN interferences checked/treated in the field?

Yes ☐

No ☐

NA ☒

Any No responses must be detailed below or on the COC.

Samples were checked for turbidity and then preserved with nitric acid upon arrival in the laboratory. - MaryKemp - 11/28/2023 1:29:15 PM

Pg 1 of 1 Workorder # 2311931

Client: SCI Engineering INC
Address: 130 Point West Blvd
City/State/Zip: Saint Charles/MO/63301
Contact: Brian Lieb Phone: 636-949-8200
Email: blieb@sciengineering.com Fax: _____

Samples on: ☐ ICE ☐ BLUE ICE ☒ NO ICE NA °C
Preserved in: ☐ LAB ☐ FIELD FOR LAB USE ONLY

LAB NOTES:

Client Comments:

Must Meet 5 PPB

Are these samples known to be involved in litigation? If yes, a surcharge will apply: ☐ Yes ☒ No

Are these samples known to be hazardous? ☐ Yes ☒ No

Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section: ☒ Yes ☐ No

PROJECT NAME/NUMBER

2018-0351.2A T200

SAMPLE COLLECTOR'S NAME

[E] Box ✓ 9/15/2

RESULTS REQUESTED

 Standard

☐ 1-2 Day (100% Surcharge)

☐ Other☐ 3 Day (50% Surcharge)

BILLING INSTRUCTIONS

567

and Type of Containers

INDICATE ANALYSIS REQUESTED

# and Type of Containers	INDICATE ANALYSIS REQUESTED	
Turb Check	✓	✓
DW Pb	✓	✓
Other		
TSP		
NaHSO4		
MeOH		
HCL		
H2SO4		
NaOH		
HNO3		
UNP	1	1

[illegible]

Relinquished By	Date/Time	Received By	Date/Time
<i>[Signature]</i>	11/22/23 22:30	<i>[Signature]</i>	10/28/23 102
<i>[Signature]</i>	11/28/23 1135	<i>[Signature]</i>	11/28/23 1135

*The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions

HW M28