



SCI ENGINEERING, INC.

EARTH • SCIENCE • SOLUTIONS

GEOTECHNICAL
ENVIRONMENTAL
NATURAL RESOURCES
CULTURAL RESOURCES
CONSTRUCTION SERVICES

July 13, 2026

Patrick McCart
Rockwood School District
17146 Manchester Road
Wildwood, Missouri 63040

RE: Lead in Drinking Water Report - Resample
Pathways Wellness Center/Admin Annex A
500 North Central Avenue
Eureka, Missouri
SCI No. 2018-0351.2A Task 200

Dear Patrick McCart:

INTRODUCTION

SCI Engineering, Inc. (SCI) is pleased to submit this report summarizing lead in drinking water testing activities performed on July 18 and 28, 2023, and subsequent resampling conducted on March 29, and November 27, 2024, July 7, 2025, and March 20, 2026. The purpose of the sampling activities was to screen for elevated levels of lead in the drinking water at potable water sources throughout the above-referenced structure.

Following the initial testing, the school district performed remediation on fixtures which previously exceeded the action level. The remediated fixtures were then resampled, the results of which are summarized herein.

The drinking water survey is intended to satisfy the requirements for the “Get the Lead Out of School Drinking Water Act” (GTLOSDWA), Section 160.077 administered by the Missouri Department of Health and Senior Services. Potable water sources to be tested were identified by the school district prior to SCI’s field activities.

LIMITATIONS

SCI’s testing activities were limited to locations identified by the school district. If any additional potable water sources need testing, please contact SCI, and we will make arrangements for testing of these fixtures. Potable water sources that were not sampled will need a sign placed near each fixture informing students and faculty that it is not to be used as a drinking water source.

During the course of performing the survey of the structure, the sink in the first-floor kitchen of Pathways Wellness Center was not operational, and therefore not sampled. If this fixture is made operational, it should be sampled or labeled non-potable. SCI was able to sample all other locations identified by the school district.

DRINKING WATER SURVEY

SCI collected “first draw” samples which consisted of collecting a water sample from each fixture or sample location after it remained stagnant for at least eight hours. Prior to sampling, SCI first mobilized to the site to flush the identified potable water fixtures throughout the structure. Once each fixture was flushed, a sign was placed on the fixture indicating it should not be used. SCI then revisited the site, after a minimum of eight hours, to collect water samples from the fixtures.

On July 18 and 28, 2023, SCI collected 10 drinking water samples (PWC-1 through PWC-10) from various water fixtures located throughout the structures and submitted them for analytical testing. During this sampling event, 4 sample locations exceeded the action level (AL) of 5.0 micrograms lead per liter of water. These fixtures were taken out of service until remediation activities could be completed.

During SCI’s resampling event on March 29 and November 27, 2024, drinking water samples were collected from the fixtures which exceeded 5.0 micrograms lead per liter of water. During this resampling event, 3 of the sample fixtures were below the AL and were returned to service. The sample was above the AL, and further remediation activities were recommended.

During SCI’s resampling event on July 7, 2025, the fixture which had previously exceeded the AL was retested. During this resampling event, the fixture still exceeded the AL, and further remediation activities were recommended.

During SCI’s resampling event on March 20, 2026, the fixture which had previously exceeded the AL was retested. During this resampling event, the fixture was below the AL and was returned to service.

All drinking water samples were analyzed for total lead by U.S. EPA Method 200.8. SCI collected a minimum of 250 milliliters of water from each location. Sampled water was containerized in laboratory-provided sample containers and shipped to the accredited lab using standard chain-of-custody procedures.

The drinking water samples were analyzed for lead in accordance with the GTLOSDWA Section 160.077, which establishes an action level (AL) of 5 parts per billion (ppb). The drinking water samples which initially exceeded the AL are identified in Table 1, attached. Additionally, the results of SCI’s resampling efforts are included in the right-hand columns below. Results in bold from SCI’s resampling indicate a result greater than the AL. A copy of the analytical test results and chain-of-custody for all samples is enclosed.

CONCLUSION AND RECOMMENDATIONS

As previously mentioned, no drinking water samples exceeded the AL of 5 ppb. Therefore, all tested fixtures are compliant per GTLOSDWA and should be tested every five years.

Within seven business days after receiving this report, the school district shall contact parents and staff via written notification which shall include the following:

- The test results and a summary that explains such results;
- A description of any remedial steps taken;

- A description of general health effects of lead contamination and community specific resources; and
- If there is not enough water to meet the drinking water needs of the students, teachers, and staff, bottled water shall be provided.

Additionally, within two weeks of receiving this report, the results and any lead remediation plans must be made available on the school's website.

This report, and subsequent annual testing reports, must be submitted to the Missouri Department of Health and Senior Services, Healthy Drinking Water Unit, PO Box 570, Jefferson City, MO 65102-0570.


SCI appreciates the opportunity to be of service to you on this project. Please contact us if you have any questions or comments regarding the information provided.

Respectfully,

SCI ENGINEERING, INC.



Ethan D. Boyer
Staff Scientist



Jessica B. Keeven, CHMM
Environmental Services Manager

EDB/GBK/bmw

Enclosures

Lead Testing Results
Table 1 – Lead in Drinking Water Results



Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

August 18, 2023

Glenn Grissom
SCI Engineering
130 Point W. Blvd.
St. Charles, MO 63301

RE: 2018-0351.2T-Administrative Office

Dear Glenn Grissom:

Please find enclosed the **revised** analytical results for the **5** sample(s) the laboratory received on **7/20/23 3:25 pm** and logged in under work order **GG03858**. All testing is performed according to our current TNI accreditations unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of Pace Analytical Services, LLC.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

Pace Analytical Services appreciates the opportunity to provide you with analytical expertise. We are always trying to improve our customer service and we welcome you to contact the General Manager, Lisa Grant, with any feedback you have about your experience with our laboratory at 309-683-1764 or lisa.grant@pacelabs.com.

A handwritten signature in black ink, appearing to read 'Chenise Lambert-Sykes'.

Chenise Lambert-Sykes
Project Manager
(314)432-0550
Chenise.Lambert-Sykes@pacelabs.com

**SAMPLE RECEIPT CHECK LIST**

Items not applicable will be marked as in compliance

Work Order GG03858

YES	Samples received within temperature compliance when applicable
YES	COC present upon sample receipt
YES	COC completed & legible
YES	Sampler name & signature present
YES	Unique sample IDs assigned
YES	Sample collection location recorded
YES	Date & time collected recorded on COC
YES	Relinquished by client signature on COC
YES	COC & labels match
YES	Sample labels are legible
YES	Appropriate bottle(s) received
YES	Sufficient sample volume received
YES	Sample containers received undamaged
YES	Zero headspace, <6 mm present in VOA vials
NO	Trip blank(s) received
YES	All non-field analyses received within holding times
NO	Short hold time analysis
YES	Current PDC COC submitted
NO	Case narrative provided



Pace Analytical Services, LLC

2231 W. Altorfer Drive

Peoria, IL 61615

(800)752-6651

Case Narrative

This report was revised to update the sample IDs, as previously requested by the client. The updated chain of custody is also included.



ANALYTICAL RESULTS

Sample: GG03858-01
Name: PWC-6
Matrix: Drinking Water - Grab

Sampled: 07/18/23 18:22

Received: 07/20/23 15:25

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		08/15/23 13:19	1	1.00	08/16/23 17:31	KMC	EPA 200.8 REV 5.4

Sample: GG03858-02
Name: PWC-7
Matrix: Drinking Water - Grab

Sampled: 07/18/23 18:26

Received: 07/20/23 15:25

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		08/15/23 13:19	1	1.00	08/16/23 17:32	KMC	EPA 200.8 REV 5.4

Sample: GG03858-03
Name: PWC-8
Matrix: Drinking Water - Grab

Sampled: 07/18/23 18:31

Received: 07/20/23 15:25

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	6.33	ug/L		08/15/23 13:19	1	1.00	08/16/23 17:34	KMC	EPA 200.8 REV 5.4

Sample: GG03858-04
Name: PWC-9
Matrix: Drinking Water - Grab

Sampled: 07/18/23 18:24

Received: 07/20/23 15:25

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		08/15/23 13:19	1	1.00	08/16/23 17:35	KMC	EPA 200.8 REV 5.4



Pace Analytical Services, LLC

2231 W. Altorfer Drive

Peoria, IL 61615

(800)752-6651

ANALYTICAL RESULTS

Sample: GG03858-05

Name: PWC-10

Matrix: Drinking Water - Grab

Sampled: 07/18/23 18:32

Received: 07/20/23 15:25

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
<u>Total Metals - PIA</u>									
Lead	< 1.00	ug/L		08/15/23 13:19	1	1.00	08/16/23 17:40	KMC	EPA 200.8 REV 5.4



QC SAMPLE RESULTS

Parameter	Result	Unit	Qual	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit
<u>Batch B341306 - DW 200.8 no prep - EPA 200.8 REV 5.4</u>									
Blank (B341306-BLK1)				Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	< 1.00	ug/L							
LCS (B341306-BS1)				Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	51.0	ug/L		50.00		102	85-115		
Matrix Spike (B341306-MS1)				Sample: GG03848-23 Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	65.2	ug/L		50.00	3.65	123	70-130		
Matrix Spike (B341306-MS2)				Sample: GG03848-33 Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	64.8	ug/L		50.00	0.481	129	70-130		
Matrix Spike (B341306-MS3)				Sample: GG03858-04 Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	52.0	ug/L		50.00	0.270	103	70-130		
Matrix Spike (B341306-MS4)				Sample: GG03861-09 Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	97.3	ug/L	Q1	50.00	30.4	134	70-130		
Matrix Spike (B341306-MS5)				Sample: GG03993-06 Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	65.7	ug/L		50.00	1.22	129	70-130		
Matrix Spike (B341306-MS6)				Sample: GG03993-24 Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	49.0	ug/L		50.00	0.927	96	70-130		
Matrix Spike (B341306-MS7)				Sample: GG03848-39 Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	51.5	ug/L		50.00	1.66	100	70-130		
Matrix Spike (B341306-MS8)				Sample: GG03993-62 Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	63.3	ug/L		50.00	1.59	123	70-130		
Matrix Spike (B341306-MS9)				Sample: GG03993-80 Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	61.5	ug/L		50.00	8.38	106	70-130		
Matrix Spike (B341306-MSA)				Sample: GG03993-96 Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	51.4	ug/L		50.00	0.663	102	70-130		
Matrix Spike (B341306-MSB)				Sample: GG03931-09 Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	69.6	ug/L		50.00	0.563	138	70-130		
Matrix Spike (B341306-MSC)				Sample: GG03994-02 Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	72.5	ug/L		50.00	0.472	144	70-130		
Matrix Spike (B341306-MSD)				Sample: GG03994-12 Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	83.6	ug/L		50.00	0.593	166	70-130		
Matrix Spike Dup (B341306-MSD1)				Sample: GG03848-23 Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	77.9	ug/L	Q2	50.00	3.65	149	70-130	18	20
Matrix Spike Dup (B341306-MSD2)				Sample: GG03848-33 Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	69.8	ug/L	Q2	50.00	0.481	139	70-130	7	20
Matrix Spike Dup (B341306-MSD3)				Sample: GG03858-04 Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	60.5	ug/L		50.00	0.270	120	70-130	15	20
Matrix Spike Dup (B341306-MSD4)				Sample: GG03861-09 Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	89.1	ug/L		50.00	30.4	117	70-130	9	20
Matrix Spike Dup (B341306-MSD5)				Sample: GG03993-06 Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	59.6	ug/L		50.00	1.22	117	70-130	10	20
Matrix Spike Dup (B341306-MSD6)				Sample: GG03993-24 Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	48.0	ug/L		50.00	0.927	94	70-130	2	20
Matrix Spike Dup (B341306-MSD7)				Sample: GG03848-39 Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	51.7	ug/L		50.00	1.66	100	70-130	0.4	20



QC SAMPLE RESULTS

Parameter	Result	Unit	Qual	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit
Matrix Spike Dup (B341306-MSD8)	Sample: GG03993-62			Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	51.8	ug/L		50.00	1.59	100	70-130	20	20
Matrix Spike Dup (B341306-MSD9)	Sample: GG03993-80			Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	65.2	ug/L		50.00	8.38	114	70-130	6	20
Matrix Spike Dup (B341306-MSDA)	Sample: GG03993-96			Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	53.1	ug/L		50.00	0.663	105	70-130	3	20
Matrix Spike Dup (B341306-MSDB)	Sample: GG03931-09			Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	76.1	ug/L		50.00	0.563	151	70-130	9	20
Matrix Spike Dup (B341306-MSDC)	Sample: GG03994-02			Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	68.6	ug/L		50.00	0.472	136	70-130	6	20
Matrix Spike Dup (B341306-MSDD)	Sample: GG03994-12			Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	45.4	ug/L		50.00	0.593	90	70-130	59	20
Matrix Spike Dup (B341306-MSDE)	Sample: GG03992-03			Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	51.1	ug/L		50.00	1.59	99	70-130	2	20
Matrix Spike Dup (B341306-MSDF)	Sample: GG04148-03			Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	48.8	ug/L		50.00	1.58	94	70-130	0.4	20
Matrix Spike (B341306-MSE)	Sample: GG03992-03			Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	50.2	ug/L		50.00	1.59	97	70-130		
Matrix Spike (B341306-MSF)	Sample: GG04148-03			Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	48.6	ug/L		50.00	1.58	94	70-130		



NOTES

Specifications regarding method revisions, method modifications, and calculations used for analysis are available upon request. Please contact your project manager.

* Not a TNI accredited analyte

Certifications

CHI - McHenry, IL - 4314-A W. Crystal Lake Road, McHenry, IL 60050

TNI Accreditation for Drinking Water and Wastewater Fields of Testing through IL EPA Accreditation No. 100279

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17556

PIA - Peoria, IL - 2231 W. Altorfer Drive, Peoria, IL 61615

TNI Accreditation for Drinking Water, Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. 100230

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17553

Drinking Water Certifications/Accreditations: Iowa (240); Kansas (E-10338); Missouri (870)

Wastewater Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

Solid and Hazardous Material Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO - 1805 W Sunset Street, Springfield, MO 65807

USEPA DMR-QA Program

STL - Hazelwood, MO - 944 Anglum Rd, Hazelwood, MO 63042

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through KS KDHE Certification No. E-10389

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. - 200080

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory, Registry No. 171050

Missouri Department of Natural Resources - Certificate of Approval for Microbiological Laboratory Service - No. 1050

Qualifiers

Q1 Matrix Spike failed % recovery acceptance limits. The associated blank spike recovery was acceptable.

Q2 Matrix Spike Duplicate failed % recovery acceptance limits. The associated blank spike recovery was acceptable.

Certified by: Chenise Lambert-Sykes, Project Manager



STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

Page 9 of 11

1 **CLIENT:** Client's company name
ADDRESS: Client's mailing address
CITY, STATE, ZIP: Client's city, state and zip code for mailing
CONTACT PERSON: Person to receive results
PROJECT NUMBER: Client's reference to the project or work involved with these samples.
PROJECT LOCATION: Client's location of project
PURCHASE ORDER NUMBER: Client's invoicing information
PHONE NUMBER: Client's contact phone number
E-MAIL: Client's e-mail for correspondence and final report
DATE SHIPPED: Month, date and year samples were shipped or delivered to the lab
SAMPLER: Printed name of sample collector
SAMPLER'S SIGNATURE: Signature of sample collector
REGULATORY PROGRAM: Circle regulatory program if applicable.
STATE WHERE SAMPLES COLLECTED: Enter the state if different from client address

2 **SAMPLE DESCRIPTION:** The unique sample description you want to appear on the analytical report
DATE COLLECTED: Date sample was collected. For composite samples, this is typically the date when the last aliquot was added.
TIME COLLECTED: Time sample was collected. For composite samples, this is typically the time when the last aliquot was added.
SAMPLE TYPE: Place a check mark in the box marked "GRAB" if the sample was collected at one time from one specific location. Place a check mark in the box marked "COMP" if the sample is a composite of samples collected at one or more times or locations and combined to make one sample.
MATRIX TYPE: From field above. If "OTHER" please identify
BOTLE COUNT: Total number of containers submitted for the samples
PRESERVATION CODE: Indicate bottle preservative using the codes on the front of the COC for non-PACE bottles, provided by the client.

3 **ANALYSIS REQUESTED:** Write the analysis name (or an abbreviation), the name of a group of tests, or the method number you would like us to perform. Examples are BOD, TCLP Metals, PCBs, Method 624, etc. Place a check mark in the small boxes that correspond to the sample(s) on which you want these tests performed.

REMARKS: List special instructions about the sample here. This space can also be used for listing additional analyses, or to request an extra copy of the report to be sent to an alternate person/address.

4 To be completed by laboratory personnel.

5 **TURNAROUND TIME REQUESTED:** Circle "NORMAL" if you want routine 10 working day TAT. If faster results are needed circle "RUSH", indicated the due date requested, and, if possible, call the lab in advance to schedule this work. Surcharges may apply for non-routine turnaround times.
RUSH RESULTS VIA: Choose method by which you would like to receive the RUSH results by circling either "PHONE" or E-MAIL". List the appropriate number/e-mail if different from that listed in section 1.

6 Place your initials on the line to give the lab permission to proceed with analysis without calling you regarding a sample nonconformance. If the sample does not meet the Sample Acceptance Policy requirements then the appropriate case narrative and/or data qualifiers will be added to the corresponding analysis and may not be acceptable to use for regulatory purposes. Contact your project manager for further information or to obtain a copy of the Sample Acceptance Policy.

Summarized Sample Acceptance Policy Requirements:

- Proper, full and completed chain-of-custody documentation
- Readable unique sample container identification written in indelible ink
- Appropriate sample container
- Sufficient sample volume to perform requested tests
- Received within required holding time
- Received within temperature preservation requirements
- Sample containers received in good condition (not leaking or broken)
- Any custody seal intact
- Properly preserved, and
- No headspace in volatile water samples

A data qualifier and/or case narrative will be added to the final test report when the above sample acceptance requirements are not met.

BOX 6 CANNOT BE USED FOR DRINKING WATER COMPLIANCE SAMPLES.

7 **RELINQUISHED BY/RECEIVED BY:** This form must be signed each time the sample(s) changes hands. Chain-of-Custody seals are available upon request if needed.

8 To be completed by laboratory personnel.

Sample Acceptance Policy – Receiving facility's specific policy available from your project manager.

SERVING YOU IN THE FOLLOWING LOCATIONS

2231 W Altorfer Dr
Peoria, IL 61615
309-692-9688

944 Anglum Road
Hazelwood, MO 63042
314-432-0550

1805 W Sunset St.
Springfield, MO 65807
417-964-8924

4314-A Crystal Lake Rd
McHenry, IL 60050
815-344-4044

Thank you for using Pace Analytical Services, LLC
Please call 800-752-6651 if you have any questions about completing this form.



Pace Analytical Services, LLC
2231 W. Altorfer Drive
Peoria, IL 61615
(800)752-6651

August 18, 2023

Glenn Grissom
SCI Engineering
130 Point W. Blvd.
St. Charles, MO 63301

RE: 2018-0351.2T-Administrative Office

Dear Glenn Grissom:

Please find enclosed the **revised** analytical results for the **5** sample(s) the laboratory received on **7/20/23 3:25 pm** and logged in under work order **GG03858**. All testing is performed according to our current TNI accreditations unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of Pace Analytical Services, LLC.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

Pace Analytical Services appreciates the opportunity to provide you with analytical expertise. We are always trying to improve our customer service and we welcome you to contact the General Manager, Lisa Grant, with any feedback you have about your experience with our laboratory at 309-683-1764 or lisa.grant@pacelabs.com.

A handwritten signature in black ink, appearing to read 'Chenise Lambert-Sykes'.

Chenise Lambert-Sykes
Project Manager
(314)432-0550
Chenise.Lambert-Sykes@pacelabs.com

**SAMPLE RECEIPT CHECK LIST**

Items not applicable will be marked as in compliance

Work Order GG03858

YES	Samples received within temperature compliance when applicable
YES	COC present upon sample receipt
YES	COC completed & legible
YES	Sampler name & signature present
YES	Unique sample IDs assigned
YES	Sample collection location recorded
YES	Date & time collected recorded on COC
YES	Relinquished by client signature on COC
YES	COC & labels match
YES	Sample labels are legible
YES	Appropriate bottle(s) received
YES	Sufficient sample volume received
YES	Sample containers received undamaged
YES	Zero headspace, <6 mm present in VOA vials
NO	Trip blank(s) received
YES	All non-field analyses received within holding times
NO	Short hold time analysis
YES	Current PDC COC submitted
NO	Case narrative provided



Pace Analytical Services, LLC

2231 W. Altorfer Drive

Peoria, IL 61615

(800)752-6651

Case Narrative

This report was revised to update the sample IDs, as previously requested by the client. The updated chain of custody is also included.



ANALYTICAL RESULTS

Sample: GG03858-01
Name: PWC-6
Matrix: Drinking Water - Grab

Sampled: 07/18/23 18:22

Received: 07/20/23 15:25

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		08/15/23 13:19	1	1.00	08/16/23 17:31	KMC	EPA 200.8 REV 5.4

Sample: GG03858-02
Name: PWC-7
Matrix: Drinking Water - Grab

Sampled: 07/18/23 18:26

Received: 07/20/23 15:25

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		08/15/23 13:19	1	1.00	08/16/23 17:32	KMC	EPA 200.8 REV 5.4

Sample: GG03858-03
Name: PWC-8
Matrix: Drinking Water - Grab

Sampled: 07/18/23 18:31

Received: 07/20/23 15:25

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	6.33	ug/L		08/15/23 13:19	1	1.00	08/16/23 17:34	KMC	EPA 200.8 REV 5.4

Sample: GG03858-04
Name: PWC-9
Matrix: Drinking Water - Grab

Sampled: 07/18/23 18:24

Received: 07/20/23 15:25

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		08/15/23 13:19	1	1.00	08/16/23 17:35	KMC	EPA 200.8 REV 5.4



Pace Analytical Services, LLC

2231 W. Altorfer Drive

Peoria, IL 61615

(800)752-6651

ANALYTICAL RESULTS

Sample: GG03858-05

Name: PWC-10

Matrix: Drinking Water - Grab

Sampled: 07/18/23 18:32

Received: 07/20/23 15:25

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
<u>Total Metals - PIA</u>									
Lead	< 1.00	ug/L		08/15/23 13:19	1	1.00	08/16/23 17:40	KMC	EPA 200.8 REV 5.4



QC SAMPLE RESULTS

Parameter	Result	Unit	Qual	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit
<u>Batch B341306 - DW 200.8 no prep - EPA 200.8 REV 5.4</u>									
Blank (B341306-BLK1)				Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	< 1.00	ug/L							
LCS (B341306-BS1)				Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	51.0	ug/L		50.00		102	85-115		
Matrix Spike (B341306-MS1)				Sample: GG03848-23 Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	65.2	ug/L		50.00	3.65	123	70-130		
Matrix Spike (B341306-MS2)				Sample: GG03848-33 Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	64.8	ug/L		50.00	0.481	129	70-130		
Matrix Spike (B341306-MS3)				Sample: GG03858-04 Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	52.0	ug/L		50.00	0.270	103	70-130		
Matrix Spike (B341306-MS4)				Sample: GG03861-09 Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	97.3	ug/L	Q1	50.00	30.4	134	70-130		
Matrix Spike (B341306-MS5)				Sample: GG03993-06 Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	65.7	ug/L		50.00	1.22	129	70-130		
Matrix Spike (B341306-MS6)				Sample: GG03993-24 Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	49.0	ug/L		50.00	0.927	96	70-130		
Matrix Spike (B341306-MS7)				Sample: GG03848-39 Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	51.5	ug/L		50.00	1.66	100	70-130		
Matrix Spike (B341306-MS8)				Sample: GG03993-62 Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	63.3	ug/L		50.00	1.59	123	70-130		
Matrix Spike (B341306-MS9)				Sample: GG03993-80 Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	61.5	ug/L		50.00	8.38	106	70-130		
Matrix Spike (B341306-MSA)				Sample: GG03993-96 Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	51.4	ug/L		50.00	0.663	102	70-130		
Matrix Spike (B341306-MSB)				Sample: GG03931-09 Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	69.6	ug/L		50.00	0.563	138	70-130		
Matrix Spike (B341306-MSC)				Sample: GG03994-02 Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	72.5	ug/L		50.00	0.472	144	70-130		
Matrix Spike (B341306-MSD)				Sample: GG03994-12 Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	83.6	ug/L		50.00	0.593	166	70-130		
Matrix Spike Dup (B341306-MSD1)				Sample: GG03848-23 Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	77.9	ug/L	Q2	50.00	3.65	149	70-130	18	20
Matrix Spike Dup (B341306-MSD2)				Sample: GG03848-33 Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	69.8	ug/L	Q2	50.00	0.481	139	70-130	7	20
Matrix Spike Dup (B341306-MSD3)				Sample: GG03858-04 Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	60.5	ug/L		50.00	0.270	120	70-130	15	20
Matrix Spike Dup (B341306-MSD4)				Sample: GG03861-09 Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	89.1	ug/L		50.00	30.4	117	70-130	9	20
Matrix Spike Dup (B341306-MSD5)				Sample: GG03993-06 Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	59.6	ug/L		50.00	1.22	117	70-130	10	20
Matrix Spike Dup (B341306-MSD6)				Sample: GG03993-24 Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	48.0	ug/L		50.00	0.927	94	70-130	2	20
Matrix Spike Dup (B341306-MSD7)				Sample: GG03848-39 Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	51.7	ug/L		50.00	1.66	100	70-130	0.4	20



QC SAMPLE RESULTS

Parameter	Result	Unit	Qual	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit
Matrix Spike Dup (B341306-MSD8)	Sample: GG03993-62			Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	51.8	ug/L		50.00	1.59	100	70-130	20	20
Matrix Spike Dup (B341306-MSD9)	Sample: GG03993-80			Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	65.2	ug/L		50.00	8.38	114	70-130	6	20
Matrix Spike Dup (B341306-MSDA)	Sample: GG03993-96			Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	53.1	ug/L		50.00	0.663	105	70-130	3	20
Matrix Spike Dup (B341306-MSDB)	Sample: GG03931-09			Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	76.1	ug/L		50.00	0.563	151	70-130	9	20
Matrix Spike Dup (B341306-MSDC)	Sample: GG03994-02			Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	68.6	ug/L		50.00	0.472	136	70-130	6	20
Matrix Spike Dup (B341306-MSDD)	Sample: GG03994-12			Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	45.4	ug/L		50.00	0.593	90	70-130	59	20
Matrix Spike Dup (B341306-MSDE)	Sample: GG03992-03			Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	51.1	ug/L		50.00	1.59	99	70-130	2	20
Matrix Spike Dup (B341306-MSDF)	Sample: GG04148-03			Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	48.8	ug/L		50.00	1.58	94	70-130	0.4	20
Matrix Spike (B341306-MSE)	Sample: GG03992-03			Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	50.2	ug/L		50.00	1.59	97	70-130		
Matrix Spike (B341306-MSF)	Sample: GG04148-03			Prepared: 08/15/23 Analyzed: 08/16/23					
Lead	48.6	ug/L		50.00	1.58	94	70-130		



NOTES

Specifications regarding method revisions, method modifications, and calculations used for analysis are available upon request. Please contact your project manager.

* Not a TNI accredited analyte

Certifications

CHI - McHenry, IL - 4314-A W. Crystal Lake Road, McHenry, IL 60050

TNI Accreditation for Drinking Water and Wastewater Fields of Testing through IL EPA Accreditation No. 100279

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17556

PIA - Peoria, IL - 2231 W. Altorfer Drive, Peoria, IL 61615

TNI Accreditation for Drinking Water, Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. 100230

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17553

Drinking Water Certifications/Accreditations: Iowa (240); Kansas (E-10338); Missouri (870)

Wastewater Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

Solid and Hazardous Material Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO - 1805 W Sunset Street, Springfield, MO 65807

USEPA DMR-QA Program

STL - Hazelwood, MO - 944 Anglum Rd, Hazelwood, MO 63042

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through KS KDHE Certification No. E-10389

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. - 200080

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory, Registry No. 171050

Missouri Department of Natural Resources - Certificate of Approval for Microbiological Laboratory Service - No. 1050

Qualifiers

Q1 Matrix Spike failed % recovery acceptance limits. The associated blank spike recovery was acceptable.

Q2 Matrix Spike Duplicate failed % recovery acceptance limits. The associated blank spike recovery was acceptable.

Certified by: Chenise Lambert-Sykes, Project Manager



STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

Page 9 of 11

1 **CLIENT:** Client's company name
ADDRESS: Client's mailing address
CITY, STATE, ZIP: Client's city, state and zip code for mailing
CONTACT PERSON: Person to receive results
PROJECT NUMBER: Client's reference to the project or work involved with these samples.
PROJECT LOCATION: Client's location of project
PURCHASE ORDER NUMBER: Client's invoicing information
PHONE NUMBER: Client's contact phone number
E-MAIL: Client's e-mail for correspondence and final report
DATE SHIPPED: Month, date and year samples were shipped or delivered to the lab
SAMPLER: Printed name of sample collector
SAMPLER'S SIGNATURE: Signature of sample collector
REGULATORY PROGRAM: Circle regulatory program if applicable.
STATE WHERE SAMPLES COLLECTED: Enter the state if different from client address

2 **SAMPLE DESCRIPTION:** The unique sample description you want to appear on the analytical report
DATE COLLECTED: Date sample was collected. For composite samples, this is typically the date when the last aliquot was added.
TIME COLLECTED: Time sample was collected. For composite samples, this is typically the time when the last aliquot was added.
SAMPLE TYPE: Place a check mark in the box marked "GRAB" if the sample was collected at one time from one specific location. Place a check mark in the box marked "COMP" if the sample is a composite of samples collected at one or more times or locations and combined to make one sample.
MATRIX TYPE: From field above. If "OTHER" please identify
BOTLE COUNT: Total number of containers submitted for the samples
PRESERVATION CODE: Indicate bottle preservative using the codes on the front of the COC for non-PACE bottles, provided by the client.

3 **ANALYSIS REQUESTED:** Write the analysis name (or an abbreviation), the name of a group of tests, or the method number you would like us to perform. Examples are BOD, TCLP Metals, PCBs, Method 624, etc. Place a check mark in the small boxes that correspond to the sample(s) on which you want these tests performed.

REMARKS: List special instructions about the sample here. This space can also be used for listing additional analyses, or to request an extra copy of the report to be sent to an alternate person/address.

4 To be completed by laboratory personnel.

5 **TURNAROUND TIME REQUESTED:** Circle "NORMAL" if you want routine 10 working day TAT. If faster results are needed circle "RUSH", indicated the due date requested, and, if possible, call the lab in advance to schedule this work. Surcharges may apply for non-routine turnaround times.
RUSH RESULTS VIA: Choose method by which you would like to receive the RUSH results by circling either "PHONE" or E-MAIL". List the appropriate number/e-mail if different from that listed in section 1.

6 Place your initials on the line to give the lab permission to proceed with analysis without calling you regarding a sample nonconformance. If the sample does not meet the Sample Acceptance Policy requirements then the appropriate case narrative and/or data qualifiers will be added to the corresponding analysis and may not be acceptable to use for regulatory purposes. Contact your project manager for further information or to obtain a copy of the Sample Acceptance Policy.

Summarized Sample Acceptance Policy Requirements:

- Proper, full and completed chain-of-custody documentation
- Readable unique sample container identification written in indelible ink
- Appropriate sample container
- Sufficient sample volume to perform requested tests
- Received within required holding time
- Received within temperature preservation requirements
- Sample containers received in good condition (not leaking or broken)
- Any custody seal intact
- Properly preserved, and
- No headspace in volatile water samples

A data qualifier and/or case narrative will be added to the final test report when the above sample acceptance requirements are not met.

BOX 6 CANNOT BE USED FOR DRINKING WATER COMPLIANCE SAMPLES.

7 **RELINQUISHED BY/RECEIVED BY:** This form must be signed each time the sample(s) changes hands. Chain-of-Custody seals are available upon request if needed.

8 To be completed by laboratory personnel.

Sample Acceptance Policy – Receiving facility's specific policy available from your project manager.

SERVING YOU IN THE FOLLOWING LOCATIONS

2231 W Altorfer Dr
Peoria, IL 61615
309-692-9688

944 Anglum Road
Hazelwood, MO 63042
314-432-0550

1805 W Sunset St.
Springfield, MO 65807
417-964-8924

4314-A Crystal Lake Rd
McHenry, IL 60050
815-344-4044

Thank you for using Pace Analytical Services, LLC
Please call 800-752-6651 if you have any questions about completing this form.



CHAIN OF CUSTODY RECORD
STATE WHERE SAMPLE COLLECTED MO

PAGE _____ OF _____ 3/3/2021



Pace Analytical Services, LLC

2231 W. Altorfer Drive

Peoria, IL 61615

(800)752-6651

September 01, 2023

Glenn Grissom
SCI Engineering
130 Point W. Blvd.
St. Charles, MO 63301

RE: Drinking Water Lead-2018-0351.2T-Pathways Wellness Center

Dear Glenn Grissom:

Please find enclosed the analytical results for the **5** sample(s) the laboratory received on **8/1/23 4:30 pm** and logged in under work order **GH00260**. All testing is performed according to our current TNI accreditations unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of Pace Analytical Services, LLC.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

Pace Analytical Services appreciates the opportunity to provide you with analytical expertise. We are always trying to improve our customer service and we welcome you to contact the General Manager, Lisa Grant, with any feedback you have about your experience with our laboratory at 309-683-1764 or lisa.grant@pacelabs.com.

A handwritten signature in black ink, appearing to read 'Chenise Lambert-Sykes'.

Chenise Lambert-Sykes
Project Manager
(314)432-0550
Chenise.Lambert-Sykes@pacelabs.com

**SAMPLE RECEIPT CHECK LIST**

Items not applicable will be marked as in compliance

Work Order GH00260

YES	Samples received within temperature compliance when applicable
YES	COC present upon sample receipt
YES	COC completed & legible
YES	Sampler name & signature present
YES	Unique sample IDs assigned
YES	Sample collection location recorded
YES	Date & time collected recorded on COC
YES	Relinquished by client signature on COC
YES	COC & labels match
YES	Sample labels are legible
YES	Appropriate bottle(s) received
YES	Sufficient sample volume received
YES	Sample containers received undamaged
YES	Zero headspace, <6 mm present in VOA vials
NO	Trip blank(s) received
YES	All non-field analyses received within holding times
NO	Short hold time analysis
YES	Current PDC COC submitted
NO	Case narrative provided



ANALYTICAL RESULTS

Sample: GH00260-01
Name: PWC-01
Matrix: Drinking Water - Grab

Sampled: 07/28/23 20:44
Received: 08/01/23 16:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	3.43	ug/L		08/31/23 09:53	1	1.00	08/31/23 17:37	KMC	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GH00260-02
Name: PWC-02
Matrix: Drinking Water - Grab

Sampled: 07/28/23 20:45
Received: 08/01/23 16:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	3.61	ug/L		08/31/23 09:53	1	1.00	08/31/23 17:39	KMC	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GH00260-03
Name: PWC-03
Matrix: Drinking Water - Grab

Sampled: 07/28/23 20:48
Received: 08/01/23 16:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	9.32	ug/L		08/31/23 09:53	1	1.00	08/31/23 17:40	KMC	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GH00260-04
Name: PWC-04
Matrix: Drinking Water - Grab

Sampled: 07/28/23 20:48
Received: 08/01/23 16:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	5.79	ug/L		08/31/23 09:53	1	1.00	08/31/23 17:42	KMC	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



Pace Analytical Services, LLC

2231 W. Altorfer Drive

Peoria, IL 61615

(800)752-6651

ANALYTICAL RESULTS

Sample: GH00260-05

Name: PWC-05

Matrix: Drinking Water - Grab

Sampled: 07/28/23 20:52

Received: 08/01/23 16:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
<u>Total Metals - PIA</u>									
Lead	7.28	ug/L		08/31/23 09:53	1	1.00	08/31/23 17:43	KMC	EPA 200.8 REV 5.4



QC SAMPLE RESULTS

Parameter	Result	Unit	Qual	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit
<u>Batch B342691 - DW 200.8 no prep - EPA 200.8 REV 5.4</u>									
Blank (B342691-BLK1)				Prepared & Analyzed: 08/31/23					
Lead	< 1.00	ug/L							
LCS (B342691-BS1)				Prepared & Analyzed: 08/31/23					
Lead	52.8	ug/L		50.00		106	85-115		
Matrix Spike (B342691-MS1)				Prepared & Analyzed: 08/31/23					
Lead	46.3	ug/L		50.00	2.00	89	70-130		
Matrix Spike (B342691-MS2)				Prepared & Analyzed: 08/31/23					
Lead	49.7	ug/L		50.00	0.234	99	70-130		
Matrix Spike (B342691-MS3)				Prepared & Analyzed: 08/31/23					
Lead	50.8	ug/L		50.00	1.13	99	70-130		
Matrix Spike (B342691-MS4)				Prepared: 08/31/23 Analyzed: 09/01/23					
Lead	46.6	ug/L		50.00		93	70-130		
Matrix Spike (B342691-MS5)				Prepared: 08/31/23 Analyzed: 09/01/23					
Lead	46.8	ug/L		50.00	1.60	90	70-130		
Matrix Spike (B342691-MS6)				Prepared: 08/31/23 Analyzed: 09/01/23					
Lead	78.4	ug/L		50.00	32.3	92	70-130		
Matrix Spike (B342691-MS7)				Prepared: 08/31/23 Analyzed: 09/01/23					
Lead	65.7	ug/L		50.00	20.9	90	70-130		
Matrix Spike (B342691-MS8)				Prepared: 08/31/23 Analyzed: 09/01/23					
Lead	69.5	ug/L		50.00	25.0	89	70-130		
Matrix Spike (B342691-MS9)				Prepared: 08/31/23 Analyzed: 09/01/23					
Lead	48.4	ug/L		50.00	1.11	95	70-130		
Matrix Spike (B342691-MSA)				Prepared: 08/31/23 Analyzed: 09/01/23					
Lead	46.7	ug/L		50.00		93	70-130		
Matrix Spike (B342691-MSB)				Prepared: 08/31/23 Analyzed: 09/01/23					
Lead	52.2	ug/L		50.00		104	70-130		
Matrix Spike (B342691-MSC)				Prepared: 08/31/23 Analyzed: 09/01/23					
Lead	49.1	ug/L		50.00	ND	98	70-130		
Matrix Spike (B342691-MSD)				Prepared: 08/31/23 Analyzed: 09/01/23					
Lead	50.0	ug/L		50.00	2.42	95	70-130		
Matrix Spike Dup (B342691-MSD1)				Prepared & Analyzed: 08/31/23					
Lead	48.6	ug/L		50.00	2.00	93	70-130	5	20
Matrix Spike Dup (B342691-MSD2)				Prepared & Analyzed: 08/31/23					
Lead	52.8	ug/L		50.00	0.234	105	70-130	6	20
Matrix Spike Dup (B342691-MSD3)				Prepared & Analyzed: 08/31/23					
Lead	47.7	ug/L		50.00	1.13	93	70-130	6	20
Matrix Spike Dup (B342691-MSD4)				Prepared: 08/31/23 Analyzed: 09/01/23					
Lead	45.0	ug/L		50.00		90	70-130	4	20
Matrix Spike Dup (B342691-MSD5)				Prepared: 08/31/23 Analyzed: 09/01/23					
Lead	43.9	ug/L		50.00	1.60	85	70-130	6	20
Matrix Spike Dup (B342691-MSD6)				Prepared: 08/31/23 Analyzed: 09/01/23					
Lead	79.4	ug/L		50.00	32.3	94	70-130	1	20
Matrix Spike Dup (B342691-MSD7)				Prepared: 08/31/23 Analyzed: 09/01/23					
Lead	63.9	ug/L		50.00	20.9	86	70-130	3	20



QC SAMPLE RESULTS

Parameter	Result	Unit	Qual	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit
Matrix Spike Dup (B342691-MSD8)	Sample: GH00641-32			Prepared: 08/31/23 Analyzed: 09/01/23					
Lead	70.0	ug/L		50.00	25.0	90	70-130	0.8	20
Matrix Spike Dup (B342691-MSD9)	Sample: GH00642-08			Prepared: 08/31/23 Analyzed: 09/01/23					
Lead	48.8	ug/L		50.00	1.11	95	70-130	0.7	20
Matrix Spike Dup (B342691-MSDA)	Sample: GG05176-08			Prepared: 08/31/23 Analyzed: 09/01/23					
Lead	45.4	ug/L		50.00		91	70-130	3	20
Matrix Spike Dup (B342691-MSDB)	Sample: GG05176-17			Prepared: 08/31/23 Analyzed: 09/01/23					
Lead	47.9	ug/L		50.00		96	70-130	9	20
Matrix Spike Dup (B342691-MSDC)	Sample: GG05184-12			Prepared: 08/31/23 Analyzed: 09/01/23					
Lead	47.8	ug/L		50.00	ND	96	70-130	3	20
Matrix Spike Dup (B342691-MSDD)	Sample: GH01281-08			Prepared: 08/31/23 Analyzed: 09/01/23					
Lead	50.5	ug/L		50.00	2.42	96	70-130	0.9	20
Matrix Spike Dup (B342691-MSDE)	Sample: GH01281-31			Prepared: 08/31/23 Analyzed: 09/01/23					
Lead	51.5	ug/L		50.00	2.79	97	70-130	5	20
Matrix Spike (B342691-MSE)	Sample: GH01281-31			Prepared: 08/31/23 Analyzed: 09/01/23					
Lead	54.4	ug/L		50.00	2.79	103	70-130		



NOTES

Specifications regarding method revisions, method modifications, and calculations used for analysis are available upon request. Please contact your project manager.

* Not a TNI accredited analyte

Certifications

CHI - McHenry, IL - 4314-A W. Crystal Lake Road, McHenry, IL 60050

TNI Accreditation for Drinking Water and Wastewater Fields of Testing through IL EPA Accreditation No. 100279

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17556

PIA - Peoria, IL - 2231 W. Altorfer Drive, Peoria, IL 61615

TNI Accreditation for Drinking Water, Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. 100230

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17553

Drinking Water Certifications/Accreditations: Iowa (240); Kansas (E-10338); Missouri (870)

Wastewater Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

Solid and Hazardous Material Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO - 1805 W Sunset Street, Springfield, MO 65807

USEPA DMR-QA Program

STL - Hazelwood, MO - 944 Anglum Rd, Hazelwood, MO 63042

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through KS KDHE Certification No. E-10389

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. - 200080

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory, Registry No. 171050

Missouri Department of Natural Resources - Certificate of Approval for Microbiological Laboratory Service - No. 1050



Certified by: Jon Robert Handshy For Chenise Lambert-Sykes, Project Manager

[illegible]

- 1 **CLIENT:** Client's company name
ADDRESS: Client's mailing address
CITY, STATE, ZIP: Client's city, state and zip code for mailing
CONTACT PERSON: Person to receive results
PROJECT NUMBER: Client's reference to the project or work involved with these samples.
PROJECT LOCATION: Client's location of project
PURCHASE ORDER NUMBER: Client's invoicing information
PHONE NUMBER: Client's contact phone number
E-MAIL: Client's e-mail for correspondence and final report
DATE SHIPPED: Month, date and year samples were shipped or delivered to the lab
SAMPLER: Printed name of sample collector
SAMPLER'S SIGNATURE: Signature of sample collector
REGULATORY PROGRAM: Circle regulatory program if applicable.
STATE WHERE SAMPLES COLLECTED: Enter the state if different from client address

- 2 **SAMPLE DESCRIPTION:** The unique sample description you want to appear on the analytical report
DATE COLLECTED: Date sample was collected. For composite samples, this is typically the date when the last aliquot was added.
TIME COLLECTED: Time sample was collected. For composite samples, this is typically the time when the last aliquot was added.
SAMPLE TYPE: Place a check mark in the box marked "GRAB" if the sample was collected at one time from one specific location. Place a check mark in the box marked "COMP" if the sample is a composite of samples collected at one or more times or locations and combined to make one sample.
MATRIX TYPE: From field above. If "OTHER" please identify
BOTLE COUNT: Total number of containers submitted for the samples
PRESERVATION CODE: Indicate bottle preservative using the codes on the front of the COC for non-PACE bottles, provided by the client.

- 3 **ANALYSIS REQUESTED:** Write the analysis name (or an abbreviation), the name of a group of tests, or the method number you would like us to perform. Examples are BOD, TCLP Metals, PCBs, Method 624, etc. Place a check mark in the small boxes that correspond to the sample(s) on which you want these tests performed.
REMARKS: List special instructions about the sample here. This space can also be used for listing additional analyses, or to request an extra copy of the report to be sent to an alternate person/address.

- 4 To be completed by laboratory personnel.
- 5 **TURNAROUND TIME REQUESTED:** Circle "NORMAL" if you want routine 10 working day TAT. If faster results are needed circle "RUSH", indicated the due date requested, and, if possible, call the lab in advance to schedule this work. Surcharges may apply for non-routine turnaround times.
RUSH RESULTS VIA: Choose method by which you would like to receive the RUSH results by circling either "PHONE" or E-MAIL". List the appropriate number/e-mail if different from that listed in section 1.
- 6 Place your initials on the line to give the lab permission to proceed with analysis without calling you regarding a sample nonconformance. If the sample does not meet the Sample Acceptance Policy requirements then the appropriate case narrative and/or data qualifiers will be added to the corresponding analysis and may not be acceptable to use for regulatory purposes. Contact your project manager for further information or to obtain a copy of the Sample Acceptance Policy.

Summarized Sample Acceptance Policy Requirements:

- Proper, full and completed chain-of-custody documentation
- Readable unique sample container identification written in indelible ink
- Appropriate sample container
- Sufficient sample volume to perform requested tests
- Received within required holding time
- Received within temperature preservation requirements
- Sample containers received in good condition (not leaking or broken)
- Any custody seal intact
- Properly preserved, and
- No headspace in volatile water samples

A data qualifier and/or case narrative will be added to the final test report when the above sample acceptance requirements are not met.

BOX 6 CANNOT BE USED FOR DRINKING WATER COMPLIANCE SAMPLES.

- 7 **RELINQUISHED BY/RECEIVED BY:** This form must be signed each time the sample(s) changes hands. Chain-of-Custody seals are available upon request if needed.
- 8 To be completed by laboratory personnel.

Sample Acceptance Policy – Receiving facility's specific policy available from your project manager.

SERVING YOU IN THE FOLLOWING LOCATIONS

2231 W Altorfer Dr
Peoria, IL 61615
309-692-9688

944 Anglum Road
Hazelwood, MO 63042
314-432-0550

1805 W Sunset St.
Springfield, MO 65807
417-964-8924

4314-A Crystal Lake Rd
McHenry, IL 60050
815-344-4044

Thank you for using Pace Analytical Services, LLC
Please call 800-752-6651 if you have any questions about completing this form.



Pace Analytical Services, LLC

2231 W. Altorfer Drive

Peoria, IL 61615

(800)752-6651

September 01, 2023

Glenn Grissom
SCI Engineering
130 Point W. Blvd.
St. Charles, MO 63301

RE: Drinking Water Lead-2018-0351.2T-Pathways Wellness Center

Dear Glenn Grissom:

Please find enclosed the analytical results for the **5** sample(s) the laboratory received on **8/1/23 4:30 pm** and logged in under work order **GH00260**. All testing is performed according to our current TNI accreditations unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of Pace Analytical Services, LLC.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

Pace Analytical Services appreciates the opportunity to provide you with analytical expertise. We are always trying to improve our customer service and we welcome you to contact the General Manager, Lisa Grant, with any feedback you have about your experience with our laboratory at 309-683-1764 or lisa.grant@pacelabs.com.

A handwritten signature in black ink, appearing to read 'Chenise Lambert-Sykes'.

Chenise Lambert-Sykes
Project Manager
(314)432-0550
Chenise.Lambert-Sykes@pacelabs.com

**SAMPLE RECEIPT CHECK LIST**

Items not applicable will be marked as in compliance

Work Order GH00260

YES	Samples received within temperature compliance when applicable
YES	COC present upon sample receipt
YES	COC completed & legible
YES	Sampler name & signature present
YES	Unique sample IDs assigned
YES	Sample collection location recorded
YES	Date & time collected recorded on COC
YES	Relinquished by client signature on COC
YES	COC & labels match
YES	Sample labels are legible
YES	Appropriate bottle(s) received
YES	Sufficient sample volume received
YES	Sample containers received undamaged
YES	Zero headspace, <6 mm present in VOA vials
NO	Trip blank(s) received
YES	All non-field analyses received within holding times
NO	Short hold time analysis
YES	Current PDC COC submitted
NO	Case narrative provided



ANALYTICAL RESULTS

Sample: GH00260-01
Name: PWC-01
Matrix: Drinking Water - Grab

Sampled: 07/28/23 20:44
Received: 08/01/23 16:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	3.43	ug/L		08/31/23 09:53	1	1.00	08/31/23 17:37	KMC	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GH00260-02
Name: PWC-02
Matrix: Drinking Water - Grab

Sampled: 07/28/23 20:45
Received: 08/01/23 16:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	3.61	ug/L		08/31/23 09:53	1	1.00	08/31/23 17:39	KMC	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GH00260-03
Name: PWC-03
Matrix: Drinking Water - Grab

Sampled: 07/28/23 20:48
Received: 08/01/23 16:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	9.32	ug/L		08/31/23 09:53	1	1.00	08/31/23 17:40	KMC	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: GH00260-04
Name: PWC-04
Matrix: Drinking Water - Grab

Sampled: 07/28/23 20:48
Received: 08/01/23 16:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	5.79	ug/L		08/31/23 09:53	1	1.00	08/31/23 17:42	KMC	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



Pace Analytical Services, LLC

2231 W. Altorfer Drive

Peoria, IL 61615

(800)752-6651

ANALYTICAL RESULTS

Sample: GH00260-05

Name: PWC-05

Matrix: Drinking Water - Grab

Sampled: 07/28/23 20:52

Received: 08/01/23 16:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
<u>Total Metals - PIA</u>									
Lead	7.28	ug/L		08/31/23 09:53	1	1.00	08/31/23 17:43	KMC	EPA 200.8 REV 5.4



QC SAMPLE RESULTS

Parameter	Result	Unit	Qual	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit
<u>Batch B342691 - DW 200.8 no prep - EPA 200.8 REV 5.4</u>									
Blank (B342691-BLK1)				Prepared & Analyzed: 08/31/23					
Lead	< 1.00	ug/L							
LCS (B342691-BS1)				Prepared & Analyzed: 08/31/23					
Lead	52.8	ug/L		50.00		106	85-115		
Matrix Spike (B342691-MS1)				Prepared & Analyzed: 08/31/23					
Lead	46.3	ug/L		50.00	2.00	89	70-130		
Matrix Spike (B342691-MS2)				Prepared & Analyzed: 08/31/23					
Lead	49.7	ug/L		50.00	0.234	99	70-130		
Matrix Spike (B342691-MS3)				Prepared & Analyzed: 08/31/23					
Lead	50.8	ug/L		50.00	1.13	99	70-130		
Matrix Spike (B342691-MS4)				Prepared: 08/31/23 Analyzed: 09/01/23					
Lead	46.6	ug/L		50.00		93	70-130		
Matrix Spike (B342691-MS5)				Prepared: 08/31/23 Analyzed: 09/01/23					
Lead	46.8	ug/L		50.00	1.60	90	70-130		
Matrix Spike (B342691-MS6)				Prepared: 08/31/23 Analyzed: 09/01/23					
Lead	78.4	ug/L		50.00	32.3	92	70-130		
Matrix Spike (B342691-MS7)				Prepared: 08/31/23 Analyzed: 09/01/23					
Lead	65.7	ug/L		50.00	20.9	90	70-130		
Matrix Spike (B342691-MS8)				Prepared: 08/31/23 Analyzed: 09/01/23					
Lead	69.5	ug/L		50.00	25.0	89	70-130		
Matrix Spike (B342691-MS9)				Prepared: 08/31/23 Analyzed: 09/01/23					
Lead	48.4	ug/L		50.00	1.11	95	70-130		
Matrix Spike (B342691-MSA)				Prepared: 08/31/23 Analyzed: 09/01/23					
Lead	46.7	ug/L		50.00		93	70-130		
Matrix Spike (B342691-MSB)				Prepared: 08/31/23 Analyzed: 09/01/23					
Lead	52.2	ug/L		50.00		104	70-130		
Matrix Spike (B342691-MSC)				Prepared: 08/31/23 Analyzed: 09/01/23					
Lead	49.1	ug/L		50.00	ND	98	70-130		
Matrix Spike (B342691-MSD)				Prepared: 08/31/23 Analyzed: 09/01/23					
Lead	50.0	ug/L		50.00	2.42	95	70-130		
Matrix Spike Dup (B342691-MSD1)				Prepared & Analyzed: 08/31/23					
Lead	48.6	ug/L		50.00	2.00	93	70-130	5	20
Matrix Spike Dup (B342691-MSD2)				Prepared & Analyzed: 08/31/23					
Lead	52.8	ug/L		50.00	0.234	105	70-130	6	20
Matrix Spike Dup (B342691-MSD3)				Prepared & Analyzed: 08/31/23					
Lead	47.7	ug/L		50.00	1.13	93	70-130	6	20
Matrix Spike Dup (B342691-MSD4)				Prepared: 08/31/23 Analyzed: 09/01/23					
Lead	45.0	ug/L		50.00		90	70-130	4	20
Matrix Spike Dup (B342691-MSD5)				Prepared: 08/31/23 Analyzed: 09/01/23					
Lead	43.9	ug/L		50.00	1.60	85	70-130	6	20
Matrix Spike Dup (B342691-MSD6)				Prepared: 08/31/23 Analyzed: 09/01/23					
Lead	79.4	ug/L		50.00	32.3	94	70-130	1	20
Matrix Spike Dup (B342691-MSD7)				Prepared: 08/31/23 Analyzed: 09/01/23					
Lead	63.9	ug/L		50.00	20.9	86	70-130	3	20



QC SAMPLE RESULTS

Parameter	Result	Unit	Qual	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit
Matrix Spike Dup (B342691-MSD8)	Sample: GH00641-32			Prepared: 08/31/23 Analyzed: 09/01/23					
Lead	70.0	ug/L		50.00	25.0	90	70-130	0.8	20
Matrix Spike Dup (B342691-MSD9)	Sample: GH00642-08			Prepared: 08/31/23 Analyzed: 09/01/23					
Lead	48.8	ug/L		50.00	1.11	95	70-130	0.7	20
Matrix Spike Dup (B342691-MSDA)	Sample: GG05176-08			Prepared: 08/31/23 Analyzed: 09/01/23					
Lead	45.4	ug/L		50.00		91	70-130	3	20
Matrix Spike Dup (B342691-MSDB)	Sample: GG05176-17			Prepared: 08/31/23 Analyzed: 09/01/23					
Lead	47.9	ug/L		50.00		96	70-130	9	20
Matrix Spike Dup (B342691-MSDC)	Sample: GG05184-12			Prepared: 08/31/23 Analyzed: 09/01/23					
Lead	47.8	ug/L		50.00	ND	96	70-130	3	20
Matrix Spike Dup (B342691-MSDD)	Sample: GH01281-08			Prepared: 08/31/23 Analyzed: 09/01/23					
Lead	50.5	ug/L		50.00	2.42	96	70-130	0.9	20
Matrix Spike Dup (B342691-MSDE)	Sample: GH01281-31			Prepared: 08/31/23 Analyzed: 09/01/23					
Lead	51.5	ug/L		50.00	2.79	97	70-130	5	20
Matrix Spike (B342691-MSE)	Sample: GH01281-31			Prepared: 08/31/23 Analyzed: 09/01/23					
Lead	54.4	ug/L		50.00	2.79	103	70-130		



NOTES

Specifications regarding method revisions, method modifications, and calculations used for analysis are available upon request. Please contact your project manager.

* Not a TNI accredited analyte

Certifications

CHI - McHenry, IL - 4314-A W. Crystal Lake Road, McHenry, IL 60050

TNI Accreditation for Drinking Water and Wastewater Fields of Testing through IL EPA Accreditation No. 100279

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17556

PIA - Peoria, IL - 2231 W. Altorfer Drive, Peoria, IL 61615

TNI Accreditation for Drinking Water, Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. 100230

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17553

Drinking Water Certifications/Accreditations: Iowa (240); Kansas (E-10338); Missouri (870)

Wastewater Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

Solid and Hazardous Material Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO - 1805 W Sunset Street, Springfield, MO 65807

USEPA DMR-QA Program

STL - Hazelwood, MO - 944 Anglum Rd, Hazelwood, MO 63042

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through KS KDHE Certification No. E-10389

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. - 200080

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory, Registry No. 171050

Missouri Department of Natural Resources - Certificate of Approval for Microbiological Laboratory Service - No. 1050



Certified by: Jon Robert Handshy For Chenise Lambert-Sykes, Project Manager

- 1 **CLIENT:** Client's company name
ADDRESS: Client's mailing address
CITY, STATE, ZIP: Client's city, state and zip code for mailing
CONTACT PERSON: Person to receive results
PROJECT NUMBER: Client's reference to the project or work involved with these samples.
PROJECT LOCATION: Client's location of project
PURCHASE ORDER NUMBER: Client's invoicing information
PHONE NUMBER: Client's contact phone number
E-MAIL: Client's e-mail for correspondence and final report
DATE SHIPPED: Month, date and year samples were shipped or delivered to the lab
SAMPLER: Printed name of sample collector
SAMPLER'S SIGNATURE: Signature of sample collector
REGULATORY PROGRAM: Circle regulatory program if applicable.
STATE WHERE SAMPLES COLLECTED: Enter the state if different from client address

- 2 **SAMPLE DESCRIPTION:** The unique sample description you want to appear on the analytical report
DATE COLLECTED: Date sample was collected. For composite samples, this is typically the date when the last aliquot was added.
TIME COLLECTED: Time sample was collected. For composite samples, this is typically the time when the last aliquot was added.
SAMPLE TYPE: Place a check mark in the box marked "GRAB" if the sample was collected at one time from one specific location. Place a check mark in the box marked "COMP" if the sample is a composite of samples collected at one or more times or locations and combined to make one sample.
MATRIX TYPE: From field above. If "OTHER" please identify
BOTLE COUNT: Total number of containers submitted for the samples
PRESERVATION CODE: Indicate bottle preservative using the codes on the front of the COC for non-PACE bottles, provided by the client.

- 3 **ANALYSIS REQUESTED:** Write the analysis name (or an abbreviation), the name of a group of tests, or the method number you would like us to perform. Examples are BOD, TCLP Metals, PCBs, Method 624, etc. Place a check mark in the small boxes that correspond to the sample(s) on which you want these tests performed.
REMARKS: List special instructions about the sample here. This space can also be used for listing additional analyses, or to request an extra copy of the report to be sent to an alternate person/address.

- 4 To be completed by laboratory personnel.
- 5 **TURNAROUND TIME REQUESTED:** Circle "NORMAL" if you want routine 10 working day TAT. If faster results are needed circle "RUSH", indicated the due date requested, and, if possible, call the lab in advance to schedule this work. Surcharges may apply for non-routine turnaround times.
RUSH RESULTS VIA: Choose method by which you would like to receive the RUSH results by circling either "PHONE" or E-MAIL". List the appropriate number/e-mail if different from that listed in section 1.
- 6 Place your initials on the line to give the lab permission to proceed with analysis without calling you regarding a sample nonconformance. If the sample does not meet the Sample Acceptance Policy requirements then the appropriate case narrative and/or data qualifiers will be added to the corresponding analysis and may not be acceptable to use for regulatory purposes. Contact your project manager for further information or to obtain a copy of the Sample Acceptance Policy.

Summarized Sample Acceptance Policy Requirements:

- Proper, full and completed chain-of-custody documentation
- Readable unique sample container identification written in indelible ink
- Appropriate sample container
- Sufficient sample volume to perform requested tests
- Received within required holding time
- Received within temperature preservation requirements
- Sample containers received in good condition (not leaking or broken)
- Any custody seal intact
- Properly preserved, and
- No headspace in volatile water samples

A data qualifier and/or case narrative will be added to the final test report when the above sample acceptance requirements are not met.

BOX 6 CANNOT BE USED FOR DRINKING WATER COMPLIANCE SAMPLES.

- 7 **RELINQUISHED BY/RECEIVED BY:** This form must be signed each time the sample(s) changes hands. Chain-of-Custody seals are available upon request if needed.
- 8 To be completed by laboratory personnel.

Sample Acceptance Policy – Receiving facility's specific policy available from your project manager.

SERVING YOU IN THE FOLLOWING LOCATIONS

2231 W Altorfer Dr
Peoria, IL 61615
309-692-9688

944 Anglum Road
Hazelwood, MO 63042
314-432-0550

1805 W Sunset St.
Springfield, MO 65807
417-964-8924

4314-A Crystal Lake Rd
McHenry, IL 60050
815-344-4044

Thank you for using Pace Analytical Services, LLC
Please call 800-752-6651 if you have any questions about completing this form.

April 03, 2024

Brian Lieb
SCI Engineering, Inc.
130 Point West Boulevard
St. Charles, MO 63301
TEL: (314) 956-8240
FAX: (636) 949-8269



Illinois	100226
Illinois	1004652024-2
Kansas	E-10374
Louisiana	05002
Louisiana	05003
Oklahoma	9978

RE: 2018-0351.2A T200

WorkOrder: 24040086

Dear Brian Lieb:

TEKLAB, INC received 2 samples on 4/1/2024 2:08:00 PM for the analysis presented in the following report.

Samples are analyzed on an as received basis unless otherwise requested and documented. The sample results contained in this report relate only to the requested analytes of interest as directed on the chain of custody. NELAP accredited fields of testing are indicated by the letters NELAP under the Certification column. Unless otherwise documented within this report, Teklab Inc. analyzes samples utilizing the most current methods in compliance with 40CFR. All tests are performed in the Collinsville, IL laboratory unless otherwise noted in the Case Narrative.

All quality control criteria applicable to the test methods employed for this project have been satisfactorily met and are in accordance with NELAP except where noted. The following report shall not be reproduced, except in full, without the written approval of Teklab, Inc.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,



Elizabeth A. Hurley
Director of Customer Service
(618)344-1004 ex 33
ehurley@teklabinc.com



Report Contents

<http://www.teklabinc.com/>

Client: SCI Engineering, Inc.

Work Order: 24040086

Client Project: 2018-0351.2A T200

Report Date: 03-Apr-24

This reporting package includes the following:

Cover Letter	1
Report Contents	2
Definitions	3
Case Narrative	5
Accreditations	6
Laboratory Results	7
Receiving Check List	8
Chain of Custody	Appended

Client: SCI Engineering, Inc.

Work Order: 24040086

Client Project: 2018-0351.2A T200

Report Date: 03-Apr-24

Abbr Definition

* Analytes on report marked with an asterisk are not NELAP accredited

CCV Continuing calibration verification is a check of a standard to determine the state of calibration of an instrument between recalibration.

CRQL A Client Requested Quantitation Limit is a reporting limit that varies according to customer request. The CRQL may not be less than the MDL.

DF Dilution factor is the dilution performed during analysis only and does not take into account any dilutions made during sample preparation. The reported result is final and includes all dilution factors.

DNI Did not ignite

DUP Laboratory duplicate is a replicate aliquot prepared under the same laboratory conditions and independently analyzed to obtain a measure of precision.

ICV Initial calibration verification is a check of a standard to determine the state of calibration of an instrument before sample analysis is initiated.

IDPH IL Dept. of Public Health

LCS Laboratory control sample is a sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes and analyzed exactly like a sample to establish intra-laboratory or analyst specific precision and bias or to assess the performance of all or a portion of the measurement system.

LCSD Laboratory control sample duplicate is a replicate laboratory control sample that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MBLK Method blank is a sample of a matrix similar to the batch of associated sample (when available) that is free from the analytes of interest and is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedures, and in which no target analytes or interferences should present at concentrations that impact the analytical results for sample analyses.

MDL "The method detection limit is defined as the minimum measured concentration of a substance that can be reported with 99% confidence that the measured concentration is distinguishable from method blank results."

MS Matrix spike is an aliquot of matrix fortified (spiked) with known quantities of specific analytes that is subjected to the entire analytical procedures in order to determine the effect of the matrix on an approved test method's recovery system. The acceptable recovery range is listed in the QC Package (provided upon request).

MSD Matrix spike duplicate means a replicate matrix spike that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MW Molecular weight

NC Data is not acceptable for compliance purposes

ND Not Detected at the Reporting Limit

NELAP NELAP Accredited

PQL Practical quantitation limit means the lowest level that can be reliably achieved within specified limits of precision and accuracy during routine laboratory operation conditions.

RL The reporting limit the lowest level that the data is displayed in the final report. The reporting limit may vary according to customer request or sample dilution. The reporting limit may not be less than the MDL.

RPD Relative percent difference is a calculated difference between two recoveries (ie. MS/MSD). The acceptable recovery limit is listed in the QC Package (provided upon request).

SPK The spike is a known mass of target analyte added to a blank sample or sub-sample; used to determine recovery deficiency or for other quality control purposes.

Surr Surrogates are compounds which are similar to the analytes of interest in chemical composition and behavior in the analytical process, but which are not normally found in environmental samples.

TIC Tentatively identified compound: Analytes tentatively identified in the sample by using a library search. Only results not in the calibration standard will be reported as tentatively identified compounds. Results for tentatively identified compounds that are not present in the calibration standard, but are assigned a specific chemical name based upon the library search, are calculated using total peak areas from reconstructed ion chromatograms and a response factor of one. The nearest Internal Standard is used for the calculation. The results of any TICs must be considered estimated, and are flagged with a "T". If the estimated result is above the calibration range it is flagged "ET"

TNTC Too numerous to count (> 200 CFU)

Client: SCI Engineering, Inc.

Work Order: 24040086

Client Project: 2018-0351.2A T200

Report Date: 03-Apr-24

Qualifiers

- | | |
|---|--|
| # - Unknown hydrocarbon | B - Analyte detected in associated Method Blank |
| C - RL shown is a Client Requested Quantitation Limit | E - Value above quantitation range |
| H - Holding times exceeded | I - Associated internal standard was outside method criteria |
| J - Analyte detected below quantitation limits | M - Manual Integration used to determine area response |
| ND - Not Detected at the Reporting Limit | R - RPD outside accepted recovery limits |
| S - Spike Recovery outside recovery limits | T - TIC(Tentatively identified compound) |
| X - Value exceeds Maximum Contaminant Level | |



Case Narrative

<http://www.teklabinc.com/>

Client: SCI Engineering, Inc.

Work Order: 24040086

Client Project: 2018-0351.2A T200

Report Date: 03-Apr-24

Cooler Receipt Temp: 24.1 °C

Locations

Collinsville

Address 5445 Horseshoe Lake Road
Collinsville, IL 62234-7425
Phone (618) 344-1004
Fax (618) 344-1005
Email jhriley@teklabinc.com

Collinsville Air

Address 5445 Horseshoe Lake Road
Collinsville, IL 62234-7425
Phone (618) 344-1004
Fax (618) 344-1005
Email EHurley@teklabinc.com

Springfield

Address 3920 Pintail Dr
Springfield, IL 62711-9415
Phone (217) 698-1004
Fax (217) 698-1005
Email KKlostermann@teklabinc.com

Chicago

Address 1319 Butterfield Rd.
Downers Grove, IL 60515
Phone (630) 324-6855
Fax
Email arenner@teklabinc.com

Kansas City

Address 8421 Nieman Road
Lenexa, KS 66214
Phone (913) 541-1998
Fax (913) 541-1998
Email jhriley@teklabinc.com

Client: SCI Engineering, Inc.**Work Order:** 24040086**Client Project:** 2018-0351.2A T200**Report Date:** 03-Apr-24

State	Dept	Cert #	NELAP	Exp Date	Lab
Illinois	IEPA	100226	NELAP	1/31/2025	Collinsville
Illinois	IEPA	1004652024-2	NELAP	4/30/2025	Collinsville
Kansas	KDHE	E-10374	NELAP	4/30/2024	Collinsville
Louisiana	LDEQ	05002	NELAP	6/30/2024	Collinsville
Louisiana	LDEQ	05003	NELAP	6/30/2024	Collinsville
Oklahoma	ODEQ	9978	NELAP	8/31/2024	Collinsville
Arkansas	ADEQ	88-0966		3/14/2024	Collinsville
Illinois	IDPH	17584		5/31/2025	Collinsville
Iowa	IDNR	430		6/1/2024	Collinsville
Kentucky	UST	0073		1/31/2025	Collinsville
Missouri	MDNR	00930		10/31/2026	Collinsville
Missouri	MDNR	930		1/31/2025	Collinsville



Laboratory Results

<http://www.teklabinc.com/>

Client: SCI Engineering, Inc.

Work Order: 24040086

Client Project: 2018-0351.2A T200

Report Date: 03-Apr-24

Matrix: DRINKING WATER

Sample ID	Client Sample ID	Certification	Qual	RL	Result	Units	DF	Date Analyzed	Date Collected
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)									
Lead									
24040086-001A	PWC-5	NELAP		1.0	3.3	µg/L	1	04/03/2024 7:37	03/29/2024 16:35
24040086-002A	PWC-8	NELAP		1.0	1.3	µg/L	1	04/03/2024 8:23	03/29/2024 16:45



Receiving Check List

<http://www.teklabinc.com/>

Client: SCI Engineering, Inc.

Work Order: 24040086

Client Project: 2018-0351.2A T200

Report Date: 03-Apr-24

Carrier: John Duarte

Received By: LEH

Completed by:

On:

01-Apr-24

Paul Schultz

Reviewed by:

On:

01-Apr-24

Elizabeth A. Hurley

Pages to follow: Chain of custody

1

Extra pages included

0

Shipping container/cooler in good condition?

Yes ☒

No ☐

Not Present ☐

Temp °C 24.1

Type of thermal preservation?

None ☒

Ice ☐

Blue Ice ☐

Dry Ice ☐

Chain of custody present?

Yes ☒

No ☐

Chain of custody signed when relinquished and received?

Yes ☒

No ☐

Chain of custody agrees with sample labels?

Yes ☒

No ☐

Samples in proper container/bottle?

Yes ☒

No ☐

Sample containers intact?

Yes ☒

No ☐

Sufficient sample volume for indicated test?

Yes ☒

No ☐

All samples received within holding time?

Yes ☒

No ☐

Reported field parameters measured:

Field ☐

Lab ☐

NA ☒

Container/Temp Blank temperature in compliance?

Yes ☒

No ☐

When thermal preservation is required, samples are compliant with a temperature between 0.1°C - 6.0°C, or when samples are received on ice the same day as collected.

Water – at least one vial per sample has zero headspace?

Yes ☐

No ☐

No VOA vials ☒

Water - TOX containers have zero headspace?

Yes ☐

No ☐

No TOX containers ☒

Water - pH acceptable upon receipt?

Yes ☒

No ☐

NA ☐

NPDES/CWA TCN interferences checked/treated in the field?

Yes ☐

No ☐

NA ☒

Any No responses must be detailed below or on the COC.

Samples were checked for turbidity and then preserved with nitric acid upon arrival in the laboratory.

U# 4/1/24

April 03, 2024

Brian Lieb
SCI Engineering, Inc.
130 Point West Boulevard
St. Charles, MO 63301
TEL: (314) 956-8240
FAX: (636) 949-8269



Illinois	100226
Illinois	1004652024-2
Kansas	E-10374
Louisiana	05002
Louisiana	05003
Oklahoma	9978

RE: 2018-0351.2A T200

WorkOrder: 24040086

Dear Brian Lieb:

TEKLAB, INC received 2 samples on 4/1/2024 2:08:00 PM for the analysis presented in the following report.

Samples are analyzed on an as received basis unless otherwise requested and documented. The sample results contained in this report relate only to the requested analytes of interest as directed on the chain of custody. NELAP accredited fields of testing are indicated by the letters NELAP under the Certification column. Unless otherwise documented within this report, Teklab Inc. analyzes samples utilizing the most current methods in compliance with 40CFR. All tests are performed in the Collinsville, IL laboratory unless otherwise noted in the Case Narrative.

All quality control criteria applicable to the test methods employed for this project have been satisfactorily met and are in accordance with NELAP except where noted. The following report shall not be reproduced, except in full, without the written approval of Teklab, Inc.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,



Elizabeth A. Hurley
Director of Customer Service
(618)344-1004 ex 33
ehurley@teklabinc.com



Report Contents

<http://www.teklabinc.com/>

Client: SCI Engineering, Inc.

Work Order: 24040086

Client Project: 2018-0351.2A T200

Report Date: 03-Apr-24

This reporting package includes the following:

Cover Letter	1
Report Contents	2
Definitions	3
Case Narrative	5
Accreditations	6
Laboratory Results	7
Receiving Check List	8
Chain of Custody	Appended

Client: SCI Engineering, Inc.

Work Order: 24040086

Client Project: 2018-0351.2A T200

Report Date: 03-Apr-24

Abbr Definition

* Analytes on report marked with an asterisk are not NELAP accredited

CCV Continuing calibration verification is a check of a standard to determine the state of calibration of an instrument between recalibration.

CRQL A Client Requested Quantitation Limit is a reporting limit that varies according to customer request. The CRQL may not be less than the MDL.

DF Dilution factor is the dilution performed during analysis only and does not take into account any dilutions made during sample preparation. The reported result is final and includes all dilution factors.

DNI Did not ignite

DUP Laboratory duplicate is a replicate aliquot prepared under the same laboratory conditions and independently analyzed to obtain a measure of precision.

ICV Initial calibration verification is a check of a standard to determine the state of calibration of an instrument before sample analysis is initiated.

IDPH IL Dept. of Public Health

LCS Laboratory control sample is a sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes and analyzed exactly like a sample to establish intra-laboratory or analyst specific precision and bias or to assess the performance of all or a portion of the measurement system.

LCSD Laboratory control sample duplicate is a replicate laboratory control sample that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MBLK Method blank is a sample of a matrix similar to the batch of associated sample (when available) that is free from the analytes of interest and is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedures, and in which no target analytes or interferences should present at concentrations that impact the analytical results for sample analyses.

MDL "The method detection limit is defined as the minimum measured concentration of a substance that can be reported with 99% confidence that the measured concentration is distinguishable from method blank results."

MS Matrix spike is an aliquot of matrix fortified (spiked) with known quantities of specific analytes that is subjected to the entire analytical procedures in order to determine the effect of the matrix on an approved test method's recovery system. The acceptable recovery range is listed in the QC Package (provided upon request).

MSD Matrix spike duplicate means a replicate matrix spike that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MW Molecular weight

NC Data is not acceptable for compliance purposes

ND Not Detected at the Reporting Limit

NELAP NELAP Accredited

PQL Practical quantitation limit means the lowest level that can be reliably achieved within specified limits of precision and accuracy during routine laboratory operation conditions.

RL The reporting limit the lowest level that the data is displayed in the final report. The reporting limit may vary according to customer request or sample dilution. The reporting limit may not be less than the MDL.

RPD Relative percent difference is a calculated difference between two recoveries (ie. MS/MSD). The acceptable recovery limit is listed in the QC Package (provided upon request).

SPK The spike is a known mass of target analyte added to a blank sample or sub-sample; used to determine recovery deficiency or for other quality control purposes.

Surr Surrogates are compounds which are similar to the analytes of interest in chemical composition and behavior in the analytical process, but which are not normally found in environmental samples.

TIC Tentatively identified compound: Analytes tentatively identified in the sample by using a library search. Only results not in the calibration standard will be reported as tentatively identified compounds. Results for tentatively identified compounds that are not present in the calibration standard, but are assigned a specific chemical name based upon the library search, are calculated using total peak areas from reconstructed ion chromatograms and a response factor of one. The nearest Internal Standard is used for the calculation. The results of any TICs must be considered estimated, and are flagged with a "T". If the estimated result is above the calibration range it is flagged "ET"

TNTC Too numerous to count (> 200 CFU)

Client: SCI Engineering, Inc.

Work Order: 24040086

Client Project: 2018-0351.2A T200

Report Date: 03-Apr-24

Qualifiers

- | | |
|---|--|
| # - Unknown hydrocarbon | B - Analyte detected in associated Method Blank |
| C - RL shown is a Client Requested Quantitation Limit | E - Value above quantitation range |
| H - Holding times exceeded | I - Associated internal standard was outside method criteria |
| J - Analyte detected below quantitation limits | M - Manual Integration used to determine area response |
| ND - Not Detected at the Reporting Limit | R - RPD outside accepted recovery limits |
| S - Spike Recovery outside recovery limits | T - TIC(Tentatively identified compound) |
| X - Value exceeds Maximum Contaminant Level | |



Case Narrative

<http://www.teklabinc.com/>

Client: SCI Engineering, Inc.

Work Order: 24040086

Client Project: 2018-0351.2A T200

Report Date: 03-Apr-24

Cooler Receipt Temp: 24.1 °C

Locations

Collinsville

Address 5445 Horseshoe Lake Road
Collinsville, IL 62234-7425
Phone (618) 344-1004
Fax (618) 344-1005
Email jhriley@teklabinc.com

Collinsville Air

Address 5445 Horseshoe Lake Road
Collinsville, IL 62234-7425
Phone (618) 344-1004
Fax (618) 344-1005
Email EHurley@teklabinc.com

Springfield

Address 3920 Pintail Dr
Springfield, IL 62711-9415
Phone (217) 698-1004
Fax (217) 698-1005
Email KKlostermann@teklabinc.com

Chicago

Address 1319 Butterfield Rd.
Downers Grove, IL 60515
Phone (630) 324-6855
Fax
Email arenner@teklabinc.com

Kansas City

Address 8421 Nieman Road
Lenexa, KS 66214
Phone (913) 541-1998
Fax (913) 541-1998
Email jhriley@teklabinc.com

Client: SCI Engineering, Inc.**Work Order:** 24040086**Client Project:** 2018-0351.2A T200**Report Date:** 03-Apr-24

State	Dept	Cert #	NELAP	Exp Date	Lab
Illinois	IEPA	100226	NELAP	1/31/2025	Collinsville
Illinois	IEPA	1004652024-2	NELAP	4/30/2025	Collinsville
Kansas	KDHE	E-10374	NELAP	4/30/2024	Collinsville
Louisiana	LDEQ	05002	NELAP	6/30/2024	Collinsville
Louisiana	LDEQ	05003	NELAP	6/30/2024	Collinsville
Oklahoma	ODEQ	9978	NELAP	8/31/2024	Collinsville
Arkansas	ADEQ	88-0966		3/14/2024	Collinsville
Illinois	IDPH	17584		5/31/2025	Collinsville
Iowa	IDNR	430		6/1/2024	Collinsville
Kentucky	UST	0073		1/31/2025	Collinsville
Missouri	MDNR	00930		10/31/2026	Collinsville
Missouri	MDNR	930		1/31/2025	Collinsville



Laboratory Results

<http://www.teklabinc.com/>

Client: SCI Engineering, Inc.

Work Order: 24040086

Client Project: 2018-0351.2A T200

Report Date: 03-Apr-24

Matrix: DRINKING WATER

Sample ID	Client Sample ID	Certification	Qual	RL	Result	Units	DF	Date Analyzed	Date Collected
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)									
Lead									
24040086-001A	PWC-5	NELAP		1.0	3.3	µg/L	1	04/03/2024 7:37	03/29/2024 16:35
24040086-002A	PWC-8	NELAP		1.0	1.3	µg/L	1	04/03/2024 8:23	03/29/2024 16:45



Receiving Check List

<http://www.teklabinc.com/>

Client: SCI Engineering, Inc.

Work Order: 24040086

Client Project: 2018-0351.2A T200

Report Date: 03-Apr-24

Carrier: John Duarte

Received By: LEH

Completed by:

On:

01-Apr-24

Paul Schultz

Reviewed by:

On:

01-Apr-24

Elizabeth A. Hurley

Pages to follow:

Chain of custody

1

Extra pages included

0

Shipping container/cooler in good condition?

Yes ☒

No ☐

Not Present ☐

Temp °C 24.1

Type of thermal preservation?

None ☒

Ice ☐

Blue Ice ☐

Dry Ice ☐

Chain of custody present?

Yes ☒

No ☐

Chain of custody signed when relinquished and received?

Yes ☒

No ☐

Chain of custody agrees with sample labels?

Yes ☒

No ☐

Samples in proper container/bottle?

Yes ☒

No ☐

Sample containers intact?

Yes ☒

No ☐

Sufficient sample volume for indicated test?

Yes ☒

No ☐

All samples received within holding time?

Yes ☒

No ☐

Reported field parameters measured:

Field ☐

Lab ☐

NA ☒

Container/Temp Blank temperature in compliance?

Yes ☒

No ☐

When thermal preservation is required, samples are compliant with a temperature between 0.1°C - 6.0°C, or when samples are received on ice the same day as collected.

Water – at least one vial per sample has zero headspace?

Yes ☐

No ☐

No VOA vials ☒

Water - TOX containers have zero headspace?

Yes ☐

No ☐

No TOX containers ☒

Water - pH acceptable upon receipt?

Yes ☒

No ☐

NA ☐

NPDES/CWA TCN interferences checked/treated in the field?

Yes ☐

No ☐

NA ☒

Any No responses must be detailed below or on the COC.

Samples were checked for turbidity and then preserved with nitric acid upon arrival in the laboratory.

TEKLAB INC, 5445 Horseshoe Lake Road, Collinsville, IL 62234 Phone (618) 344-1004 Fax (618) 344-1005

[illegible]

*The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions

UH 4/1/24



Pace Analytical Services, LLC

2231 W. Altorfer Drive

Peoria, IL 61615

(800)752-6651

December 12, 2024

Brian Lieb
SCI Engineering
130 Point W. Blvd.
St. Charles, MO 63301

RE: 2018-0351.2A-T200-PATHWAYS WELLNESS

Dear Brian Lieb:

Please find enclosed the analytical results for the **2** sample(s) the laboratory received on **12/3/24 4:50 pm** and logged in under work order **HL01111**. All testing is performed according to our current TNI accreditations unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of Pace Analytical Services, LLC.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

Pace Analytical Services appreciates the opportunity to provide you with analytical expertise . We are always trying to improve our customer service and we welcome you to contact the General Manager, Lisa Grant, with any feedback you have about your experience with our laboratory at 309-683-1764 or lisa.grant@pacelabs.com.

A handwritten signature in black ink, appearing to read 'Chenise Lambert-Sykes'.

Chenise Lambert-Sykes
Project Manager
(314)432-0550
Chenise.Lambert-Sykes@pacelabs.com

**SAMPLE RECEIPT CHECK LIST**

Items not applicable will be marked as in compliance

Work Order HL01111

YES	Samples received within temperature compliance when applicable
YES	COC present upon sample receipt
YES	COC completed & legible
YES	Sampler name & signature present
YES	Unique sample IDs assigned
YES	Sample collection location recorded
YES	Date & time collected recorded on COC
YES	Relinquished by client signature on COC
YES	COC & labels match
YES	Sample labels are legible
YES	Appropriate bottle(s) received
YES	Sufficient sample volume received
YES	Sample containers received undamaged
YES	Zero headspace, <6 mm present in VOA vials
YES	Trip blank(s) received
YES	All non-field analyses received within holding times
YES	Short hold time analysis
YES	Current PDC COC submitted
NO	Case narrative provided



ANALYTICAL RESULTS

Sample: HL01111-01
Name: PWC-03R
Matrix: Drinking Water - Grab

Sampled: 11/27/24 18:18
Received: 12/03/24 16:50

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	4.50	ug/L		12/11/24 10:05	1	1.00	12/11/24 12:55	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------

Sample: HL01111-02
Name: PWC-04R
Matrix: Drinking Water - Grab

Sampled: 11/27/24 18:20
Received: 12/03/24 16:50

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	12.0	ug/L		12/11/24 10:05	1	1.00	12/11/24 12:59	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



QC SAMPLE RESULTS

Parameter	Result	Unit	Qual	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit
<u>Batch B450611 - DW 200.8 no prep - EPA 200.8 REV 5.4</u>									
Blank (B450611-BLK1)				Prepared & Analyzed: 12/11/24					
Lead	< 1.00	ug/L							
LCS (B450611-BS1)				Prepared & Analyzed: 12/11/24					
Lead	52.9	ug/L		50.00		106	85-115		
Matrix Spike (B450611-MS1)				Prepared & Analyzed: 12/11/24					
Lead	57.8	ug/L		50.00	0.341	115	70-130		
Matrix Spike (B450611-MS2)				Prepared & Analyzed: 12/11/24					
Lead	57.0	ug/L		50.00	3.02	108	70-130		
Matrix Spike (B450611-MS3)				Prepared & Analyzed: 12/11/24					
Lead	58.3	ug/L		50.00	6.95	103	70-130		
Matrix Spike (B450611-MS4)				Prepared & Analyzed: 12/11/24					
Lead	63.7	ug/L		50.00	12.0	103	70-130		
Matrix Spike (B450611-MS5)				Prepared & Analyzed: 12/11/24					
Lead	51.8	ug/L		50.00	0.753	102	70-130		
Matrix Spike (B450611-MS6)				Prepared & Analyzed: 12/11/24					
Lead	75.3	ug/L		50.00	21.6	107	70-130		
Matrix Spike (B450611-MS7)				Prepared & Analyzed: 12/11/24					
Lead	101	ug/L		50.00	45.8	111	70-130		
Matrix Spike (B450611-MS8)				Prepared & Analyzed: 12/11/24					
Lead	72.0	ug/L		50.00	18.1	108	70-130		
Matrix Spike (B450611-MS9)				Prepared & Analyzed: 12/11/24					
Lead	56.6	ug/L		50.00	3.75	106	70-130		
Matrix Spike (B450611-MSA)				Prepared & Analyzed: 12/11/24					
Lead	54.8	ug/L		50.00	1.80	106	70-130		
Matrix Spike (B450611-MSB)				Prepared & Analyzed: 12/11/24					
Lead	53.4	ug/L		50.00	2.56	102	70-130		
Matrix Spike (B450611-MSC)				Prepared & Analyzed: 12/11/24					
Lead	64.3	ug/L		50.00	8.30	112	70-130		
Matrix Spike (B450611-MSD)				Prepared & Analyzed: 12/11/24					
Lead	58.6	ug/L		50.00	0.0280	117	70-130		
Matrix Spike Dup (B450611-MSD1)				Prepared & Analyzed: 12/11/24					
Lead	55.4	ug/L		50.00	0.341	110	70-130	4	20
Matrix Spike Dup (B450611-MSD2)				Prepared & Analyzed: 12/11/24					
Lead	57.0	ug/L		50.00	3.02	108	70-130	0.02	20
Matrix Spike Dup (B450611-MSD3)				Prepared & Analyzed: 12/11/24					
Lead	59.3	ug/L		50.00	6.95	105	70-130	2	20
Matrix Spike Dup (B450611-MSD4)				Prepared & Analyzed: 12/11/24					
Lead	64.4	ug/L		50.00	12.0	105	70-130	1	20
Matrix Spike Dup (B450611-MSD5)				Prepared & Analyzed: 12/11/24					
Lead	53.5	ug/L		50.00	0.753	105	70-130	3	20
Matrix Spike Dup (B450611-MSD6)				Prepared & Analyzed: 12/11/24					
Lead	75.4	ug/L		50.00	21.6	108	70-130	0.08	20
Matrix Spike Dup (B450611-MSD7)				Prepared & Analyzed: 12/11/24					
Lead	96.6	ug/L		50.00	45.8	102	70-130	5	20



QC SAMPLE RESULTS

Parameter	Result	Unit	Qual	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit
Matrix Spike Dup (B450611-MSD8)	Sample: HL01131-04			Prepared & Analyzed: 12/11/24					
Lead	70.6	ug/L		50.00	18.1	105	70-130	2	20
Matrix Spike Dup (B450611-MSD9)	Sample: HL01134-02			Prepared & Analyzed: 12/11/24					
Lead	56.2	ug/L		50.00	3.75	105	70-130	0.7	20
Matrix Spike Dup (B450611-MSDA)	Sample: HL00670-02			Prepared & Analyzed: 12/11/24					
Lead	54.3	ug/L		50.00	1.80	105	70-130	0.9	20
Matrix Spike Dup (B450611-MSDB)	Sample: HL01147-03			Prepared & Analyzed: 12/11/24					
Lead	53.2	ug/L		50.00	2.56	101	70-130	0.3	20
Matrix Spike Dup (B450611-MSDC)	Sample: HL00107-07			Prepared & Analyzed: 12/11/24					
Lead	63.4	ug/L		50.00	8.30	110	70-130	1	20
Matrix Spike Dup (B450611-MSDD)	Sample: HL00109-02			Prepared & Analyzed: 12/11/24					
Lead	63.4	ug/L		50.00	0.0280	127	70-130	8	20
Matrix Spike Dup (B450611-MSDE)	Sample: HL00170-08			Prepared & Analyzed: 12/11/24					
Lead	58.0	ug/L		50.00	2.53	111	70-130	0.6	20
Matrix Spike Dup (B450611-MSDF)	Sample: HL00170-18			Prepared & Analyzed: 12/11/24					
Lead	55.6	ug/L		50.00	0.787	110	70-130	1	20
Matrix Spike Dup (B450611-MSDG)	Sample: HL00183-02			Prepared & Analyzed: 12/11/24					
Lead	51.0	ug/L		50.00	ND	102	70-130	2	20
Matrix Spike Dup (B450611-MSDH)	Sample: HL00174-08			Prepared & Analyzed: 12/11/24					
Lead	54.5	ug/L		50.00	0.656	108	70-130	0.7	20
Matrix Spike Dup (B450611-MSDI)	Sample: HL00169-08			Prepared & Analyzed: 12/11/24					
Lead	59.0	ug/L		50.00	1.02	116	70-130	2	20
Matrix Spike Dup (B450611-MSDJ)	Sample: HL00169-18			Prepared & Analyzed: 12/11/24					
Lead	58.1	ug/L		50.00	0.499	115	70-130	1	20
Matrix Spike Dup (B450611-MSDK)	Sample: HL00302-06			Prepared & Analyzed: 12/11/24					
Lead	57.0	ug/L		50.00	0.0520	114	70-130	0.9	20
Matrix Spike (B450611-MSE)	Sample: HL00170-08			Prepared & Analyzed: 12/11/24					
Lead	57.7	ug/L		50.00	2.53	110	70-130		
Matrix Spike (B450611-MSF)	Sample: HL00170-18			Prepared & Analyzed: 12/11/24					
Lead	56.1	ug/L		50.00	0.787	111	70-130		
Matrix Spike (B450611-MSG)	Sample: HL00183-02			Prepared & Analyzed: 12/11/24					
Lead	50.0	ug/L		50.00	ND	100	70-130		
Matrix Spike (B450611-MSH)	Sample: HL00174-08			Prepared & Analyzed: 12/11/24					
Lead	54.2	ug/L		50.00	0.656	107	70-130		
Matrix Spike (B450611-MSI)	Sample: HL00169-08			Prepared & Analyzed: 12/11/24					
Lead	57.7	ug/L		50.00	1.02	113	70-130		
Matrix Spike (B450611-MSJ)	Sample: HL00169-18			Prepared & Analyzed: 12/11/24					
Lead	58.7	ug/L		50.00	0.499	116	70-130		
Matrix Spike (B450611-MSK)	Sample: HL00302-06			Prepared & Analyzed: 12/11/24					
Lead	57.5	ug/L		50.00	0.0520	115	70-130		



NOTES

Specifications regarding method revisions, method modifications, and calculations used for analysis are available upon request. Please contact your project manager.

* Not a TNI accredited analyte

Certifications

CHI - McHenry, IL - 4314-A W. Crystal Lake Road, McHenry, IL 60050

TNI Accreditation for Drinking Water and Wastewater Fields of Testing through IL EPA Accreditation No. 100279

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17556

PIA - Peoria, IL - 2231 W. Altorfer Drive, Peoria, IL 61615

TNI Accreditation for Drinking Water, Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. 100230

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17553

Drinking Water Certifications/Accreditations: Iowa (240); Kansas (E-10338); Missouri (870)

Wastewater Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

Solid and Hazardous Material Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO - 1805 W Sunset Street, Springfield, MO 65807

USEPA DMR-QA Program

STL - Hazelwood, MO - 944 Anglum Rd, Hazelwood, MO 63042

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through KS KDHE Certification No. E-10389

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. - 200080

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory, Registry No. 171050

Missouri Department of Natural Resources - Certificate of Approval for Microbiological Laboratory Service - No. 1050

Certified by: Chenise Lambert-Sykes, Project Manager



REGULATORY PROGRAM (CIRCLE):	NPDES
	RCRA
	TACO: RES OR IND/COMM
	CCDD

CHAIN OF CUSTODY RECORD
STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT SCI Engineering ADDRESS 130 Point West Blvd CITY St. Charles, MO 63301 STATE ZIP CONTACT PERSON Brian Lieb		PROJECT NUMBER 2018-0351.2A PHONE NUMBER (314) 581-7570 PROJECT LOCATION Pathways Wellness E-MAIL blieb@sciengineering.com		PURCHASE ORDER # DATE SHIPPED MATRIX TYPES: NH ₃ -NASTEMATER DW- DRINKING WATER GW- GROUND WATER MS- METAL USE MS- NON AQUEOUS SOLID LQ- LEACHATE OIL- OIL SOL- SOLID		ANALYSIS REQUESTED LOGGED BY: <u>HLO/III</u> CLIENT: SCI Engineering PROJECT: Drinking Water Lead PROJ. MGR.: Chenise Lambert-Sykes CUSTODY SEAL #:		REMARKS	
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT) PWC - 03R PWC - 04R		DATE COLLECTED 11/27/24 TIME COLLECTED 1818 SAMPLE TYPE X COMP X BOTTLE COUNT 1 MATRIX TYPE DW PRES CODE 6 PROVIDED		DW Pb Turb Check		3		4 (FOR LAB USE ONLY)	
CHEMICAL PRESERVATION CODES: 1 - HCL 2 - H2SO4 3 - HNO3 4 - NAOH 5 - NA2S2O3 6 - UNPRESERVED 7 - OTHER		DATE RESULTS NEEDED 6		I understand that by initiating this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.		COMMENTS: (FOR LAB USE ONLY)		SAMPLE TEMPERATURE UPON RECEIPT °C	
RELINQUISHED BY: (SIGNATURE) DATE 12/2/24 TIME 1030		RECEIVED BY: (SIGNATURE) DATE 12/3/24 TIME 1030		CHILL PROCESS STARTED PRIOR TO RECEIPT SAMPLE(S) RECEIVED ON ICE SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N Y OR N Y OR N		DATE AND TIME TAKEN FROM SAMPLE BOTTLE 1650		DATE AND TIME TAKEN FROM SAMPLE BOTTLE	

ENV-FRM-PEOR-0098 v02_Sample Condition Upon Receipt



Client Name: SCI Engineering

Work Order #: _____

Completed by Initials/Date: CRB 12-3-20 1650

Sample Intake Notes:

Custody Seal Present on Package(s)	Yes ☒ No ☐	
If yes, was seal intact	Yes ☐ No ☐	
Samples received within temperature compliance	Yes ☐ No ☒ N/A	
Was Project Manager contacted if samples were received out of temperature compliance	Yes ☐ No ☐	
Chain of Custody Present	☒ Yes ☐ No	
Current PACE CoC Submitted	☒ Yes ☐ No	
Rush Turn Around Time Requested	Yes ☐ No ☒	
CoC is Legible	☒ Yes ☐ No	
Sampler Name Present	☒ Yes ☐ No	
Sampler Signature Present	☒ Yes ☐ No	
USDA Regulated Soil	Yes ☐ No ☒ N/A	
Country of Origin	Yes ☐ No ☐	
State of Origin		
Unique Sample ID's Present on CoC (If not, Note Container ID's & Contact Project Manager)	☒ Yes ☐ No	
Container(s) Received Intact (If not, Note & Contact Project Manager)	☒ Yes ☐ No	
Containers Received Labeled	☒ Yes ☐ No	
Container Labels are Legible	☒ Yes ☐ No	
Sample Collection Date Present on CoC	☒ Yes ☐ No	
Sample Collection Time Present on CoC	☒ Yes ☐ No	
CoC Relinquished by Client	☒ Yes ☐ No	
CoC and Sample Container Labels Match <u>CRB</u>	☒ Yes ☐ No	<u>VE-9R2 → 9R3</u>
Appropriate Bottles	☒ Yes ☐ No	
Sufficient Sample Volume	☒ Yes ☐ No	
Zero Headspace (<6 mm or no bubbles) present in VOA vials (If headspace is present, note sample ID and # of vials)	Yes ☐ No ☒ N/A	
Trip Blank(s) Received	Yes ☐ No ☒ N/A	
If present, are they Listed on CoC	Yes ☐ No ☐	
All (Non-Field) Analysis Received Within Hold Times	Yes ☐ No ☐	
Short Hold Time Analysis Requested (48 Hours or Less)	Yes ☐ No ☐	
Case Narrative Needed	Yes ☐ No ☐	

Client Notification/Resolution:

If checked, please see attached form for additional comments ☐

Person Contacted: _____

Date/Time: _____

Comments/Resolution: _____

PM Review is documented electronically in LIMS. By releasing the project, the PM acknowledges they have reviewed the sample.



Pace Analytical Services, LLC

2231 W. Altorfer Drive

Peoria, IL 61615

(800)752-6651

July 24, 2025

Glenn Grissom
SCI Engineering
130 Point W. Blvd.
St. Chariles, MO 63301

RE: 2018-0351-2A Task 200 - PWC

Dear Glenn Grissom:

Please find enclosed the analytical results for the **1** sample(s) the laboratory received on **7/10/25 4:30 pm** and logged in under work order **IG02338**. All testing is performed according to our current TNI accreditations unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of Pace Analytical Services, LLC.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

Pace Analytical Services appreciates the opportunity to provide you with analytical expertise . We are always trying to improve our customer service and we welcome you to contact the General Manager, Lisa Grant, with any feedback you have about your experience with our laboratory at 309-683-1764 or lisa.grant@pacelabs.com.

A handwritten signature in black ink, appearing to read 'Chenise Lambert-Sykes'.

Chenise Lambert-Sykes
Project Manager
(314)432-0550
Chenise.Lambert-Sykes@pacelabs.com



Pace Analytical Services, LLC

2231 W. Altorfer Drive

Peoria, IL 61615

(800)752-6651

ANALYTICAL RESULTS

Sample: IG02338-01

Name: PWC - 4R2

Matrix: Drinking Water - Grab

Sampled: 07/07/25 20:50

Received: 07/10/25 16:30

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	-----	----------	---------	--------

Total Metals - PIA

Lead	5.65	ug/L		07/22/25 06:52	1	1.00	07/22/25 10:39	BRS	EPA 200.8 REV 5.4
------	------	------	--	----------------	---	------	----------------	-----	-------------------



QC SAMPLE RESULTS

Parameter	Result	Unit	Qual	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit
<u>Batch B538313 - DW 200.8 no prep - EPA 200.8 REV 5.4</u>									
Blank (B538313-BLK1)				Prepared & Analyzed: 07/22/25					
Lead	< 1.00	ug/L							
LCS (B538313-BS1)				Prepared & Analyzed: 07/22/25					
Lead	52.8	ug/L		50.00		106	85-115		
Matrix Spike (B538313-MS1)				Prepared & Analyzed: 07/22/25					
Lead	59.9	ug/L		50.00	2.37	115	70-130		
Matrix Spike (B538313-MS2)				Prepared & Analyzed: 07/22/25					
Lead	55.6	ug/L		50.00	0.618	110	70-130		
Matrix Spike (B538313-MS3)				Prepared & Analyzed: 07/22/25					
Lead	52.4	ug/L		50.00	0.0260	105	70-130		
Matrix Spike (B538313-MS4)				Prepared & Analyzed: 07/22/25					
Lead	52.8	ug/L		50.00	1.51	103	70-130		
Matrix Spike (B538313-MS5)				Prepared & Analyzed: 07/22/25					
Lead	51.4	ug/L		50.00	0.146	103	70-130		
Matrix Spike (B538313-MS6)				Prepared & Analyzed: 07/22/25					
Lead	50.4	ug/L		50.00	0.613	100	70-130		
Matrix Spike (B538313-MS7)				Prepared & Analyzed: 07/22/25					
Lead	53.9	ug/L		50.00	3.03	102	70-130		
Matrix Spike (B538313-MS8)				Prepared & Analyzed: 07/22/25					
Lead	59.9	ug/L		50.00	8.98	102	70-130		
Matrix Spike (B538313-MS9)				Prepared & Analyzed: 07/22/25					
Lead	58.7	ug/L		50.00	6.18	105	70-130		
Matrix Spike (B538313-MSA)				Prepared & Analyzed: 07/22/25					
Lead	49.9	ug/L		50.00	ND	100	70-130		
Matrix Spike (B538313-MSB)				Prepared & Analyzed: 07/22/25					
Lead	53.5	ug/L		50.00	ND	107	70-130		
Matrix Spike (B538313-MSC)				Prepared & Analyzed: 07/22/25					
Lead	55.2	ug/L		50.00	0.455	109	70-130		
Matrix Spike (B538313-MSD)				Prepared & Analyzed: 07/22/25					
Lead	51.1	ug/L		50.00	0.538	101	70-130		
Matrix Spike Dup (B538313-MSD1)				Prepared & Analyzed: 07/22/25					
Lead	56.9	ug/L		50.00	2.37	109	70-130	5	20
Matrix Spike Dup (B538313-MSD2)				Prepared & Analyzed: 07/22/25					
Lead	54.0	ug/L		50.00	0.618	107	70-130	3	20
Matrix Spike Dup (B538313-MSD3)				Prepared & Analyzed: 07/22/25					
Lead	53.3	ug/L		50.00	0.0260	107	70-130	2	20
Matrix Spike Dup (B538313-MSD4)				Prepared & Analyzed: 07/22/25					
Lead	52.3	ug/L		50.00	1.51	102	70-130	1	20
Matrix Spike Dup (B538313-MSD5)				Prepared & Analyzed: 07/22/25					
Lead	52.1	ug/L		50.00	0.146	104	70-130	1	20
Matrix Spike Dup (B538313-MSD6)				Prepared & Analyzed: 07/22/25					
Lead	48.2	ug/L		50.00	0.613	95	70-130	5	20
Matrix Spike Dup (B538313-MSD7)				Prepared & Analyzed: 07/22/25					
Lead	53.1	ug/L		50.00	3.03	100	70-130	2	20



QC SAMPLE RESULTS

Parameter	Result	Unit	Qual	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit
Matrix Spike Dup (B538313-MSD8)	Sample: IG02336-01			Prepared & Analyzed: 07/22/25					
Lead	60.7	ug/L		50.00	8.98	103	70-130	1	20
Matrix Spike Dup (B538313-MSD9)	Sample: IG02343-02			Prepared & Analyzed: 07/22/25					
Lead	58.0	ug/L		50.00	6.18	104	70-130	1	20
Matrix Spike Dup (B538313-MSDA)	Sample: IG03532-06			Prepared & Analyzed: 07/22/25					
Lead	50.8	ug/L		50.00	ND	102	70-130	2	20
Matrix Spike Dup (B538313-MSDB)	Sample: IG02229-01			Prepared & Analyzed: 07/22/25					
Lead	54.5	ug/L		50.00	ND	109	70-130	2	20
Matrix Spike Dup (B538313-MSDC)	Sample: IG02443-02			Prepared & Analyzed: 07/22/25					
Lead	55.6	ug/L		50.00	0.455	110	70-130	0.8	20
Matrix Spike Dup (B538313-MSDD)	Sample: IG03235-01			Prepared & Analyzed: 07/22/25					
Lead	52.2	ug/L		50.00	0.538	103	70-130	2	20
Matrix Spike Dup (B538313-MSDE)	Sample: IG03242-01			Prepared & Analyzed: 07/22/25					
Lead	59.8	ug/L		50.00	7.06	106	70-130	0.02	20
Matrix Spike Dup (B538313-MSDF)	Sample: IG03527-06			Prepared & Analyzed: 07/22/25					
Lead	51.5	ug/L		50.00	0.778	102	70-130	1	20
Matrix Spike Dup (B538313-MSDG)	Sample: IG03535-01			Prepared & Analyzed: 07/22/25					
Lead	50.5	ug/L		50.00	0.163	101	70-130	0.3	20
Matrix Spike Dup (B538313-MSDH)	Sample: IG03513-09			Prepared & Analyzed: 07/22/25					
Lead	51.6	ug/L		50.00	0.561	102	70-130	2	20
Matrix Spike Dup (B538313-MSDI)	Sample: IG03513-19			Prepared & Analyzed: 07/22/25					
Lead	51.8	ug/L		50.00	0.0390	103	70-130	2	20
Matrix Spike Dup (B538313-MSDJ)	Sample: IG03523-01			Prepared & Analyzed: 07/22/25					
Lead	51.5	ug/L		50.00	0.0840	103	70-130	2	20
Matrix Spike Dup (B538313-MSDK)	Sample: IG03517-06			Prepared & Analyzed: 07/22/25					
Lead	51.6	ug/L		50.00	0.0910	103	70-130	1	20
Matrix Spike Dup (B538313-MSDL)	Sample: IG03530-06			Prepared & Analyzed: 07/22/25					
Lead	51.9	ug/L		50.00	0.862	102	70-130	0.3	20
Matrix Spike Dup (B538313-MSDM)	Sample: IG02935-01			Prepared & Analyzed: 07/22/25					
Lead	257	ug/L		50.00	204	106	70-130	1	20
Matrix Spike (B538313-MSE)	Sample: IG03242-01			Prepared & Analyzed: 07/22/25					
Lead	59.8	ug/L		50.00	7.06	106	70-130		
Matrix Spike (B538313-MSF)	Sample: IG03527-06			Prepared & Analyzed: 07/22/25					
Lead	50.8	ug/L		50.00	0.778	100	70-130		
Matrix Spike (B538313-MSG)	Sample: IG03535-01			Prepared & Analyzed: 07/22/25					
Lead	50.3	ug/L		50.00	0.163	100	70-130		
Matrix Spike (B538313-MSH)	Sample: IG03513-09			Prepared & Analyzed: 07/22/25					
Lead	52.5	ug/L		50.00	0.561	104	70-130		
Matrix Spike (B538313-MSI)	Sample: IG03513-19			Prepared & Analyzed: 07/22/25					
Lead	50.7	ug/L		50.00	0.0390	101	70-130		
Matrix Spike (B538313-MSJ)	Sample: IG03523-01			Prepared & Analyzed: 07/22/25					
Lead	50.2	ug/L		50.00	0.0840	100	70-130		
Matrix Spike (B538313-MSK)	Sample: IG03517-06			Prepared & Analyzed: 07/22/25					
Lead	50.9	ug/L		50.00	0.0910	102	70-130		
Matrix Spike (B538313-MSL)	Sample: IG03530-06			Prepared & Analyzed: 07/22/25					
Lead	52.1	ug/L		50.00	0.862	103	70-130		



Pace Analytical Services, LLC

2231 W. Altorfer Drive

Peoria, IL 61615

(800)752-6651

QC SAMPLE RESULTS

Parameter	Result	Unit	Qual	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit
Matrix Spike (B538313-MSM)				Sample: IG02935-01		Prepared & Analyzed: 07/22/25			
Lead	254	ug/L		50.00	204	98	70-130		



NOTES

Specifications regarding method revisions, method modifications, and calculations used for analysis are available upon request. Please contact your project manager.

* Not a TNI accredited analyte

Certifications

CHI - McHenry, IL - 4314-A W. Crystal Lake Road, McHenry, IL 60050

TNI Accreditation for Drinking Water and Wastewater Fields of Testing through IL EPA Accreditation No. 100279

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17556

PIA - Peoria, IL - 2231 W. Altorfer Drive, Peoria, IL 61615

TNI Accreditation for Drinking Water, Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. 100230

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17553

Drinking Water Certifications/Accreditations: Iowa (240); Kansas (E-10338); Missouri (870)

Wastewater Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

Solid and Hazardous Material Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO - 1805 W Sunset Street, Springfield, MO 65807

USEPA DMR-QA Program

STL - Hazelwood, MO - 944 Anglum Rd, Hazelwood, MO 63042

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through KS KDHE Certification No. E-10389

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. - 200080

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory, Registry No. 171050

Missouri Department of Natural Resources - Certificate of Approval for Microbiological Laboratory Service - No. 1050



Certified by: Station For Chenise Lambert-Sykes, Project Manager



Pace Analytical Services, LLC

2231 W. Altorfer Drive

Peoria, IL 61615

(800)752-6651

April 01, 2026

Glenn Grissom
SCI Engineering
130 Point W. Blvd.
St. Chariles, MO 63301

RE: 2018-0351.2AT200-Pathways Wellness

Dear Glenn Grissom:

Please find enclosed the analytical results for the **1** sample(s) the laboratory received on **3/25/26 1:51 pm** and logged in under work order **JC04720**. All testing is performed according to our current TNI accreditations unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of Pace Analytical Services, LLC.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

Pace Analytical Services appreciates the opportunity to provide you with analytical expertise . We are always trying to improve our customer service and we welcome you to contact the General Manager, Lisa Grant, with any feedback you have about your experience with our laboratory at 309-683-1764 or lisa.grant@pacelabs.com.

A handwritten signature in black ink, appearing to read 'Chenise Lambert-Sykes'.

Chenise Lambert-Sykes
Project Manager
(314)432-0550
Chenise.Lambert-Sykes@pacelabs.com



Pace Analytical Services, LLC

2231 W. Altorfer Drive

Peoria, IL 61615

(800)752-6651

ANALYTICAL RESULTS

Sample: JC04720-01

Name: PWC - 04R3

Matrix: Drinking Water - Grab

Sampled: 03/20/26 19:05

Received: 03/25/26 13:51

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
<u>Total Metals - PIA</u>									
Lead	< 1.00	ug/L		03/31/26 09:35	1	1.00	03/31/26 13:22	BRS	EPA 200.8 REV 5.4



QC SAMPLE RESULTS

Parameter	Result	Unit	Qual	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit
<u>Batch B629677 - DW 200.8 no prep - EPA 200.8 REV 5.4</u>									
Matrix Spike (B629677-MS1)	Sample: JC04582-07			Prepared & Analyzed: 03/31/26					
Lead	53.4	ug/L		50.00	0.245	106	70-130		
Matrix Spike (B629677-MS2)	Sample: JC04412-01			Prepared & Analyzed: 03/31/26					
Lead	52.8	ug/L		50.00	0.0840	105	70-130		
Matrix Spike (B629677-MS3)	Sample: JC04719-01			Prepared & Analyzed: 03/31/26					
Lead	52.0	ug/L		50.00	0.156	104	70-130		
Matrix Spike (B629677-MS4)	Sample: JC04679-01			Prepared & Analyzed: 03/31/26					
Lead	50.6	ug/L		50.00	0.0210	101	70-130		
Matrix Spike (B629677-MS5)	Sample: JC05036-05			Prepared & Analyzed: 03/31/26					
Lead	52.1	ug/L		50.00	0.794	103	70-130		
Matrix Spike (B629677-MS6)	Sample: JC05032-04			Prepared & Analyzed: 03/31/26					
Lead	50.2	ug/L		50.00	0.0510	100	70-130		
Matrix Spike (B629677-MS7)	Sample: JC05027-02			Prepared & Analyzed: 03/31/26					
Lead	50.1	ug/L		50.00	ND	100	70-130		
Matrix Spike (B629677-MS8)	Sample: JC04493-02			Prepared & Analyzed: 03/31/26					
Lead	51.1	ug/L		50.00	ND	102	70-130		
Matrix Spike (B629677-MS9)	Sample: JC04712-06			Prepared & Analyzed: 03/31/26					
Lead	50.5	ug/L		50.00	0.126	101	70-130		
Matrix Spike (B629677-MSA)	Sample: JC04669-10			Prepared & Analyzed: 03/31/26					
Lead	51.0	ug/L		50.00	0.0370	102	70-130		
Matrix Spike (B629677-MSB)	Sample: JC04669-20			Prepared & Analyzed: 03/31/26					
Lead	52.4	ug/L		50.00	0.0660	105	70-130		
Matrix Spike (B629677-MSC)	Sample: JC05041-06			Prepared & Analyzed: 03/31/26					
Lead	51.2	ug/L		50.00	0.383	102	70-130		
Matrix Spike (B629677-MSD)	Sample: JC04978-08			Prepared & Analyzed: 03/31/26					
Lead	50.7	ug/L		50.00	0.436	101	70-130		
Matrix Spike Dup (B629677-MSD1)	Sample: JC04582-07			Prepared & Analyzed: 03/31/26					
Lead	52.6	ug/L		50.00	0.245	105	70-130	2	20
Matrix Spike Dup (B629677-MSD2)	Sample: JC04412-01			Prepared & Analyzed: 03/31/26					
Lead	52.5	ug/L		50.00	0.0840	105	70-130	0.6	20
Matrix Spike Dup (B629677-MSD3)	Sample: JC04719-01			Prepared & Analyzed: 03/31/26					
Lead	52.6	ug/L		50.00	0.156	105	70-130	1	20
Matrix Spike Dup (B629677-MSD4)	Sample: JC04679-01			Prepared & Analyzed: 03/31/26					
Lead	53.9	ug/L		50.00	0.0210	108	70-130	6	20
Matrix Spike Dup (B629677-MSD5)	Sample: JC05036-05			Prepared & Analyzed: 03/31/26					
Lead	51.5	ug/L		50.00	0.794	101	70-130	1	20
Matrix Spike Dup (B629677-MSD6)	Sample: JC05032-04			Prepared & Analyzed: 03/31/26					
Lead	49.2	ug/L		50.00	0.0510	98	70-130	2	20
Matrix Spike Dup (B629677-MSD7)	Sample: JC05027-02			Prepared & Analyzed: 03/31/26					
Lead	51.3	ug/L		50.00	ND	103	70-130	2	20
Matrix Spike Dup (B629677-MSD8)	Sample: JC04493-02			Prepared & Analyzed: 03/31/26					
Lead	51.4	ug/L		50.00	ND	103	70-130	0.6	20
Matrix Spike Dup (B629677-MSD9)	Sample: JC04712-06			Prepared & Analyzed: 03/31/26					
Lead	52.1	ug/L		50.00	0.126	104	70-130	3	20



QC SAMPLE RESULTS

Parameter	Result	Unit	Qual	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit
Matrix Spike Dup (B629677-MSDA)	Sample: JC04669-10		Prepared & Analyzed: 03/31/26						
Lead	51.2	ug/L		50.00	0.0370	102	70-130	0.3	20
Matrix Spike Dup (B629677-MSDB)	Sample: JC04669-20		Prepared & Analyzed: 03/31/26						
Lead	50.0	ug/L		50.00	0.0660	100	70-130	5	20
Matrix Spike Dup (B629677-MSDC)	Sample: JC05041-06		Prepared & Analyzed: 03/31/26						
Lead	51.9	ug/L		50.00	0.383	103	70-130	1	20
Matrix Spike Dup (B629677-MSDD)	Sample: JC04978-08		Prepared & Analyzed: 03/31/26						
Lead	49.8	ug/L		50.00	0.436	99	70-130	2	20
Matrix Spike Dup (B629677-MSDE)	Sample: JC04978-18		Prepared & Analyzed: 03/31/26						
Lead	52.5	ug/L		50.00	0.0770	105	70-130	2	20
Matrix Spike Dup (B629677-MSDG)	Sample: JC04730-04		Prepared & Analyzed: 03/31/26						
Lead	58.5	ug/L		50.00	4.52	108	70-130	4	20
Matrix Spike (B629677-MSE)	Sample: JC04978-18		Prepared & Analyzed: 03/31/26						
Lead	51.3	ug/L		50.00	0.0770	102	70-130		
Matrix Spike (B629677-MSF)	Sample: JC04978-28		Prepared & Analyzed: 03/31/26						
Lead	53.0	ug/L		50.00	1.48	103	70-130		
Matrix Spike (B629677-MSG)	Sample: JC04730-04		Prepared & Analyzed: 03/31/26						
Lead	56.4	ug/L		50.00	4.52	104	70-130		



NOTES

Specifications regarding method revisions, method modifications, and calculations used for analysis are available upon request. Please contact your project manager.

* Not a TNI accredited analyte

Certifications

CHI - McHenry, IL - 4314-A W. Crystal Lake Road, McHenry, IL 60050

TNI Accreditation for Drinking Water and Wastewater Fields of Testing through IL EPA Accreditation No. 100279

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17556

PIA - Peoria, IL - 2231 W. Altorfer Drive, Peoria, IL 61615

TNI Accreditation for Drinking Water, Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. 100230

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17553

Drinking Water Certifications/Accreditations: Iowa (240); Kansas (E-10338); Missouri (870)

Wastewater Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

Solid and Hazardous Material Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO - 1805 W Sunset Street, Springfield, MO 65807

USEPA DMR-QA Program

STL - Hazelwood, MO - 944 Anglum Rd, Hazelwood, MO 63042

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through KS KDHE Certification No. E-10389

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. - 200080

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory, Registry No. 171050

Missouri Department of Natural Resources - Certificate of Approval for Microbiological Laboratory Service - No. 1050

Certified by: Chenise Lambert-Sykes, Project Manager



Pace® Location Requested (City/State): CHAIN-OF-CUSTODY Analytical Request Document									
Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields									
Company Name: SCI Engineering Street Address: 130 Point West Blvd St. Charles, MO 63301		Contact/Report To: Ethan Boyer Phone #: (314) 341-1911, or 636-949-8200 E-Mail: EBoyer@sciengineering.com Cc E-Mail:		Invoice to: Ethan Boyer Invoice E-mail: EBoyer@sciengineering.com Purchase Order # (if applicable): Quote #:		Country / State origin of sample(s): Reportable [] Yes [] No		Time Zone Collected: [] AK [] PT [] MT [] CT [] ET Data Deliverables: [] Level II [] Level III [] Level IV [] EQUIS [] Other:	
Customer Project #: 2018-0751-2A T200 Project Name: Drinking Water Lead Site Collection Info/Facility ID (as applicable): Pathways Wellness		Regulatory Program (DW, RCRA, etc.) as applicable: Rush (Pre-approval required): [] Same Day [] 1 Day [] 2 Day [] 3 Day Other:		DW PWSID # or WW Permit # as applicable: Field Filtered (if applicable): [] Yes [] No Analysis:		Field Filtered (if applicable): [] Yes [] No Analysis:		Request: Standard Turn * Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Wastewater (WW), Product (P), Soil/Solid (SS), Oil/DOL Wipe (WP), Tissue (TS), Biosolids (BS), Vapor (V), Surface Water (SW), Sediment (SD), Sludge (SL), Cask (CX), Leachate (LL), Biosolid (BS), Other (OT)	
Matrix * DW G		Composite Start Date: Time:		Collected or Composite End Date: Time:		# Cont. 1		Residual Chlorine Result: Units:	
Customer Sample ID PWC-04R3		Date: Time:		Date: Time:		Date: Time:		Date: Time:	
Additional Instructions from Pace®:									
Relinquished by (Company): Signature: <i>Ethan Boyer</i> Date/Time: 2/23/26 1200		Received by (Company): Signature: <i>David Jennings</i> Date/Time: 2/23/26 1351		Relinquished by (Company): Signature: <i>Ethan Boyer</i> Date/Time: 2/23/26 1200		Received by (Company): Signature: <i>David Jennings</i> Date/Time: 2/23/26 1351		Relinquished by (Company): Signature: <i>Ethan Boyer</i> Date/Time: 2/23/26 1200	
Relinquished by (Company): Signature: <i>Ethan Boyer</i> Date/Time: 2/23/26 1200		Received by (Company): Signature: <i>David Jennings</i> Date/Time: 2/23/26 1351		Relinquished by (Company): Signature: <i>Ethan Boyer</i> Date/Time: 2/23/26 1200		Received by (Company): Signature: <i>David Jennings</i> Date/Time: 2/23/26 1351		Relinquished by (Company): Signature: <i>Ethan Boyer</i> Date/Time: 2/23/26 1200	
Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace® Terms and Conditions found at https://www.pacelabs.com/resource-library/resource/pace-terms-and-conditions/									

LAB USE ONLY - Affix Workorder/Login Label Here

1004700

Scan QR Code for instructions



Specify Container Size **

Identify Container Preservation Type ***

Analysis Requested

Lab Use Only

Proj. Mgr:

Chemise Lambert-Sykes

Acct/Hum / Client ID:

Table #:

Profile / Template:

Prelig / Bottle Ord. ID:

Sample Comment

Preservation non-conformance identified for sample:

Customer Remarks / Special Conditions / Possible Hazards:

Coolers: Thermometer ID: Correction Factor (°C): Obs. Temp. (°C): Corrected Temp. (°C): [] On Ice

Tracking Number:

Date/Time:

Delivered by: [] In-Person [] Courier [] FedEx [] UPS [] Other

Date/Time:

Date/Time:

Date/Time:

Date/Time:

Page: 3-15-26 1351 of 1

ENV-FRM-CORQ-0019_v02_110123 ©

ENV-FRM-PEOR-0098 v05_Sample Condition Upon Receipt

Client Name: SLI Work Order #: JCO 4720 Completed by / Date: CB 3-25-26

Custody seal on cooler/box present and seal intact:	☐ Yes ☐ No ☒ N/A
Chain of Custody (CoC) Present:	☒ Yes ☐ No
CoC is Legible:	☒ Yes ☐ No
Sampler Name Present on CoC:	☒ Yes ☐ No
Sampler Signature Present on CoC:	☒ Yes ☐ No
Sample Collection Date Present on CoC:	☒ Yes ☐ No
Sample Collection Time Present on CoC:	☒ Yes ☐ No
CoC Relinquished by Client:	☒ Yes ☐ No
Unique Sample ID's Present on CoC:	☒ Yes ☐ No
CoC and Sample Container Labels Match:	☒ Yes ☐ No
Sample chilling process started prior to receipt: If yes, what type of ice:	☐ Yes ☐ No ☒ N/A ☐ Wet ☐ Blue
Samples received within temperature compliance: ($\leq 6^{\circ}\text{C}$, but above freezing or received same day collected and chill process started prior to receipt)	☐ Yes ☐ No ☒ N/A
Container(s) Received Intact:	☒ Yes ☐ No
Containers Received Labeled and Labels are Legible:	☒ Yes ☐ No
Appropriate Bottles Received for Analysis Requested:	☒ Yes ☐ No
Sufficient Sample Volume Received:	☒ Yes ☐ No
USDA Regulated Soil: Country of Origin: _____ State of Origin: _____	☐ Yes ☐ No ☒ N/A
Trip Blank(s) Received: If present, are they Listed on CoC:	☐ Yes ☐ No ☒ N/A ☐ Yes ☐ No
VOA vials are free of any headspace larger than pea sized bubble (>6mm) – Applies to methods 8260, 624, 524.2 - including THM vials *If headspace is present, note sample ID and # of vials	☐ Yes ☐ No ☒ N/A
All (Non-Field) Analysis Received Within Hold Times:	☒ Yes ☐ No
Rush Turn Around Time Requested or Time Sensitive Analysis:	☐ Yes ☒ No
Short Hold Time Analysis (48 Hours or Less):	☐ Yes ☒ No

Client Notification/ Resolution:

If checked, please see attached form for additional comments ☐

Person Contacted: _____ Date/Time: _____

Comments/ Resolution: _____

PM Review is documented electronically in LIMS. By releasing the project, the PM acknowledges they have reviewed the sample.

WORK ORDER #: _____ INITIALS: Cgb

Drinking Water Bottle Receipt Form

SOC (Synthetic Organic Chemicals)

Method	Description	Bottle Type	Qty	-1	-2	-3	-4	-5	-6	-7	-8
Chlorine Check	Chlorine Check	P, U, 150 ml	1								
M504	EDB & DBCP	C,V, 40 ml, Na2S2O3	3								
M504 Trip Blank	Trip Blank	C,V, 40 ml, Na2S2O3	2								
M505 (subcontract)	Toxaphene	C,V, 40 ml, Na2S2O3	3								
M515.3/548	Chlorinated Acids/Endothal	A, G, 500 ml, Na2S2O3	2								
M525.2	Semi-Volatiles	A, G, 1000 ml, Na2S2O3 + HCl	3								
M531	Carbamates	A, V, 60 ml, Na2S2O3 + MCAA	1								
M549.2	Diquat	A, P, 1000 ml, Na2S2O3 + H2SO4	1								
M550	Benzo(a)Pyrene	A, G, 1000 ml, Na2S2O3 + HCl	3								
*M547	Glyphosate	A, V, 60 ml, Na2S2O3	1								
*M547 Trip Blank	Trip Blank	A, V, 60 ml, Na2S2O3	1								

**SOC_W_GLPPOS" & "SOC_IDPH_GROUP A" ONLY

VOC (Volatile Organic Chemicals)

Method	Description	Bottle Type	Qty	-1	-2	-3	-4	-5	-6	-7	-8
M524.2	Regulated Volatile	C,V, 40 ml, HCl	3								
M524.2 Trip Blank	Trip Blank	C,V, 40 ml, HCl	3								
Chlorine Check	Chlorine Check	P, U, 150 ml	1								

IOC (Inorganic Chemicals)

Method	Description	Bottle Type	Qty	-1	-2	-3	-4	-5	-6	-7	-8
*300.0 SO4 & Fluoride Probe	Sulfate by IC/Fluoride Probe	P, 500 ml, Total	1								
**Metals - As, Ba, Be, Cd, Cr, Fe, Hg, Mn, Na, Ni, Sb, Se, Tl, Zn & Turb Check	Metals	P, 250 ml, HNO3, Total	1								
CN-T Kelada DW	Cyanide Total	P, 250 ml, NaOH	1								

*Excluded from "IOC IDPH SHORT LIST"

**Excluded Fe, Mn ,Na ,Ni & Zn from "IOC IDPH SHORT LIST" Fe, Mn ,Na ,Ni & Zn

THM/HAA

Method	Description	Bottle Type	Qty	-1	-2	-3	-4	-5	-6	-7	-8
THM M524	Trihalomethane	C,V, 40 ml, Na2S2O3	4								
HAA M552	Haloacetic Acid	A, V, 60 ML NH4CL	4								
Chlorine Check	Chlorine Check	P, U, 150 ml	1								

TOC

Method	Description	Bottle Type	Qty	-1	-2	-3	-4	-5	-6	-7	-8
TOC	Total Organic Carbon	A, V, 40 ml, H2SO4	3								

Chlorite/Bromate

Method	Description	Bottle Type	Qty	-1	-2	-3	-4	-5	-6	-7	-8
Bromate (Subcontract)	Bromate	P, 100 ml, EDA	1								
Chlorite (Subcontract)	Chlorite	P, 100 ml, EDA	1								

Lead/Copper

Method	Description	Bottle Type	Qty
Lead/Copper	Lead Copper	P, 1000ml LC	
School Lead	Lead	P, 250ml LC	1

PFAS

Method	Description	Bottle Type	Qty	-1	-2	-3	-4	-5	-6	-7	-8
M533	PFAS	533, P, 250mL, C2H7NO2									
M533 FRB	PFAS - FRB	533, P, 250mL, C2H7NO2									
M537.1	PFAS	537.1, P, 250 mL, TRZ									
M537.1 FRB	PFAS - FRB	537.1, P, 250 mL, TRZ									

Table 1 – Lead in Drinking Water Results

Sample Number	Sample Location	Sample Description	Initial Result (ppb)	1st Resample (ppb)	2nd Resample (ppb)	3rd Resample (ppb)
PWC-03	Pathways Wellness Center - Gym	Water Fountain	9.32	4.5	NS	
PWC-04	Pathways Wellness Center - Gym	Bottle Filler	5.79	12	5.65	<1.00
PWC-05	Pathways Wellness Center - 2 nd Floor Hallway near Room B-202	Water Fountain	7.28	3.3	NS	
PWC-08	Admin Annex A - 2 nd Floor Hallway	Ice/Water Machine	6.33	1.3	NS	