



**ROOFING IMPROVEMENTS AT EAST CENTRAL HS AND SPRINGDALE
ELEMENTARY**

07.22.26

Addendum # 6

This addendum is hereby a part of those documents and contracts, the same as if bound therein and it shall supersede anything contained in the original bid manual with which it might conflict.

1. Bid opening date is July 31, 2026, at 10:00AM, Room 600. Submit bids prior to 10:00AM in room 623.

At Springdale Elementary School:

1. Where three (3) new fixed access ladders are to be installed, they shall now be ramps that are to match the same style, configuration, and attachment method as the ramp shown in the photo below that is currently in place at Springdale Elementary. Ramps are to be included in the total base bid.



2. Gutters and Downspouts – Material Clarification

The Bid Documents identify prefinished aluminum as the base specification for gutters and downspouts, with 24-gauge prefinished steel/Galvalume permitted as an approved equal. For clarity and to ensure uniformity among bids, 24-gauge prefinished steel/Galvalume shall be the material provided for all gutters and downspouts on this project.

The End