



COMPTON UNIFIED SCHOOL DISTRICT
BUSINESS AND ADMINISTRATIVE SERVICES DIVISION PURCHASING AND
CONTRACTS DEPARTMENT

ADDENDUM No. 2

CONSTRUCTION SERVICES FOR SOIL REMEDIATION

BID NUMBER 27-001

DATE ISSUED: July 27, 2026

ADDENDUM NO. 2

DATE EFFECTIVE: July 27, 2026

BID NO.: **BID 27-001**

CONTACT: Mikkiala Peele, Contracts Analyst for CUSD

INTENT

This addendum is issued following the pre-bid meeting and job walk. Its purpose is to provide bidders with supplemental information clarifying Pre-Bid Question #14 and extend the Bid Submission and the Public Bid Opening due dates, ensuring all participants have access to the same details and updates related to the project.

CLARIFICATION FOR PE- BID QUESTION # 14:

<u>Pre-Bid RFI</u> <u>#</u>	<u>Subject</u>	<u>Pre-Bid Question</u>	<u>UPDATED Pre-Bid RFI Response</u>
14	PCB-Impacted Soil	PCB-Impacted Soil (AOC2, AOC3, AOC4) — TSCA Management Approach Soil in AOC2, AOC3, and AOC4 contains PCBs at elevated concentrations. Whether this material can go to a Class II facility versus requiring a Class I (or TSCA-permitted) facility significantly affects cost. Please confirm: Will the PCB-impacted soil be managed and disposed	Bidders shall classify, manage, and dispose of the excavated PCB-impacted soil as required by law, which may include consideration of 40 CFR 761; for purposes of bidding, Bidders shall assume that the excavated PCB-impacted soil would not be a PCB Remediation Waste under 40 CFR 761.

		of as "PCB Remediation Waste" under 40 CFR 761? If so, will it be managed under TSCA's Risk-Based, Self-Implementing, or Performance-Based cleanup option?	
--	--	--	--

CHANGE TO SCHEDULE:

BID SCHEDULE		
Event / Occurrence	Time / Date / Deadline	NEW DEADLINE TIME/ DATE
Bids Due / Public Bid Opening	July 27, 2026, Bids Due 1:00 p.m. Bid Opening 1:20 p.m.	July 30, 2026, -Bids Due 1:00 p.m. -Bid Opening 1:20 p.m.

Bidders are required to include this addendum, along with any other issued addenda(s), in their submission packet to acknowledge receipt and understanding of the information provided.

Failure to include all addenda(s) may result in the bid being deemed non-responsive.

Acknowledgment: I hereby acknowledge receipt of the following addenda and have made the necessary revisions to my proposal, plans, and/or specifications, etc.

Company

Authorized Signer

Date