Alpha Analytical Laboratories, Inc. email: clientservices@alpha-labs.com
Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

28 July 2026

Reed Union School District
Attn: Eduardo Munoz
277 Karen Way
Tiburon, CA 94920
RE: Lead & Copper
Work Order: 26G3401

Enclosed are the results of analyses for samples received by the laboratory on 07/17/26 08:19. If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Stephen F. McWeeney
Project Manager

Alpha Analytical Laboratories, Inc. email: clientservices@alpha-labs.com
Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Reed Union School District	Project Manager: Eduardo Munoz	
277 Karen Way	Project: Lead & Copper	Reported:
Tiburon, CA 94920	Project Number: Bel Aire School - Lead + Copper Test	07/28/26 11:39

Bay Area: 262 Rickenbacker Circle | Livermore, CA 94551 | 925-828-6226 | ELAP# 2728
Central Valley: 9090 Union Park Way Suite 113 | Elk Grove, CA 95624 | 916-686-5190 | ELAP# 2922
North Bay: 737 Southpoint Blvd Unit D| Petaluma, CA 94954 | 707-769-3128 | ELAP# 2303
San Diego: 980 Park Center Drive Suite C | Vista, CA 92081| 760-930-2555 | ELAP# 3055
Los Angeles: 1250 E. 29th Street | Signal Hill, CA 90755 | 424-267-5032 | ELAP# 3091

ANALYTICAL REPORT FOR SAMPLES

Sample ID	Laboratory ID	Matrix	Date Sampled	Date Received
Bel Aire Teacher Courtyard DF	26G3401-01	Water	07/16/26 07:55	07/17/26 08:19
Bel Aire Lunch Area DF	26G3401-02	Water	07/16/26 07:30	07/17/26 08:19
Bel Aire A Bld Ext DR	26G3401-03	Water	07/16/26 07:45	07/17/26 08:19
Bel Aire B Bld Ext DF	26G3401-04	Water	07/16/26 07:35	07/17/26 08:19
Bel Aire M Bld Ext DR	26G3401-05	Water	07/16/26 07:39	07/17/26 08:19

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Alpha Analytical Laboratories, Inc. email: clientservices@alpha-labs.com
Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Reed Union School District	Project Manager: Eduardo Munoz	
277 Karen Way	Project: Lead & Copper	Reported:
Tiburon, CA 94920	Project Number: Bel Aire School - Lead + Copper Test	07/28/26 11:39

	Result	Units	Reporting Limit	Dilution	Batch	Prepared	Analyzed	ELAP#	Method	Note
Bel Aire Teacher Courtyard DF (26G3401-01)			**Sample Type: Water**				**Sampled: 07/16/26 07:55**			
Metals by EPA Method 200.8 ICP/MS										
Copper	**70**	**ug/L**	**50**	1	AG65605	07/20/26 08:22	07/20/26 13:56	2303	EPA 200.8	
Lead	ND	ug/L	5.0	1	AG65605	07/20/26 08:22	07/20/26 13:56	2303	EPA 200.8	
Bel Aire Lunch Area DF (26G3401-02)			**Sample Type: Water**				**Sampled: 07/16/26 07:30**			
Metals by EPA Method 200.8 ICP/MS										
Copper	**100**	**ug/L**	**50**	1	AG65605	07/20/26 08:22	07/20/26 14:00	2303	EPA 200.8	
Lead	ND	ug/L	5.0	1	AG65605	07/20/26 08:22	07/20/26 14:00	2303	EPA 200.8	
Bel Aire A Bld Ext DR (26G3401-03)			**Sample Type: Water**				**Sampled: 07/16/26 07:45**			
Metals by EPA Method 200.8 ICP/MS										
Copper	**59**	**ug/L**	**50**	1	AG65605	07/20/26 08:22	07/20/26 14:03	2303	EPA 200.8	
Lead	ND	ug/L	5.0	1	AG65605	07/20/26 08:22	07/20/26 14:03	2303	EPA 200.8	
Bel Aire B Bld Ext DF (26G3401-04)			**Sample Type: Water**				**Sampled: 07/16/26 07:35**			
Metals by EPA Method 200.8 ICP/MS										
Copper	**86**	**ug/L**	**50**	1	AG65605	07/20/26 08:22	07/20/26 14:07	2303	EPA 200.8	
Lead	ND	ug/L	5.0	1	AG65605	07/20/26 08:22	07/20/26 14:07	2303	EPA 200.8	
Bel Aire M Bld Ext DR (26G3401-05)			**Sample Type: Water**				**Sampled: 07/16/26 07:39**			
Metals by EPA Method 200.8 ICP/MS										
Copper	ND	ug/L	50	1	AG65605	07/20/26 08:22	07/20/26 14:11	2303	EPA 200.8	
Lead	ND	ug/L	5.0	1	AG65605	07/20/26 08:22	07/20/26 14:11	2303	EPA 200.8	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Alpha Analytical Laboratories, Inc. email: clientservices@alpha-labs.com
Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Reed Union School District	Project Manager: Eduardo Munoz	
277 Karen Way	Project: Lead & Copper	Reported:
Tiburon, CA 94920	Project Number: Bel Aire School - Lead + Copper Test	07/28/26 11:39

Notes and Definitions

ND	Analyte NOT DETECTED at or above the reporting limit
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference

* ELAP does not offer accreditation in this matrix for the requested analyte/method combination.

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Alpha Analytical Laboratories Inc.
www.alpha-labs.com
WATERS, SEDIMENTS, SOLIDS

Corporate Laboratory (1551)
208 Mason Street, Ukiah CA 95482
707.468.0401 (phone)
707.468.5267 (fax)
clientservices@alpha-labs.com

North Bay Laboratory (2303)
737 Southpoint Blvd. Ste. E, Petaluma 94954

Bay Area Laboratory (2728)
262 Rickenbacker Circle, Livermore CA 94551

Central Valley Laboratory (2922)
9090 Union Park Way #113, Elk Grove CA 95624

San Diego Service Center
2722 Loker Ave West, Ste A, Carlsbad CA 92010

Chain of Custody - Work Order

Reports and Invoices delivered by email in PDF format

Lab No 2603401 Pg ____ of ____

Signature below authorizes work under terms stated on reverse side.

Report to	Invoice to (if different)	Project Information
Company: Reed union School Dist	Contact:	Project ID: Bel Aire School - Lead + cooper test
Attn: Eduardo Munoz	Email address:	Project No:
Address: 277 Karen Way. Tiburon Ca 94920	Address:	PO Number:
Phone/Fax: (415)725-2042	Phone/Fax:	
Email Address: emunoz@reedschools.org		

Field Sampler - Printed Name & Signature:

Sample Identification	Sampling Date	Sampling Time	Container: 40ml VOA Vial	Plastic	Glass	Sleeve	Other	Preservative: HCL	HNO3	H2SO4	Other	None	Matrix: Drinking Water	Wastewater	Soil	Other	Total Number of Containers per Sample ID	Analysis Request: Pb-4 (X)
Bel Aire-Teacher courtyard D.F.	7/16	7:55Am																X
Bel Aire Lunch area D.F.	7/16	7:30Am																
Bel Aire A Bld. ext D.F	7/16	7:45Am																
Bel Aire B-Bld. ext D.F	7/16	7:35Am																
Bel Aire N-Bld. ext D.F	7/16	7:39Am																

TAT
- Standard 10 days: ☒
- RUSH: 5 days ☐ / 48 hours ☐ / Other: ____days ☐
- Preapproval required

TEMP °C
- Ukiah
- Livermore
- Elk Grove
- Petaluma 19.0
- Carlsbad

Notes / DDW Source Codes

Relinquished by	Received by	Date	Time
		7.17.26	8:19

DDW Write On EDT Transmission? ☐ Yes ☐ No

State System Number: _____

If "Y" please enter the Source Number(s) in the column above

CA Geotracker EDF Report? ☐ Yes ☐ No

Global ID: Sampling Company Log Code:

EDF to (Email Address):

Travel and Site Time: | Mileage: | Misc. Supplies: