Alpha Analytical Laboratories, Inc. email: clientservices@alpha-labs.com
Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

28 July 2026

Reed Union School District
Attn: Eduardo Munoz
277 Karen Way
Tiburon, CA 94920
RE: Lead & Copper
Work Order: 26G3402

Enclosed are the results of analyses for samples received by the laboratory on 07/17/26 08:19. If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Stephen F. McWeeney
Project Manager

Alpha Analytical Laboratories, Inc. email: clientservices@alpha-labs.com
Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Reed Union School District	Project Manager: Eduardo Munoz	
277 Karen Way	Project: Lead & Copper	Reported:
Tiburon, CA 94920	Project Number: Del Mar School	07/28/26 11:41

Bay Area: 262 Rickenbacker Circle | Livermore, CA 94551 | 925-828-6226 | ELAP# 2728
Central Valley: 9090 Union Park Way Suite 113 | Elk Grove, CA 95624 | 916-686-5190 | ELAP# 2922
North Bay: 737 Southpoint Blvd Unit D| Petaluma, CA 94954 | 707-769-3128 | ELAP# 2303
San Diego: 980 Park Center Drive Suite C | Vista, CA 92081| 760-930-2555 | ELAP# 3055
Los Angeles: 1250 E. 29th Street | Signal Hill, CA 90755 | 424-267-5032 | ELAP# 3091

ANALYTICAL REPORT FOR SAMPLES

Sample ID	Laboratory ID	Matrix	Date Sampled	Date Received
Del Mon Locker Room DR	26G3402-01	Water	07/16/26 07:30	07/17/26 08:19
Del Mon Room 21 Ext DR	26G3402-02	Water	07/16/26 07:30	07/17/26 08:19
Del Mon Gym DR	26G3402-03	Water	07/16/26 07:30	07/17/26 08:19
Del Mon Staff Restroom Ex DF	26G3402-04	Water	07/16/26 07:30	07/17/26 08:19
Del Mon Amphitheater DF	26G3402-05	Water	07/16/26 07:35	07/17/26 08:19
Del Mon Room 17 Interior	26G3402-06	Water	07/16/26 07:22	07/17/26 08:19

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Alpha Analytical Laboratories, Inc. email: clientservices@alpha-labs.com
Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Reed Union School District	Project Manager: Eduardo Munoz	
277 Karen Way	Project: Lead & Copper	Reported:
Tiburon, CA 94920	Project Number: Del Mar School	07/28/26 11:41

	Result	Units	Reporting Limit	Dilution	Batch	Prepared	Analyzed	ELAP#	Method	Note
Del Mon Locker Room DR (26G3402-01)			**Sample Type: Water**				**Sampled: 07/16/26 07:30**			
Metals by EPA Method 200.8 ICP/MS										
Copper	**140**	**ug/L**	**50**	1	AG65605	07/20/26 08:22	07/20/26 14:15	2303	EPA 200.8	
Lead	ND	ug/L	5.0	1	AG65605	07/20/26 08:22	07/20/26 14:15	2303	EPA 200.8	
Del Mon Room 21 Ext DR (26G3402-02)			**Sample Type: Water**				**Sampled: 07/16/26 07:30**			
Metals by EPA Method 200.8 ICP/MS										
Copper	**180**	**ug/L**	**50**	1	AG65605	07/20/26 08:22	07/20/26 14:27	2303	EPA 200.8	
Lead	ND	ug/L	5.0	1	AG65605	07/20/26 08:22	07/20/26 14:27	2303	EPA 200.8	
Del Mon Gym DR (26G3402-03)			**Sample Type: Water**				**Sampled: 07/16/26 07:30**			
Metals by EPA Method 200.8 ICP/MS										
Copper	**370**	**ug/L**	**50**	1	AG65605	07/20/26 08:22	07/20/26 14:31	2303	EPA 200.8	
Lead	ND	ug/L	5.0	1	AG65605	07/20/26 08:22	07/20/26 14:31	2303	EPA 200.8	
Del Mon Staff Restroom Ex DF (26G3402-04)			**Sample Type: Water**				**Sampled: 07/16/26 07:30**			
Metals by EPA Method 200.8 ICP/MS										
Copper	**160**	**ug/L**	**50**	1	AG65696	07/21/26 06:27	07/21/26 09:25	2303	EPA 200.8	
Lead	ND	ug/L	5.0	1	AG65696	07/21/26 06:27	07/21/26 09:25	2303	EPA 200.8	
Del Mon Amphitheater DF (26G3402-05)			**Sample Type: Water**				**Sampled: 07/16/26 07:35**			
Metals by EPA Method 200.8 ICP/MS										
Copper	**490**	**ug/L**	**50**	1	AG65696	07/21/26 06:27	07/21/26 09:29	2303	EPA 200.8	
Lead	ND	ug/L	5.0	1	AG65696	07/21/26 06:27	07/21/26 09:29	2303	EPA 200.8	
Del Mon Room 17 Interior (26G3402-06)			**Sample Type: Water**				**Sampled: 07/16/26 07:22**			
Metals by EPA Method 200.8 ICP/MS										
Copper	**94**	**ug/L**	**50**	1	AG65696	07/21/26 06:27	07/21/26 09:37	2303	EPA 200.8	
Lead	ND	ug/L	5.0	1	AG65696	07/21/26 06:27	07/21/26 09:37	2303	EPA 200.8	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Alpha Analytical Laboratories, Inc. email: clientservices@alpha-labs.com
Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Reed Union School District	Project Manager: Eduardo Munoz	
277 Karen Way	Project: Lead & Copper	Reported:
Tiburon, CA 94920	Project Number: Del Mar School	07/28/26 11:41

Notes and Definitions

QM-05 The spike recovery was outside acceptance limits for the MS and/or MSD due to matrix interference. The LCS and/or LCSD were within acceptance limits showing that the laboratory is in control and the data is acceptable.

ND Analyte NOT DETECTED at or above the reporting limit

dry Sample results reported on a dry weight basis

RPD Relative Percent Difference

* ELAP does not offer accreditation in this matrix for the requested analyte/method combination.

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Alpha Analytical Laboratories Inc.
www.alpha-labs.com
WATERS, SEDIMENTS, SOLIDS

Corporate Laboratory (1551)
208 Mason Street, Ukiah CA 95482
707.468.0401 (phone)
707.468.5267 (fax)
clientservices@alpha-labs.com

Bay Area Laboratory (2728)
262 Rickenbacker Circle, Livermore CA 94551

Central Valley Laboratory (2922)
9090 Union Park Way #113, Elk Grove CA 95624

North Bay Laboratory (2303)
737 Southpoint Blvd. Ste. E, Petaluma 94954

San Diego Service Center
2722 Loker Ave West, Ste A, Carlsbad CA 92010

Chain of Custody - Work Order

Reports and Invoices delivered by email in PDF format

Lab No 26G3402 Pg ____ of ____

Signature below authorizes work under terms stated on reverse side.

Report to	Invoice to (if different)	Project Information
Company: Reed union School Dist	Contact:	Project ID: Del Mar School.
Attn: Eduardo Munoz	Email address:	Project No:
Address: 277 Karen Way. Tiburon CA 94920	Address:	PO Number:
Phone/Fax: (415) 725-2042	Phone/Fax:	
Email Address: emunoz@reedschools.org		

Field Sampler - Printed Name & Signature:

Sample Identification	Sampling Date	Sampling Time	Container: 40ml VOA Vial	Container: Plastic	Container: Glass	Container: Sleeve	Container: Other	Preservative: HCL	Preservative: HNO3	Preservative: H2SO4	Preservative: Other	Preservative: None	Matrix: Drinking Water	Matrix: Wastewater	Matrix: Soil	Matrix: Other	Total Number of Containers per Sample ID	Analysis Request: Pb 6010	Notes / DDW Source Codes
Del mar Locker room DP-	7/16	7:30 AM															1	X	
Del mar Room 21 Ext DP	7/16	7:30 AM															1		
Del mar Gym DP.	7/16	7:30 AM															1		
Del mar staff Restroom Ext DP	7/16	7:30 AM															1		
Del mar Amphitheater DP	7/16	7:35 AM															1		
Del mar Room 17 interior	7/16	7:22 AM															1		

TAT	TEMP °C
Standard 10 days ✓	Ukiah
RUSH: 5 days ○	Livermore
48 hours ○	Elk Grove
Other: ___days ○	Petaluma 19.0
Preapproval required	Carlsbad

Relinquished by	Received by	Date	Time
		7.17.16	8:19

DDW Write On EDT Transmission? ○ Yes ○ No

State System Number: _____

If "Y" please enter the Source Number(s) in the column above

CA Geotracker EDF Report? ○ Yes ○ No

Global ID: Sampling Company Log Code:

EDF to (Email Address):

Travel and Site Time:	Mileage:	Misc. Supplies: