Updated June 1, 2026

Sumner-Bonney Lake School District Action Plan: Lead in Drinking Water

School Information

School Name(s): Bonney Lake Elementary School, Crestwood Elementary School, Daffodil Valley Elementary School, Lakeridge Middle School, Liberty Ridge Elementary School, Maple Lawn Elementary School, Donald Eismann Elementary School, Victor Falls Elementary School, Sumner Middle School, Sumner High School, Mountain View Middle School, Elhi Hill High School, Robert Miller Gym

School District: Sumner-Bonney Lake School District

County: Pierce

Sampling and Testing Information

School Name	Sampling Date	Date Test Results Received	Sampling and Testing Provider
Bonney Lake Elementary School	11/19/2025	11/25/2025	☑ DOH (for sampling and testing)
Crestwood Elementary School	11/20/2025	11/26/2025	☑ DOH (for sampling and testing)

Daffodil Valley Elementary School	11/21/2025	12/02/2025	☑ DOH (for sampling and testing)
Lakeridge Middle School	11/22/2025	12/08/2025	☑ DOH (for sampling and testing)
Liberty Ridge Elementary School	12/17/2025	01/07/2026	☑ DOH (for sampling and testing)
Maple Lawn Elementary School	12/19/2025	12/30/2025	☑ DOH (for sampling and testing)
Donald Eismann Elementary School	01/07/2026	01/21/2026	☑ DOH (for sampling and testing)
Victor Falls Elementary School	01/08/2026	01/14/2026	☑ DOH (for sampling and testing)
Sumner Middle School	01/09/2026	01/21/2026	☑ DOH (for sampling and testing)

Sumner High School	01/10/2026	01/16/2026	☑ DOH (for sampling and testing)
Mountain View Middle School	01/31/2026	02/18/2026	☑ DOH (for sampling and testing)
Elhi Hill High School	03/07/2026	04/17/2026	☑ Other: Contractor (Orion Environmental Services)
Robert Miller Gym	02/21/2026	04/17/2026	☑ Other: Contractor (Orion Environmental Services)

Testing Requirements
RCW 28A.210.410 and RCW 43.70.830 require all drinking water outlets in public schools built, or with all plumbing replaced, before 2016 be tested for lead at least once between July 1, 2014, and June 30, 2026. Retesting shall occur at least once every five years thereafter. Drinking water sampling and testing must be done in partnership with DOH or contracted through an accredited lab.

Action Plan Requirements
If test results reveal elevated lead levels above 5 parts per billion (ppb) at any outlet used for drinking or cooking, an action plan must be developed. If a district has an existing action plan, you have the option of updating the existing plan to meet the following requirements instead of creating a new one.

Per RCW 28A.210.410, a school's action plan must meet the following requirements:

- The action plan shall be developed in consultation with DOH or your local health jurisdiction and in accordance with DOH's technical guidance.
- Consult with the Office of the Superintendent of Public Instruction (OSPI) when seeking funding for remediation activities. The OSPI Lead in Water Remediation Grant is a potential source of funding.
- Before the action plan is officially adopted, it must be shared publicly with opportunity for public comment.

For testing that occurred after July 25, 2021, the deadline for adopting the action plan is six months after receiving elevated lead test results.

The action plan must include:

- **Mitigation measures** implemented since receiving elevated lead test results.
- A schedule of **remediation activities** that adhere to the technical guidance. The schedule may be based on the availability of state or federal funding for remediation activities.
- A plan for **post-remediation sampling and testing** to confirm remediation activities have reduced lead concentrations at drinking water outlets to 5 or fewer ppb.

Action Plan

Mitigation Measures

Mitigation measures are immediate (temporary or permanent) actions, such as shutting off an outlet or marking as "hand wash only," to stop access to drinking water with elevated lead concentrations. Outlets with lead concentrations exceeding 15 ppb must be shut off immediately upon receiving test results in accordance with the technical guidance.

Sumner-Bonney Lake School District has identified 120 drinking water outlets with elevated lead levels requiring mitigation Since receiving the lead test results, the district has implemented permanent mitigation measures across its schools. Outlets that tested with severely elevated levels or could not be restricted have been permanently abandoned to immediately remove access and may be replaced/retested as needed. The district is providing bottled water as needed at

specific locations. Additionally, permanent "Handwash Only" signage was placed on remaining sink taps to restrict them from being used for drinking or food preparation.

Mitigation measures have been implemented as follows:

Sample Collection Date	Sample ID	School Name	Building Name	Fixture Information	Lead Test Result (ppb)	Mitigation Measure	Status	Date Implemented
CRESTWOOD ELEMENTARY SCHOOL (CWE)								
11/20/2025	415722	CWE	Main Building	Room 2 Tap	88	Added "handwash only" signage	☑ permanent	Current
11/20/2025	415730	CWE	Main Building	Room 5 Tap	79	Added "handwash only" signage	☑ permanent	Current

Sample Collection Date	Sample ID	School Name	Building Name	Fixture Information	Lead Test Result (ppb)	Mitigation Measure	Status	Date Implemented
11/20/2025	415720	CWE	Main Building	Room 1 Tap	73	Added "handwash only" signage	☑ permanent	Current
11/20/2025	415724	CWE	Main Building	Room 2 Tap	53	Added "handwash only" signage	☑ permanent	Current
11/20/2025	415726	CWE	Main Building	Room 3 Tap	52	Added "handwash only" signage	☑ permanent	Current

Sample Collection Date	Sample ID	School Name	Building Name	Fixture Information	Lead Test Result (ppb)	Mitigation Measure	Status	Date Implemented
11/20/2025	415752	CWE	Main Building	Room 22 Tap	50	Added "handwash only" signage	☑ permanent	Current
11/20/2025	415728	CWE	Main Building	Room 4 Tap	49	Added "handwash only" signage	☑ permanent	Current
11/20/2025	415697	CWE	Main Building	Pod Sink Next To Rm 14	46	Added "handwash only" signage	☑ permanent	Current
11/20/2025	415731	CWE	Main Building	Room 5 Fountain	37	Abandoned fixture	☑ permanent	Current

Sample Collection Date	Sample ID	School Name	Building Name	Fixture Information	Lead Test Result (ppb)	Mitigation Measure	Status	Date Implemented
11/20/2025	415714	CWE	Main Building	Room 9 Tap	34	Added "handwash only" signage	☑ permanent	Current
11/20/2025	415729	CWE	Main Building	Room 4 Fountain	34	Abandoned fixture	☑ permanent	Current
11/20/2025	415718	CWE	Main Building	Room 1 Tap	33	Added "handwash only" signage	☑ permanent	Current
11/20/2025	415699	CWE	Main Building	Room 14 Tap	32	Added "handwash only" signage	☑ permanent	Current

Sample Collection Date	Sample ID	School Name	Building Name	Fixture Information	Lead Test Result (ppb)	Mitigation Measure	Status	Date Implemented
11/20/2025	415721	CWE	Main Building	Room 1 Fountain	31	Abandoned fixture	☑ permanent	Current
11/20/2025	415701	CWE	Main Building	Room 13 Tap	30	Added "handwash only" signage	☑ permanent	Current
11/20/2025	415733	CWE	Main Building	Pod Sink Outside Of Rm 5 Fountain	29	Abandoned fixture	☑ permanent	Current
11/20/2025	415746	CWE	Main Building	Room 20 Tap	29	Added "handwash only" signage	☑ permanent	Current

Sample Collection Date	Sample ID	School Name	Building Name	Fixture Information	Lead Test Result (ppb)	Mitigation Measure	Status	Date Implemented
11/20/2025	415703	CWE	Main Building	Room 15 Tap	27	Added "handwash only" signage	☑ permanent	Current
11/20/2025	415723	CWE	Main Building	Room 2 Fountain	26	Abandoned fixture	☑ permanent	Current
11/20/2025	415705	CWE	Main Building	Room 16 Tap	25	Added "handwash only" signage	☑ permanent	Current
11/20/2025	415710	CWE	Main Building	Room 17 Tap	24	Added "handwash only" signage	☑ permanent	Current

Sample Collection Date	Sample ID	School Name	Building Name	Fixture Information	Lead Test Result (ppb)	Mitigation Measure	Status	Date Implemented
11/20/2025	415738	CWE	Main Building	Room 7 Fountain	24	Abandoned fixture	☑ permanent	Current
11/20/2025	415750	CWE	Main Building	Room 21 Tap	24	Added "handwash only" signage	☑ permanent	Current
11/20/2025	415742	CWE	Main Building	Room 18 Tap	23	Added "handwash only" signage	☑ permanent	Current
11/20/2025	415754	CWE	Main Building	Room 23 Tap	23	Added "handwash only" signage	☑ permanent	Current

Sample Collection Date	Sample ID	School Name	Building Name	Fixture Information	Lead Test Result (ppb)	Mitigation Measure	Status	Date Implemented
11/20/2025	415683	CWE	Main Building	Music Room Tap	20	Added "handwash only" signage	☑ permanent	Current
11/20/2025	415708	CWE	Main Building	Room 12 Tap	19	Added "handwash only" signage	☑ permanent	Current
11/20/2025	415687	CWE	Main Building	Nurses Office Tap	18	Added "handwash only" signage	☑ permanent	Current

Sample Collection Date	Sample ID	School Name	Building Name	Fixture Information	Lead Test Result (ppb)	Mitigation Measure	Status	Date Implemented
11/20/2025	415716	CWE	Main Building	Room 9 Tap	16	Added "handwash only" signage	☑ permanent	Current
11/20/2025	415735	CWE	Main Building	Room 6 Fountain	16	Abandoned fixture	☑ permanent	Current
11/20/2025	415748	CWE	Main Building	Pod Sink Outside Of Rm 20 Tap	16	Added "handwash only" signage	☑ permanent	Current
11/20/2025	415725	CWE	Main Building	Room 2 Fountain	15	Abandoned fixture	☑ permanent	Current

Sample Collection Date	Sample ID	School Name	Building Name	Fixture Information	Lead Test Result (ppb)	Mitigation Measure	Status	Date Implemented
11/20/2025	415712	CWE	Main Building	Room 11 Tap	14	Added "handwash only" signage	☑ permanent	Current
11/20/2025	415717	CWE	Main Building	Room 9 Fountain	12	Abandoned fixture	☑ permanent	Current
11/20/2025	415719	CWE	Main Building	Room 1 Fountain	11	Abandoned fixture	☑ permanent	Current
11/20/2025	415685	CWE	Main Building	Staff Lounge Tap	10	Added "handwash only" signage	☑ permanent	Current
11/20/2025	415709	CWE	Main Building	Room 12 Fountain	9	Abandoned fixture	☑ permanent	Current

Sample Collection Date	Sample ID	School Name	Building Name	Fixture Information	Lead Test Result (ppb)	Mitigation Measure	Status	Date Implemented
11/20/2025	415698	CWE	Main Building	Pod Sink Next To Rm 14 Fountain	8	Abandoned fixture	☑ permanent	Current
11/20/2025	415713	CWE	Main Building	Room 11 Fountain	8	Abandoned fixture	☑ permanent	Current
11/20/2025	415715	CWE	Main Building	Room 9 Fountain	8	Abandoned fixture	☑ permanent	Current
11/20/2025	415732	CWE	Main Building	Pod Sink Outside Of Rm 5 Tap	8	Added "handwash only" signage	☑ permanent	Current
11/20/2025	415745	CWE	Main Building	Room 19 Fountain	8	Abandoned fixture	☑ permanent	Current

Sample Collection Date	Sample ID	School Name	Building Name	Fixture Information	Lead Test Result (ppb)	Mitigation Measure	Status	Date Implemented
11/20/2025	415753	CWE	Main Building	Room 22 Fountain	8	Abandoned fixture	☑ permanent	Current
11/20/2025	415711	CWE	Main Building	Room 17 Fountain	7	Abandoned fixture	☑ permanent	Current
11/20/2025	415736	CWE	Main Building	Room 7 Tap	7	Added "handwash only" signage	☑ permanent	Current
11/20/2025	415749	CWE	Main Building	Pod Sink Outside Rm 20 Fountain	7	Abandoned fixture	☑ permanent	Current

Sample Collection Date	Sample ID	School Name	Building Name	Fixture Information	Lead Test Result (ppb)	Mitigation Measure	Status	Date Implemented
11/20/2025	415734	CWE	Main Building	Room 6 Tap	6	Added "handwash only" signage	☑ permanent	Current
11/20/2025	415747	CWE	Main Building	Room 20 Fountain	6	Abandoned fixture	☑ permanent	Current
02/21/2026	02-285-08	CWE	Main Building	Fixture 12 Tap (2nd Draw)	5.8	Added "handwash only" signage	☑ permanent	Current
DAFFODIL VALLEY ELEMENTARY (DVE)								

Sample Collection Date	Sample ID	School Name	Building Name	Fixture Information	Lead Test Result (ppb)	Mitigation Measure	Status	Date Implemented
11/21/2025	405451	DVE	Main Building	Room 128 Tap	20	Added "handwash only" signage	☑ permanent	Current
11/21/2025	405424	DVE	Portable 1	Room 4 Water Fountain	16	Abandoned fixture	☑ permanent	Current
11/21/2025	410890	DVE	Main Building	Library Tap	14	Added "handwash only" signage	☑ permanent	Current
11/21/2025	405423	DVE	Portable 1	Room 4 Tap	8	Added "handwash only" signage	☑ permanent	Current

Sample Collection Date	Sample ID	School Name	Building Name	Fixture Information	Lead Test Result (ppb)	Mitigation Measure	Status	Date Implemented
11/21/2025	410887	DVE	Main Building	Room 127 Tap	8	Added "handwash only" signage	☑ permanent	Current
11/21/2025	410886	DVE	Main Building	Room 301 Tap	6	Added "handwash only" signage	☑ permanent	Current
LAKERIDGE MIDDLE SCHOOL (LMS)								
11/22/2025	414517	LMS	Main Building	Kitchen Bread Maker Pot Filler	533	Abandoned fixture	☑ permanent	Current

Sample Collection Date	Sample ID	School Name	Building Name	Fixture Information	Lead Test Result (ppb)	Mitigation Measure	Status	Date Implemented
11/22/2025	414467	LMS	Main Building	Kitchen Tap (2 of 7)	127	Abandoned fixture	☑ permanent	Current
11/22/2025	414498	LMS	Main Building	2nd Floor Work Room Tap	62	Added "handwash only" signage	☑ permanent	Current
11/22/2025	414472	LMS	Main Building	Kitchen Tap (Furthest sink west)	31	Abandoned fixture	☑ permanent	Current
11/22/2025	414504	LMS	Main Building	Room 605 Water Fountain	13	Turned off / Abandoned	☑ permanent	Current

Sample Collection Date	Sample ID	School Name	Building Name	Fixture Information	Lead Test Result (ppb)	Mitigation Measure	Status	Date Implemented
11/22/2025	414471	LMS	Main Building	Kitchen Prep Sink Tap	8	Abandoned fixture	☑ permanent	Current
11/22/2025	414477	LMS	Main Building	Room 408 Tap	7	Added "handwash only" signage	☑ permanent	Current
11/22/2025	414496	LMS	Main Building	Library Office Tap	7	Added "handwash only" signage	☑ permanent	Current
11/22/2025	414502	LMS	Main Building	Room 608 Water Fountain	7	Turned off / Abandoned	☑ permanent	Current

Sample Collection Date	Sample ID	School Name	Building Name	Fixture Information	Lead Test Result (ppb)	Mitigation Measure	Status	Date Implemented
11/22/2025	414448	LMS	Main Building	Room 208 Water Fountain	6	Turned off / Abandoned	☑ permanent	Current
11/22/2025	414451	LMS	Main Building	Room 204 Tap	6	Added "handwash only" signage	☑ permanent	Current
11/22/2025	414487	LMS	Main Building	Room 402 Tap	6	Added "handwash only" signage	☑ permanent	Current
11/22/2025	414497	LMS	Main Building	Library Office Water Fountain	6	Turned off / Abandoned	☑ permanent	Current

Sample Collection Date	Sample ID	School Name	Building Name	Fixture Information	Lead Test Result (ppb)	Mitigation Measure	Status	Date Implemented
LIBERTY RIDGE ELEMENTARY (LRE)								
12/17/2025	414226	LRE	Main Building	Pod Sink Outside Of Rm 8 Fountain	120	Abandoned fixture	☑ permanent	Current
12/17/2025	414252	LRE	Main Building	Pod Sink Outside Of Rm 13 Tap	37	Added "handwash only" signage	☑ permanent	Current
12/17/2025	414225	LRE	Main Building	Pod Sink Outside Of Rm 8 Tap	25	Added "handwash only" signage	☑ permanent	Current

Sample Collection Date	Sample ID	School Name	Building Name	Fixture Information	Lead Test Result (ppb)	Mitigation Measure	Status	Date Implemented
12/17/2025	414213	LRE	Main Building	Room 3 Water Fountain	22	Abandoned fixture	☑ permanent	Current
12/17/2025	414216	LRE	Main Building	Room 4 Tap	18	Added "handwash only" signage	☑ permanent	Current
12/17/2025	414267	LRE	Main Building	Pod Sink Outside Of Rm 19 Tap	16	Added "handwash only" signage	☑ permanent	Current
12/17/2025	414258	LRE	Main Building	Links Room Tap	10	Added "handwash only" signage	☑ permanent	Current

Sample Collection Date	Sample ID	School Name	Building Name	Fixture Information	Lead Test Result (ppb)	Mitigation Measure	Status	Date Implemented
12/17/2025	414212	LRE	Main Building	Room 3 Tap	9	Added "handwash only" signage	☑ permanent	Current
12/17/2025	414257	LRE	Main Building	Room 11 Water Fountain	8	Abandoned fixture	☑ permanent	Current
12/17/2025	414219	LRE	Main Building	Room 5 Tap	7	Added "handwash only" signage	☑ permanent	Current
12/17/2025	414239	LRE	Portable 38	Portable 38 Tap	7	Added "handwash only" signage	☑ permanent	Current

Sample Collection Date	Sample ID	School Name	Building Name	Fixture Information	Lead Test Result (ppb)	Mitigation Measure	Status	Date Implemented
12/17/2025	414271	LRE	Main Building	Room 18 Tap	7	Added "handwash only" signage	☑ permanent	Current
12/17/2025	414270	LRE	Main Building	Room 20 Water Fountain	6	Abandoned fixture	☑ permanent	Current
BONNEY LAKE HIGH SCHOOL (BLHS)								
12/20/2025	411892	BLHS	Area 100	Kitchen Sprayer	166	Abandoned fixture	☑ permanent	Current

Sample Collection Date	Sample ID	School Name	Building Name	Fixture Information	Lead Test Result (ppb)	Mitigation Measure	Status	Date Implemented
12/20/2025	411899	BLHS	Area 100	Kitchen Tap (6 of 7)	45	Added "handwash only" signage	☑ permanent	Current
12/20/2025	411898	BLHS	Area 100	Kitchen Tap (6 of 7, large pot)	22	Added "handwash only" signage	☑ permanent	Current
12/20/2025	414390	BLHS	Area 400	Room 459 Tap	12	Added "handwash only" signage	☑ permanent	Current

Sample Collection Date	Sample ID	School Name	Building Name	Fixture Information	Lead Test Result (ppb)	Mitigation Measure	Status	Date Implemented
12/20/2025	411880	BLHS	Area 300	Room 309 Tap	11	Added "handwash only" signage	☑ permanent	Current
12/20/2025	414384	BLHS	Area 300	Room 359 Faculty Office Tap	11	Added "handwash only" signage	☑ permanent	Current
12/20/2025	414395	BLHS	Area 400	Room 409 Tap	11	Added "handwash only" signage	☑ permanent	Current

Sample Collection Date	Sample ID	School Name	Building Name	Fixture Information	Lead Test Result (ppb)	Mitigation Measure	Status	Date Implemented
12/20/2025	411884	BLHS	Area 200	Room 208 Tap	8	Added "handwash only" signage	☑ permanent	Current
12/20/2025	411900	BLHS	Area 100	Kitchen Meat Sink Tap	8	Added "handwash only" signage	☑ permanent	Current
12/20/2025	411893	BLHS	Area 100	Kitchen Prep Sink Tap	6	Added "handwash only" signage	☑ permanent	Current

Sample Collection Date	Sample ID	School Name	Building Name	Fixture Information	Lead Test Result (ppb)	Mitigation Measure	Status	Date Implemented
12/20/2025	411910	BLHS	Area 500	Room 505 Tap	6	Added "handwash only" signage	☑ permanent	Current
SUMNER MIDDLE SCHOOL (SMS)								
01/09/2026	411364	SMS	Main Building	Kitchen Sprayer	43	Abandoned fixture	☑ permanent	Current
01/09/2026	411360	SMS	Main Building	Kitchen Tap	12	Added "handwash only" signage	☑ permanent	Current

Sample Collection Date	Sample ID	School Name	Building Name	Fixture Information	Lead Test Result (ppb)	Mitigation Measure	Status	Date Implemented
01/09/2026	411376	SMS	Portable 707	Portable 707 Tap	11	Abandoned (bottled water given)	☑ permanent	Current
01/09/2026	411382	SMS	Main Building	Room 501 Tap	7	Added "handwash only" signage	☑ permanent	Current
01/09/2026	411380	SMS	Main Building	Room 501 Tap	6	Added "handwash only" signage	☑ permanent	Current

Sample Collection Date	Sample ID	School Name	Building Name	Fixture Information	Lead Test Result (ppb)	Mitigation Measure	Status	Date Implemented
01/09/2026	411383	SMS	Main Building	Room 501 Tap	6	Added "handwash only" signage	☑ permanent	Current
01/09/2026	411385	SMS	Main Building	Room 501 Tap	6	Added "handwash only" signage	☑ permanent	Current
01/09/2026	411392	SMS	Main Building	Nurses Office Tap	6	Added "handwash only" signage	☑ permanent	Current

Sample Collection Date	Sample ID	School Name	Building Name	Fixture Information	Lead Test Result (ppb)	Mitigation Measure	Status	Date Implemented
01/09/2026	411393	SMS	Main Building	Staff Lounge Tap	6	Added "handwash only" signage	☑ permanent	Current
01/09/2026	411398	SMS	Main Building	Room 311 Tap	6	Added "handwash only" signage	☑ permanent	Current
SUMNER HIGH SCHOOL (SHS)								
01/10/2026	411451	SHS	Main Building	Student Store Tap	27	Added "handwash only" signage	☑ permanent	Current

Sample Collection Date	Sample ID	School Name	Building Name	Fixture Information	Lead Test Result (ppb)	Mitigation Measure	Status	Date Implemented
01/10/2026	411445	SHS	Main Building	Concessions Water Fountain	16	Abandoned fixture	☑ permanent	Current
01/10/2026	411453	SHS	Main Building	Old Kitchen Tap	15	Added "handwash only" signage	☑ permanent	Current
01/10/2026	411469	SHS	Athletics Office	Athletics Office Tap	14	Added "handwash only" signage	☑ permanent	Current
01/10/2026	411473	SHS	Pool	Pool Water Fountain	13	Abandoned fixture	☑ permanent	Current

Sample Collection Date	Sample ID	School Name	Building Name	Fixture Information	Lead Test Result (ppb)	Mitigation Measure	Status	Date Implemented
01/10/2026	411465	SHS	Main Building	Room 8a Water Fountain	12	Abandoned fixture	☑ permanent	Current
01/10/2026	411455	SHS	Main Building	Spart Mart Tap	11	Added "handwash only" signage	☑ permanent	Current
01/10/2026	411454	SHS	Main Building	Old Kitchen Sprayer	6	Added "handwash only" signage	☑ permanent	Current
MOUNTAIN VIEW MIDDLE (MMS)								

Sample Collection Date	Sample ID	School Name	Building Name	Fixture Information	Lead Test Result (ppb)	Mitigation Measure	Status	Date Implemented
01/31/2026	414954	MMS	Main Building	Kitchen Sprayer	3451	Abandoned fixture	☑ permanent	Current
01/31/2026	414955	MMS	Main Building	Kitchen Tap	366	Abandoned fixture	☑ permanent	Current
01/31/2026	414957	MMS	Main Building	Kitchen Sprayer	15	Abandoned fixture	☑ permanent	Current
01/31/2026	414947	MMS	Main Building	Nurses Office Tap	13	Added "handwash only" signage	☑ permanent	Current
01/31/2026	414952	MMS	Main Building	Kitchen Tap	10	Abandoned fixture	☑ permanent	Current

Sample Collection Date	Sample ID	School Name	Building Name	Fixture Information	Lead Test Result (ppb)	Mitigation Measure	Status	Date Implemented
01/31/2026	414956	MMS	Main Building	Kitchen Tap	8	Added "handwash only" signage	☑ permanent	Current
ELHI HILL HIGH SCHOOL (ELHS)								
03/07/2026	EH10	ELHS	Elhi Hill Program	10 Left Sink Tap	81	Added "handwash only" signage	☑ permanent	Current
03/07/2026	EH11	ELHS	Elhi Hill Program	10 Right Sink Tap	24	Added "handwash only" signage	☑ permanent	Current

Sample Collection Date	Sample ID	School Name	Building Name	Fixture Information	Lead Test Result (ppb)	Mitigation Measure	Status	Date Implemented
03/07/2026	EH01	ELHS	Elhi Hill Program	01 Sink Tap	7.8	Added "handwash only" signage	☑ permanent	Current
03/07/2026	EH09	ELHS	Elhi Hill Program	17 Sink Tap	7.1	Added "handwash only" signage	☑ permanent	Current

Remediation Schedule

Remediation activities are short-term or permanent control measures to reduce lead concentrations in drinking water to 5 ppb or less. Per RCW 28A.210.410, outlets that have elevated lead levels (above 5 ppb) must be identified, remediated (if not permanently mitigated), and retested. Refer to the technical guidance for remediation options.

Sumner-Bonney Lake School District has identified 3 drinking water outlets with elevated lead levels requiring remediation (Crestwood Elementary bottle filler array and Victor Falls Elementary kitchen tap).

Remediation activities have been or will be implemented as follows. This list is subject to change due to operational needs:

Sample Collection Date	Sample ID	School Name	Building Name	Fixture Information	Lead Test Result (ppb)	Remediation Activity	Planned or Completed Implementation Date
11/20/2025	415740	CWE	Main Building	Main Entrance Foyer (Bottle Filler)	50	Replaced filter (functional); adding bottle fillers during remodel	Current / Remodel Date
11/20/2025	415741	CWE	Main Building	Main Entrance Foyer (Fountain)	8	Replaced filter (functional); adding bottle fillers during remodel	Current / Remodel Date
01/08/2026	411294	VFE	Main Building	Kitchen (Tap)	6	Replaced fixture	Completed 02/14/2026

Post-Remediation Testing

School Name	Completed Post-Remediation Testing	Planned Post-Remediation Testing
Crestwood Elementary School	0 outlets **have been** sampled and retested by contractor	Replace fixtures over time; flush systems; retest. Date:TBD
Victor Falls Elementary School	1 outlet **has been** sampled and retested by: Orion; Sampling date: 02/14/2026	0 outlets **will be** sampled and retested by contractor

Communication Plan

Sumner-Bonney Lake School District will communicate information about the plan for remedial action to reduce lead concentrations in drinking water through the district's website at sumnersd.org/waterquality in the fall of each year. This information will be communicated annually until post-remediation retesting does not detect an elevated lead level (above 5 ppb) at any drinking water outlet.

Contact Information

The following person(s) is the main point of contact for more information related to this action plan.

Name: David Coutts
Role: Director, Maintenance and Operations
Email: david_coutts@sumnersd.org
Phone: 253-891-6300
Preferred contact method: Email