

PO Box 733
Marlboro, NY 12542
Phone 845-236-7823
Fax 845-236-3911
NYSDOH #10824

ENVIRONMENTAL LABWORKS, INC.

August 10, 2026

Mr. Kyle Harjes
Onteora Central School District
Buildings & Grounds Department
4166 Route 28
Boiceville, NY 12412

Dear Mr. Harjes,


The following are results of the analyses performed on a water sample from **Onteora Central School District - High School Retest** received at the laboratory on 07/21/26.

Date/Time Collected: 07/21/26 9:45am First Draw
Collected By: UC BOCES
Project ID: 07212646
Secondary ID: HS262928
PWS ID: ---

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	ACTION LEVEL	ANALYZED
OCS #333 Outdoor Spigot by track 07212646-1	EPA 200.8 Lead	<0.00040 mg/L	0.005 mg/L	07/27/26

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #12150. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

Thank you,



for Michael F. Lupi
Technical Director