

Lead in School Drinking Water Report

South Whidbey High School/Middle School Campus - Corrected



EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreekids@doh.wa.gov.

DEFINITIONS

Fixture Housing
Location

Room/space where
fixture is located
(i.e. room number,
gym, playground)

Fixture Housing Type

Structure that contains
the individual fixtures
where water samples
were collected from.
Fixture housing may
contain one or more
individual fixture for
sampling.

Fixture Location
Details

Location within a
room or space where
fixture housing is
located, starting to the
left of the entrance and
rotating clockwise, of
the total number of
fixture housings in a
room or space
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water
Fountain, Water Bottle
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2026-04-18

Date(s) analyzed: 2026-04-29, 2026-04-30

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	418474	2026-04-18	Main Building	Sink	Rm123	3 of 3 teachers desk	Tap	center	462
2	418475	2026-04-18	Main Building	Sink	Rm121	1 of 1	Tap	center	43
3	418472	2026-04-18	Main Building	Sink	Rm123	1 of 3 left	Tap	center	32
4	418466	2026-04-18	Main Building	Sink	Rm103	1 of 3 produce sink	Sprayer	center	27
5	418473	2026-04-18	Main Building	Sink	Rm123	2 of 3 right	Tap	center	27
6	418471	2026-04-18	Main Building	Sink	Rm124	1 of 1	Tap	center	22
7	418467	2026-04-18	Main Building	Sink	Rm103	2 of 3 across from ovens	Tap	center	21
8	418476	2026-04-18	Main Building	Sink	Rm131	1 of 1	Tap	center	19
9	418477	2026-04-18	Main Building	Sink	Rm132	1 of 2 right of fridge	Tap	center	17

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
10	418478	2026-04-18	Main Building	Sink	Rm132	2 of 2 across from fridge	Tap	center	13
11	418482	2026-04-18	Main Building	Fountain	Hallway 37	1 of 1	Water Fountain	center	8
12	418480	2026-04-18	Main Building	Sink	Rm421	1 of 1	Tap	center	7
13	418483	2026-04-18	Main Building	Fountain	Hallway 36	1 of 1	Water Fountain	center	7
14	418465	2026-04-18	Main Building	Sink	Rm103	1 of 3 produce sink	Tap	center	6
15	418470	2026-04-18	Main Building	Fountain	Hallway 5	1 of 1	Water Fountain	center	6
16	418479	2026-04-18	Main Building	Sink	Rm424	1 of 1	Tap	center	6
17	418469	2026-04-18	Main Building	Sink	Rm102	1 of 1	Tap	center	2
18	418460	2026-04-18	Main Building	Fountain	Rm113	1 of 1	Water Fountain	center	1
19	418457	2026-04-18	Main Building	Fountain With Bottle Filler	Hallway 12	1 of 1	Water Fountain	center	<1
20	418458	2026-04-18	Main Building	Fountain With Bottle Filler	Hallway 12	1 of 1	Water Bottle Filler	center	<1
21	418459	2026-04-18	Main Building	Fountain	Rm112	1 of 1	Water Fountain	center	<1
22	418461	2026-04-18	Main Building	Fountain	Rm114	1 of 1	Water Fountain	center	<1
23	418462	2026-04-18	Main Building	Fountain	Rm115	1 of 1	Water Fountain	center	<1

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
24	418463	2026-04-18	Main Building	Fountain - Multi-level	Rm116	1 of 1	Water Fountain	left	<1
25	418464	2026-04-18	Main Building	Fountain - Multi-level	Rm116	1 of 1	Water Fountain	right	<1
26	418468	2026-04-18	Main Building	Ice Machine	Rm103	3 of 3	Ice Machine	center	<1
27	418481	2026-04-18	Main Building	Fountain	Hallway 41	1 of 1	Water Fountain	center	<1