BRANDYWINE SCIENCE CENTER INC.
204 LINE ROAD
KENNETT SQUARE, PA 19348
PA DEP # 15-00301
(610) 444-9850

ORIGIN OF SAMPLE	**NAME**	Unionville-Chadds Ford Sch Dst			
	ADDRESS	740 Unionville Road			
	CITY/STATE	Kennett Square, PA 19348			
	PWS #	**N/A**			
Sample Source	**Location**	Hillendale Elementary	**SAMPLE INFORMATION**	**SAMPLE DATE**	9/23/2024
	PUBLIC	x		**SAMPLE TIME**	see below
SAMPLE COLLECTED BY	**LAB STAFF**			**DATE RECEIVED**	9/23/2024
	OTHER	Erik N		**TIME RECEIVED**	12:00
				DATE OF REPORT	10/14/2024

	CHEMICAL ANALYSIS	RESULT	DEP LIMIT	UNITS	DATE ANALYZED	Method	REPORTING LIMIT
lab# 414093 HE #701 9/23/2024 6:57	LEAD	<0.005	0.0150	mg/L	9/25/2024	SM 3113 B	0.005
	COPPER	0.219	1.3	mg/L	10/1/2024	SM 3111 B	0.05
lab# 414094 HE #702 9/23/2024 6:53	LEAD	<0.005	0.0150	mg/L	9/25/2024	SM 3113 B	0.005
	COPPER	0.140	1.3	mg/L	10/1/2024	SM 3111 B	0.05
lab# 414095 HE #703 9/23/2024 6:54	LEAD	<0.005	0.0150	mg/L	9/26/2024	SM 3113 B	0.005
	COPPER	0.121	1.3	mg/L	10/1/2024	SM 3111 B	0.05
lab# 414096 HE #704 9/23/2024 6:57	LEAD	<0.005	0.0150	mg/L	9/26/2024	SM 3113 B	0.005
	COPPER	0.187	1.3	mg/L	10/1/2024	SM 3111 B	0.05
lab# 414097 HE #705 9/23/2024 7:13	LEAD	<0.005	0.0150	mg/L	9/26/2024	SM 3113 B	0.005
	COPPER	0.103	1.3	mg/L	10/1/2024	SM 3111 B	0.05

Henry D. Clemens III
Laboratory Director

BRANDYWINE SCIENCE CENTER INC.
204 LINE ROAD
KENNETT SQUARE, PA 19348
PA DEP # 15-00301
(610) 444-9850

ORIGIN OF SAMPLE	**NAME**	Unionville-Chadds Ford Sch Dst			
	ADDRESS	740 Unionville Road			
	CITY/STATE	Kennett Square, PA 19348			
	PWS #	**N/A**			
Sample Source	**Location**	Hillendale Elementary	**SAMPLE INFORMATION**	**SAMPLE DATE**	9/23/2024
	PUBLIC	x		**SAMPLE TIME**	see below
SAMPLE COLLECTED BY	**LAB STAFF**			**DATE RECEIVED**	9/23/2024
	OTHER	Erik N		**TIME RECEIVED**	12:00
				DATE OF REPORT	10/14/2024

	CHEMICAL ANALYSIS	RESULT	DEP LIMIT	UNITS	DATE ANALYZED	Method	REPORTING LIMIT
lab# 414098	LEAD	<0.005	0.0150	mg/L	9/26/2024	SM 3113 B	0.005
HE #706	COPPER	0.111	1.3	mg/L	10/1/2024	SM 3111 B	0.05
9/23/2024 7:03							
lab# 414099	LEAD	<0.005	0.0150	mg/L	9/26/2024	SM 3113 B	0.005
HE #707	COPPER	0.190	1.3	mg/L	10/1/2024	SM 3111 B	0.05
9/23/2024 6:58							
lab# 414100	LEAD	<0.005	0.0150	mg/L	9/26/2024	SM 3113 B	0.005
HE #708	COPPER	0.058	1.3	mg/L	10/1/2024	SM 3111 B	0.05
9/23/2024 6:59							
lab# 414101	LEAD	<0.005	0.0150	mg/L	9/26/2024	SM 3113 B	0.005
HE #709	COPPER	0.157	1.3	mg/L	10/1/2024	SM 3111 B	0.05
9/23/2024 7:05							
lab# 414102	LEAD	<0.005	0.0150	mg/L	9/26/2024	SM 3113 B	0.005
HE #710	COPPER	0.142	1.3	mg/L	10/1/2024	SM 3111 B	0.05
9/23/1934 7:01							

Henry D. Clemens III
Laboratory Director

BRANDYWINE SCIENCE CENTER INC.
204 LINE ROAD
KENNETT SQUARE, PA 19348
PA DEP # 15-00301
(610) 444-9850

ORIGIN OF SAMPLE	**NAME**	Unionville-Chadds Ford Sch Dst			
	ADDRESS	740 Unionville Road			
	CITY/STATE	Kennett Square, PA 19348			
	PWS #	N/A			
Sample Source	**Location**	Hillendale Elementary	**SAMPLE INFORMATION**	**SAMPLE DATE**	9/23/2024
	PUBLIC	x		**SAMPLE TIME**	see below
SAMPLE COLLECTED BY	**LAB STAFF**			**DATE RECEIVED**	9/23/2024
	OTHER	Erik N		**TIME RECEIVED**	12:00
				DATE OF REPORT	10/14/2024

	CHEMICAL ANALYSIS	RESULT	DEP LIMIT	UNITS	DATE ANALYZED	Method	REPORTING LIMIT
Lab# 414103	LEAD	<0.005	0.0150	mg/L	9/26/2024	SM 3113 B	0.005
HE #711	COPPER	0.276	1.3	mg/L	10/1/2024	SM 3111 B	0.05
9/23/2024 7:11							

Henry D. Clemens III
Laboratory Director