BRANDYWINE SCIENCE CENTER INC.
204 LINE ROAD
KENNETT SQUARE, PA 19348
PA DEP # 15-00301
(610) 444-9850

ORIGIN OF SAMPLE	**NAME**	Unionville-Chadds Ford Sch Dst			
	ADDRESS	740 Unionville Road			
	CITY/STATE	Kennett Square, PA 19348			
	PWS #	N/A			
Sample Source	**Location**	Unionville Elementary	**SAMPLE INFORMATION**	**SAMPLE DATE**	9/17/2024
	AQUA	x		**SAMPLE TIME**	see below
SAMPLE COLLECTED BY	**LAB STAFF**			**DATE RECEIVED**	9/17/2024
	OTHER	Erik N		**TIME RECEIVED**	13:25
				DATE OF REPORT	10/14/2024

	CHEMICAL ANALYSIS	RESULT	DEP LIMIT	UNITS	DATE ANALYZED	Method	REPORTING LIMIT
lab# 413795	LEAD	<0.005	0.0150	mg/L	9/20/2024	SM 3113 B	0.005
UE #701	COPPER	0.057	1.3	mg/L	10/1/2024	SM 3111 B	0.05
9/17/2024 7:02							
lab# 413796	LEAD	<0.005	0.0150	mg/L	9/20/2024	SM 3113 B	0.005
UE #702	COPPER	<0.05	1.3	mg/L	10/1/2024	SM 3111 B	0.05
9/17/2024 6:27							
lab# 413797	LEAD	<0.005	0.0150	mg/L	9/20/2024	SM 3113 B	0.005
UE #703	COPPER	0.065	1.3	mg/L	10/1/2024	SM 3111 B	0.05
9/17/2024 6:26							
lab# 413798	LEAD	<0.005	0.0150	mg/L	9/20/2024	SM 3113 B	0.005
UE #704	COPPER	0.093	1.3	mg/L	10/1/2024	SM 3111 B	0.05
9/17/2024 6:51							
lab# 413799	LEAD	<0.005	0.0150	mg/L	9/20/2024	SM 3113 B	0.005
UE #705	COPPER	0.079	1.3	mg/L	10/1/2024	SM 3111 B	0.05
9/17/2024 6:41							

Henry D. Clemens III
Laboratory Director

BRANDYWINE SCIENCE CENTER INC.
204 LINE ROAD
KENNETT SQUARE, PA 19348
PA DEP # 15-00301
(610) 444-9850

ORIGIN OF SAMPLE	**NAME**	Unionville-Chadds Ford Sch Dst			
	ADDRESS	740 Unionville Road			
	CITY/STATE	Kennett Square, PA 19348			
	PWS #	**N/A**			
Sample Source	**Location**	Unionville Elementary	**SAMPLE INFORMATION**	**SAMPLE DATE**	9/17/2024
	AQUA	x		**SAMPLE TIME**	see below
SAMPLE COLLECTED BY	**LAB STAFF**			**DATE RECEIVED**	9/17/2024
	OTHER	Erik N		**TIME RECEIVED**	13:25
				DATE OF REPORT	10/14/2024

	CHEMICAL ANALYSIS	RESULT	DEP LIMIT	UNITS	DATE ANALYZED	Method	REPORTING LIMIT
lab# 413800	LEAD	<0.005	0.0150	mg/L	9/20/2024	SM 3113 B	0.005
UE #706	COPPER	<0.05	1.3	mg/L	10/1/2024	SM 3111 B	0.05
9/17/2024 6:31							
lab# 413801	LEAD	<0.005	0.0150	mg/L	9/20/2024	SM 3113 B	0.005
UE #707	COPPER	0.065	1.3	mg/L	10/1/2024	SM 3111 B	0.05
9/17/2024 6:37							
lab# 413802	LEAD	<0.005	0.0150	mg/L	9/20/2024	SM 3113 B	0.005
UE #708	COPPER	0.128	1.3	mg/L	10/1/2024	SM 3111 B	0.05
9/17/2024 6:38							
lab# 413803	LEAD	<0.005	0.0150	mg/L	9/20/2024	SM 3113 B	0.005
UE #709	COPPER	0.087	1.3	mg/L	10/1/2024	SM 3111 B	0.05
9/17/2024 6:43							
lab# 413804	LEAD	<0.005	0.0150	mg/L	9/20/2024	SM 3113 B	0.005
UE #710	COPPER	0.117	1.3	mg/L	10/1/2024	SM 3111 B	0.05
9/17/2024 6:47							

Henry D. Clemens III
Laboratory Director

BRANDYWINE SCIENCE CENTER INC.
204 LINE ROAD
KENNETT SQUARE, PA 19348
PA DEP # 15-00301
(610) 444-9850

ORIGIN OF SAMPLE	**NAME**	Unionville-Chadds Ford Sch Dst			
	ADDRESS	740 Unionville Road			
	CITY/STATE	Kennett Square, PA 19348			
	PWS #	**N/A**			
Sample Source	**Location**	Unionville Elementary	**SAMPLE INFORMATION**	**SAMPLE DATE**	9/17/2024
	AQUA	x		**SAMPLE TIME**	see below
SAMPLE COLLECTED BY	**LAB STAFF**			**DATE RECEIVED**	9/17/2024
	OTHER	Erik N		**TIME RECEIVED**	13:25
				DATE OF REPORT	10/14/2024

	CHEMICAL ANALYSIS	RESULT	DEP LIMIT	UNITS	DATE ANALYZED	Method	REPORTING LIMIT
lab# 413805	LEAD	<0.005	0.0150	mg/L	9/20/2024	SM 3113 B	0.005
UE #711	COPPER	0.064	1.3	mg/L	10/1/2024	SM 3111 B	0.05
9/17/2024 6:49							
lab# 413806	LEAD	<0.005	0.0150	mg/L	9/20/2024	SM 3113 B	0.005
UE #712	COPPER	0.098	1.3	mg/L	10/1/2024	SM 3111 B	0.05
9/17/2024 6:50							
lab# 413807	LEAD	<0.005	0.0150	mg/L	9/20/2024	SM 3113 B	0.005
UE #713	COPPER	0.114	1.3	mg/L	10/1/2024	SM 3111 B	0.05
9/17/2024 6:39							
lab# 413808	LEAD	<0.005	0.0150	mg/L	9/20/2024	SM 3113 B	0.005
EU #714	COPPER	0.094	1.3	mg/L	10/1/2024	SM 3111 B	0.05
9/17/2024 6:56							
lab# 413809	LEAD	<0.005	0.0150	mg/L	9/20/2024	SM 3113 B	0.005
UE #715	COPPER	0.107	1.3	mg/L	10/1/2024	SM 3111 B	0.05
9/17/2024 6:58							

Henry D. Clemens III
Laboratory Director

BRANDYWINE SCIENCE CENTER INC.
204 LINE ROAD
KENNETT SQUARE, PA 19348
PA DEP # 15-00301
(610) 444-9850

ORIGIN OF SAMPLE	**NAME**	Unionville-Chadds Ford Sch Dst			
	ADDRESS	740 Unionville Road			
	CITY/STATE	Kennett Square, PA 19348			
	PWS #	**N/A**			
Sample Source	**Location**	Unionville Elementary	**SAMPLE INFORMATION**	**SAMPLE DATE**	9/17/2024
	AQUA	x		**SAMPLE TIME**	see below
SAMPLE COLLECTED BY	**LAB STAFF**			**DATE RECEIVED**	9/17/2024
	OTHER	Erik N		**TIME RECEIVED**	13:25
				DATE OF REPORT	10/14/2024

	CHEMICAL ANALYSIS	RESULT	DEP LIMIT	UNITS	DATE ANALYZED	Method	REPORTING LIMIT
lab# 413810	LEAD	<0.005	0.0150	mg/L	9/20/2024	SM 3113 B	0.005
UE 716	COPPER	0.069	1.3	mg/L	10/1/2024	SM 3111 B	0.05
9/17/2024 6:53							
lab# 413811	LEAD	<0.005	0.0150	mg/L	9/20/2024	SM 3113 B	0.005
UE #717	COPPER	0.117	1.3	mg/L	10/1/2024	SM 3111 B	0.05
9/17/2024 6:55							
lab# 413812	LEAD	<0.005	0.0150	mg/L	9/20/2024	SM 3113 B	0.005
UE #718	COPPER	0.257	1.3	mg/L	10/1/2024	SM 3111 B	0.05
9/17/2024 6:59							

Henry D. Clemens III
Laboratory Director