



August 25, 2026

Will Wenzloff
Hillsboro School District
4901 SE Witch Hazel Road
Hillsboro, Oregon 97123

Via email: wenzlofw@hsd.k12.or.us

Regarding: Drinking Water Sampling Report
Indian Hills ES – Modular Building
21260 SW Rock Road
Beaverton, Oregon
Apex Project No. 26010605 / 0014

Dear Mr. Wenzloff:

On August 15, 2026, Apex Companies LLC (Apex) collected drinking water samples from the modular building at Indian Hills Elementary School, located at 21260 SW Rock Road in Beaverton, Oregon. The testing was requested by Hillsboro School District as part of their efforts to ensure that concentrations of lead in drinking water at the building remain below the Oregon Department of Education (ODE) action level of 10 parts per billion (ppb).

Water from all fixtures in the building used for drinking or food preparation have lead concentrations below 10 ppb.

Eleven samples were collected and delivered under chain of custody to Apex Laboratories in Tigard, Oregon, for lead analysis. The results of the sampling are shown below.

Fixture Number	Sample Number	Location / Room No.	Results (ppb)
001	22391003-001WB26A	Lobby – water bottle filler	ND
002	22391003-002DF26A	Lobby – drinking fountain, left	ND
003	22391003-003DF26A	Lobby – drinking fountain, right	ND
004	22391003-004CF26A	K-3 – classroom faucet	0.453
005	22391003-005CF26A	K-2 – classroom faucet	0.628
006	22391003-006CFB26A	K-1 – classroom faucet	0.845
007	22391003-007BF26A	Boys Restroom Sink – Left	0.505
008	22391003-008BF26A	Boys Restroom Sink - Right	0.612
009	22391003-009BF26A	Girls Restroom Sink – Left	0.830
010	22391003-010BF26A	Girls Restroom Sink - Right	0.613
011	22391003-011BFB26A	Staff Restroom Sink	0.264

ND = no lead detected

Please refer to the attached laboratory analytical report for additional details. The laboratory analytical results are reported in micrograms per liter ($\mu\text{g/L}$), a unit of measure that is equivalent to ppb.

Sampling methodology and the interpretation of laboratory results were based on the Environmental Protection Agency guidance document titled *3Ts for Reducing Lead in Drinking Water in Schools*. Following this guideline, Apex collected first draw samples from each test location. First draw samples consist of the first 250 milliliters (mL) of water drawn from a fixture after the water has been sitting stagnant for at least 8 hours. The 3Ts' sampling protocol specifying 250-mL samples is designed to maximize the likelihood that the highest concentrations of lead in water used for consumption are identified.

Please feel free to contact me at 503.515.4726 or dale.voeller@apexc.com with any questions or comments.

Sincerely,

A handwritten signature in black ink, appearing to read 'Dale Voeller', with a stylized, cursive script.

Dale Voeller, CHMM, CSP
Senior Project Manager

Attachment: Fixture Location Drawing
 Laboratory Analytical Report


$$3/16" = 1'-0"$$

OCCUPANT LOAD FOR EGRESS DESIGN					
ROOM	AREA S.F.	OCCUPANT FACTOR	OCCUPANT LOAD	C.P.O.E. TRAVEL DISTANCE	EXIT ACCESS TRAVEL DISTANCE
CLASSROOM #1:	740	20 SF/P	37P	52'-6"	25'-0"
CLASSROOM #2:	740	20 SF/P	37P	52'-6"	25'-0"
CLASSROOM #3:	740	20 SF/P	37P	52'-6"	25'-0"

A-0.1



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223

503-718-2323

ORELAP ID: OR100062

Monday, August 24, 2026

Dale Voeller

Apex Companies, LLC - Portland

4412 S Corbett Ave

Portland, OR 97239

RE: A6H1334 - Hillsboro School District - Indian Hills ES/26010605

Thank you for using Apex Laboratories. We greatly appreciate your business and strive to provide the highest quality services to the environmental industry.

Enclosed are the results of analyses for work order A6H1334, which was received by the laboratory on 8/17/2026 at 1:03:00PM.

If you have any questions concerning this report or the services we offer, please feel free to contact me by email at: jwoodcock@apex-labs.com, or by phone at 503-718-2323.

Please note: All samples will be disposed of within 30 days of sample receipt, unless prior arrangements have been made.

Cooler Receipt Information

Acceptable Receipt Temperature is less than, or equal to, 6 degC (not frozen), or received on ice the same day as sampling.

(See Cooler Receipt Form for details)

Default Cooler 23.8 degC

This Final Report is the official version of the data results for this sample submission, unless superseded by a subsequent, labeled amended report.

All other deliverables derived from this data, including Electronic Data Deliverables (EDDs), CLP-like forms, client requested summary sheets, and all other products are considered secondary to this report.



Apex Laboratories

The results in this report apply to the samples analyzed in accordance with the chain of custody document(s) and updated by any subsequent written communications. This analytical report must be reproduced in its entirety.

Jason Woodcock, Project Manager



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062

Apex Companies, LLC - Portland

4412 S Corbett Ave
Portland, OR 97239

Project: **Hillsboro School District**

Project Number: **Indian Hills ES/26010605**

Project Manager: **Dale Voeller**

Report ID:

A6H1334 - 08 24 26 1303

ANALYTICAL REPORT FOR SAMPLES

SAMPLE INFORMATION

Client Sample ID	Laboratory ID	Matrix	Date Sampled	Date Received
22391003-001WB26A	A6H1334-01	Drinking Water	08/15/26 00:00	08/17/26 13:03
22391003-002DF26A	A6H1334-02	Drinking Water	08/15/26 00:00	08/17/26 13:03
22391003-003DF26A	A6H1334-03	Drinking Water	08/15/26 00:00	08/17/26 13:03
22391003-004CF26A	A6H1334-04	Drinking Water	08/15/26 00:00	08/17/26 13:03
22391003-005CF26A	A6H1334-05	Drinking Water	08/15/26 00:00	08/17/26 13:03
22391003-006CF26A	A6H1334-06	Drinking Water	08/15/26 00:00	08/17/26 13:03
22391003-007BF26A	A6H1334-07	Drinking Water	08/15/26 00:00	08/17/26 13:03
22391003-008BF26A	A6H1334-08	Drinking Water	08/15/26 00:00	08/17/26 13:03
22391003-009BF26A	A6H1334-09	Drinking Water	08/15/26 00:00	08/17/26 13:03
22391003-010BF26A	A6H1334-10	Drinking Water	08/15/26 00:00	08/17/26 13:03
22391003-011BF26A	A6H1334-11	Drinking Water	08/15/26 00:00	08/17/26 13:03

Apex Laboratories

The results in this report apply to the samples analyzed in accordance with the chain of custody document(s) and updated by any subsequent written communications. This analytical report must be reproduced in its entirety.

Jason Woodcock, Project Manager

**ANALYTICAL REPORT****Apex Laboratories, LLC**6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062**Apex Companies, LLC - Portland**4412 S Corbett Ave
Portland, OR 97239Project: **Hillsboro School District**Project Number: **Indian Hills ES/26010605**Project Manager: **Dale Voeller****Report ID:****A6H1334 - 08 24 26 1303****ANALYTICAL SAMPLE RESULTS****Total Metals in Drinking Water by EPA 200.8 (ICPMS)**

Analyte	Sample Result	Detection Limit	Reporting Limit	Units	Dilution	Date Analyzed	Method Ref.	Notes
22391003-001WB26A (A6H1334-01RE1)				Matrix: Drinking Water				
Batch: 26H0515								
Lead	ND	---	0.200	ug/L	1	08/19/26 16:31	EPA 200.8	
22391003-002DF26A (A6H1334-02RE1)				Matrix: Drinking Water				
Batch: 26H0515								
Lead	ND	---	0.200	ug/L	1	08/19/26 16:37	EPA 200.8	
22391003-003DF26A (A6H1334-03)				Matrix: Drinking Water				
Batch: 26H0515								
Lead	ND	---	0.200	ug/L	1	08/19/26 16:39	EPA 200.8	
22391003-004CF26A (A6H1334-04)				Matrix: Drinking Water				
Batch: 26H0515								
Lead	0.453	---	0.200	ug/L	1	08/19/26 16:41	EPA 200.8	
22391003-005CF26A (A6H1334-05)				Matrix: Drinking Water				
Batch: 26H0515								
Lead	0.628	---	0.200	ug/L	1	08/19/26 16:43	EPA 200.8	
22391003-006CF26A (A6H1334-06)				Matrix: Drinking Water				
Batch: 26H0515								
Lead	0.845	---	0.200	ug/L	1	08/19/26 16:45	EPA 200.8	
22391003-007BF26A (A6H1334-07)				Matrix: Drinking Water				
Batch: 26H0515								
Lead	0.505	---	0.200	ug/L	1	08/19/26 16:52	EPA 200.8	
22391003-008BF26A (A6H1334-08)				Matrix: Drinking Water				
Batch: 26H0515								
Lead	0.612	---	0.200	ug/L	1	08/19/26 16:53	EPA 200.8	
22391003-009BF26A (A6H1334-09)				Matrix: Drinking Water				
Batch: 26H0515								
Lead	0.830	---	0.200	ug/L	1	08/19/26 16:56	EPA 200.8	

Apex Laboratories

Jason Woodcock, Project Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document(s) and updated by any subsequent written communications. This analytical report must be reproduced in its entirety.

**ANALYTICAL REPORT****Apex Laboratories, LLC**6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323

ORELAP ID: OR100062

Apex Companies, LLC - Portland4412 S Corbett Ave
Portland, OR 97239Project: **Hillsboro School District**Project Number: **Indian Hills ES/26010605**Project Manager: **Dale Voeller****Report ID:****A6H1334 - 08 24 26 1303****ANALYTICAL SAMPLE RESULTS****Total Metals in Drinking Water by EPA 200.8 (ICPMS)**

Analyte	Sample Result	Detection Limit	Reporting Limit	Units	Dilution	Date Analyzed	Method Ref.	Notes
22391003-010BF26A (A6H1334-10)				Matrix: Drinking Water				
Batch: 26H0515								
Lead	0.613	---	0.200	ug/L	1	08/19/26 16:58	EPA 200.8	
22391003-011BF26A (A6H1334-11)				Matrix: Drinking Water				
Batch: 26H0515								
Lead	0.264	---	0.200	ug/L	1	08/19/26 17:00	EPA 200.8	

Apex Laboratories

Jason Woodcock, Project Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document(s) and updated by any subsequent written communications. This analytical report must be reproduced in its entirety.



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062Apex Companies, LLC - Portland
4412 S Corbett Ave
Portland, OR 97239Project: Hillsboro School District
Project Number: Indian Hills ES/26010605
Project Manager: Dale VoellerReport ID:
A6H1334 - 08 24 26 1303

QUALITY CONTROL (QC) SAMPLE RESULTS

Total Metals in Drinking Water by EPA 200.8 (ICPMS)

Analyte	Result	Detection Limit	Reporting Limit	Units	Dilution	Spike Amount	Source Result	% REC	% REC Limits	RPD	RPD Limit	Notes
Batch 26H0515 - EPA 200.8 Direct Analysis							Drinking Water					
Blank (26H0515-BLK1)		Prepared: 08/19/26 07:52			Analyzed: 08/19/26 15:00							
<u>EPA 200.8</u>												
Lead	ND	---	0.200	ug/L	1	---	---	---	---	---	---	
LCS (26H0515-BS3)		Prepared: 08/19/26 07:52			Analyzed: 08/19/26 16:30							
<u>EPA 200.8</u>												
Lead	15.3	---	0.201	ug/L	1	15.0	---	102	85 - 115%	---	---	Q-16
Duplicate (26H0515-DUP2)		Prepared: 08/19/26 07:52			Analyzed: 08/19/26 16:33							
<u>QC Source Sample: 22391003-001WB26A (A6H1334-01RE1)</u>												
<u>EPA 200.8</u>												
Lead	ND	---	0.200	ug/L	1	---	ND	---	---	---	20%	Q-16
Matrix Spike (26H0515-MS2)		Prepared: 08/19/26 07:52			Analyzed: 08/19/26 17:02							
<u>QC Source Sample: 22391003-011BF26A (A6H1334-11)</u>												
<u>EPA 200.8</u>												
Lead	15.5	---	0.201	ug/L	1	15.0	0.264	101	70 - 130%	---	---	
Matrix Spike (26H0515-MS3)		Prepared: 08/19/26 07:52			Analyzed: 08/19/26 16:35							
<u>QC Source Sample: 22391003-001WB26A (A6H1334-01RE1)</u>												
<u>EPA 200.8</u>												
Lead	15.5	---	0.201	ug/L	1	15.0	ND	103	70 - 130%	---	---	Q-16

Apex Laboratories

Jason Woodcock, Project Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document(s) and updated by any subsequent written communications. This analytical report must be reproduced in its entirety.

**ANALYTICAL REPORT****Apex Laboratories, LLC**6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323

ORELAP ID: OR100062

Apex Companies, LLC - Portland4412 S Corbett Ave
Portland, OR 97239Project: **Hillsboro School District**Project Number: **Indian Hills ES/26010605**Project Manager: **Dale Voeller****Report ID:****A6H1334 - 08 24 26 1303****SAMPLE PREPARATION INFORMATION****Total Metals in Drinking Water by EPA 200.8 (ICPMS)****Prep: EPA 200.8 Direct Analysis**

Lab Number	Matrix	Method	Sampled	Prepared	Sample Initial/Final	Default Initial/Final	RL Prep Factor
Batch: 26H0515							
A6H1334-01RE1	Drinking Water	EPA 200.8	08/15/26 00:00	08/19/26 07:52	10mL/10mL	10mL/10mL	1.00
A6H1334-02RE1	Drinking Water	EPA 200.8	08/15/26 00:00	08/19/26 07:52	10mL/10mL	10mL/10mL	1.00
A6H1334-03	Drinking Water	EPA 200.8	08/15/26 00:00	08/19/26 07:52	10mL/10mL	10mL/10mL	1.00
A6H1334-04	Drinking Water	EPA 200.8	08/15/26 00:00	08/19/26 07:52	10mL/10mL	10mL/10mL	1.00
A6H1334-05	Drinking Water	EPA 200.8	08/15/26 00:00	08/19/26 07:52	10mL/10mL	10mL/10mL	1.00
A6H1334-06	Drinking Water	EPA 200.8	08/15/26 00:00	08/19/26 07:52	10mL/10mL	10mL/10mL	1.00
A6H1334-07	Drinking Water	EPA 200.8	08/15/26 00:00	08/19/26 07:52	10mL/10mL	10mL/10mL	1.00
A6H1334-08	Drinking Water	EPA 200.8	08/15/26 00:00	08/19/26 07:52	10mL/10mL	10mL/10mL	1.00
A6H1334-09	Drinking Water	EPA 200.8	08/15/26 00:00	08/19/26 07:52	10mL/10mL	10mL/10mL	1.00
A6H1334-10	Drinking Water	EPA 200.8	08/15/26 00:00	08/19/26 07:52	10mL/10mL	10mL/10mL	1.00
A6H1334-11	Drinking Water	EPA 200.8	08/15/26 00:00	08/19/26 07:52	10mL/10mL	10mL/10mL	1.00

Apex Laboratories

Jason Woodcock, Project Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document(s) and updated by any subsequent written communications. This analytical report must be reproduced in its entirety.



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323

ORELAP ID: OR100062

Apex Companies, LLC - Portland

4412 S Corbett Ave
Portland, OR 97239

Project: Hillsboro School District

Project Number: Indian Hills ES/26010605

Project Manager: Dale Voeller

Report ID:

A6H1334 - 08 24 26 1303

QUALIFIER DEFINITIONS

Client Sample and Quality Control (QC) Sample Qualifier Definitions:

Apex Laboratories

Q-16 Reanalysis of an original Batch QC sample.

Apex Laboratories

The results in this report apply to the samples analyzed in accordance with the chain of custody document(s) and updated by any subsequent written communications. This analytical report must be reproduced in its entirety.

Jason Woodcock, Project Manager



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062

Apex Companies, LLC - Portland

4412 S Corbett Ave
Portland, OR 97239

Project: **Hillsboro School District**

Project Number: **Indian Hills ES/26010605**

Project Manager: **Dale Voeller**

Report ID:

A6H1334 - 08 24 26 1303

REPORTING NOTES AND CONVENTIONS:

Abbreviations:

DET Analyte DETECTED at or above the detection or reporting limit.
ND Analyte NOT DETECTED at or above the detection or reporting limit.
NR Result Not Reported.
RPD Relative Percent Difference. RPDs for Matrix Spikes and Matrix Spike Duplicates are based on concentration, not recovery.

Detection Limits: Limit of Detection (LOD)

Limits of Detection (LODs) are normally set at a level of one half the validated Limit of Quantitation (LOQ).
If no value is listed ('-----'), then the data has not been evaluated below the Reporting Limit.

Reporting Limits: Limit of Quantitation (LOQ)

Validated Limits of Quantitation (LOQs) are reported as the Reporting Limits for all analyses where the LOQ, MRL, PQL or CRL are requested. The LOQ represents a level at or above the low point of the calibration curve, that has been validated according to Apex Laboratories' comprehensive LOQ policies and procedures.

Reporting and Detection Limits: Default Limits

Default Reporting and Detection Limits are based on 100% dry weight with the minimum dilution for the analysis. Reporting and Detection Limits are raised due to moisture content, additional dilutions required for analysis, matrix interferences and in other cases, as necessary.

Reporting Conventions:

Basis: Results for soil samples are generally reported on a 100% dry weight basis.

Results where dry weight correction has not been applied do not have the "dry" designation appended to the units, and results are reported on an "as received" basis.

Results for Volatiles analyses on soils and sediments that are reported on a "dry weight" basis include the water miscible solvent (WMS) correction referenced in the EPA 8000 Method guidance documents. Solid and Liquid samples reported on an "As Received" basis do not have the WMS correction applied, as dry weight was not performed.

QC Source:

In cases where there is insufficient sample provided for Sample Duplicates and/or Matrix Spikes, a Lab Control Sample Duplicate (LCS Dup) may be analyzed to demonstrate accuracy and precision of the extraction batch.

Non-Client Batch QC Samples (Duplicates and Matrix Spike/Duplicates) are not included in this report. Please request a Full QC report if this data is required.

Miscellaneous Notes:

" --- " QC results are not applicable. For example, % Recoveries for Blanks and Duplicates, % RPD for Blanks, Blank Spikes and Matrix Spikes, etc.

" *** " Used to indicate a possible discrepancy with the Sample and Sample Duplicate results when the %RPD is not available. In this case, either the Sample or the Sample Duplicate has a reportable result for this analyte, while the other is Non Detect (ND).

Apex Laboratories

The results in this report apply to the samples analyzed in accordance with the chain of custody document(s) and updated by any subsequent written communications. This analytical report must be reproduced in its entirety.

Jason Woodcock, Project Manager



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062

Apex Companies, LLC - Portland

4412 S Corbett Ave
Portland, OR 97239

Project: Hillsboro School District

Project Number: Indian Hills ES/26010605

Project Manager: Dale Voeller

Report ID:

A6H1334 - 08 24 26 1303

REPORTING NOTES AND CONVENTIONS (Cont.):

Blanks:

Standard practice is to evaluate the results from Blank QC Samples down to a level equal to one half of the Reporting Limit (RL).

Blank results for gravimetric analyses are evaluated to the Reporting Level, not to half of the Reporting Level.

-For Blank hits falling between $\frac{1}{2}$ the RL and the RL (J flagged hits), the associated sample and QC data will receive a 'B-02' qualifier.

-For Blank hits above the RL, the associated sample and QC data will receive a 'B' qualifier, per Apex Laboratories' Blank Policy.

For further details, please request a copy of this document.

Sample results flagged with a 'B' or 'B-02' qualifier are potentially biased high if the sample results are less than ten times the level found in the blank for inorganic analyses, or less than five times the level found in the blank for organic analyses.

'B' and 'B-02' qualifications are only applied to sample results detected above the Reporting Level.

Preparation Notes:

Mixed Matrix Samples:

Water Samples:

Water samples containing significant amounts of sediment are decanted or separated prior to extraction, and only the water portion analyzed, unless otherwise directed by the client.

Soil and Sediment Samples:

Soil and Sediment samples containing significant amounts of water are decanted prior to extraction, and only the solid portion analyzed, unless otherwise directed by the client.

Sampling and Preservation Notes:

Certain regulatory programs, such as National Pollutant Discharge Elimination System (NPDES), require that activities such as sample filtration (for dissolved metals, orthophosphate, hexavalent chromium, etc.) and testing of short hold analytes (pH, Dissolved Oxygen, etc.) be performed in the field (on-site) within a short time window. In addition, sample matrix spikes are required for some analyses, and sufficient volume must be provided, and billable site specific QC requested, if this is required. All regulatory permits should be reviewed to ensure that these requirements are being met.

Data users should be aware of which regulations pertain to the samples they submit for testing. If related sample collection activities are not approved for a particular regulatory program, results should be considered estimates. Apex Laboratories will qualify these analytes according to the most stringent requirements, however results for samples that are for non-regulatory purposes may be acceptable.

Apex Laboratories

The results in this report apply to the samples analyzed in accordance with the chain of custody document(s) and updated by any subsequent written communications. This analytical report must be reproduced in its entirety.

Jason Woodcock, Project Manager



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062

Apex Companies, LLC - Portland

4412 S Corbett Ave
Portland, OR 97239

Project: **Hillsboro School District**

Project Number: **Indian Hills ES/26010605**

Project Manager: **Dale Voeller**

Report ID:

A6H1334 - 08 24 26 1303

Decanted Samples:

Soils/Sediments:

Unless TCLP analysis is required or there is notification otherwise for a specific project, all Soil and Sediments containing excess water are decanted prior to analysis in order to provide the most representative sample for analysis.

Water Samples:

Water samples containing solids and sediment may need to be decanted in order to eliminate these particulates from the water extractions. In the case of organics extractions, a solvent rinse of the container will not be performed.

Volatiles Soils (5035s)

Samples that are field preserved by 5035 for volatiles are dry weight corrected using the same dry weight correction as for normal analyses.

In the case of decanted samples, the dry weight may be performed on a decanted sample, while the aliquot for 5035 may not have been treated the same way. If this is a concern, please submit separate containers for dry weight analysis for volatiles can be provided.

All samples decanted in the laboratory are noted in this report with the DCNT qualifier indicating the sample was decanted.

Apex Laboratories

The results in this report apply to the samples analyzed in accordance with the chain of custody document(s) and updated by any subsequent written communications. This analytical report must be reproduced in its entirety.

Jason Woodcock, Project Manager



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062

Apex Companies, LLC - Portland

4412 S Corbett Ave
Portland, OR 97239

Project: Hillsboro School District

Project Number: Indian Hills ES/26010605

Project Manager: Dale Voeller

Report ID:

A6H1334 - 08 24 26 1303

LABORATORY ACCREDITATION INFORMATION

ORELAP Certification ID: OR100062 (Primary Accreditation)

EPA ID: OR01039

All methods and analytes reported from work performed at Apex Laboratories are included on Apex Laboratories' ORELAP Scope of Certification, with the exception of any analyte(s) listed below:

Apex Laboratories

Matrix	Analysis	Analyte	TNI_ID	Accreditation
--------	----------	---------	--------	---------------

All reported analytes are included in Apex Laboratories' current ORELAP scope.

Secondary Accreditations

Apex Laboratories also maintains reciprocal accreditation with non-TNI states (Washington DOE), as well as other state specific accreditations not listed here.

Subcontract Laboratory Accreditations

Subcontracted data falls outside of Apex Laboratories' Scope of Accreditation.

Please see the Subcontract Laboratory report for full details, or contact your Project Manager for more information.

Field Testing Parameters

Results for Field Tested data are provided by the client or sampler, and fall outside of Apex Laboratories' Scope of Accreditation.

Apex Laboratories

Jason Woodcock, Project Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document(s) and updated by any subsequent written communications. This analytical report must be reproduced in its entirety.



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062

Apex Companies, LLC - Portland

4412 S Corbett Ave
Portland, OR 97239

Project: Hillsboro School District

Project Number: Indian Hills ES/26010605

Project Manager: Dale Voeller

Report ID:

A6H1334 - 08 24 26 1303

Lead in Drinking Water Testing Program

Date Collected: 08/15/2026

Apex Project: 26010605 / 0014

School Name: Indian Hills ES

District: Hillsboro School District

Building: Modular Building - Round 1

Building Number: 22391003

Analysis Requested: Lead (Pb) in Drinking Water

Email Results To: dale.voeller@apexcos.com

Turnaround Time: 10-day

	Fixture Number	Sample Number	Room / Location
1	001	22391003-001WB26A	Lobby - water bottle filler
2	002	22391003-002DF26A	Lobby - drinking fountain, left
3	003	22391003-003DF26A	Lobby - drinking fountain, right
4	004	22391003-004CF26A	K-3 - classroom faucet
5	005	22391003-005CF26A	K-2 - classroom faucet
6	006	22391003-006CFB26A	K-1 - classroom faucet
7	007	22391003-007BF26A	Boys Restroom Sink - Left
8	008	22391003-008BF26A	Boys Restroom Sink - Right
9	009	22391003-009BF26A	Girls Restroom Sink - Left
10	010	22391003-010BF26A	Girls Restroom Sink - Right
11	011	22391003-011BF26A	Staff Restroom Sink
12	012		
13	013		
14	014		
15	015		
16	016		
17	017		
18	018		
19	019		
20	020		

Relinquished By/Signature: Dale Voeller

Date/Time: 8/15/26 @ 11:40 AM

Received By/Signature: Jason Woodcock

Date/Time: 8/17/26

1303



1 of 1

Apex Laboratories

Jason Woodcock

Jason Woodcock, Project Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document(s) and updated by any subsequent written communications. This analytical report must be reproduced in its entirety.



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street

Tigard, OR 97223

503-718-2323

ORELAP ID: OR100062

Apex Companies, LLC - Portland

4412 S Corbett Ave

Portland, OR 97239

Project: Hillsboro School District

Project Number: Indian Hills ES/26010605

Project Manager: Dale Voeller

Report ID:

A6H1334 - 08 24 26 1303

APEX LABS COOLER RECEIPT FORM

Client: Apex Companies Element WO#: A6 H1334Project/Project #: Lead in drinking water Testing Program /26010605 / 0014

Delivery Info:

Date/time received: 8/17/26 @ 1303 By: JREDelivered by: Apex ☒ Client ☐ ESS ☐ FedEx ☐ UPS ☐ Radio ☐ Morgan ☐ SDS ☐ Evergreen ☐ Other ☐From USDA Regulated Origin? Yes ☐ No ☒Cooler Inspection Date/time inspected: 8/17/26 @ 1328 By: JREChain of Custody included? Yes ☒ No ☐Signed/dated by client? Yes ☒ No ☐Contains USDA Reg. Soils? Yes ☐ No ☒ Unsure (email RegSoils) ☐

	Cooler #1	Cooler #2	Cooler #3	Cooler #4	Cooler #5	Cooler #6	Cooler #7
Temperature (°C)	<u>23.8</u>						
Custody seals? (Y/N)	<u>N</u>						
Received on ice? (Y/N)	<u>N</u>						
Temp. blanks? (Y/N)	<u>N</u>						
Ice type: (Gel/Real/Other)	<u>None</u>						
Condition (In/Out)	<u>out</u>						

Cooler out of temp? (Y/N) Possible reason why: Drinking watersGreen dots applied to out of temperature samples? Yes ☒ No ☐Out of temperature samples form initiated? Yes ☒ No ☐Sample Inspection: Date/time inspected: 8/18/26 @ 0906 By: KMSAll samples intact? Yes ☒ No ☐ Comments: Bottle labels/COCs agree? Yes ☐ No ☒ Comments: Labels read 003DW, 002DW, 002DF, 003DF.COC/container discrepancies form initiated? Yes ☐ No ☒Containers/volumes received appropriate for analysis? Yes ☒ No ☐ Comments: Do VOA vials have visible headspace? Yes ☐ No ☐ NA ☒Comments: Water samples: pH checked: Yes ☒ No ☐ NA ☐ pH appropriate? Yes ☒ No ☐ NA ☐ pH ID: AUSG277Comments: Labeled by: JSWitness: JSCooler Inspected by: JS

Form Y-003 R-02 -

Apex Laboratories

Jason Woodcock, Project Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document(s) and updated by any subsequent written communications. This analytical report must be reproduced in its entirety.