Mercer Island School District

Lead Water Testing - Results/Mitigation/Remediaton Measures

Initial Test Results Received	11/21/2025
Re-Testing Results Received	5/21/2026 & 5/29/2026 (LR)
Final-Testing Results Received	8/18/2026 (LR)

	Sample Collection Date	Sampling and Testing Provider	Sample ID	School Name	Location	Fixture Information	Lead Test Result (ppb)	Mitigation Measure (Indicate temporary or permanent)	Date Implemented	Re-Testing Sample Collection Date	New Lead Test Result (ppb)	Re-Testing (third) Sample Collection Date	Third Lead Test Result (ppb)	Notes
1	10/18/2025	Dept of Health (DOH)	415256	Mercer Island High School	Kitchen Island (2 of 4)	Sink	7	Replaced Fixture - Permanent	12/22/2025	04/29/2026	2			
2	10/18/2025	Dept of Health (DOH)	415265	Mercer Island High School	Library Office/Work Area	Sink	6	Replaced Fixture - Permanent	12/22/2025	04/29/2026	<1			
3	10/29/2025	Dept of Health (DOH)	411042	Islander Middle School (100/200 & 300 Bldgs)	Workroom/ Storage	Sink	6	Replaced Fixture - Permanent	12/09/2025	04/29/2026	Not potable water and did not get re-tested. This location was marked as "Non Potable Water - Do Not Drink"			
4	10/15/2025	Dept of Health (DOH)	415823	Island Park	Room 122	Sink	23	Replaced Fixture - Permanent	11/22/2025	04/29/2026	3			
5	10/15/2025	Dept of Health (DOH)	415828	Island Park	Room 130	Sink	14	Replaced Fixture - Permanent	11/22/2025	04/29/2026	2			
6	10/15/2025	Dept of Health (DOH)	415807	Island Park	Room 117	Sink	12	Replaced Fixture - Permanent	11/22/2025	04/29/2026	2			
7	10/15/2025	Dept of Health (DOH)	415806	Island Park	Library Office	Sink	10	Replaced Fixture - Permanent	11/24/2025	04/29/2026	1			
8	10/15/2025	Dept of Health (DOH)	415833	Island Park	Office Workroom	Sink	9	Replaced Fixture - Permanent	12/08/2025	04/29/2026	1			
9	10/15/2025	Dept of Health (DOH)	415834	Island Park	Room 126	Sink	9	Replaced Fixture - Permanent	12/08/2025	04/29/2026	1			
10	10/15/2025	Dept of Health (DOH)	415831	Island Park	Nurses Office	Sink	6	Replaced Fixture - Permanent	12/09/2025	04/29/2026	<1			

11	10/16/2025	Dept of Health (DOH)	415365	Lakeridge	302 Library Office	Sink	41	Replaced Fixture - Permanent	11/22/2025	04/29/2026	14	08/06/2026	0	This fixture has been taken out of service and will undergo additional remediation & testing. This sink was thoroughly flushed and retested and passed.
12	10/16/2025	Dept of Health (DOH)	415418	Lakeridge	Workroom	Sink	8	Replaced Fixture - Permanent	12/03/2025	04/29/2026	2			
13	10/16/2025	Dept of Health (DOH)	415416	Lakeridge	Nurses Office	Fountain	7	Replaced Fixture - Permanent	12/03/2025	04/29/2026	2			
14	10/16/2025	Dept of Health (DOH)	415417	Lakeridge	Nurses Office	Tap	7	Replaced Fixture - Permanent	12/04/2025	04/29/2026	1			
15	10/17/2025	Dept of Health (DOH)	415468	West Mercer	Speech Room	Tap	52	Replaced Fixture - Permanent	11/24/2025	04/29/2026	4			
16	10/17/2025	Dept of Health (DOH)	415444	West Mercer	Pod A	Sink	21	Replaced Fixture - Permanent	11/24/2025	04/29/2026	4			
17	10/17/2025	Dept of Health (DOH)	415455	West Mercer	Pod B	Sink	20	Replaced Fixture - Permanent	11/24/2025	04/29/2026	4			
18	10/17/2025	Dept of Health (DOH)	415329	West Mercer	Pod C	Sink	19	Replaced Fixture - Permanent	11/24/2025	04/29/2026	4			
19	10/17/2025	Dept of Health (DOH)	415347	West Mercer	Counselor Room Next to Offices - Main Hallway	Sink	19	Replaced Fixture - Permanent	11/25/2025	04/29/2026	3			
20	10/17/2025	Dept of Health (DOH)	415443	West Mercer	Library Office	Sink	16	Replaced Fixture - Permanent	11/25/2025	04/29/2026	3			
21	10/17/2025	Dept of Health (DOH)	415478	West Mercer	Pod D	Sink	12	Replaced Fixture - Permanent	11/25/2025	04/29/2026	2			
22	10/17/2025	Dept of Health (DOH)	415472	West Mercer	Music Room	Fountain	11	Replaced Fixture - Permanent	12/1/2025	04/29/2026	1			
23	10/17/2025	Dept of Health (DOH)	415348	West Mercer	Nurses Office	Tap	8	Replaced Fixture - Permanent	12/2/2025	04/29/2026	1			
24	10/17/2025	Dept of Health (DOH)	415466	West Mercer	Room 111	Sink	6	Replaced Fixture - Permanent	12/3/2025	04/29/2026	<1			