

CERTIFICATE OF ANALYSIS

Client: Karl Environmental Group
20 Lauck Road
Mohnton PA 19540

Report Date: 8/26/2026
Report No.: 724873 - Lead Water
Project: 26-0791 Lead in Water Sampling
Project No.:

Client: KAR387

LEAD WATER SAMPLE ANALYSIS SUMMARY

Lab No.:7911200	Location:FB	Result(ppb):<1.00
Client No.:OHE-RM75-RBF	* Sample acidified to pH <2.	


Lab No.:7911201	Location:FB	Result(ppb):<1.00
Client No.:OHE-RM75-RFB	* Sample acidified to pH <2.	

Lab No.:7911202	Location:FB	Result(ppb):<1.00
Client No.:OHE-RM75-LFB	* Sample acidified to pH <2.	

Lab No.:7911203	Location:	Result(ppb):<1.00
Client No.:OHE-Blank	* Sample acidified to pH <2.	

Please refer to the Appendix of this report for further information regarding your analysis.

Date Received: 8/21/2026
Date Analyzed: 08/26/2026
Signature: 
Analyst: Chad Shaffer

Approved By: 
Frank E. Ehrenfeld, III
Laboratory Director

CERTIFICATE OF ANALYSIS

Client: Karl Environmental Group
20 Lauck Road
Mohnton PA 19540

Client: KAR387

Report Date: 8/26/2026
Report No.: 724873 - Lead Water
Project: 26-0791 Lead in Water Sampling
Project No.:

Appendix to Analytical Report:

Customer Contact: Mike Karl
Analysis: AAS-GF - ASTM D3559-15D

This appendix seeks to promote greater understanding of any observations, exceptions, special instructions, or circumstances that the laboratory needs to communicate to the client concerning the above samples. The information below is used to help promote your ability to make the most informed decisions for you and your customers. Please note the following points of contact for any questions you may have.

iATL Customer Service: customerservice@iatl.com
iATL Office Manager: ?wchampion@iatl.com
iATL Account Representative: Shirley Clark
Sample Login Notes: See Batch Sheet Attached
Sample Matrix: Water
Exceptions Noted: See Following Pages

General Terms, Warrants, Limits, Qualifiers:

General information about iATL capabilities and client/laboratory relationships and responsibilities are spelled out in iATL policies that are listed at www.iATL.com and in our Quality Assurance Manual per ISO 17025 standard requirements. The information therein is a representation of iATL definitions and policies for turnaround times, sample submittal, collection media, blank definitions, quantification issues and limit of detection, analytical methods and procedures, sub-contracting policies, results reporting options, fees, terms, and discounts, confidentiality, sample archival and disposal, and data interpretation.

iATL warrants the test results to be of a precision normal for the type and methodology employed for each sample submitted. iATL disclaims any other warrants, expressed or implied, including warranty of fitness for a particular purpose and warranty of merchantability. iATL accepts no legal responsibility for the purpose for which the client uses test results. Any analytical work performed must be governed by our Standard Terms and Conditions. Prices, methods and detection limits may be changed without notification. Please contact your Customer Service Representative for the most current information.

This confidential report relates only to those item(s) tested and does not represent an endorsement by NIST-NVLAP, AIHA LAP LLC, or any agency of local, state or province governments nor of any agency of the U.S. government.

This report shall not be reproduced except in full, without written approval of the laboratory.

Information Pertinent to this Report:

Analysis by AAS Graphite Furnace:

- ASTM D3559-15D

Certification:

- NYS-DOH No. 11021

- NJDEP No. 03863

Note: These methods are analytically equivalent to iATL's accredited method;

- USEPA 40CFR 141.11B

- USEPA 200.9 Pb, AAS-GF, RL <2 ppb/sample

- USEPA SW 846-7421 - Pb(AAS-GF, RL <2 ppb/sample)

Regulatory limit for lead in drinking water is 15.0 parts per billion as cited in EPA 40 CFR 141.11 National Primary Drinking Water Regulations, Subpart B: Maximum contaminant levels for inorganic chemicals.

All results are based on the samples as received at the lab. iATL assumes that appropriate sampling methods have been used and that the data upon which these results are based have been accurately supplied by the client.

Sample results are not corrected for contamination by field or analytical blanks.

PPB = Parts per billion. 1 µg/L = 1 ppb MDL = 0.24 PPB Reporting Limit (RL) = 1.0 PPB

CERTIFICATE OF ANALYSIS

Client: Karl Environmental Group
20 Lauck Road
Mohnton PA 19540

Report Date: 8/26/2026
Report No.: 724873 - Lead Water
Project: 26-0791 Lead in Water Sampling
Project No.:

Client: KAR387

Disclaimers / Qualifiers:

There may be some samples in this project that have a "NOTE:" associated with a sample result. We use added disclaimers or qualifiers to inform the client about something that requires further explanation. Here is a complete list with highlighted disclaimers pertinent to this project. For a full explanation of these and other disclaimers, please inquire at customerservice@iatl.com.

Matrix spiking is performed on each client batch to determine if interferences could impact results. When spike recoveries fall out of acceptable range matrix interference is suspected and samples are diluted until acceptable spike recovery can be achieved. Reporting limits will increase by the same degree as the dilution required.


Note: Sample dilution required due to matrix interference.

Water Sample Turbidity greater than 1.0 NTU does not meet Federal and NJ State Primary & Secondary Drinking Water Standards.

* ASTM D3559 (D) calls for the addition of acid at the time of sampling. Unless so noted on the chain of custody by the client iATL acidifies samples to a pH of <2 at least 24 hours prior to analysis.

CHAIN OF CUSTODY

www.eurofinsus.com/Built



CONTACT INFORMATION

Company:	Karl Environmental	Address:	20 Lauck Rd
Contact:	Angela Meas	Special Instructions:	200.8
Phone:	484-345-9846		

PROJECT INFORMATION

Project ID:	26-0791		
Project Description:	Lead in Water Sampling		
Project Zip Code:	08558	Sampling Date/Time:	08/21/26 7am
PO Number:		Sampled By:	[Signature]

TURN AROUND TIME

Samples for culture testing can not be rushed. Please alert us in advance of weekend analysis needs.	STD - Standard (DEFAULT) ND - Next Business Day* *Must be received by 5pm. Available for Total Coliform, E. coli (P/A)
--	--

Water Testing ANALYSIS

REQUESTED SERVICES (Check boxes below)

Legionella - NO Method	Legionella - COC Method	Legionella - New York ISO Method	Legionella - qPCR	Total Coliform, E. coli (Presence/Absence)	Heterotrophic Plate Count	AMS Waterborne Pathogens Screen *	QuantTray - Pseudomonas aeruginosa	Non-tuberculous Mycobacteria (NTM)	Endotoxin	Lead & Copper	Other (please specify test)
79111106				7911200						X	
79111107				7911201						X	
79111109				7911202						X	
79111109				7911203						X	

Sample ID	Description	Sample Type (Code below)	TAT (Above)	Total Volume/Area (as applicable)	Notes (Time of day, Temp., RH, etc.)
OHE-RM75-RBF	(BF)			150 mL	79111106
OHE-RM75-RBF	(FB)			150 mL	79111107
OHE-RM75-LFB	(FB)			150 mL	79111109
OHE-Blank				150 mL	79111109



004680127

SAMPLE TYPE CODES

P - Potable Water	NP - Non-Potable Water	O - Other
-------------------	------------------------	-----------

RELINQUISHED BY

DATE & TIME

RECEIVED BY

DATE & TIME

* Includes testing for the following: Pseudomonas sp., Acinetobacter sp., Burkholderia sp., Streptococcus sp., Group D Culture with Bile, and Non-Tuberculous Mycobacterium.

By submitting this Chain of Custody, you agree to be bound by the terms and conditions set forth at <https://www.eurofinsus.com/environment-testing/built-environment/resources/sampling-guides-cocs-and-turning>

Copyright © 2024 Eurofins Built Environment Testing