

NOTICE ABOUT YOUR DRINKING WATER

Arsenic Maximum Contaminant Level (MCL) Exceedance

Public Water System Name: **INTER LAKES HIGH SCHOOL** PWS ID: **1525010**

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards.

The Running Annual Average (RAA) calculation represents the average of all sample results collected within a one-year period. Your drinking water RAA calculation is above the enforceable MCL for the following:

Contaminant(s) and MCL	Detected level	Date sampled	Running annual average	Compliance period
Arsenic 0.0050 mg/L	0.012 mg/L	6/16/2026	0.0052 mg/L	Quarter 2 2026

This is not an emergency. If it had been you would have been notified immediately. *Some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.*

What should I do? It is not necessary to use alternate water; however, if you have specific health concerns, please contact your health care professional. General health-related questions may be directed to the EPA Safe Drinking Water Hotline at [1-800-426-4791](tel:1-800-426-4791).

Steps being taken to correct the situation:

Expected Resolution Date: 9/31/2026

Contact Name: Jason Cornelissen Company: Inter-Lakes School District

Address: 1 Laker Ln, Meredith NH Telephone Number: 603-279-5309

Please share this information with all of the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.