J.C. Broderick & Associates, Inc.

Environmental / Construction Consulting & Testing

1775 Expressway Drive North
Hauppauge, NY 11788
631.584.5492
Fax: 631.584.3395
www.jcbroderick.com

August 24, 2026

Mr. Wayne Casey
Miller Place Union Free School District
15 Memorial Drive
Miller Place, New York, 11764

Re: **Lead Testing in School Drinking Water**
Remedial Action Plan
2023 Compliance 10 NYCRR Subpart 67-4

JCB#: **25-62331-1**

Dear Mr. Casey:

J.C. Broderick & Associates, Inc. (JCB) was retained to perform lead testing and analysis of the outlets which service the above referenced school district in accordance with 10 NYCRR Subpart 67-4 (Subpart 67-4).

The outlets servicing each of the school buildings were inventoried and assigned unique identification numbers. The use and location of each outlet was reviewed to determine its applicability for testing under Subpart 67-4.

An initial first-draw sample was collected from each applicable outlet after the minimum 8-hour stagnation period. Samples were logged into a chain of custody document and delivered to an Environmental Laboratory Approval Program (ELAP) accredited laboratory for analysis.

Results from the laboratory analysis were compared with the Action Level as defined by Subpart 67-4 of 5 parts per billion (ppb). Any outlet which exceeded this level requires a remediation action plan be implemented (i.e. removal from service, placarding for non-drinking uses). Outlets which did not exceed the action level do not require further testing or remediation.

Please see the following attachments which detail the sampling and analysis performed and remediation actions taken to date.

Attachment 1: Lead in Water Remediation Plan
Attachment 2: Outlet Inventory and Lead Testing Results
Attachment 3: Laboratory Analytical Reports
Attachment 4: Laboratory Certifications

If you have any questions, or if more information is needed, please contact our office.

Sincerely,



Bryan Ezelius
J C Broderick & Associates, Inc.

Attachment 1:

Lead in Water Remediation Plan



J.C. Broderick & Associates, Inc.
Environmental Consulting & Testing
1775 Expressway Drive North
Hauppauge, New York 11788
631.584.5492 fax 631.584.3395

Lead in Water Remediation Plan

Section 67-4.4 Response of the New York State Department of Health (NYS DOH) Title 10 of the Official Compilation of the Codes, Rules and Regulations of the State of New York requires:

If the lead concentration of water at an outlet exceeds the action level, the school shall:
(a) prohibit use of the outlet until:
(1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
(2) test results indicate that the lead levels are at or below the action level;

As historical sampling results have indicated, the concentrations of lead are more likely attributable to the individual fixtures and/or their immediately adjoining plumbing, and not with the building-wide plumbing. Based upon this information, the following remedial steps are recommended:

Step 1A: Potable Outlets (Outlets intended to be used for drinking/cooking)

Immediately remove the fixture from service. If necessary, provide an adequate supply of potable water for drinking/cooking to this location at no cost to the occupants. If an outlet is seldomly used or is unnecessary, the district may consider permanent removal of the outlet and capping of its supply line.

Step 1B: Non-Potable Outlets (Outlets not intended for drinking/cooking)


See Step 1A OR Placard the outlet for non-drinking use. Signs must be clearly visible and in close proximity to the affected outlet. Example signage is provided at: https://www.health.ny.gov/environmental/water/drinking/lead/docs/donotdrinksigns_lead .pdf.



Do not use for drinking



Hand washing only





Step 2: Service & Repair or Outlet Replacement

The school district's plumber should evaluate the outlet to determine if any components require service or repair. Depending on the extent of service/repair necessary, age of the fixture, and or overall costs, the district may consider replacing the outlet entirely. Any newly installed components shall be certified lead free. (i.e. NSF/ANSI 61, NSF/ANSI-273). If servicing involves installing/replacing a point-of-use filtration system, this filter shall be certified for its lead reduction capability (i.e. NSF/ANSI 53). Follow all manufacturer's instructions for all component installations. OUTLET RESTRICTIONS MUST REMAIN IN PLACE UNTIL SATISFACTORY TEST RESULTS ARE RECEIVED. See Step 3.

Step 3: Retesting & Return to Service

Schedule a retest of the outlet. Outlet restrictions must remain in place until lead testing results at or below the action level are received. Once satisfactory results are received, the outlet may be returned to normal service. Note: It is recommended that "Do Not Drink" signage remain in place for all non-potable and non-applicable outlet types.

Attachment 2:

Outlet Inventory and Lead Testing Results



J.C. Broderick & Associates, Inc.
Environmental Consulting & Testing
1775 Expressway Drive North
Hauppauge, New York 11788
631.584.5492 fax 631.584.3395

Laboratory Lead in Water Results

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 25-62331

Miller Place Union Free School District

Miller Place High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
MILL-0001	**Custodial Office BR**	1058A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0002	**Kitchen Storage**	1057	Water Cooler	Applicable	**10/29/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0003	**Serving Area**	1056I	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
MILL-0004	**Serving Area**	1056I	Coffe Pot	Applicable	**10/29/2025**	**21.0**	1/19/2026	< 1.0	Outlet Remediated and Returned to Service, Continue O&M
MILL-0005	**Kitchen**	1056J	Hand Wash Only	Applicable	**10/29/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0006	**Kitchen**	1056J	Kitchen Faucet (Cold)	Applicable	**10/29/2025**	**1.6**			Result Below Action Level Continue O&M
MILL-0007	**Kitchen**	1056J	Kitchen Non Potable	Applicable	**10/29/2025**	**7.5**	1/19/2026	6.1	Further Investigation Determined Outlet Function as Non-Applicable. Placarded for Non-Drinking Use
MILL-0008	**Kitchen**	1056J	Kitchen Faucet (Cold)	Applicable	**10/29/2025**	**4.6**			Result Below Action Level Continue O&M
MILL-0009	**Kitchen**	1056J	Spray Nozzle	Applicable	**10/29/2025**	**OOS**			Testing Required Before Return to Service
MILL-0010	**Kitchen**	1056J	Kitchen Faucet (Cold)	Applicable	**10/29/2025**	**2.3**			Result Below Action Level Continue O&M
MILL-0011	**Kitchen**	1056J	Ice Machine	Applicable	**11/21/2025**	**< 1.0**			Result Below Action Level Continue O&M
MILL-0012	**Serving Area**	1056	Hand Wash Only	Applicable	**10/29/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0013	**Kitchen Bathroom**	1056A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0014	**Kitchen CC**	1056D	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
MILL-0015	**Cafeteria**	1055	Bottle Fill Station	Applicable	**10/29/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0016	**Cafeteria**	1055	Water Cooler	Applicable	**10/29/2025**	**<1.00 ND**			Result Below Action Level Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Miller Place High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
MILL-0017	**Cafeteria**	1055	Bottle Fill Station	Applicable	**10/29/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0018	**Cafeteria**	1055	Water Cooler	Applicable	**10/29/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0019	**Room 154 (Tech)**	1061	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0020	**Boy's LR**	1068	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0021	**Boy's LR**	1068	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0022	**Boy's LR**	1068	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0023	**Boy's LR**	1068	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0024	**Boy's LR**	1068	Water Fountain-No Chiller	Applicable	**10/29/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0025	**Boy's LR**	1068	Water Fountain-No Chiller	Applicable	**10/29/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0026	**Boy's LR**	1068	Spit Station	Non-Applicable					Placarded for Non-Drinking Use
MILL-0027	**CC in Boy's LR**	1068A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
MILL-0028	**Coach's Office (Boys) BR**	1068B2	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0029	**Coach's Offices (Girls) BR**	1073A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0030	**Girl's LR**	1074	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0031	**Girl's LR**	1074	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0032	**Girl's LR**	1074	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0033	**Girl's LR**	1074	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0034	**Girl's LR**	1074	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0035	**Girl's LR**	1074	Water Fountain-No Chiller	Applicable	**10/29/2025**	**OOS**			Testing Required Before Return to Service
MILL-0036	**Girl's LR**	1074	Water Fountain-No Chiller	Applicable	**10/29/2025**	**1.8**			Result Below Action Level Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Miller Place High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
MILL-0037	**Girl's LR**	1074	Spit Station	Non-Applicable					Placarded for Non-Drinking Use
MILL-0038	**CC in Girl's LR**	1074A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
MILL-0039	**141 Trainer Room**	1072	Water Fountain-No Chiller	Applicable	**10/29/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0040	**141 Trainer Room**	1072	Bottle Fill Station	Applicable	**10/29/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0041	**141 Trainer Room**	1072	Ice Machine	Applicable	**11/21/2025**	**< 1.0**			Result Below Action Level Continue O&M
MILL-0042	**141 Trainer Bathroom**	1072A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0043	**Men's Bathroom**	1067	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0044	**Men's Bathroom**	1067	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0045	**Men's Bathroom**	1067	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0046	**Custodial Closet**	1066	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
MILL-0047	**Women's Bathroom**	1065	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0048	**Women's Bathroom**	1065	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0049	**Women's Bathroom**	1065	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0050	**Outside Auditorium**	1054	Bottle Fill Station	Applicable	**10/29/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0051	**Outside Auditorium**	1054	Water Cooler	Applicable	**10/29/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0052	**Men's Bathroom**	1044	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0053	**Men's Bathroom**	1044	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0054	**Men's Bathroom**	1044	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0055	**Custodial Closet**	1044A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
MILL-0056	**Girl's Bathroom**	1045	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Miller Place High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
MILL-0057	**Girl's Bathroom**	1045	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0058	**Girl's Bathroom**	1045	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0059	**Room 162 (Art)**	1047	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0060	**Room 162 (Art)**	1047	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0061	**Room 162 (Art)**	1047	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0062	**Room 162 (Art)**	1047	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0063	**Room 162 (Art)**	1047	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0064	**Room 162 (Art)**	1047	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0065	**Room 166**	1053	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0066	**Room 166**	1053	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0067	**Room 166**	1053	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0068	**Room 166**	1053	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0069	**Room 166**	1053	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0070	**Room 166**	1053	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0071	**Room 166**	1053	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0072	**Room 166**	1053	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0073	**Room 166**	1053	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0074	**Room 166**	1053	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0075	**Room 166**	1053	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0076	**Room 166**	1053	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Miller Place High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
MILL-0077	**Room 166**	1053	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0078	**Room 166**	1053	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0079	**Room 166**	1053	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0080	**Room 166**	1053	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0081	**Room 166**	1053	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0082	**Room 166**	1053	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0083	**Room 163 (Art)**	1048	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0084	**Room 163 (Art)**	1048	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0085	**Room 162/163 ST**	1047A	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
MILL-0086	**Outside Room 164**	1054	Bottle Fill Station	Applicable	**10/29/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0087	**Outside Room 164**	1054	Water Cooler	Applicable	**10/29/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0088	**Room 166/165 Prep Room**	1052C	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0089	**Room 165**	1052	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0090	**Room 165**	1052	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0091	**Room 165**	1052	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0092	**Room 165**	1052	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0093	**Room 165**	1052	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0094	**Room 165**	1052	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0095	**Room 165**	1052	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0096	**Room 165**	1052	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Miller Place High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
MILL-0097	**Room 165**	1052	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0098	**Room 165**	1052	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0099	**Room 165**	1052	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0100	**Room 165**	1052	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0101	**Room 165**	1052	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0102	**Room 165**	1052	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0103	**Room 165**	1052	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0104	**Room 165**	1052	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0105	**Room 165**	1052	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0106	**Room 165**	1052	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0107	**Room 164B (Athletic OF)**	1049B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0108	**Room 131, Earth Science**	1042	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0109	**Room 131, Earth Science**	1042	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0110	**Room 131, Earth Science**	1042	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0111	**Storage Room/Prop Room**	1042C	Washing Machine	Non-Applicable					Placarded for Non-Drinking Use
MILL-0112	**Storage Room/Prop Room**	1042C	Washing Machine	Non-Applicable					Placarded for Non-Drinking Use
MILL-0113	**Faculty Lounge**	1041	Kitchen Faucet (Cold)	Applicable	**10/29/2025**	**1.4**			Result Below Action Level Continue O&M
MILL-0114	**Faculty Lounge**	1041	Bottled Water Dispenser	Applicable	**10/29/2025**	**OOS**			Testing Required Before Return to Service
MILL-0115	**Faculty Lounge**	1041	Bottled Water Dispenser	Applicable	**10/29/2025**	**OOS**			Testing Required Before Return to Service
MILL-0116	**Faculty Lounge**	1041	Bottle Fill Station	Applicable	**10/29/2025**	**<1.00 ND**			Result Below Action Level Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Miller Place High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
MILL-0117	**Health Office, Nurse's Office**	1039	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0118	**Nurse's Bathroom**	1039B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0119	**Nurse's Bathroom**	1039A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0120	**Main Office Kitchen**	1034	Kitchen Faucet (Cold)	Applicable	**10/29/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0121	**Principal's Bathroom**	1028B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0122	**Fountain by Main Office**	1043	Bottle Fill Station	Applicable	**10/29/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0123	**Fountain by Main Office**	1043	Water Cooler	Applicable	**10/29/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0124	**Guidance Office Kitchen**	1019B	Kitchen Faucet (Cold)	Applicable	**10/29/2025**	**2.3**			Result Below Action Level Continue O&M
MILL-0125	**Main Lobby & Corridors 101-125 - Outside Guidance Office**	1026	Bottle Fill Station	Applicable	**10/29/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0126	**Main Lobby & Corridors 101-125 - Outside Guidance Office**	1026	Water Cooler	Applicable	**10/29/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0127	**Boy's Bathroom**	1081	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0128	**Boy's Bathroom**	1081	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0129	**Boy's Bathroom**	1081	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0130	**Custodial Closet**	1080	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
MILL-0131	**Women's Bathroom**	1079	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0132	**Women's Bathroom**	1079	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0133	**Women's Bathroom**	1079	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0134	**Women's Bathroom**	1079	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0135	**Girl's Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0136	**Girl's Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Miller Place High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
MILL-0137	**Girl's Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0138	**Girl's Bathroom**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0139	**Custodial Closet**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
MILL-0140	**Boy's Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0141	**Boy's Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0142	**Boy's Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0143	**Boy's Bathroom**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0144	**Library Sink**	N/A	Kitchen Faucet (Cold)	Applicable	**10/29/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0145	**Fountain by bathroom**	1026	Bottle Fill Station	Applicable	**10/29/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0146	**Fountain by bathroom**	1026	Water Cooler	Applicable	**10/29/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0147	**Boy's Bathroom**	1023	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0148	**Boy's Bathroom**	1023	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0149	**Boy's Bathroom**	1023	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0150	**Custodial Closet**	1022	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
MILL-0151	**Girl's Bathroom**	1021	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0152	**Girl's Bathroom**	1021	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0153	**Girl's Bathroom**	1021	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0154	**Girl's Bathroom**	1021	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0155	**Men's Bathroom**	1012	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0156	**Men's Bathroom**	1012	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Miller Place High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
MILL-0157	**Women's Bathroom**	1013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0158	**Women's Bathroom**	1013	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0159	**Women's Bathroom**	1013	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0160	**Fountain by Room 115**	1026	Water Cooler	Applicable	**10/29/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0161	**Room 212**	2012	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0162	**Room 212**	2012	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0163	**Room 212**	2012	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0164	**Room 212**	2012	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0165	**Room 212**	2012	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0166	**Room 212**	2012	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0167	**Room 212**	2012	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0168	**Room 212**	2012	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0169	**Room 212**	2012	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0170	**Room 212**	2012	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0171	**Room 212**	2012	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0172	**Room 212**	2012	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0173	**Room 212**	2012	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0174	**Room 212/211 Prep Room**	2011P	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0175	**Room 212/211 Prep Room**	2011P	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0176	**Room 211**	2011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Miller Place High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
MILL-0177	**Room 211**	2011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0178	**Room 211**	2011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0179	**Room 211**	2011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0180	**Room 211**	2011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0181	**Room 211**	2011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0182	**Room 211**	2011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0183	**Room 211**	2011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0184	**Room 211**	2011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0185	**Room 211**	2011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0186	**Room 211**	2011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0187	**Room 211**	2011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0188	**Room 211**	2011	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0189	**Outside Room 211**	2026	Bottle Fill Station	Applicable	**10/29/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0190	**Outside Room 211**	2026	Water Cooler	Applicable	**10/29/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0191	**Room 210**	2010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0192	**Room 210**	2010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0193	**Room 210**	2010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0194	**Room 210**	2010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0195	**Room 210**	2010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0196	**Room 210**	2010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Miller Place High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
MILL-0197	**Room 210**	2010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0198	**Room 210**	2010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0199	**Room 210**	2010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0200	**Room 210**	2010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0201	**Room 210**	2010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0202	**Room 210**	2010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0203	**Room 210**	2010	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0204	**Rooms 210 and 209 Prep.**	2009P	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0205	**Rooms 210 and 209 Prep.**	2009P	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0206	**Room 209**	2009	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0207	**Room 209**	2009	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0208	**Room 209**	2009	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0209	**Room 209**	2009	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0210	**Room 209**	2009	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0211	**Room 209**	2009	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0212	**Room 209**	2009	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0213	**Room 209**	2009	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0214	**Room 208**	2008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0215	**Room 208**	2008	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0216	**Rooms 208/207 Prep**	2007P	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

Miller Place High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
MILL-0217	**Rooms 208/207 Prep**	2007P	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0218	**Room 207**	2007	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0219	**Room 207**	2007	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0220	**Room 207**	2007	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0221	**Girl's Bathroom**	2018	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0222	**Girl's Bathroom**	2018	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0223	**Girl's Bathroom**	2018	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0224	**Girl's Bathroom**	2018	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0225	**Custodial Closet**	2019	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
MILL-0226	**Boy's Bathroom**	2020	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0227	**Boy's Bathroom**	2020	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0228	**Boy's Bathroom**	2020	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0229	**Women's Bathroom**	2021	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0230	**Women's Bathroom**	2021	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0231	**Outside Women's Faculty BR**	2026	Bottle Fill Station	Applicable	**10/29/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0232	**Outside Women's Faculty BR**	2026	Water Cooler	Applicable	**10/29/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0233	**Room 230**	N/A new Const.	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0234	**Room 230**	N/A new Const.	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0235	**Room 230**	N/A new Const.	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0236	**Room 230/232 Prep**	N/A new Const.	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Miller Place High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
MILL-0237	**Room 230/232 Prep**	N/A new Const.	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0238	**Room 232**	N/A new Const.	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0239	**Room 232**	N/A new Const.	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0240	**Room 232**	N/A new Const.	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0241	**Room 232**	N/A new Const.	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0242	**Room 232**	N/A new Const.	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0243	**Room 232**	N/A new Const.	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0244	**Room 232**	N/A new Const.	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0245	**Room 232**	N/A new Const.	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0246	**Room 232**	N/A new Const.	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0247	**Room 232**	N/A new Const.	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0248	**Room 232**	N/A new Const.	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0249	**Room 232**	N/A new Const.	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0250	**Room 232**	N/A new Const.	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0251	**Room 232**	N/A new Const.	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0252	**Room 232**	N/A new Const.	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0253	**Room 232**	N/A new Const.	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0254	**Boy's Bathroom**	N/A new Const.	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0255	**Boy's Bathroom**	N/A new Const.	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0256	**Boy's Bathroom**	N/A new Const.	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use

Miller Place High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
MILL-0257	**Boy's Bathroom**	N/A new Const.	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0258	**Custodial Closet**	N/A new Const.	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
MILL-0259	**Girl's Bathroom**	N/A new Const.	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0260	**Girl's Bathroom**	N/A new Const.	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0261	**Girl's Bathroom**	N/A new Const.	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0262	**Girl's Bathroom**	N/A new Const.	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0263	**Men's Faculty Bathroom**	2022	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0264	**Men's Faculty Bathroom**	2022	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0265	**Outside Room 202**	2026	Bottle Fill Station	Applicable	**10/29/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0266	**Outside Room 202**	2026	Water Cooler	Applicable	**10/29/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0267	**North Courtyard (O/S AHERA 1078A)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0268	**North Courtyard (O/S AHERA 1002)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0269	**East Courtyard (O/S AHERA 1033)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0270	**Exterior (O/S AHERA 1059)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0271	**Exterior (O/S AHERA 1061)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0272	**Exterior (O/S AHERA 1070)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0273	**Exterior (O/S AHERA 1069)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0274	**Exterior (O/S AHERA 1071)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0275	**Exterior (O/S AHERA 1071)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0276	**Exterior (O/S AHERA 1172A)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Miller Place High School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
MILL-0277	**Exterior (O/S AHERA New Const.)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0278	**Exterior (O/S AHERA New Const. Library)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0279	**Exterior (O/S AHERA 1006)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0280	**Exterior (O/S AHERA 1009)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0281	**Exterior (O/S AHERA 1014)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0282	**Exterior (O/S AHERA 1049)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0283	**Exterior (O/S AHERA 1049)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0284	**Exterior (O/S AHERA 1052)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0285	**Exterior (O/S AHERA 1046)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0686	**141 Trainer Room**	1072	Bottle Fill Station	Applicable	**10/29/2025**	**OOS**			Testing Required Before Return to Service
MILL-0687	**Exterior**	N/A	RPZ	Non-Applicable	**10/29/2025**	**17.2**			Further Investigation Determined Outlet Function as Non-Applicable, Placarded for Non-Drinking Use
MILL-0688	**Exterior**	N/A	RPZ	Non-Applicable	**10/29/2025**	**16.8**			Further Investigation Determined Outlet Function as Non-Applicable, Placarded for Non-Drinking Use
MILL-0697	**Faculty Lounge**	1041	Bottle Fill Station	Applicable	**10/29/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0698	**Health Office**	1039	Bottle Fill Station	Applicable	**10/29/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0699	**Guidance Office Lobby**	1019	Bottle Fill Station	Applicable	**10/29/2025**	**<1.00 ND**			Result Below Action Level Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

North Country Road Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
MILL-0286	**Room 3 Bathroom**	1-01A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0287	**Room 3**	1-01	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0288	**Room 3**	1-01	Bottle Fill Station	Applicable	**10/30/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0289	**Room 3**	1-01	Water Fountain-No Chiller	Applicable	**10/30/2025**	**1.1**			Result Below Action Level Continue O&M
MILL-0290	**Faculty Bathroom, Men**	1-04	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0291	**Faculty Bathroom, Men**	1-04	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0292	**Faculty Bathroom, Women**	1-14	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0293	**Faculty Bathroom, Women**	1-14	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0294	**Room 4**	1-17	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0295	**Room 6**	1-18B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0296	**Room 6**	1-18B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0298	**Room 8**	1-25	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0299	**Room 8**	1-25	Water Fountain-No Chiller	Applicable	**10/30/2025**	**OOS**			Testing Required Before Return to Service
MILL-0300	**Room 10**	1-26	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0301	**Room 10**	1-26	Water Fountain-No Chiller	Applicable	**10/30/2025**	**OOS**			Testing Required Before Return to Service
MILL-0302	**Room 12**	1-27	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0303	**Room 12**	1-27	Water Fountain-No Chiller	Applicable	**10/30/2025**	**OOS**			Testing Required Before Return to Service
MILL-0304	**Room 15**	1-28	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0305	**Room 13**	1-29	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0306	**Boy's Bathroom**	1-22	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

North Country Road Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
MILL-0307	**Boy's Bathroom**	1-22	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0308	**Custodial Closet**	1-23	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
MILL-0309	**Girl's Bathroom**	1-24	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0310	**Girl's Bathroom**	1-24	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0311	**Fountain by Cafeteria**	1-60	Bottle Fill Station	Applicable	**10/30/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0312	**Fountain by Cafeteria**	1-60	Water Cooler	RFI					Outlet Replaced by Sticker No. 0865
MILL-0313	**Custodial Office**	1-34B	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
MILL-0314	**Kitchen**	1-35	Hand Wash Only	Applicable	**10/30/2025**	**25.0**	1/19/2026	3.3	Outlet Remediated and Returned to Service, Continue O&M
MILL-0315	**Kitchen**	1-35	Kitchen Faucet (Cold)	Applicable	**10/30/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0316	**Kitchen**	1-35	Kitchen Faucet (Cold)	Applicable	**10/30/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0317	**Kitchen Bathroom**	1-35C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0318	**Room 25**	1-58	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0319	**Room 25**	1-58	Water Fountain-No Chiller	Applicable	**10/30/2025**	**OOS**			Testing Required Before Return to Service
MILL-0320	**Room 22, Art**	1-57	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0321	**Room 22, Art**	1-57	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0322	**Room 22 Bathroom**	1-57B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0323	**Room 20**	1-56	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0324	**Room 23**	1-55	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0325	**Room 23**	1-55	Water Fountain-No Chiller	Applicable	**10/30/2025**	**OOS**			Testing Required Before Return to Service
MILL-0326	**Custodial Closet**	1-52	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

North Country Road Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
MILL-0327	**Room 21**	1-53	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0328	**Room 17**	1-36	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0329	**Room 18**	1-37	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0330	**Room 18**	1-37	Water Fountain-No Chiller	Applicable	**10/30/2025**	**OOS**			Testing Required Before Return to Service
MILL-0331	**Faculty Lounge**	1-38	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0333	**Faculty Lounge**	1-38	Bottle Fill Station	Applicable	**10/30/2025**	**OOS**			Testing Required Before Return to Service
MILL-0334	**Principal of Bathroom**	1-43GI	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0335	**Main of BR**	1-43F	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0336	**Outtside Main Office**	1-45	Water Fountain-No Chiller	Applicable	**10/30/2025**	**OOS**			Testing Required Before Return to Service
MILL-0337	**Nurse**	1-44	Nurse's Office Sink	Applicable	**10/30/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0338	**Nurse Bathroom**	1-44B	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0339	**Room 24**	1-46	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0340	**Room 27**	1-47	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0341	**Room 26**	1-48	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0342	**Room 26**	1-48	Water Fountain-No Chiller	Applicable	**10/30/2025**	**OOS**			Testing Required Before Return to Service
MILL-0343	**Room 29**	1-49	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0344	**Room 28**	1-50	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0345	**Room 31**	1-51	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0346	**Room 31**	1-51	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0347	**Room 31**	1-51	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

North Country Road Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
MILL-0348	**Room 31**	1-51	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0349	**Room 31**	1-51	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0350	**Men's Bathroom**	N/A, New	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0351	**Men's Bathroom**	N/A, New	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0352	**Between Bathrooms**	N/A, New	Bottle Fill Station	Applicable	**10/30/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0353	**Between Bathrooms**	N/A, New	Water Cooler	Applicable	**10/30/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0354	**Women's Bathroom**	N/A, New	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0355	**Women's Bathroom**	N/A, New	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0356	**Library Office**	N/A, New	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
MILL-0357	**Room 34**	N/A, New	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0358	**Room 34**	N/A, New	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0359	**Room 34**	N/A, New	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0360	**Room 34**	N/A, New	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0361	**Rooms 34/36 Prep Room**	N/A, New	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0362	**Room 36**	N/A, New	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0363	**Room 36**	N/A, New	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0364	**Room 36**	N/A, New	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0365	**Room 36**	N/A, New	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0366	**Room 36**	N/A, New	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
MILL-0367	**Room 36**	N/A, New	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

North Country Road Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
MILL-0368	**Room 38**	N/A, New	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0369	**Room 38**	N/A, New	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0370	**Room 38**	N/A, New	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0371	**Room 38**	N/A, New	Spray Nozzle	Non-Applicable					Placarded for Non-Drinking Use
MILL-0372	**Room 38**	N/A, New	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0373	**Room 38 Prep Room**	N/A, New	Science Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0386	**Room 35**	N/A, New	Washing Machine	Non-Applicable					Placarded for Non-Drinking Use
MILL-0387	**Room 35**	N/A, New	Washing Machine	Non-Applicable					Placarded for Non-Drinking Use
MILL-0388	**Girl's Bathroom**	N/A, New	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0389	**Girl's Bathroom**	N/A, New	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0390	**Girl's Bathroom**	N/A, New	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0391	**Girl's Bathroom**	N/A, New	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0392	**Between Girl's BR and CC**	N/A, New	Bottle Fill Station	Applicable	**10/30/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0393	**Between Girl's BR and CC**	N/A, New	Water Cooler	Applicable	**10/30/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0394	**Custodial Closet**	N/A, New	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
MILL-0395	**Boy's Bathroom**	N/A, New	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0396	**Boy's Bathroom**	N/A, New	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0397	**Boy's Bathroom**	N/A, New	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0398	**Boy's Bathroom**	N/A, New	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0399	**Tech Room 37**	N/A, New	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

North Country Road Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
MILL-0400	**Tech Room 39**	N/A, New	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0401	**Band Room 43**	N/A, New	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0402	**Outside Music Suite**	N/A, New	Bottle Fill Station	Applicable	**10/30/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0403	**Outside Music Suite**	N/A, New	Water Cooler	Applicable	**10/30/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0404	**Boy's Locker Room**	N/A, New	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0405	**Boy's Locker Room**	N/A, New	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0406	**Boy's Locker Room Cust. Clos.**	N/A, New	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
MILL-0407	**Girl's Bathroom**	N/A, New	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0408	**Girl's Bathroom**	N/A, New	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0409	**Girl's Bathroom**	N/A, New	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0410	**Courtyard (O/S AHERA 1-50)**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0411	**Exterior**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0412	**Exterior**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0413	**Exterior**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0414	**Exterior**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0415	**Exterior**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0416	**Exterior**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0417	**Exterior**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0418	**Exterior**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0419	**Exterior**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

North Country Road Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
MILL-0420	**Exterior**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0421	**Exterior**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0422	**Exterior**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0423	**Exterior**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0424	**Exterior**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0689	**Exterior**	N/A	RPZ	Non-Applicable					Placarded for Non-Drinking Use
MILL-0690	**Exterior**	N/A	RPZ	Non-Applicable					Placarded for Non-Drinking Use
MILL-0865	**Fountain by Cafeteria**	1-60	Water Cooler	Applicable	**10/30/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0866	**Faculty Lounge**	1-38	Bottled Water Dispenser (Cold)	Applicable	**10/30/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0867	**General Purpose Room**	N/A, New	Classroom Faucet	Applicable	**10/30/2025**	**11.3**	1/19/2026	1.1	Outlet Remediated and Returned to Service, Continue O&M
MILL-0868	**General Purpose Room**	N/A, New	Classroom Faucet	Applicable	**10/30/2025**	**1.9**			Result Below Action Level Continue O&M
MILL-0869	**General Purpose Room**	N/A, New	Classroom Faucet	Applicable	**10/30/2025**	**10.0**	1/19/2026	< 1.0	Outlet Remediated and Returned to Service, Continue O&M
MILL-0870	**General Purpose Room**	N/A, New	Classroom Faucet	Applicable	**10/30/2025**	**8.6**	1/19/2026	1.4	Outlet Remediated and Returned to Service, Continue O&M
MILL-0871	**General Purpose Room**	N/A, New	Classroom Faucet	Applicable	**10/30/2025**	**4.8**			Result Below Action Level Continue O&M
MILL-0872	**General Purpose Room**	N/A, New	Classroom Faucet	Applicable	**10/30/2025**	**10.2**	1/19/2026	1.4	Outlet Remediated and Returned to Service, Continue O&M
MILL-0873	**Room 35**	N/A, New	Home Economics Faucet (Cold)	Applicable	**10/30/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0874	**Room 35**	N/A, New	Home Economics Faucet (Cold)	Applicable	**10/30/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0875	**Room 35**	N/A, New	Home Economics Faucet (Cold)	Applicable	**10/30/2025**	**1.4**			Result Below Action Level Continue O&M
MILL-0876	**Room 35**	N/A, New	Home Economics Faucet (Cold)	Applicable	**10/30/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0877	**Room 35**	N/A, New	Home Economics Faucet (Cold)	Applicable	**10/30/2025**	**1.0**			Result Below Action Level Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

North Country Road Middle School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
MILL-0878	**Room 35**	N/A, New	Home Economics Faucet (Cold)	Applicable	**10/30/2025**	**<1.00 ND**			Result Below Action Level Continue O&M

Andrew Muller Primary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
MILL-0425	**Custodial Office**	1-01	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
MILL-0426	**Custodial Office**	1-01	Bottle Fill Station	Applicable	**10/30/2025**	**OOS**			Testing Required Before Return to Service
MILL-0427	**Kitchen**	1-09	Hand Wash Only	Applicable	**10/31/2025**	**4.6**			Result Below Action Level Continue O&M
MILL-0428	**Kitchen**	1-09	Kitchen Faucet (Cold)	Applicable	**10/31/2025**	**2.7**			Result Below Action Level Continue O&M
MILL-0429	**Kitchen**	1-09	Kitchen Non Potable	Applicable	**10/31/2025**	**5.2**	1/19/2026	6.2	Placarded for Non-Drinking Use Until Remediated
MILL-0430	**Kitchen**	1-09	Spray Nozzle	Applicable	**10/31/2025**	**5.5**	1/19/2026	2.1	Outlet Remediated and Returned to Service, Continue O&M
MILL-0431	**Kitchen**	1-09	Kitchen Faucet (Cold)	Applicable	**10/31/2025**	**1.7**			Result Below Action Level Continue O&M
MILL-0432	**Kitchen**	1-09	Hand Wash Only	Applicable	**10/31/2025**	**3.0**			Result Below Action Level Continue O&M
MILL-0433	**Kitchen Locker Rooms**	1-09A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0434	**Kitchen Locker Rooms**	1-09A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0435	**Student Bathroom 2**	1-03	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0436	**Student Bathroom 1**	1-04	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0437	**Staff Bathroom**	1-05	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0439	**Staff Lounge**	1-07	Kitchen Faucet (Cold)	Applicable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0440	**Staff Lounge**	1-07	Spray Nozzle	Applicable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0441	**Coach's Office**	1-10A	Water Fountain-No Chiller	Applicable	**10/31/2025**	**OOS**			Testing Required Before Return to Service
MILL-0444	**Fount. by Music Room**	1-08	Water Fountain-No Chiller	Applicable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0449	**Stage**	1-11	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0453	**Bathroom**	1-16	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0454	**Women's Bathroom**	1-17	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Andrew Muller Primary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
MILL-0455	**Women's Bathroom**	1-17	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0456	**Custodial Closet**	1-18	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
MILL-0457	**Nurse's Office**	1-62A	Nurse's Office Sink	Applicable	**10/31/2025**	**1.6**			Result Below Action Level Continue O&M
MILL-0458	**Nurse's Bathroom**	1-62C	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0461	**Fountain by library**	1-62	Water Fountain-No Chiller	Applicable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0462	**Library**	1-46	Hand Wash Only	Applicable	**10/31/2025**	**5.2**			Further Investigation Determined Outlet Function as Non-Applicable. Placarded for Non-Drinking Use
MILL-0471	**Custodial Closet**	1-51	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
MILL-0478	**Fountain by Room 15**	1-62	Water Fountain-No Chiller	Applicable	**10/31/2025**	**1.5**			Result Below Action Level Continue O&M
MILL-0491	**Fountain by Room 21**	1-40	Water Fountain-No Chiller	Applicable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0500	**Custodial Closet**	1-30	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
MILL-0501	**Bathroom**	1-29	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0502	**Bathroom**	1-28	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0503	**Fountain by Restrooms**	1-40	Water Fountain-No Chiller	Applicable	**11/5/2025**	**OOS**			Testing Required Before Return to Service
MILL-0516	**Custodial Closet**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
MILL-0517	**Faculty Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0518	**Room 35**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0519	**Room 35**	N/A	Water Fountain-No Chiller	Applicable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0520	**Room 35 Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0521	**Room 38**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0522	**Room 38**	N/A	Water Fountain-No Chiller	Applicable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Andrew Muller Primary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
MILL-0523	**Room 38 Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0524	**Room 36**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0525	**Room 36**	N/A	Water Fountain-No Chiller	Applicable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0526	**Room 36 Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0529	**Room 37 Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0530	**Room 40**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0531	**Room 40**	N/A	Water Fountain-No Chiller	Applicable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0532	**Room 40 Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0533	**Room 39**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0534	**Room 39**	N/A	Water Fountain-No Chiller	Applicable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0535	**Room 39 Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0536	**Principal's Bathrrom**	1-59A2	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0537	**Courtyard**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0538	**Room 35**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0539	**Exterior**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0540	**Exterior**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0541	**Exterior**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0542	**Exterior**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0543	**Exterior**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0544	**Exterior**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Andrew Muller Primary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
MILL-0545	**Exterior**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0546	**Exterior**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0547	**Exterior**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0548	**Exterior**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0691	**Exterior**	N/A	RPZ	Non-Applicable					Placarded for Non-Drinking Use
MILL-0692	**Exterior**	N/A	RPZ	Non-Applicable					Placarded for Non-Drinking Use
MILL-0879	**Staff Lounge**	107	Bottled Water Dispenser (Hot)	Non-Applicable					Placarded for Non-Drinking Use
MILL-0880	**Staff Lounge**	107	Bottled Water Dispenser (Cold)	Applicable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0881	**Staff Lounge**	107	Bottle Fill Station	Applicable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0882	**Room 3**	114	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0883	**Room 3**	114	Water Fountain-No Chiller	Applicable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0884	**Room 4**	115	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0885	**Room 4**	115	Water Fountain-No Chiller	Applicable	**10/31/2025**	**1.3**			Result Below Action Level Continue O&M
MILL-0886	**Room 1**	112	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0887	**Room 1**	112	Water Fountain-No Chiller	Applicable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0888	**Room 2**	113	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0889	**Room 2**	113	Water Fountain-No Chiller	Applicable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0890	**Room 5**	157	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0891	**Room 5**	157	Water Fountain-No Chiller	Applicable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0892	**Room 6**	155	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Andrew Muller Primary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
MILL-0893	**Room 6**	155	Water Fountain-No Chiller	Applicable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0894	**Room 9**	154	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0895	**Room 9**	154	Water Fountain-No Chiller	Applicable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0896	**Room 10**	153	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0897	**Room 10**	153	Water Fountain-No Chiller	Applicable	**10/31/2025**	**1.5**			Result Below Action Level Continue O&M
MILL-0898	**Room 11**	152	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0899	**Room 11**	152	Water Fountain-No Chiller	Applicable	**10/31/2025**	**1.3**			Result Below Action Level Continue O&M
MILL-0900	**Room 12**	150	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0901	**Room 12**	150	Water Fountain-No Chiller	Applicable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0902	**Room 12A**	149	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0903	**Room 12A**	149	Water Fountain-No Chiller	Applicable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0904	**Room 14**	148	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0905	**Room 14**	148	Water Fountain-No Chiller	Applicable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0906	**Room 15**	145	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0907	**Room 15**	145	Water Fountain-No Chiller	Applicable	**10/31/2025**	**1.1**			Result Below Action Level Continue O&M
MILL-0908	**Room 16**	144	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0909	**Room 16**	144	Water Fountain-No Chiller	Applicable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0910	**Room 17**	141	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0911	**Room 17**	141	Water Fountain-No Chiller	Applicable	**10/31/2025**	**2.5**			Result Below Action Level Continue O&M
MILL-0912	**Room 18**	120	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Andrew Muller Primary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
MILL-0913	**Room 18**	120	Water Fountain-No Chiller	Applicable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0914	**Room 19**	121	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0915	**Room 19**	121	Water Fountain-No Chiller	Applicable	**10/31/2025**	**3.1**			Result Below Action Level Continue O&M
MILL-0916	**Room 20**	122	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0917	**Room 20**	122	Water Fountain-No Chiller	Applicable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0918	**Room 21**	123	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0919	**Room 21**	123	Water Fountain-No Chiller	Applicable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0920	**Room 22**	124	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0921	**Room 22**	124	Water Fountain-No Chiller	Applicable	**10/31/2025**	**1.3**			Result Below Action Level Continue O&M
MILL-0922	**Room 23**	126	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0923	**Room 23**	126	Water Fountain-No Chiller	Applicable	**10/31/2025**	**1.9**			Result Below Action Level Continue O&M
MILL-0924	**Room 25**	131	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0925	**Room 25**	131	Water Fountain-No Chiller	Applicable	**10/31/2025**	**1.5**			Result Below Action Level Continue O&M
MILL-0926	**Room 26**	135	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0927	**Room 26**	135	Water Fountain-No Chiller	Applicable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0928	**Room 31**	134	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0929	**Room 31**	134	Water Fountain-No Chiller	Applicable	**10/31/2025**	**1.0**			Result Below Action Level Continue O&M
MILL-0930	**Room 27**	136	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0931	**Room 27**	136	Water Fountain-No Chiller	Applicable	**10/31/2025**	**1.8**			Result Below Action Level Continue O&M
MILL-0932	**Room 30**	137	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Andrew Muller Primary School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
MILL-0933	**Room 30**	137	Water Fountain-No Chiller	Applicable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0934	**Room 28**	138	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0935	**Room 28**	138	Water Fountain-No Chiller	Applicable	**10/31/2025**	**1.2**			Result Below Action Level Continue O&M
MILL-0936	**Room 29**	139	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0937	**Room 29**	139	Water Fountain-No Chiller	Applicable	**10/31/2025**	**1.8**			Result Below Action Level Continue O&M
MILL-0938	**Room 37**	N/A	Water Fountain-No Chiller	Applicable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0945	**Staff Lounge**	107	Bottled Water Dispenser (Cold)	Applicable	**8/14/2026**	**< 1.0 ND**			Result Below Action Level Continue O&M
MILL-0946	**Staff Lounge**	107	Bottled Water Dispenser (Hot)	Applicable	**8/14/2026**	**< 1.0 ND**			Result Below Action Level Continue O&M
MILL-0947	**Corridor o/s Gym (New Construction)**	N/A	Bottle Fill Station	Applicable	**8/14/2026**	**< 1.0 ND**			Result Below Action Level Continue O&M
MILL-0948	**Corridor o/s Gym (New Construction)**	N/A	Water Cooler	Applicable	**8/14/2026**	**< 1.0 ND**			Result Below Action Level Continue O&M
MILL-0949	**Corridor o/s Gym (New Construction)**	N/A	Water Cooler	Applicable	**8/14/2026**	**< 1.0 ND**			Result Below Action Level Continue O&M
MILL-0950	**Corridor o/s Book Room 24 (New Construction)**	N/A	Bottled Water Dispenser (Cold)	Applicable	**8/14/2026**	**< 1.0 ND**			Result Below Action Level Continue O&M
MILL-0951	**Corridor o/s Book Room 24 (New Construction)**	N/A	Bottled Water Dispenser (Hot)	Applicable	**8/14/2026**	**< 1.0 ND**			Result Below Action Level Continue O&M
MILL-0952	**Corridor (New Construction)**	N/A	Bottle Fill Station	Applicable	**8/14/2026**	**< 1.0 ND**			Result Below Action Level Continue O&M
MILL-0953	**Corridor (New Construction)**	N/A	Water Cooler	Applicable	**8/14/2026**	**< 1.0 ND**			Result Below Action Level Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Laddie Decker Sound Beach School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
MILL-0549	**Kitchen**	0-62	Hand Wash Only	Applicable	**10/31/2025**	**11.5**	1/19/2026	< 1.0	Outlet Remediated and Returned to Service, Continue O&M
MILL-0551	**Kitchen**	0-62	Kitchen Faucet (Cold)	Applicable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0552	**Kitchen**	0-62	Kitchen Faucet (Cold)	Applicable	**10/31/2025**	**1.3**			Result Below Action Level Continue O&M
MILL-0553	**Kitchen**	0-62	Kitchen Faucet (Cold)	Applicable	**10/31/2025**	**1.4**			Result Below Action Level Continue O&M
MILL-0554	**Kitchen**	0-62	Hand Wash Only	Applicable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0555	**Kitchen CC Vestibule**	0-62C	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
MILL-0556	**Kitchen BR**	0-62AI	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0557	**Storage**	0-61	Kitchen Faucet (Cold)	Applicable	**10/31/2025**	**14.5**			Further Investigation Determined Outlet Function as Non-Applicable. Placarded for Non-Drinking Use
MILL-0561	**Boiler Room BR**	0-73A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0562	**Boiler Room**	0-73	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0563	**Men's Bathroom**	0-32	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0564	**Women's Bathroom**	0-71	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0565	**Women's Bathroom**	0-71	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0566	**Boy's Bathroom**	0-69	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0567	**Boy's Bathroom**	0-69	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0568	**Basement Corridor o/s Elevator**	074	Bottle Fill Station	Applicable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0570	**Girl's Bathroom**	0-68	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0571	**Girl's Bathroom**	0-68	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0572	**Custodial Closet**	0-67	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
MILL-0573	**Art Room 18**	0-66	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Laddie Decker Sound Beach School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
MILL-0574	**Art Room 18**	0-66	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0575	**Room 102**	1-58	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0576	**Room 101**	1-59	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0577	**Room 103**	1-56	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0578	**Room 104**	1-57	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0579	**Room 105**	1-54	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0580	**Room 106**	1-55	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0581	**Custodial Closet**	1-52	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
MILL-0582	**Room 109**	1-50	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0583	**Room 110**	1-51	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0584	**Room 111**	1-48	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0585	**Room 112**	1-49	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0586	**Room 113**	1-46	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0587	**Room 114**	1-47	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0588	**Room 115**	1-44	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0589	**Room 116**	1-45	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0590	**Room 125**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0591	**Room 125**	N/A	Water Fountain-No Chiller	Applicable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0592	**Room 125 Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0593	**Room 125 Bathroom**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Laddie Decker Sound Beach School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
MILL-0594	**Room 124**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0595	**Room 124**	N/A	Water Fountain-No Chiller	Applicable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0596	**Room 124 Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0597	**Room 124 Bathroom**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0598	**Room 123**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0599	**Room 123**	N/A	Water Fountain-No Chiller	Applicable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0600	**Room 123 Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0601	**Room 123 Bathroom**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0602	**Room 122**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0603	**Room 122**	N/A	Water Fountain-No Chiller	Applicable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0604	**Room 122 Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0605	**Room 122 Bathroom**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0606	**Room 121**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0607	**Room 121**	N/A	Water Fountain-No Chiller	Applicable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0608	**Room 121 Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0609	**Room 121 Bathroom**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0612	**Room 120 Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0613	**Room 120 Bathroom**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0614	**Room 119**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0615	**Room 119**	N/A	Water Fountain-No Chiller	Applicable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M

OOS= Out of Service **RFI = Removed from Inventory**

Laddie Decker Sound Beach School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
MILL-0616	**Room 119 Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0617	**Room 119 Bathroom**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0618	**Room 118**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0619	**Room 118**	N/A	Water Fountain-No Chiller	Applicable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0620	**Room 118 Bathroom**	N/A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0621	**Room 118 Bathroom**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0622	**Custodial Closet**	N/A	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
MILL-0623	**Nurse**	1-41A	Nurse's Office Sink	Applicable	**10/31/2025**	**3.5**			Result Below Action Level Continue O&M
MILL-0624	**Nurse BR**	1-41A2	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0625	**Women's Bathroom**	1-40	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0626	**Women's Bathroom**	1-40	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0627	**Men's Bathroom**	1-39	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0628	**Men's Bathroom**	1-39	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0629	**Library**	1-35	Hand Wash Only	Non-Applicable					Placarded for Non-Drinking Use
MILL-0632	**Room 143**	1-02	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0633	**Room 144**	1-01	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0634	**Custodial Closet**	1-04	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
MILL-0635	**Room 140**	1-05	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0636	**Room 139**	1-06	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0637	**Room 138**	1-07	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Laddie Decker Sound Beach School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
MILL-0638	**Room 137**	1-08	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0639	**Custodial/Electrical**	1-10	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
MILL-0640	**Room 147**	1-11	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0641	**Room 148**	1-12	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0642	**Room 149**	1-13	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0643	**Room 150**	1-14	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0644	**Room 151**	1-16	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0645	**Room 135B Kitchen**	1-30A	Kitchen Faucet (Cold)	Applicable	**10/31/2025**	**2.9**			Result Below Action Level Continue O&M
MILL-0646	**Principal Bathroom**	1-30B1	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0647	**Room 152**	1-17	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0648	**Room 153**	1-19	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0649	**Room 154**	1-18	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0650	**Room 156 Bathroom**	1-22A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0651	**Room 157 Bathroom**	1-23A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0652	**Room 158 Bathroom**	1-24A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0653	**Room 159 Bathroom**	1-25A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0654	**Custodial Closet**	1-26	Slop Sink	Non-Applicable					Placarded for Non-Drinking Use
MILL-0655	**Room 160 Bathroom**	1-28A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0656	**Room 161 Bathroom**	1-27A	Bathroom Faucet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0657	**Exterior o/s AHERA #1-07**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Laddie Decker Sound Beach School

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
MILL-0658	**Exterior o/s AHERA #1-28**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0659	**Exterior o/s AHERA #1-30A**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0660	**Exterior o/s AHERA #1-32**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0661	**Exterior o/s AHERA #1-36**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0662	**Exterior o/s AHERA #1-24**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0663	**Exterior o/s AHERA #1-41**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0664	**Exterior o/s AHERA #1-42**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0665	**Exterior o/s AHERA #1-55**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0666	**Exterior o/s AHERA #1-35**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0693	**Exterior**	N/A	RPZ	Non-Applicable					Placarded for Non-Drinking Use
MILL-0694	**Exterior**	N/A	RPZ	Non-Applicable					Placarded for Non-Drinking Use
MILL-0700	**Cafeteria**	064	Bottle Fill Station	Applicable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0701	**Cafeteria**	064	Water Cooler	Applicable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0702	**Basement Corridor o/s Elevator**	074	Water Cooler	Applicable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0703	**Corridor Between Nurse & Library**	142	Bottle Fill Station	Applicable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0704	**Corridor Between Nurse & Library**	142	Water Cooler	Applicable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0705	**Room 120**	N/A	Water Fountain-No Chiller	Applicable	**10/31/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0706	**Room 120**	N/A	Classroom Faucet	Non-Applicable					Placarded for Non-Drinking Use

Administration Building

Outlet Number	Room Name	Space ID	Outlet Type	Applicable/ Non-Applicable/ RFI	Initial Sample Date	Initial Result (ppb)	Post Remediation Sample Date	Post Remediation Result (ppb)	Remediation Actions/Current Status
MILL-0667	**Exterior**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0668	**Office Kitchen**	N/A	Bottle Fill Station	Applicable	**10/29/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0669	**Office Kitchen**	N/A	Water Cooler	Applicable	**10/29/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0670	**Office Kitchen**	N/A	Water Cooler	Applicable	**10/29/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0671	**Office Kitchen**	N/A	Kitchen Faucet (Cold)	Applicable	**10/29/2025**	**<1.00 ND**			Result Below Action Level Continue O&M
MILL-0672	**Men's Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0673	**Men's Bathroom**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0674	**Women's Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0675	**Women's Bathroom**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0676	**Superintendant's Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0677	**Superintendant's Bathroom**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0678	**Women's Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0679	**Women's Bathroom**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0680	**Men's Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0681	**Men's Bathroom**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0682	**Office Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0683	**Office Bathroom**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use
MILL-0684	**Office Bathroom**	N/A	Tempered Water Outlet	Non-Applicable					Placarded for Non-Drinking Use
MILL-0685	**Office Bathroom**	N/A	Hose Bib	Non-Applicable					Placarded for Non-Drinking Use

OOS= Out of Service **RFI = Removed from Inventory**

Attachment 3:

Laboratory Analytical Reports



J.C. Broderick & Associates, Inc.
Environmental Consulting & Testing
1775 Expressway Drive North
Hauppauge, New York 11788
631.584.5492 fax 631.584.3395

Lead in Water: Chain of Custody for ED57002

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 25-62331

Building: Miller Place High School
MPHS

Client: Miller Place Union Free School District

Courier

Retest/New Install [ ]

Turn Around: ~~Normal~~ [ ] wk **Rush** _____

RECEIVED
NOV 05 '25 PM01:53
ENVIRONMENTAL LABORATORY, INC.
AN ACCREDITED LAB

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
MILL-0002	ST	1057	Kitchen Storage	WC	10/29/2025	6:07:00 AM
MILL-0004	KI	1056I	Serving Area	CP	10/29/2025	5:59:00 AM
MILL-0005	KI	1056J	Kitchen	HW	10/29/2025	6:02:00 AM
MILL-0006	KI	1056J	Kitchen	KC	10/29/2025	5:51:00 AM
MILL-0007	KI	1056J	Kitchen	KC	10/29/2025	5:51:00 AM
MILL-0008	KI	1056J	Kitchen	KC	10/29/2025	5:49:00 AM
MILL-0010	KI	1056J	Kitchen	KC	10/29/2025	5:49:00 AM
MILL-0012	KI	1056	Serving Area	HW	10/29/2025	5:47:00 AM
MILL-0015	CA	1055	Cafeteria	WF	10/29/2025	5:44:00 AM
MILL-0016	CA	1055	Cafeteria	WC	10/29/2025	5:44:00 AM
MILL-0017	CA	1055	Cafeteria	WF	10/29/2025	5:42:00 AM
MILL-0018	CA	1055	Cafeteria	WC	10/29/2025	5:42:00 AM
MILL-0024	LR	1068	Boy's LR	DW	10/29/2025	5:18:00 AM
MILL-0025	LR	1068	Boy's LR	DW	10/29/2025	5:20:00 AM
MILL-0036	LR	1074	Girl's LR	DW	10/29/2025	5:23:00 AM
MILL-0039	OF	1072	141 Trainer Room	DW	10/29/2025	5:27:00 AM
MILL-0040	OF	1072	141 Trainer Room	WF	10/29/2025	5:27:00 AM
MILL-0050	HA	1054	Outside Auditorium	WF	10/29/2025	5:37:00 AM

PB 200.8 Kathleen 11/7/25

PB 200.8 Pbns 11/7/25

Building Address
15 Memorial Drive
Miller Place , NY 11764

Analysis Type: ELAP 200.5

Lab Recieved: 11/5/25 13:53

Signature: [signature] Mary Wagner

Samplers Name: Drake Eggleston

Samplers Signature: [signature]

JCB Project Manager: Bryan Ezelius

Lead in Water: Chain of Custody for ED57002

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 25-62331

Building: Miller Place High School

MPHS

Client: Miller Place Union Free School District

Retest/New Install [ ]

Turn Around: ~~Normal~~ [ ] wk **Rush** _____

RECEIVED
ENVL ANALYTICAL, INC.
Garden Plain, NY
NOV 05 25, PM01:53

Pb 200.8 Billing 11/7/25

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
MILL-0051	HA	1054	Outside Auditorium	WC	10/29/2025	5:37:00 AM
MILL-0086	HA	1054	Outside Room 164	WF	10/29/2025	6:20:00 AM
MILL-0087	HA	1054	Outside Room 164	WC	10/29/2025	6:20:00 AM
MILL-0113	FL	1041	Faculty Lounge	KC	10/29/2025	6:13:00 AM
MILL-0116	FL	1041	Faculty Lounge	WF	10/29/2025	6:14:00 AM
MILL-0120	OF	1034	Main Office Kitchen	KC	10/29/2025	6:29:00 AM
MILL-0122	HA	1043	Fountain by Main Office	WF	10/29/2025	6:27:00 AM
MILL-0123	HA	1043	Fountain by Main Office	WC	10/29/2025	6:27:00 AM
MILL-0124	OF	1019B	Guidance Office Kitchen	KC	10/29/2025	6:34:00 AM
MILL-0125	HA	1026	Main Lobby & Corridors 101-125 - Outside Guidance Office	WF	10/29/2025	6:32:00 AM
MILL-0126	HA	1026	Main Lobby & Corridors 101-125 - Outside Guidance Office	WC	10/29/2025	6:32:00 AM
MILL-0144	LI	N/A	Library Sink	KC	10/29/2025	6:42:00 AM
MILL-0145	HA	1026	Fountain by bathroom	WF	10/29/2025	6:39:00 AM
MILL-0146	HA	1026	Fountain by bathroom	WC	10/29/2025	6:39:00 AM
MILL-0160	HA	1026	Fountain by Room 115	WC	10/29/2025	6:45:00 AM
MILL-0189	HA	2026	Outside Room 211	WF	10/29/2025	6:48:00 AM
MILL-0190	HA	2026	Outside Room 211	WC	10/29/2025	6:48:00 AM
MILL-0231	HA	2026	Outside Women's Faculty BR	WF	10/29/2025	6:53:00 AM

Building Address
15 Memorial Drive
Miller Place , NY 11764

Pb 200.8 Kathleen 11/7/25

Analysis Type: ELAP 200.5

Lab Recieved: 11/5/25 13:53

Signature:

Samplers Name: Drake Eggleston

Samplers Signature:

JCB Project Manager: Bryan Reeves

E257002

Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 25-62331

Building: Miller Place High School

MPHS

Client:
Miller Place Union Free School District

Retest/New Install [ ]

Turn Around: ~~Normal~~ 1 wk **Rush**_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
MILL-0232	HA	2026	Outside Women's Faculty BR	WC	10/29/2025	6:53:00 AM
MILL-0265	HA	2026	Outside Room 202	WF	10/29/2025	6:54:00 AM
MILL-0266	HA	2026	Outside Room 202	WC	10/29/2025	6:54:00 AM
MILL-0687	EX	N/A	Exterior	RPZ	10/29/2025	7:22:00 AM
MILL-0688	EX	N/A	Exterior	RPZ	10/29/2025	7:22:00 AM
MILL-0697	FL	1041	Faculty Lounge	WF	10/29/2025	6:16:00 AM
MILL-0698	NO	1039	Health Office	WF	10/29/2025	6:26:00 AM
MILL-0699	OF	1019	Guidance Office Lobby	WF	10/29/2025	6:38:00 AM

Samples Submitted 44

RECEIVED
ENVIRONMENTAL LAB, INC.
Carle Place, NY
NOV 05 2025 PM01:53

Pb 200.8 Bmy 11/7/25

Pb 200.8
Katherine 11/7/25

Building Address
15 Memorial Drive
Miller Place , NY 11764

Analysis Type: ELAP 200.5

Lab Recieved: 11/5/25 13:53

Signature:

Samplers Name: Drake Eggleston

Samplers Signature:

JCB Project Manager: Bryan Gaeling

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557002

LIMS Reference ID: ED57002

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: Miller Place High School: 15 Memorial Drive, Miller Place, NY 11764: Miller Place Union Free School District: Project# 25-62331

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 11/05/2025 13:53

Reported: 11/25/2025 09:28

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: MILL-0002		**Lims Reference ID:**		**ED57002-01**	**Matrix: Drinking Water**				**Sampled: 10/29/25 06:07:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/07/25 11:16	11/07/25 11:16	BP	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0004		**Lims Reference ID:**		**ED57002-02**	**Matrix: Drinking Water**				**Sampled: 10/29/25 05:59:00**
Metals									
Lead	**21.0**		1	1.0	µg/L	11/08/25 10:50	11/08/25 10:50	JH	EPA 200.8 (Dig)/EPA 200.8
Sample: MILL-0005		**Lims Reference ID:**		**ED57002-03**	**Matrix: Drinking Water**				**Sampled: 10/29/25 06:02:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/07/25 11:20	11/07/25 11:20	BP	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0006		**Lims Reference ID:**		**ED57002-04**	**Matrix: Drinking Water**				**Sampled: 10/29/25 05:51:00**
Metals									
Lead	**1.6**		1	1.0	µg/L	11/07/25 11:21	11/07/25 11:21	BP	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0007		**Lims Reference ID:**		**ED57002-05**	**Matrix: Drinking Water**				**Sampled: 10/29/25 05:51:00**
Metals									
Lead	**7.5**		1	1.0	µg/L	11/07/25 11:23	11/07/25 11:23	BP	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0008		**Lims Reference ID:**		**ED57002-06**	**Matrix: Drinking Water**				**Sampled: 10/29/25 05:49:00**
Metals									
Lead	**4.6**		1	1.0	µg/L	11/07/25 11:24	11/07/25 11:24	BP	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0010		**Lims Reference ID:**		**ED57002-07**	**Matrix: Drinking Water**				**Sampled: 10/29/25 05:49:00**
Metals									
Lead	**2.3**		1	1.0	µg/L	11/07/25 11:25	11/07/25 11:25	BP	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0012		**Lims Reference ID:**		**ED57002-08**	**Matrix: Drinking Water**				**Sampled: 10/29/25 05:47:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/07/25 11:27	11/07/25 11:27	BP	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0015		**Lims Reference ID:**		**ED57002-09**	**Matrix: Drinking Water**				**Sampled: 10/29/25 05:44:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557002
LIMS Reference ID: ED57002
EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: Miller Place High School: 15 Memorial Drive, Miller Place, NY 11764: Miller Place Union Free School District: Project# 25-62331
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 11/05/2025 13:53
Reported: 11/25/2025 09:28

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: MILL-0015 (Continued)		**Lims Reference ID:**		**ED57002-09**	**Matrix: Drinking Water**				**Sampled: 10/29/25 05:44:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	11/07/25 11:28	11/07/25 11:28	BP	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0016		**Lims Reference ID:**		**ED57002-10**	**Matrix: Drinking Water**				**Sampled: 10/29/25 05:44:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/07/25 11:29	11/07/25 11:29	BP	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0017		**Lims Reference ID:**		**ED57002-11**	**Matrix: Drinking Water**				**Sampled: 10/29/25 05:42:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/07/25 15:25	11/07/25 15:25	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0018		**Lims Reference ID:**		**ED57002-12**	**Matrix: Drinking Water**				**Sampled: 10/29/25 05:42:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/07/25 15:29	11/07/25 15:29	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0024		**Lims Reference ID:**		**ED57002-13**	**Matrix: Drinking Water**				**Sampled: 10/29/25 05:18:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/07/25 15:30	11/07/25 15:30	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0025		**Lims Reference ID:**		**ED57002-14**	**Matrix: Drinking Water**				**Sampled: 10/29/25 05:20:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/07/25 15:32	11/07/25 15:32	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0036		**Lims Reference ID:**		**ED57002-15**	**Matrix: Drinking Water**				**Sampled: 10/29/25 05:23:00**
Metals									
Lead	1.8		1	1.0	µg/L	11/20/25 15:59	11/20/25 15:59	BP	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0039		**Lims Reference ID:**		**ED57002-16**	**Matrix: Drinking Water**				**Sampled: 10/29/25 05:27:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/07/25 15:44	11/07/25 15:44	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0040		**Lims Reference ID:**		**ED57002-17**	**Matrix: Drinking Water**				**Sampled: 10/29/25 05:27:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557002
LIMS Reference ID: ED57002
EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: Miller Place High School: 15 Memorial Drive, Miller Place, NY 11764: Miller Place Union Free School District: Project# 25-62331
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 11/05/2025 13:53
Reported: 11/25/2025 09:28

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: MILL-0040 (Continued)		**Lims Reference ID:**		**ED57002-17**	**Matrix: Drinking Water**				**Sampled: 10/29/25 05:27:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	11/07/25 15:45	11/07/25 15:45	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0050		**Lims Reference ID:**		**ED57002-18**	**Matrix: Drinking Water**				**Sampled: 10/29/25 05:37:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/07/25 15:46	11/07/25 15:46	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0051		**Lims Reference ID:**		**ED57002-19**	**Matrix: Drinking Water**				**Sampled: 10/29/25 05:37:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/07/25 15:48	11/07/25 15:48	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0086		**Lims Reference ID:**		**ED57002-20**	**Matrix: Drinking Water**				**Sampled: 10/29/25 06:20:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/07/25 15:49	11/07/25 15:49	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0087		**Lims Reference ID:**		**ED57002-21**	**Matrix: Drinking Water**				**Sampled: 10/29/25 06:20:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/07/25 15:50	11/07/25 15:50	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0113		**Lims Reference ID:**		**ED57002-22**	**Matrix: Drinking Water**				**Sampled: 10/29/25 06:13:00**
Metals									
Lead	1.4		1	1.0	µg/L	11/07/25 15:52	11/07/25 15:52	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0116		**Lims Reference ID:**		**ED57002-23**	**Matrix: Drinking Water**				**Sampled: 10/29/25 06:14:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/07/25 15:56	11/07/25 15:56	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0120		**Lims Reference ID:**		**ED57002-24**	**Matrix: Drinking Water**				**Sampled: 10/29/25 06:29:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/07/25 15:59	11/07/25 15:59	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0122		**Lims Reference ID:**		**ED57002-25**	**Matrix: Drinking Water**				**Sampled: 10/29/25 06:27:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557002
LIMS Reference ID: ED57002
EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: Miller Place High School: 15 Memorial Drive, Miller Place, NY 11764: Miller Place Union Free School District: Project# 25-62331
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 11/05/2025 13:53
Reported: 11/25/2025 09:28

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: MILL-0122 (Continued)		**Lims Reference ID:**		**ED57002-25**	**Matrix: Drinking Water**				**Sampled: 10/29/25 06:27:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	11/07/25 16:01	11/07/25 16:01	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0123		**Lims Reference ID:**		**ED57002-26**	**Matrix: Drinking Water**				**Sampled: 10/29/25 06:27:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/07/25 16:02	11/07/25 16:02	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0124		**Lims Reference ID:**		**ED57002-27**	**Matrix: Drinking Water**				**Sampled: 10/29/25 06:34:00**
Metals									
Lead	2.3		1	1.0	µg/L	11/07/25 16:03	11/07/25 16:03	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0125		**Lims Reference ID:**		**ED57002-28**	**Matrix: Drinking Water**				**Sampled: 10/29/25 06:32:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/07/25 16:05	11/07/25 16:05	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0126		**Lims Reference ID:**		**ED57002-29**	**Matrix: Drinking Water**				**Sampled: 10/29/25 06:32:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/07/25 16:06	11/07/25 16:06	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0144		**Lims Reference ID:**		**ED57002-30**	**Matrix: Drinking Water**				**Sampled: 10/29/25 06:42:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/07/25 14:39	11/07/25 14:39	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0145		**Lims Reference ID:**		**ED57002-31**	**Matrix: Drinking Water**				**Sampled: 10/29/25 06:39:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/07/25 16:07	11/07/25 16:07	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0146		**Lims Reference ID:**		**ED57002-32**	**Matrix: Drinking Water**				**Sampled: 10/29/25 06:39:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/07/25 16:08	11/07/25 16:08	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0160		**Lims Reference ID:**		**ED57002-33**	**Matrix: Drinking Water**				**Sampled: 10/29/25 06:45:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557002
LIMS Reference ID: ED57002
EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: Miller Place High School: 15 Memorial Drive, Miller Place, NY 11764: Miller Place Union Free School District: Project# 25-62331
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 11/05/2025 13:53
Reported: 11/25/2025 09:28

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: MILL-0160 (Continued)		**Lims Reference ID:**		**ED57002-33**	**Matrix: Drinking Water**				**Sampled: 10/29/25 06:45:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	11/07/25 14:40	11/07/25 14:40	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0189		**Lims Reference ID:**		**ED57002-34**	**Matrix: Drinking Water**				**Sampled: 10/29/25 06:48:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/07/25 14:41	11/07/25 14:41	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0190		**Lims Reference ID:**		**ED57002-35**	**Matrix: Drinking Water**				**Sampled: 10/29/25 06:48:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/07/25 14:45	11/07/25 14:45	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0231		**Lims Reference ID:**		**ED57002-36**	**Matrix: Drinking Water**				**Sampled: 10/29/25 06:53:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/07/25 14:49	11/07/25 14:49	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0232		**Lims Reference ID:**		**ED57002-37**	**Matrix: Drinking Water**				**Sampled: 10/29/25 06:53:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/08/25 10:51	11/08/25 10:51	JH	EPA 200.8 (Dig)/EPA 200.8
Sample: MILL-0265		**Lims Reference ID:**		**ED57002-38**	**Matrix: Drinking Water**				**Sampled: 10/29/25 06:54:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/07/25 14:50	11/07/25 14:50	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0266		**Lims Reference ID:**		**ED57002-39**	**Matrix: Drinking Water**				**Sampled: 10/29/25 06:54:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/07/25 14:52	11/07/25 14:52	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0687		**Lims Reference ID:**		**ED57002-40**	**Matrix: Drinking Water**				**Sampled: 10/29/25 07:22:00**
Metals									
Lead	17.2		1	1.0	µg/L	11/07/25 14:53	11/07/25 14:53	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0688		**Lims Reference ID:**		**ED57002-41**	**Matrix: Drinking Water**				**Sampled: 10/29/25 07:22:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557002
LIMS Reference ID: ED57002
EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: Miller Place High School: 15 Memorial Drive, Miller Place, NY 11764: Miller Place Union Free School District: Project# 25-62331
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 11/05/2025 13:53
Reported: 11/25/2025 09:28

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: MILL-0688 (Continued)		**Lims Reference ID:**		**ED57002-41**	**Matrix: Drinking Water**				**Sampled: 10/29/25 07:22:00**
Metals (Continued)									
Lead	**16.8**		1	1.0	µg/L	11/07/25 14:54	11/07/25 14:54	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0697		**Lims Reference ID:**		**ED57002-42**	**Matrix: Drinking Water**				**Sampled: 10/29/25 06:16:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/07/25 14:56	11/07/25 14:56	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0698		**Lims Reference ID:**		**ED57002-43**	**Matrix: Drinking Water**				**Sampled: 10/29/25 06:26:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/07/25 14:57	11/07/25 14:57	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0699		**Lims Reference ID:**		**ED57002-44**	**Matrix: Drinking Water**				**Sampled: 10/29/25 06:38:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/07/25 14:58	11/07/25 14:58	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557002

LIMS Reference ID: ED57002

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name:	Miller Place High School: 15 Memorial Drive, Miller Place, NY 11764: Miller Place Union Free School District: Project# 25-62331
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	11/05/2025 13:53
Reported:	11/25/2025 09:28

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557002

LIMS Reference ID: ED57002

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name:	Miller Place High School: 15 Memorial Drive, Miller Place, NY 11764: Miller Place Union Free School District: Project# 25-62331
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	11/05/2025 13:53
Reported:	11/25/2025 09:28

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EDS7004

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 25-62331

Building: Administration Building

ADMMP

Client: Miller Place Union Free School District

Courier

Retest/New Install [ ]

Turn Around: (Normal) Twk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
MILL-0668	KI/OF	N/A	Office Kitchen	WF	10/29/2025	7:11:00 AM
MILL-0669	KI/OF	N/A	Office Kitchen	WC	10/29/2025	7:11:00 AM
MILL-0670	KI/OF	N/A	Office Kitchen	WC	10/29/2025	7:11:00 AM
MILL-0671	KI/OF	N/A	Office Kitchen	KC	10/29/2025	7:15:00 AM

Samples Submitted 4

Pb 200.8 Billing 11/7/25

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
NOV 05 25, PM01:53

Building Address
North Country Road
Miller Place , NY 11764

Analysis Type: ELAP 200.5

Lab Recieved: 11/5/25 13:53

Signature: Ryan Wagner

Samplers Name: Drake Eggleston

Samplers Signature: Drake Eggleston

JCB Project Manager: Bryan Ezelius

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557004

LIMS Reference ID: ED57004

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: Administration Building: North Country Road, Miller Place, NY 11764: Miller Place Union Free School District: Project# 25-62331

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 11/05/2025 13:53

Reported: 11/25/2025 09:26

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: MILL-0668		**Lims Reference ID:**		**ED57004-01**	**Matrix: Drinking Water**				**Sampled: 11/04/25 07:11:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/07/25 10:29	11/07/25 10:29	BP	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0669		**Lims Reference ID:**		**ED57004-02**	**Matrix: Drinking Water**				**Sampled: 11/04/25 07:11:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/07/25 10:30	11/07/25 10:30	BP	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0670		**Lims Reference ID:**		**ED57004-03**	**Matrix: Drinking Water**				**Sampled: 11/04/25 07:11:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/07/25 10:31	11/07/25 10:31	BP	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0671		**Lims Reference ID:**		**ED57004-04**	**Matrix: Drinking Water**				**Sampled: 11/04/25 07:15:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/07/25 10:33	11/07/25 10:33	BP	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557004

LIMS Reference ID: ED57004

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name:	Administration Building: North Country Road, Miller Place, NY 11764: Miller Place Union Free School District: Project# 25-62331
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	11/05/2025 13:53
Reported:	11/25/2025 09:26

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557004

LIMS Reference ID: ED57004

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: Administration Building: North Country Road, Miller Place, NY 11764: Miller Place Union Free School District: Project# 25-62331

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 11/05/2025 13:53

Reported: 11/25/2025 09:26

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for ED569996

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 25-62331

Building: North Country Road Middle School

NCRMS

Client: Miller Place Union Free School District

Courier

Retest/New Install [ ]

Turn Around: (Normal 1 wk) **Rush** _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
MILL-0288	CR	1-01	Room 3	WF	10/30/2025	5:26:00 AM
MILL-0289	CR	1-01	Room 3	DW	10/30/2025	5:27:00 AM
MILL-0311	HA	1-60	Fountain by Cafeteria	WF	10/30/2025	5:39:00 AM
MILL-0314	KI	1-35	Kitchen	HW	10/30/2025	5:43:00 AM
MILL-0315	KI	1-35	Kitchen	KC	10/30/2025	5:44:00 AM
MILL-0316	KI	1-35	Kitchen	KC	10/30/2025	5:44:00 AM
MILL-0332	FL	1-38	Faculty Lounge	DW	10/30/2025	5:54:00 AM
MILL-0337	NO	1-44	Nurse	NS	10/30/2025	6:02:00 AM
MILL-0352	HA	N/A, New Construction	Between Bathrooms	WF	10/30/2025	6:06:00 AM
MILL-0353	HA	N/A, New Construction	Between Bathrooms	WC	10/30/2025	6:06:00 AM
MILL-0392	HA	N/A, New Construction	Between Girl's BR and CC	WF	10/30/2025	6:27:00 AM
MILL-0393	HA	N/A, New Construction	Between Girl's BR and CC	WC	10/30/2025	6:27:00 AM
MILL-0402	HA	N/A, New Construction	Outside Music Suite	WF	10/30/2025	6:28:00 AM
MILL-0403	HA	N/A, New Construction	Outside Music Suite	WC	10/30/2025	6:28:00 AM
MILL-0865	HA	1-60	Fountain by Cafeteria	WC	10/30/2025	5:39:00 AM
MILL-0866	FL	1-38	Faculty Lounge	BWC	10/30/2025	5:54:00 AM
MILL-0867	HE	N/A, New Construction	Room 33	EC	10/30/2025	6:57:00 AM
MILL-0868	HE	N/A, New Construction	Room 33	EC	10/30/2025	6:57:00 AM

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
NOV 05 25 PM01:49

JB 200.8 Modified 11/20/25

Building Address
191 North Country Road
Miller Place , NY 11764

Analysis Type: ELAP 200.5

Lab Recieved: ASTanley 11/5/25

Signature: 1:49pm

Samplers Name: Matthew Lane

Samplers Signature: Matthew

JCB Project Manager: Bryan Ezelius

Lead in Water: Chain of Custody for ED569996

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 25-62331

Building: North Country Road Middle School

NCRMS

Client: Miller Place Union Free School District

Retest/New Install [ ]

Turn Around: (Normal 1 wk) **Rush**_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
MILL-0869	HE	N/A, New Construction	Room 33	EC	10/30/2025	6:57:00 AM
MILL-0870	HE	N/A, New Construction	Room 33	EC	10/30/2025	6:58:00 AM
MILL-0871	HE	N/A, New Construction	Room 33	EC	10/30/2025	6:58:00 AM
MILL-0872	HE	N/A, New Construction	Room 33	EC	10/30/2025	6:58:00 AM
MILL-0873	HE	N/A, New Construction	Room 35	EC	10/30/2025	7:05:00 AM
MILL-0874	HE	N/A, New Construction	Room 35	EC	10/30/2025	7:05:00 AM
MILL-0875	HE	N/A, New Construction	Room 35	EC	10/30/2025	7:05:00 AM
MILL-0876	HE	N/A, New Construction	Room 35	EC	10/30/2025	7:06:00 AM
MILL-0877	HE	N/A, New Construction	Room 35	EC	10/30/2025	7:06:00 AM
MILL-0878	HE	N/A, New Contruction	Room 35	EC	10/30/2025	7:06:00 AM

Samples Submitted 28

MB Rows 8 thru 11/20/25

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
NOV 05 25, PM01:48

Building Address
191 North Country Road
Miller Place , NY 11764

Analysis Type: ELAP 200.5

Lab Recieved: Astanley 11/5/25

Signature: 1:49pm

Samplers Name: Matthew Lane

Samplers Signature: Matt Lane

JCB Project Manager: Bryan Evelius

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556996

LIMS Reference ID: ED56996

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 25-62331, North Country Road Middle School, NCRMS, Miller Place Union Free School District, 191 North Country Road Miller Place, NY 11764

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 11/05/2025 13:49

Reported: 11/25/2025 09:29

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: MILL-0288		**Lims Reference ID:**		**ED56996-01**	**Matrix: Drinking Water**				**Sampled: 10/30/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/14/25 18:45	11/14/25 18:45	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0289		**Lims Reference ID:**		**ED56996-02**	**Matrix: Drinking Water**				**Sampled: 10/30/25 00:00:00**
Metals									
Lead	**1.1**		1	1.0	µg/L	11/14/25 18:49	11/14/25 18:49	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0311		**Lims Reference ID:**		**ED56996-03**	**Matrix: Drinking Water**				**Sampled: 10/30/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/14/25 18:50	11/14/25 18:50	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0314		**Lims Reference ID:**		**ED56996-04**	**Matrix: Drinking Water**				**Sampled: 10/30/25 00:00:00**
Metals									
Lead	**25.0**		1	1.0	µg/L	11/20/25 13:51	11/20/25 13:51	BP	EPA 200.8 (Dig)/EPA 200.8
Sample: MILL-0315		**Lims Reference ID:**		**ED56996-05**	**Matrix: Drinking Water**				**Sampled: 10/30/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/14/25 18:52	11/14/25 18:52	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0316		**Lims Reference ID:**		**ED56996-06**	**Matrix: Drinking Water**				**Sampled: 10/30/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/14/25 18:56	11/14/25 18:56	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0332		**Lims Reference ID:**		**ED56996-07**	**Matrix: Drinking Water**				**Sampled: 10/30/25 00:00:00**
Metals									
Lead	**9.2**		1	1.0	µg/L	11/14/25 18:57	11/14/25 18:57	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0337		**Lims Reference ID:**		**ED56996-08**	**Matrix: Drinking Water**				**Sampled: 10/30/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/14/25 18:58	11/14/25 18:58	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0352		**Lims Reference ID:**		**ED56996-09**	**Matrix: Drinking Water**				**Sampled: 10/30/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556996
LIMS Reference ID: ED56996
EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 25-62331, North Country Road Middle School, NCRMS, Miller Place Union Free School District, 191 North Country Road Miller Place, NY 11764
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 11/05/2025 13:49
Reported: 11/25/2025 09:29

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: MILL-0352 (Continued)		**Lims Reference ID:**		**ED56996-09**	**Matrix: Drinking Water**				**Sampled: 10/30/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	11/14/25 18:59	11/14/25 18:59	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0353		**Lims Reference ID:**		**ED56996-10**	**Matrix: Drinking Water**				**Sampled: 10/30/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/14/25 19:01	11/14/25 19:01	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0392		**Lims Reference ID:**		**ED56996-11**	**Matrix: Drinking Water**				**Sampled: 10/30/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/14/25 19:02	11/14/25 19:02	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0393		**Lims Reference ID:**		**ED56996-12**	**Matrix: Drinking Water**				**Sampled: 10/30/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/14/25 19:03	11/14/25 19:03	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0402		**Lims Reference ID:**		**ED56996-13**	**Matrix: Drinking Water**				**Sampled: 10/30/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/14/25 19:07	11/14/25 19:07	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0403		**Lims Reference ID:**		**ED56996-14**	**Matrix: Drinking Water**				**Sampled: 10/30/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/14/25 19:11	11/14/25 19:11	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0865		**Lims Reference ID:**		**ED56996-15**	**Matrix: Drinking Water**				**Sampled: 10/30/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/14/25 19:12	11/14/25 19:12	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0866		**Lims Reference ID:**		**ED56996-16**	**Matrix: Drinking Water**				**Sampled: 10/30/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/14/25 19:13	11/14/25 19:13	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0867		**Lims Reference ID:**		**ED56996-17**	**Matrix: Drinking Water**				**Sampled: 10/30/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556996
LIMS Reference ID: ED56996
EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 25-62331, North Country Road Middle School, NCRMS, Miller Place Union Free School District, 191 North Country Road Miller Place, NY 11764
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 11/05/2025 13:49
Reported: 11/25/2025 09:29

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: MILL-0867 (Continued)		**Lims Reference ID:**		**ED56996-17**	**Matrix: Drinking Water**				**Sampled: 10/30/25 00:00:00**
Metals (Continued)									
Lead	11.3		1	1.0	µg/L	11/20/25 13:52	11/20/25 13:52	BP	EPA 200.8 (Dig)/EPA 200.8
Sample: MILL-0868		**Lims Reference ID:**		**ED56996-18**	**Matrix: Drinking Water**				**Sampled: 10/30/25 00:00:00**
Metals									
Lead	1.9		1	1.0	µg/L	11/20/25 13:53	11/20/25 13:53	BP	EPA 200.8 (Dig)/EPA 200.8
Sample: MILL-0869		**Lims Reference ID:**		**ED56996-19**	**Matrix: Drinking Water**				**Sampled: 10/30/25 00:00:00**
Metals									
Lead	10.0		1	1.0	µg/L	11/20/25 13:55	11/20/25 13:55	BP	EPA 200.8 (Dig)/EPA 200.8
Sample: MILL-0870		**Lims Reference ID:**		**ED56996-20**	**Matrix: Drinking Water**				**Sampled: 10/30/25 00:00:00**
Metals									
Lead	8.6		1	1.0	µg/L	11/20/25 13:56	11/20/25 13:56	BP	EPA 200.8 (Dig)/EPA 200.8
Sample: MILL-0871		**Lims Reference ID:**		**ED56996-21**	**Matrix: Drinking Water**				**Sampled: 10/30/25 00:00:00**
Metals									
Lead	4.8		1	1.0	µg/L	11/20/25 13:57	11/20/25 13:57	BP	EPA 200.8 (Dig)/EPA 200.8
Sample: MILL-0872		**Lims Reference ID:**		**ED56996-22**	**Matrix: Drinking Water**				**Sampled: 10/30/25 00:00:00**
Metals									
Lead	10.2		1	1.0	µg/L	11/20/25 13:58	11/20/25 13:58	BP	EPA 200.8 (Dig)/EPA 200.8
Sample: MILL-0873		**Lims Reference ID:**		**ED56996-23**	**Matrix: Drinking Water**				**Sampled: 10/30/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/14/25 19:15	11/14/25 19:15	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0874		**Lims Reference ID:**		**ED56996-24**	**Matrix: Drinking Water**				**Sampled: 10/30/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/14/25 19:16	11/14/25 19:16	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0875		**Lims Reference ID:**		**ED56996-25**	**Matrix: Drinking Water**				**Sampled: 10/30/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556996
LIMS Reference ID: ED56996
EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 25-62331, North Country Road Middle School, NCRMS, Miller Place Union Free School District, 191 North Country Road Miller Place, NY 11764
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 11/05/2025 13:49
Reported: 11/25/2025 09:29

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: MILL-0875 (Continued)		**Lims Reference ID:**		**ED56996-25**	**Matrix: Drinking Water**				**Sampled: 10/30/25 00:00:00**
Metals (Continued)									
Lead	**1.4**		1	1.0	µg/L	11/14/25 19:17	11/14/25 19:17	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0876		**Lims Reference ID:**		**ED56996-26**	**Matrix: Drinking Water**				**Sampled: 10/30/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/14/25 19:19	11/14/25 19:19	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0877		**Lims Reference ID:**		**ED56996-27**	**Matrix: Drinking Water**				**Sampled: 10/30/25 00:00:00**
Metals									
Lead	**1.0**		1	1.0	µg/L	11/20/25 14:05	11/20/25 14:05	BP	EPA 200.8 (Dig)/EPA 200.8
Sample: MILL-0878		**Lims Reference ID:**		**ED56996-28**	**Matrix: Drinking Water**				**Sampled: 10/30/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/14/25 19:20	11/14/25 19:20	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556996
LIMS Reference ID: ED56996
EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 25-62331, North Country Road Middle School, NCRMS, Miller Place Union Free School District, 191 North Country Road Miller Place, NY 11764
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 11/05/2025 13:49
Reported: 11/25/2025 09:29

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062556996

LIMS Reference ID: ED56996

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: 25-62331, North Country Road Middle School, NCRMS, Miller Place Union Free School District, 191 North Country Road Miller Place, NY 11764

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 11/05/2025 13:49

Reported: 11/25/2025 09:29

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for ED57031

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 25-62331

Building: Andrew Muller Primary School

AMPS

Client: Miller Place Union Free School Distri

Courier

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush_____

RECEIVED
ENSL ANALYTICAL, INC.
Carle Place, NY
NOV 06 25 PM01:54

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
MILL-0427	KI	1-09	Kitchen	HW	10/31/2025	6:23:00 AM
MILL-0428	KI	1-09	Kitchen	KC	10/31/2025	6:23:00 AM
MILL-0429	KI	1-09	Kitchen	KC	10/31/2025	6:24:00 AM
MILL-0430	KI	1-09	Kitchen	SN	10/31/2025	6:24:00 AM
MILL-0431	KI	1-09	Kitchen	KC	10/31/2025	6:25:00 AM
MILL-0432	KI	1-09	Kitchen	HW	10/31/2025	6:25:00 AM
MILL-0439	FL	1-07	Staff Lounge	KC	10/31/2025	6:35:00 AM
MILL-0440	FL	1-07	Staff Lounge	SN	10/31/2025	6:35:00 AM
MILL-0444	HA	1-08	Fount. by Music Room	DW	10/31/2025	6:48:00 AM
MILL-0450	SP	1-11	Stage	SN	10/31/2025	7:11:00 AM
MILL-0457	NO	1-62A	Nurse's Office	NS	10/31/2025	6:55:00 AM
MILL-0461	HA	1-62	Fountain by library	DW	10/31/2025	7:30:00 AM
MILL-0462	LI	1-46	Library	KC	10/31/2025	7:32:00 AM
MILL-0478	HA	1-62	Fountain by Room 15	DW	10/31/2025	7:50:00 AM
MILL-0491	HA	1-40	Fountain by Room 21	DW	10/31/2025	8:06:00 AM
MILL-0519	CR	N/A	Room 35	DW	10/31/2025	8:25:00 AM
MILL-0522	CR	N/A	Room 38	DW	10/31/2025	8:26:00 AM
MILL-0525	CR	N/A	Room 36	DW	10/31/2025	8:27:00 AM

Pb 200.8 Modified 11/11/25

Building Address
65 Lower Rocky Point Road
Miller Place , NY 11764

Analysis Type: ELAP 200.5

Lab Recieved: 11/6/25 13:54

Signature: [signature] Ikam Wakshlag

Samplers Name: Matthew Lane

Samplers Signature: [signature]

JCB Project Manager: Bryan Ezelius

Lead in Water: Chain of Custody for ED57031

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 25-62331

Building: Andrew Muller Primary School

AMPS

Client: Miller Place Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush_____

RECEIVED ENSL ANALYTICAL INC. Central Islip, NY NOV 06 25, PM01:54

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
MILL-0531	CR	N/A	Room 40	DW	10/31/2025	8:30:00 AM
MILL-0534	CR	N/A	Room 39	DW	10/31/2025	8:32:00 AM
MILL-0880	FL	107	Staff Lounge	BWC	10/31/2025	6:41:00 AM
MILL-0881	FL	107	Staff Lounge	WF	10/31/2025	6:41:00 AM
MILL-0883	CR	114	Room 3	DW	10/31/2025	7:04:00 AM
MILL-0885	CR	115	Room 4	DW	10/31/2025	7:08:00 AM
MILL-0887	CR	112	Room 1	DW	10/31/2025	7:14:00 AM
MILL-0889	CR	113	Room 2	DW	10/31/2025	7:18:00 AM
MILL-0891	CR	157	Room 5	DW	10/31/2025	7:25:00 AM
MILL-0893	CR	155	Room 6	DW	10/31/2025	7:27:00 AM
MILL-0895	CR	154	Room 9	DW	10/31/2025	7:34:00 AM
MILL-0897	CR	153	Room 10	DW	10/31/2025	7:37:00 AM
MILL-0899	CR	152	Room 11	DW	10/31/2025	7:40:00 AM
MILL-0901	CR	150	Room 12	DW	10/31/2025	7:43:00 AM
MILL-0903	CR	149	Room 12A	DW	10/31/2025	7:45:00 AM
MILL-0905	CR	148	Room 14	DW	10/31/2025	7:48:00 AM
MILL-0907	CR	145	Room 15	DW	10/31/2025	7:52:00 AM
MILL-0909	CR	144	Room 16	DW	10/31/2025	7:57:00 AM

11/6/25 Kathleen

Building Address
65 Lower Rocky Point Road
Miller Place , NY 11764

Analysis Type: ELAP 200.5

Lab Recieved: 11/6/25 13:54

Signature: Mary Wagner

Samplers Name: Matthew Lane

Samplers Signature: Matthew Lane

JCB Project Manager: Bryan Ezelius

Lead in Water: Chain of Custody for ED57031

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 25-62331

Building: Andrew Muller Primary School

AMPS

Client: Miller Place Union Free School District

Retest/New Install | |

Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
MILL-0911	CR	141	Room 17	DW	10/31/2025	8:00:00 AM
MILL-0913	CR	120	Room 18	DW	10/31/2025	8:02:00 AM
MILL-0915	CR	121	Room 19	DW	10/31/2025	8:03:00 AM
MILL-0917	CR	122	Room 20	DW	10/31/2025	8:05:00 AM
MILL-0919	CR	123	Room 21	DW	10/31/2025	8:08:00 AM
MILL-0921	CR	124	Room 22	DW	10/31/2025	8:10:00 AM
MILL-0923	CR	126	Room 23	DW	10/31/2025	8:11:00 AM
MILL-0925	CR	131	Room 25	DW	10/31/2025	8:12:00 AM
MILL-0927	CR	135	Room 26	DW	10/31/2025	8:15:00 AM
MILL-0929	CR	134	Room 31	DW	10/31/2025	8:17:00 AM
MILL-0931	CR	136	Room 27	DW	10/31/2025	8:18:00 AM
MILL-0933	CR	137	Room 30	DW	10/31/2025	8:20:00 AM
MILL-0935	CR	138	Room 28	DW	10/31/2025	8:21:00 AM
MILL-0937	CR	139	Room 29	DW	10/31/2025	8:22:00 AM
MILL-0938	CR	N/A	Room 37	DW	10/31/2025	8:29:00 AM

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
NOV 06 25, PM01:54

Pb Kathodeau 200.0 11/14/25

Building Address
65 Lower Rocky Point Road
Miller Place , NY 11764

Analysis Type: ELAP 200.5

Lab Recieved: 11/6/25 13:54

Signature:

Samplers Name: Matthew Lane

Samplers Signature:

JCB Project Manager: Bryan Ezelius

Lead in Water: Chain of Custody for

ED57031

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 25-62331

Building: Andrew Muller Primary School

AMPS

Client: Miller Place Union Free School District

Retest/New Install [ ]

Turn Around: (Normal 1 wk) **Rush** _____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time

Samples Submitted 51

RECEIVED
ENSL ANALYTICAL, INC.
Carle Place, NY
NOV 06 25, PM01:54

Building Address
65 Lower Rocky Point Road
Miller Place , NY 11764

Analysis Type: ELAP 200.5

Lab Recieved: 11/6/25 13:54

Signature: [signature]

Samplers Name: Matthew Lane

Samplers Signature: [signature]

JCB Project Manager: Bryan Ezelius

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557031

LIMS Reference ID: ED57031

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: Andrew Muller Primary School: 65 Lower Rocky Point Road, Miller Place, NY 11764: Miller Place Union Free School District: Project# 25-62331

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 11/06/2025 13:54

Reported: 11/25/2025 09:24

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: MILL-0427		**Lims Reference ID:**		**ED57031-01**	**Matrix: Drinking Water**				**Sampled: 11/06/25 06:23:00**
Metals									
Lead	**4.6**		1	1.0	µg/L	11/14/25 15:31	11/14/25 15:31	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0428		**Lims Reference ID:**		**ED57031-02**	**Matrix: Drinking Water**				**Sampled: 11/06/25 06:23:00**
Metals									
Lead	**2.7**		1	1.0	µg/L	11/14/25 15:35	11/14/25 15:35	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0429		**Lims Reference ID:**		**ED57031-03**	**Matrix: Drinking Water**				**Sampled: 11/06/25 06:24:00**
Metals									
Lead	**5.2**		1	1.0	µg/L	11/14/25 15:37	11/14/25 15:37	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0430		**Lims Reference ID:**		**ED57031-04**	**Matrix: Drinking Water**				**Sampled: 11/06/25 06:24:00**
Metals									
Lead	**5.5**		1	1.0	µg/L	11/14/25 15:38	11/14/25 15:38	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0431		**Lims Reference ID:**		**ED57031-05**	**Matrix: Drinking Water**				**Sampled: 11/06/25 06:25:00**
Metals									
Lead	**1.7**		1	1.0	µg/L	11/14/25 15:42	11/14/25 15:42	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0432		**Lims Reference ID:**		**ED57031-06**	**Matrix: Drinking Water**				**Sampled: 11/06/25 06:25:00**
Metals									
Lead	**3.0**		1	1.0	µg/L	11/14/25 15:43	11/14/25 15:43	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0439		**Lims Reference ID:**		**ED57031-07**	**Matrix: Drinking Water**				**Sampled: 11/06/25 06:35:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/14/25 15:44	11/14/25 15:44	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0440		**Lims Reference ID:**		**ED57031-08**	**Matrix: Drinking Water**				**Sampled: 11/06/25 06:35:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/14/25 15:46	11/14/25 15:46	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0444		**Lims Reference ID:**		**ED57031-09**	**Matrix: Drinking Water**				**Sampled: 11/06/25 06:48:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557031
LIMS Reference ID: ED57031
EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: Andrew Muller Primary School: 65 Lower Rocky Point Road, Miller Place, NY 11764: Miller Place Union Free School District: Project# 25-62331
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 11/06/2025 13:54
Reported: 11/25/2025 09:24

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: MILL-0444 (Continued)		**Lims Reference ID:**		**ED57031-09**	**Matrix: Drinking Water**				**Sampled: 11/06/25 06:48:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	11/14/25 15:47	11/14/25 15:47	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0450		**Lims Reference ID:**		**ED57031-10**	**Matrix: Drinking Water**				**Sampled: 11/06/25 07:11:00**
Metals									
Lead	15.5		1	1.0	µg/L	11/14/25 15:48	11/14/25 15:48	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0457		**Lims Reference ID:**		**ED57031-11**	**Matrix: Drinking Water**				**Sampled: 11/06/25 06:55:00**
Metals									
Lead	1.6		1	1.0	µg/L	11/14/25 15:49	11/14/25 15:49	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0461		**Lims Reference ID:**		**ED57031-12**	**Matrix: Drinking Water**				**Sampled: 11/06/25 07:30:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/14/25 15:53	11/14/25 15:53	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0462		**Lims Reference ID:**		**ED57031-13**	**Matrix: Drinking Water**				**Sampled: 11/06/25 07:32:00**
Metals									
Lead	5.2		1	1.0	µg/L	11/14/25 15:57	11/14/25 15:57	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0478		**Lims Reference ID:**		**ED57031-14**	**Matrix: Drinking Water**				**Sampled: 11/06/25 07:50:00**
Metals									
Lead	1.5		1	1.0	µg/L	11/14/25 15:58	11/14/25 15:58	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0491		**Lims Reference ID:**		**ED57031-15**	**Matrix: Drinking Water**				**Sampled: 11/06/25 08:06:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/14/25 16:00	11/14/25 16:00	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0519		**Lims Reference ID:**		**ED57031-16**	**Matrix: Drinking Water**				**Sampled: 11/06/25 08:25:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/14/25 16:01	11/14/25 16:01	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0522		**Lims Reference ID:**		**ED57031-17**	**Matrix: Drinking Water**				**Sampled: 11/06/25 08:26:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557031
LIMS Reference ID: ED57031
EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: Andrew Muller Primary School: 65 Lower Rocky Point Road, Miller Place, NY 11764: Miller Place Union Free School District: Project# 25-62331
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 11/06/2025 13:54
Reported: 11/25/2025 09:24

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: MILL-0522 (Continued)		**Lims Reference ID:**		**ED57031-17**	**Matrix: Drinking Water**				**Sampled: 11/06/25 08:26:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	11/14/25 16:02	11/14/25 16:02	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0525		**Lims Reference ID:**		**ED57031-18**	**Matrix: Drinking Water**				**Sampled: 11/06/25 08:27:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/14/25 16:03	11/14/25 16:03	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0531		**Lims Reference ID:**		**ED57031-19**	**Matrix: Drinking Water**				**Sampled: 11/06/25 08:30:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/14/25 16:05	11/14/25 16:05	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0534		**Lims Reference ID:**		**ED57031-20**	**Matrix: Drinking Water**				**Sampled: 11/06/25 08:32:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/14/25 16:06	11/14/25 16:06	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0880		**Lims Reference ID:**		**ED57031-21**	**Matrix: Drinking Water**				**Sampled: 11/06/25 06:41:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/14/25 16:20	11/14/25 16:20	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0881		**Lims Reference ID:**		**ED57031-22**	**Matrix: Drinking Water**				**Sampled: 11/06/25 06:41:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/14/25 16:24	11/14/25 16:24	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0883		**Lims Reference ID:**		**ED57031-23**	**Matrix: Drinking Water**				**Sampled: 11/06/25 07:04:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/14/25 16:25	11/14/25 16:25	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0885		**Lims Reference ID:**		**ED57031-24**	**Matrix: Drinking Water**				**Sampled: 11/06/25 07:08:00**
Metals									
Lead	1.3		1	1.0	µg/L	11/14/25 16:26	11/14/25 16:26	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0887		**Lims Reference ID:**		**ED57031-25**	**Matrix: Drinking Water**				**Sampled: 11/06/25 07:14:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557031
LIMS Reference ID: ED57031
EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: Andrew Muller Primary School: 65 Lower Rocky Point Road, Miller Place, NY 11764: Miller Place Union Free School District: Project# 25-62331
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 11/06/2025 13:54
Reported: 11/25/2025 09:24

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: MILL-0887 (Continued)		**Lims Reference ID:**		**ED57031-25**	**Matrix: Drinking Water**				**Sampled: 11/06/25 07:14:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	11/14/25 16:30	11/14/25 16:30	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0889		**Lims Reference ID:**		**ED57031-26**	**Matrix: Drinking Water**				**Sampled: 11/06/25 07:18:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/14/25 16:32	11/14/25 16:32	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0891		**Lims Reference ID:**		**ED57031-27**	**Matrix: Drinking Water**				**Sampled: 11/06/25 07:25:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/14/25 16:33	11/14/25 16:33	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0893		**Lims Reference ID:**		**ED57031-28**	**Matrix: Drinking Water**				**Sampled: 11/06/25 07:27:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/14/25 16:34	11/14/25 16:34	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0895		**Lims Reference ID:**		**ED57031-29**	**Matrix: Drinking Water**				**Sampled: 11/06/25 07:34:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/14/25 16:35	11/14/25 16:35	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0897		**Lims Reference ID:**		**ED57031-30**	**Matrix: Drinking Water**				**Sampled: 11/06/25 07:37:00**
Metals									
Lead	1.5		1	1.0	µg/L	11/14/25 16:37	11/14/25 16:37	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0899		**Lims Reference ID:**		**ED57031-31**	**Matrix: Drinking Water**				**Sampled: 11/06/25 07:40:00**
Metals									
Lead	1.3		1	1.0	µg/L	11/14/25 16:38	11/14/25 16:38	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0901		**Lims Reference ID:**		**ED57031-32**	**Matrix: Drinking Water**				**Sampled: 11/06/25 07:43:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/14/25 16:42	11/14/25 16:42	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0903		**Lims Reference ID:**		**ED57031-33**	**Matrix: Drinking Water**				**Sampled: 11/06/25 07:45:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557031
LIMS Reference ID: ED57031
EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: Andrew Muller Primary School: 65 Lower Rocky Point Road, Miller Place, NY 11764: Miller Place Union Free School District: Project# 25-62331
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 11/06/2025 13:54
Reported: 11/25/2025 09:24

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: MILL-0903 (Continued)		**Lims Reference ID:**		**ED57031-33**	**Matrix: Drinking Water**				**Sampled: 11/06/25 07:45:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	11/14/25 17:01	11/14/25 17:01	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0905		**Lims Reference ID:**		**ED57031-34**	**Matrix: Drinking Water**				**Sampled: 11/06/25 07:48:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/14/25 17:02	11/14/25 17:02	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0907		**Lims Reference ID:**		**ED57031-35**	**Matrix: Drinking Water**				**Sampled: 11/06/25 07:52:00**
Metals									
Lead	1.1		1	1.0	µg/L	11/14/25 16:48	11/14/25 16:48	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0909		**Lims Reference ID:**		**ED57031-36**	**Matrix: Drinking Water**				**Sampled: 11/06/25 07:57:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/14/25 16:49	11/14/25 16:49	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0911		**Lims Reference ID:**		**ED57031-37**	**Matrix: Drinking Water**				**Sampled: 11/06/25 08:00:00**
Metals									
Lead	2.5		1	1.0	µg/L	11/14/25 16:51	11/14/25 16:51	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0913		**Lims Reference ID:**		**ED57031-38**	**Matrix: Drinking Water**				**Sampled: 11/06/25 08:02:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/14/25 17:08	11/14/25 17:08	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0915		**Lims Reference ID:**		**ED57031-39**	**Matrix: Drinking Water**				**Sampled: 11/06/25 08:03:00**
Metals									
Lead	3.1		1	1.0	µg/L	11/14/25 16:53	11/14/25 16:53	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0917		**Lims Reference ID:**		**ED57031-40**	**Matrix: Drinking Water**				**Sampled: 11/06/25 08:05:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/14/25 17:10	11/14/25 17:10	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0919		**Lims Reference ID:**		**ED57031-41**	**Matrix: Drinking Water**				**Sampled: 11/06/25 08:08:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557031
LIMS Reference ID: ED57031
EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: Andrew Muller Primary School: 65 Lower Rocky Point Road, Miller Place, NY 11764: Miller Place Union Free School District: Project# 25-62331
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 11/06/2025 13:54
Reported: 11/25/2025 09:24

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: MILL-0919 (Continued)		**Lims Reference ID:**		**ED57031-41**	**Matrix: Drinking Water**				**Sampled: 11/06/25 08:08:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	11/14/25 18:13	11/14/25 18:13	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0921		**Lims Reference ID:**		**ED57031-42**	**Matrix: Drinking Water**				**Sampled: 11/06/25 08:10:00**
Metals									
Lead	1.3		1	1.0	µg/L	11/14/25 18:15	11/14/25 18:15	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0923		**Lims Reference ID:**		**ED57031-43**	**Matrix: Drinking Water**				**Sampled: 11/06/25 08:11:00**
Metals									
Lead	1.9		1	1.0	µg/L	11/14/25 18:18	11/14/25 18:18	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0925		**Lims Reference ID:**		**ED57031-44**	**Matrix: Drinking Water**				**Sampled: 11/06/25 08:12:00**
Metals									
Lead	1.5		1	1.0	µg/L	11/14/25 18:22	11/14/25 18:22	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0927		**Lims Reference ID:**		**ED57031-45**	**Matrix: Drinking Water**				**Sampled: 11/06/25 08:15:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/14/25 18:24	11/14/25 18:24	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0929		**Lims Reference ID:**		**ED57031-46**	**Matrix: Drinking Water**				**Sampled: 11/06/25 08:17:00**
Metals									
Lead	1.0		1	1.0	µg/L	11/14/25 18:25	11/14/25 18:25	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0931		**Lims Reference ID:**		**ED57031-47**	**Matrix: Drinking Water**				**Sampled: 11/06/25 08:18:00**
Metals									
Lead	1.8		1	1.0	µg/L	11/14/25 18:26	11/14/25 18:26	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0933		**Lims Reference ID:**		**ED57031-48**	**Matrix: Drinking Water**				**Sampled: 11/06/25 08:20:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/14/25 18:27	11/14/25 18:27	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0935		**Lims Reference ID:**		**ED57031-49**	**Matrix: Drinking Water**				**Sampled: 11/06/25 08:21:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557031
LIMS Reference ID: ED57031
EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: Andrew Muller Primary School: 65 Lower Rocky Point Road, Miller Place, NY 11764: Miller Place Union Free School District: Project# 25-62331
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 11/06/2025 13:54
Reported: 11/25/2025 09:24

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: MILL-0935 (Continued)		**Lims Reference ID:**		**ED57031-49**	**Matrix: Drinking Water**				**Sampled: 11/06/25 08:21:00**
Metals (Continued)									
Lead	**1.2**		1	1.0	µg/L	11/14/25 18:29	11/14/25 18:29	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0937		**Lims Reference ID:**		**ED57031-50**	**Matrix: Drinking Water**				**Sampled: 11/06/25 08:22:00**
Metals									
Lead	**1.8**		1	1.0	µg/L	11/14/25 18:30	11/14/25 18:30	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0938		**Lims Reference ID:**		**ED57031-51**	**Matrix: Drinking Water**				**Sampled: 11/06/25 08:29:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/14/25 18:31	11/14/25 18:31	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557031
LIMS Reference ID: ED57031
EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: Andrew Muller Primary School: 65 Lower Rocky Point Road, Miller Place, NY 11764: Miller Place Union Free School District: Project# 25-62331
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 11/06/2025 13:54
Reported: 11/25/2025 09:24

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557031

LIMS Reference ID: ED57031

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: Andrew Muller Primary School: 65 Lower Rocky Point Road, Miller Place, NY 11764: Miller Place Union Free School District: Project# 25-62331

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 11/06/2025 13:54

Reported: 11/25/2025 09:24

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for

ED57053

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 25-62331

Building: Laddie Decker Sound Beach School

LDSBS

Client: Miller Place Union Free School District

Courier

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush_____

RECEIVED
ENGL ANALYTICAL INC.
Castle Place, NY
NOV 07 25 PM01:30

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
MILL-0549	KI	0-62	Kitchen	HW	10/31/2025	6:35:00 AM
MILL-0551	KI	0-62	Kitchen	KC	10/31/2025	6:28:00 AM
MILL-0552	KI	0-62	Kitchen	KC	10/31/2025	6:30:00 AM
MILL-0553	KI	0-62	Kitchen	KC	10/31/2025	6:32:00 AM
MILL-0554	KI	0-62	Kitchen	HW	10/31/2025	6:32:00 AM
MILL-0557	FL	0-61	Faculty Dining	KC	10/31/2025	6:40:00 AM
MILL-0558	FL	0-61	Faculty Dining	SN	10/31/2025	6:40:00 AM
MILL-0568	HA	074	Basement Corridor o/s Elevator	WF	10/31/2025	6:45:00 AM
MILL-0591	CR	N/A	Room 125	DW	10/31/2025	6:58:00 AM
MILL-0595	CR	N/A	Room 124	DW	10/31/2025	7:02:00 AM
MILL-0599	CR	N/A	Room 123	DW	10/31/2025	7:04:00 AM
MILL-0603	CR	N/A	Room 122	DW	10/31/2025	7:06:00 AM
MILL-0607	CR	N/A	Room 121	DW	10/31/2025	7:07:00 AM
MILL-0615	CR	N/A	Room 119	DW	10/31/2025	7:12:00 AM
MILL-0619	CR	N/A	Room 118	DW	10/31/2025	7:12:00 AM
MILL-0623	NO	1-41A	Nurse	NS	10/31/2025	6:55:00 AM
MILL-0645	KI/OF	1-30A	Room 135B Kitchen	KC	10/31/2025	7:52:00 AM
MILL-0700	CA	064	Cafeteria	WF	10/31/2025	6:42:00 AM

Building Address
197 North Country Road
Miller Place , NY 11764

Analysis Type: ELAP 200.5

Lab Recieved: S. Cherofsky 11/7/25

Signature: S. Cherofsky 1:30pm

Samplers Name: Vinson Zheng

Samplers Signature: Vinson Zheng

JCB Project Manager: Bryan Ezeiza

11/12/25
11/7/25

Lead in Water: Chain of Custody for

ED57053

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 25-62331

Client: Miller Place Union Free School District

Building: Laddie Decker Sound Beach School

LDSBS

Retest/New Install [ ]

Turn Around: ~~Normal~~ 1 wk **Rush**_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
MILL-0701	CA	064	Cafeteria	WC	10/31/2025	6:42:00 AM
MILL-0702	HA	074	Basement Corridor o/s Elevator	WC	10/31/2025	6:46:00 AM
MILL-0703	HA	142	Corridor Between Nurse & Library	WF	10/31/2025	6:51:00 AM
MILL-0704	HA	142	Corridor Between Nurse & Library	WC	10/31/2025	6:51:00 AM
MILL-0705	CR	N/A	Room 120	DW	10/31/2025	7:10:00 AM

Samples Submitted 23

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
NOV 07 25, PM01:30

11/12/25 Emily 8-000 W

Building Address
197 North Country Road
Miller Place , NY 11764

Analysis Type: ELAP 200.5

Lab Recieved: S. Cherofsky 11/7/25

Signature: S. Cherofsky 1:30pm

Samplers Name: Vivian Zheng

Samplers Signature: Vivian Zheng

JCB Project Manager: Bryan Ezelius

11/12/25 8-000 W

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557053
LIMS Reference ID: ED57053
EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: #25-62331, Miller Place Union Free School District; Laddie Decker Sound Beach School, 197 N Country Rd, Miller Place, NY 11764
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 11/07/2025 13:30
Reported: 11/25/2025 09:21

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: MILL-0549		**Lims Reference ID:**		**ED57053-01**	**Matrix: Drinking Water**				**Sampled: 10/31/25 00:00:00**
Metals									
Lead	**11.5**		1	1.0	µg/L	11/12/25 12:39	11/12/25 12:39	BP	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0551		**Lims Reference ID:**		**ED57053-02**	**Matrix: Drinking Water**				**Sampled: 10/31/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/12/25 12:40	11/12/25 12:40	BP	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0552		**Lims Reference ID:**		**ED57053-03**	**Matrix: Drinking Water**				**Sampled: 10/31/25 00:00:00**
Metals									
Lead	**1.3**		1	1.0	µg/L	11/12/25 12:41	11/12/25 12:41	BP	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0553		**Lims Reference ID:**		**ED57053-04**	**Matrix: Drinking Water**				**Sampled: 10/31/25 00:00:00**
Metals									
Lead	**1.4**		1	1.0	µg/L	11/15/25 12:13	11/15/25 12:13	JH	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0554		**Lims Reference ID:**		**ED57053-05**	**Matrix: Drinking Water**				**Sampled: 10/31/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/15/25 12:17	11/15/25 12:17	JH	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0557		**Lims Reference ID:**		**ED57053-06**	**Matrix: Drinking Water**				**Sampled: 10/31/25 00:00:00**
Metals									
Lead	**14.5**		1	1.0	µg/L	11/15/25 12:18	11/15/25 12:18	JH	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0558		**Lims Reference ID:**		**ED57053-07**	**Matrix: Drinking Water**				**Sampled: 10/31/25 00:00:00**
Metals									
Lead	**14.5**		1	1.0	µg/L	11/15/25 12:20	11/15/25 12:20	JH	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0568		**Lims Reference ID:**		**ED57053-08**	**Matrix: Drinking Water**				**Sampled: 10/31/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/15/25 12:21	11/15/25 12:21	JH	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0591		**Lims Reference ID:**		**ED57053-09**	**Matrix: Drinking Water**				**Sampled: 10/31/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557053
LIMS Reference ID: ED57053
EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: #25-62331, Miller Place Union Free School District; Laddie Decker Sound Beach School, 197 N Country Rd, Miller Place, NY 11764
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 11/07/2025 13:30
Reported: 11/25/2025 09:21

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: MILL-0591 (Continued)		**Lims Reference ID:**		**ED57053-09**	**Matrix: Drinking Water**				**Sampled: 10/31/25 00:00:00**
Metals (Continued)									
Lead	< 1.0		1	1.0	µg/L	11/15/25 12:25	11/15/25 12:25	JH	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0595		**Lims Reference ID:**		**ED57053-10**	**Matrix: Drinking Water**				**Sampled: 10/31/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/15/25 12:27	11/15/25 12:27	JH	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0599		**Lims Reference ID:**		**ED57053-11**	**Matrix: Drinking Water**				**Sampled: 10/31/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/15/25 12:28	11/15/25 12:28	JH	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0603		**Lims Reference ID:**		**ED57053-12**	**Matrix: Drinking Water**				**Sampled: 10/31/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/15/25 12:29	11/15/25 12:29	JH	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0607		**Lims Reference ID:**		**ED57053-13**	**Matrix: Drinking Water**				**Sampled: 10/31/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/15/25 12:31	11/15/25 12:31	JH	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0615		**Lims Reference ID:**		**ED57053-14**	**Matrix: Drinking Water**				**Sampled: 10/31/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/15/25 12:32	11/15/25 12:32	JH	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0619		**Lims Reference ID:**		**ED57053-15**	**Matrix: Drinking Water**				**Sampled: 10/31/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/15/25 12:36	11/15/25 12:36	JH	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0623		**Lims Reference ID:**		**ED57053-16**	**Matrix: Drinking Water**				**Sampled: 10/31/25 00:00:00**
Metals									
Lead	3.5		1	1.0	µg/L	11/15/25 12:38	11/15/25 12:38	JH	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0645		**Lims Reference ID:**		**ED57053-17**	**Matrix: Drinking Water**				**Sampled: 10/31/25 00:00:00**
Metals									

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557053
LIMS Reference ID: ED57053
EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: #25-62331, Miller Place Union Free School District; Laddie Decker Sound Beach School, 197 N Country Rd, Miller Place, NY 11764
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 11/07/2025 13:30
Reported: 11/25/2025 09:21

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: MILL-0645 (Continued)		**Lims Reference ID:**		**ED57053-17**	**Matrix: Drinking Water**				**Sampled: 10/31/25 00:00:00**
Metals (Continued)									
Lead	2.9		1	1.0	µg/L	11/15/25 12:42	11/15/25 12:42	JH	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0700		**Lims Reference ID:**		**ED57053-18**	**Matrix: Drinking Water**				**Sampled: 10/31/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/15/25 12:43	11/15/25 12:43	JH	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0701		**Lims Reference ID:**		**ED57053-19**	**Matrix: Drinking Water**				**Sampled: 10/31/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/15/25 12:45	11/15/25 12:45	JH	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0702		**Lims Reference ID:**		**ED57053-20**	**Matrix: Drinking Water**				**Sampled: 10/31/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/15/25 12:46	11/15/25 12:46	JH	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0703		**Lims Reference ID:**		**ED57053-21**	**Matrix: Drinking Water**				**Sampled: 10/31/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/15/25 12:48	11/15/25 12:48	JH	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0704		**Lims Reference ID:**		**ED57053-22**	**Matrix: Drinking Water**				**Sampled: 10/31/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/15/25 12:49	11/15/25 12:49	JH	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0705		**Lims Reference ID:**		**ED57053-23**	**Matrix: Drinking Water**				**Sampled: 10/31/25 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	11/15/25 12:50	11/15/25 12:50	JH	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557053
LIMS Reference ID: ED57053
EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: #25-62331, Miller Place Union Free School District; Laddie Decker Sound Beach School, 197 N Country Rd, Miller Place, NY 11764
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 11/07/2025 13:30
Reported: 11/25/2025 09:21

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557053
LIMS Reference ID: ED57053
EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: #25-62331, Miller Place Union Free School District; Laddie Decker Sound Beach School, 197 N Country Rd, Miller Place, NY 11764
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 11/07/2025 13:30
Reported: 11/25/2025 09:21

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

ED57350

Lead in Water: Chain of Custody for

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 25-62331

Building: Miller Place High School

MPHS

Client: Miller Place Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
MILL-0011	KI	1056J	Kitchen	IM	11/21/25	16:45
MILL-0041	OF	1072	141 Trainer Room	IM	11/21/25	16:50

Samples Submitted 2

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
NOV 24 25, PM01:23

Pb 200.8
Validate
11/24/25

Walk In

Building Address
15 Memorial Drive
Miller Place , NY 11764

Analysis Type: ELAP 200.5

Lab Recieved: _____

Signature: _____

Samplers Name: Jared Bonfare

Samplers Signature: _____

JCB Project Manager: Bryan Eveleth

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557350

LIMS Reference ID: ED57350

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: JCB#: 25-62331, Miller Place High School, Miller Place Union Free School District, 15 Memorial Drive, Miller Place, NY 11764

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 11/24/2025 13:23

Reported: 11/25/2025 12:06

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: MILL-0011		**Lims Reference ID:**		**ED57350-01**	**Matrix: Drinking Water**				**Sampled: 11/21/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/24/25 17:55	11/24/25 17:55	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0041		**Lims Reference ID:**		**ED57350-02**	**Matrix: Drinking Water**				**Sampled: 11/21/25 00:00:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	11/24/25 17:56	11/24/25 17:56	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557350

LIMS Reference ID: ED57350

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: JCB#: 25-62331, Miller Place High School, Miller Place Union Free School District, 15 Memorial Drive, Miller Place, NY 11764

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 11/24/2025 13:23

Reported: 11/25/2025 12:06

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062557350

LIMS Reference ID: ED57350

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name:	JCB#: 25-62331, Miller Place High School, Miller Place Union Free School District, 15 Memorial Drive, Miller Place, NY 11764
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	11/24/2025 13:23
Reported:	11/25/2025 12:06

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for

EE50329

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 25-62331

Building: Laddie Decker Sound Beach School

LDSBS

Client: Miller Place Union Free School District

Retest/New Install [ ]

Turn Around: Normal 1 wk **Rush**_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
MILL-0549	KI	0-62	Kitchen	HW	1/19/2026	11:03:00 AM

Samples Submitted 1

Pb 200.8
Kathleen
1/21/26

Walk In

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JAN 20 26, PM07:50

Building Address
197 North Country Road
Miller Place , NY 11764

Analysis Type: ELAP 200.5

Lab Recieved: Sign Cell 01/20/26

Signature: 7:50 pm

Samplers Name: Matthew Lane

Samplers Signature:

JCB Project Manager: Bryan Ezelius

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650329

LIMS Reference ID: EE50329

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: Laddie Decker Sound Beach School, 197 North Country Road Miller Place NY 11764, JCB#:25-62331, Miller Place Union Free School District
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 01/20/2026 19:50
Reported: 01/22/2026 09:12

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: MILL-0549			**Lims Reference ID:**	**EE50329-01**	**Matrix: Drinking Water**			**Sampled:**	**01/19/26 11:03:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	01/21/26 17:19	01/21/26 17:19	KT1	EPA 200.8 (Dig)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650329
LIMS Reference ID: EE50329
EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name:	Laddie Decker Sound Beach School, 197 North Country Road Miller Place NY 11764, JCB#:25-62331, Miller Place Union Free School District
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	01/20/2026 19:50
Reported:	01/22/2026 09:12

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650329
LIMS Reference ID: EE50329
EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name:	Laddie Decker Sound Beach School, 197 North Country Road Miller Place NY 11764, JCB#:25-62331, Miller Place Union Free School District
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	01/20/2026 19:50
Reported:	01/22/2026 09:12

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EES0330

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 25-62331

Building: North Country Road Middle School

NCRMS

Client: Miller Place Union Free School District

Retest/New Install [ ]

Turn Around: (Normal 1 wk) Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
MILL-0314	KI	1-35	Kitchen	HW	1/19/2026	10:43:00 AM
MILL-0867	HE	N/A, New Construction	General Purpose Room	CF	1/19/2026	10:52:00 AM
MILL-0869	HE	N/A, New Construction	General Purpose Room	CF	1/19/2026	10:50:00 AM
MILL-0870	HE	N/A, New Construction	General Purpose Room	CF	1/19/2026	10:49:00 AM
MILL-0872	HE	N/A, New Construction	General Purpose Room	CF	1/19/2026	10:47:00 AM

Samples Submitted 5

Walk In

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JAN 20 26, PM07:50

Pb 200.8
Kathleen
1/22/26

Building Address
191 North Country Road
Miller Place , NY 11764

Analysis Type: ELAP 200.5

Lab Recieved: San Cell 01/20/26

Signature: MM Cell 7:50PM

Samplers Name: matthew Lane

Samplers Signature:

JCB Project Manager: Bryan Ezell

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650330
LIMS Reference ID: EE50330
EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: North Country Road Middle School, 191 North Country Road MIller Place NY 11764, Miller Place Union Free School District, JCB#:25-62331
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 01/20/2026 19:50
Reported: 01/23/2026 09:19

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: MILL-0314			**Lims Reference ID:**	**EE50330-01**	**Matrix: Drinking Water**				**Sampled: 01/19/26 10:43:00**
Metals									
Lead	**3.3**		1	1.0	µg/L	01/22/26 19:40	01/22/26 19:40	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0867			**Lims Reference ID:**	**EE50330-02**	**Matrix: Drinking Water**				**Sampled: 01/19/26 10:43:00**
Metals									
Lead	**1.1**		1	1.0	µg/L	01/22/26 19:44	01/22/26 19:44	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0869			**Lims Reference ID:**	**EE50330-03**	**Matrix: Drinking Water**				**Sampled: 01/19/26 10:43:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	01/21/26 17:21	01/21/26 17:21	KT1	EPA 200.8 (Dig)/EPA 200.8
Sample: MILL-0870			**Lims Reference ID:**	**EE50330-04**	**Matrix: Drinking Water**				**Sampled: 01/19/26 10:43:00**
Metals									
Lead	**1.4**		1	1.0	µg/L	01/22/26 19:45	01/22/26 19:45	KT1	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0872			**Lims Reference ID:**	**EE50330-05**	**Matrix: Drinking Water**				**Sampled: 01/19/26 10:43:00**
Metals									
Lead	**1.4**		1	1.0	µg/L	01/22/26 19:49	01/22/26 19:49	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650330
LIMS Reference ID: EE50330
EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name:	North Country Road Middle School, 191 North Country Road MIller Place NY 11764, Miller Place Union Free School District, JCB#:25-62331
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	01/20/2026 19:50
Reported:	01/23/2026 09:19

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650330
LIMS Reference ID: EE50330
EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: North Country Road Middle School, 191 North Country Road MIller Place NY 11764, Miller Place Union Free School District, JCB#:25-62331
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 01/20/2026 19:50
Reported: 01/23/2026 09:19

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EE50331

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 25-62331

Building: Andrew Muller Primary School

AMPS

Client: Miller Place Union Free School District

Retest/New Install | |

Turn Around: (Normal 1 wk) Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
MILL-0429	KI	1-09	Kitchen	KN	1/19/2026	11:12:00 AM
MILL-0430	KI	1-09	Kitchen	SN	1/19/2026	11:12:00 AM

Samples Submitted 2

Walk In

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JAN 20 26, PM07:49

Pb 200.8
Kathleen
1/22/26

Building Address
65 Lower Rocky Point Road
Miller Place , NY 11764

Analysis Type: ELAP 200.5

Lab Recieved: Sean Cahill 01/20/26

Signature: 7:49pm

Samplers Name: Matthew Lane

Samplers Signature:

JCB Project Manager: Bryan Ezelius

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650331
LIMS Reference ID: EE50331
EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: Andrew Muller Primary School, 65 Lower Rocky Point Road Miller Placef NY 11764,Miller Place Union Free School District, JCB#:25-62331
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 01/20/2026 19:49
Reported: 01/23/2026 09:21

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: MILL-0429			**Lims Reference ID:**		**EE50331-01**	**Matrix: Drinking Water**			**Sampled: 01/19/26 11:12:00**
Metals									
Lead	**5.2**		1	1.0	µg/L	01/21/26 17:22	01/21/26 17:22	KT1	EPA 200.8 (Dig)/EPA 200.8
Sample: MILL-0430			**Lims Reference ID:**		**EE50331-02**	**Matrix: Drinking Water**			**Sampled: 01/19/26 11:12:00**
Metals									
Lead	**2.1**		1	1.0	µg/L	01/22/26 19:51	01/22/26 19:51	KT1	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650331

LIMS Reference ID: EE50331

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: Andrew Muller Primary School, 65 Lower Rocky Point Road Miller Placef NY 11764,Miller Place Union Free School District, JCB#:25-62331

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 01/20/2026 19:49

Reported: 01/23/2026 09:21

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650331
LIMS Reference ID: EE50331
EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: Andrew Muller Primary School, 65 Lower Rocky Point Road Miller Placef NY 11764,Miller Place Union Free School District, JCB#:25-62331
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 01/20/2026 19:49
Reported: 01/23/2026 09:21

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for EES0332

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 25-62331

Building: Miller Place High School

MPHS

Client: Miller Place Union Free School District

Retest/New Install [ ]

Turn Around: (Normal 1 wk) Rush_____

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
MILL-0004	KI	1056I	Serving Area	CP	1/19/2026	10:27:00 AM
MILL-0007	KI	1056J	Kitchen	KN	1/19/2026	10:21:00 AM

Samples Submitted 2

Walk In

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
JAN 20 26, PM07:49

PB 2008
Katherine
1/21/26

Building Address
15 Memorial Drive
Miller Place , NY 11764

Analysis Type: ELAP 200.5

Lab Recieved: Sean Cahill 01/20/26

Signature:

Samplers Name: Matthew Lane

Samplers Signature:

JCB Project Manager: Bryan Ezelius

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650332

LIMS Reference ID: EE50332

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: Miller Place High School, 15 Memorical Drive Miller Place NY 11764, Miller Place Union Free School District, JCB#:25-62331

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 01/20/2026 19:49

Reported: 01/22/2026 09:14

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: MILL-0004			**Lims Reference ID:**		**EE50332-01**	**Matrix: Drinking Water**			**Sampled: 01/19/26 10:27:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	01/21/26 17:23	01/21/26 17:23	KT1	EPA 200.8 (Dig)/EPA 200.8
Sample: MILL-0007			**Lims Reference ID:**		**EE50332-02**	**Matrix: Drinking Water**			**Sampled: 01/19/26 10:21:00**
Metals									
Lead	**6.1**		1	1.0	µg/L	01/21/26 17:24	01/21/26 17:24	KT1	EPA 200.8 (Dig)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650332
LIMS Reference ID: EE50332
EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: Miller Place High School, 15 Memorical Drive Miller Place NY 11764, Miller Place Union Free School District, JCB#:25-62331
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 01/20/2026 19:49
Reported: 01/22/2026 09:14

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2026
06-NYSDOH	New York State Department of Health	11469	04/01/2026
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2026
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	08/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062650332
LIMS Reference ID: EE50332
EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: Miller Place High School, 15 Memorical Drive Miller Place NY 11764, Miller Place Union Free School District, JCB#:25-62331
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 01/20/2026 19:49
Reported: 01/22/2026 09:14

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead in Water: Chain of Custody for

EE54033

J. C. BRODERICK AND ASSOCIATES, INC.
1775 Expressway North Hauppauge, NY 11788
TEL: (631) 584-5492 FAX: (631) 584-3395

JCB #: 26-65095

Building: Andrew Muller Primary School

AMPS

Client: Miller Place Union Free School District

Retest/New Install ID:

Turn Around: Normal 1 wk Rush

Sample ID	Functional Space Type	AHERA ID	Common Room Name	Outlet Type	Sample Date	Sample Time
MILL-0945	FL	107	Staff Lounge	BWC	8/14/2026	6:30:00 AM
MILL-0946	FL	107	Staff Lounge	BWH	8/14/2026	6:31:00 AM
MILL-0947	HA	N/A	Corridor o/s Gym (New Construction)	WF	8/14/2026	6:35:00 AM
MILL-0948	HA	N/A	Corridor o/s Gym (New Construction)	WC	8/14/2026	6:35:00 AM
MILL-0949	HA	N/A	Corridor o/s Gym (New Construction)	WC	8/14/2026	6:36:00 AM
MILL-0950	HA	N/A	Corridor o/s Book Room 24 (New Construction)	BWC	8/14/2026	7:47:00 AM
MILL-0951	HA	N/A	Corridor o/s Book Room 24 (New Construction)	BWH	8/14/2026	7:47:00 AM
MILL-0952	HA	N/A	Corridor (New Construction)	WF	8/14/2026	7:49:00 AM
MILL-0953	HA	N/A	Corridor (New Construction)	WC	8/14/2026	7:49:00 AM

Samples Submitted 9

Courier

RECEIVED
EMSL ANALYTICAL, INC.
Carle Place, NY
AUG 14 26, PM 01:06

200.8 8/13/26

Building Address
65 Lower Rocky Point Road
Miller Place , NY 11764

Analysis Type: ELAP 200.5

Lab Recieved: 8/14/26 13:06

Signature:

Samplers Name: Jarett Bonifacio

Samplers Signature:

JCB Project Manager: Bryan Ezel

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062654033

LIMS Reference ID: EE54033

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: Andrew Muller Primary School: 65 Lower Rocky Point Road, Miller Place, NY 11764: Miller Place Union Free School District: Project# 26-65095

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 08/14/2026 13:06

Reported: 08/17/2026 14:49

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: MILL-0945		**Lims Reference ID:**		**EE54033-01**	**Matrix: Drinking Water**				**Sampled: 08/13/26 06:30:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	08/15/26 21:24	08/15/26 21:24	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0946		**Lims Reference ID:**		**EE54033-02**	**Matrix: Drinking Water**				**Sampled: 08/13/26 06:31:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	08/15/26 21:26	08/15/26 21:26	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0947		**Lims Reference ID:**		**EE54033-03**	**Matrix: Drinking Water**				**Sampled: 08/13/26 06:35:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	08/15/26 21:30	08/15/26 21:30	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0948		**Lims Reference ID:**		**EE54033-04**	**Matrix: Drinking Water**				**Sampled: 08/13/26 06:35:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	08/15/26 21:32	08/15/26 21:32	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0949		**Lims Reference ID:**		**EE54033-05**	**Matrix: Drinking Water**				**Sampled: 08/13/26 06:36:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	08/15/26 21:33	08/15/26 21:33	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0950		**Lims Reference ID:**		**EE54033-06**	**Matrix: Drinking Water**				**Sampled: 08/13/26 07:47:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	08/15/26 21:35	08/15/26 21:35	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0951		**Lims Reference ID:**		**EE54033-07**	**Matrix: Drinking Water**				**Sampled: 08/13/26 07:47:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	08/15/26 21:36	08/15/26 21:36	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0952		**Lims Reference ID:**		**EE54033-08**	**Matrix: Drinking Water**				**Sampled: 08/13/26 00:00:00**
Metals									
Lead	< 1.0		1	1.0	µg/L	08/15/26 21:38	08/15/26 21:38	DAZ	EPA 200.8 (DA)/EPA 200.8
Sample: MILL-0953		**Lims Reference ID:**		**EE54033-09**	**Matrix: Drinking Water**				**Sampled: 08/13/26 07:49:00**

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062654033
LIMS Reference ID: EE54033
EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: Andrew Muller Primary School: 65 Lower Rocky Point Road, Miller Place, NY 11764: Miller Place Union Free School District: Project# 26-65095
Project ID: _06 - Carle Place Lead Analyses
Customer PO:
Sales Rep: Jeromy Bish
Received: 08/14/2026 13:06
Reported: 08/17/2026 14:49

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: MILL-0953 (Continued)			**Lims Reference ID:**	**EE54033-09**	**Matrix: Drinking Water**			**Sampled:**	**08/13/26 07:49:00**
Metals									
Lead	**< 1.0**		1	1.0	µg/L	08/15/26 21:42	08/15/26 21:42	DAZ	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062654033

LIMS Reference ID: EE54033

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name: Andrew Muller Primary School: 65 Lower Rocky Point Road, Miller Place, NY 11764: Miller Place Union Free School District: Project# 26-65095

Project ID: _06 - Carle Place Lead Analyses

Customer PO:

Sales Rep: Jeromy Bish

Received: 08/14/2026 13:06

Reported: 08/17/2026 14:49

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	06-NYSELAP

List of Certifications

Code	Description	Number	Expires
06-NYSELAP	NY NYS ELAP	11469	04/01/2027
06-NYSDOH	New York State Department of Health	11469	04/01/2027
06-CTDPH	Connecticut Department of Public Health	PH-0249	03/31/2027
06-California ELAP	California Water Boards	2339	04/01/2027
06-AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC) - ELLAP	102344	10/01/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

528 Mineola Avenue, Carle Place, NY, 11514
Telephone: 516.997.7251 Fax:856-786-5974
EMSL-CP-06

EMSL Order ID: 062654033

LIMS Reference ID: EE54033

EMSL Customer ID: JCBR50

Attention: Bryan Ezelius
J.C. Broderick & Associates [JCBR50]
1775 Expressway Drive North, Suite 1
Hauppauge, NY 11788
(631) 584-5492
bezelius@jcbroderick.com

Project Name:	Andrew Muller Primary School: 65 Lower Rocky Point Road, Miller Place, NY 11764: Miller Place Union Free School District: Project# 26-65095
Project ID:	_06 - Carle Place Lead Analyses
Customer PO:	
Sales Rep:	Jeromy Bish
Received:	08/14/2026 13:06
Reported:	08/17/2026 14:49

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

James Han Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Attachment 4:

Laboratory Certifications



J.C. Broderick & Associates, Inc.
Environmental Consulting & Testing
1775 Expressway Drive North
Hauppauge, New York 11788
631.584.5492 fax 631.584.3395

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER

Expires 12:01 AM April 01, 2027
Issued April 01, 2026

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MR. DANIEL CLARKE
EMSL ANALYTICAL, INC.
528 MINEOLA AVE.
CARLE PLACE, NY 11514

NY Lab Id No: 11469

is hereby APPROVED as an Environmental Laboratory in conformance with the National Environmental Laboratory Accreditation Conference Standards (2016) for the category ENVIRONMENTAL ANALYSES POTABLE WATER
All approved analytes are listed below:

Bacteriology

Coliform, Total / E. coli (Qualitative)	SM 21, 23 9222A,B,C
	SM 20, 21-23 9223B (-04) (Colilert)
E. coli (Enumeration)	SM 21, 23 9222A,B,C
Heterotrophic Plate Count	SM 20, 21-23 9215B (-04)

Metals I

Copper, Total	EPA 200.8 Rev. 5.4
Lead, Total	EPA 200.8 Rev. 5.4
Silver, Total	EPA 200.8 Rev. 5.4

Miscellaneous

Asbestos	EPA 100.2

Serial No.: 72126

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at https://apps.health.ny.gov/pubdoh/applinks/wc/elappublicweb/, by phone (518) 485-5570 or by email to elap@health.ny.gov.