



Hendry County School District

Dedicated to Excellence in Education
ALL IN ALL THE TIME

ADDENDUM #4

(ITB 27-0001) LaBelle High School Re-roofing project

ADDENDUM DATE: September 3, 2026

ITB RELATED DOCUMENTS-

Additional RFI Responses

All provisions of the original ITB and previously issued addenda remain in effect except as specifically modified or clarified by this Addendum.

ADDITIONAL RFI's

1st Class Roofing Inc.

Questions:

1. Has the district's building official reviewed the specified 3-inch thickness and made a determination on the R-value required for this project?
2. Should the base bid be priced on 3 inches as specified, or on the thickness required to meet current code?
3. If additional thickness is required, please confirm the R-value the district wants bidders to price.

Answer: The base bid should be priced on 3 inches as specified in the RFP.



Hendry County School District

Reedy Roofing:

Question:

Will the RFI submission date be extended since the job walk was done on 8/20/2026?

Answer:

RFI's will be answered within this addendum

Follow up question response to additional RFI's:

This project will be a complete roof tear-off rather than a roof-over. Additionally, we are proceeding with the 3-inch polyisocyanurate insulation as originally specified.

For any additional information please refer to the ITB.

For any questions, please reach out via email to Anthony Busin, busina@hendry-schools.net or Robert Kingman at kingmanr@hendry-schools.net

**ACKNOWLEDGE RECEIPT OF THIS ADDENDUM AND RETURN IT WITH YOUR SUBMITTAL.
FAILURE TO SIGN AND RETURN WITH YOUR SUBMITTAL COULD RESULT IN REJECTION OF
YOUR PROPOSAL.**

SIGNATURE

PRINT OR TYPE NAME



Hendry County School District

Dedicated to Excellence in Education

ALL IN ALL THE TIME

COMPANY NAME

EMAIL ADDRESS