

Client: Scotch Plains Fanwood Board of Education

Project No.: 26-324 Pb & Cu

PROJECT: : La Grande Elementary School 330 South Avenue, Fanwood, NJ 07023

Lead (Pb) & Copper (Cu) in drinking water sampling

FIELD TECHNICIAN(s): Leonardo Bitondo

REPORT DATE: September 3, 2026

EnviroVision Consultants, Inc. was contracted by the Scotch Plains – Fanwood Board of Education to conduct a representative Lead (Pb) & Copper (Cu) water sampling at the above-mentioned facility.

Leonardo Bitondo, EnviroVision's environmental field technician arrived at the project site early morning on August 26, 2026, prior to occupant arrival and proceeded to collect water samples from designated water outlets identified by the Scotch Plains Fanwood Board of Education. These outlets included twenty-nine sinks, bottle fillers, fountains, and a water cooler (any water sources thought to have any chance of being used for drinking, cooking, food prep, etc.).

Samples were analyzed at EMSL Analytical Inc. in Cinnaminson, New Jersey *(NJDEP# 03036), accredited in accordance with NELAC (National Environmental Laboratory Accreditation Conference). The analytical method utilized was inductively coupled plasma mass spectrometry ICP-MS (EPA 200.8).

All of sample analyzed indicated Lead or Copper in water levels below the recommended 'action level' as established by The United States Environmental Protection Agency (USEPA) of 15 parts per billion (ppb) for Lead and 1300 parts per billion (ppb) for copper. Note: 1 ppb = 1ug/L

LAGRANDE ELEMENTARY SCHOOL, 330 SOUTH AVENUE, FANWOOD, NJ - LEAD (PB) & COPPER (CU) IN WATER RESULTS:

**ALL WATER OUTLETS SAMPLED INDICATED "NONE DETECTED" OR LESS THAN
ESTABLISHED USEPA THRESHOLD OF 15 PPB LEAD AND/OR 1300 PPB
COPPER**

If/when a source/faucet meets or exceeds the USEPA threshold, EnviroVision recommends that the faucet/outlet be put out of service until the system can be further evaluated and proper remedial action is achieved. None of the samples collected and analyzed at the LaGrande Elementary School indicated the need for remedial action at this time.



20-21 Wagaraw Road – Bldg. 35E, Fair Lawn, NJ 07410
(973) 636-9145 / info@envirovisionconsultants.com
NJDOH IEHA License #: 1097

Project No.: 26-324

Should you have any questions, or if we could be of any further assistance, please feel free to contact our office. EnviroVision looks forward to providing you with the service and attention to detail you should expect from us.

Sincerely,
EnviroVision Consultants, Inc.

Cathy DiNardo

Cathy DiNardo, Project Manager

See attached: Lab results, associated data sheets

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012634612

LIMS Reference ID: AE34612

EMSL Customer ID: RAMA51

Attention: Cathy DiNardo

EnviroVision Consultants, Inc [RAMA51]

20-21 Wagaraw Rd, Bldg 35E

Fair Lawn, NJ 07410

(973) 636-9145

envirovision@optonline.net

Project Name:

La Grande ES 26-324

Project ID:

_Master Project-RAMA51

Customer PO:

Sales Rep:

Sheryl Steinmetz

Received:

08/26/2026 09:30

Reported:

09/02/2026 17:01

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LGNS-1/Nurse Left Sink									
Lims Reference ID:				AE34612-01	Matrix: Drinking Water			Sampled: 08/26/26 06:11:00	
Metals									
Copper	ND	1		35	µg/L	08/31/26 14:30	09/01/26 12:11	PL	EPA 200.8 (DA)/EPA 200.8
Lead	ND	1		1.00	µg/L	08/31/26 14:30	09/01/26 12:11	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LGNS-2/Nurse Right Sink									
Lims Reference ID:				AE34612-02	Matrix: Drinking Water			Sampled: 08/26/26 06:11:00	
Metals									
Copper	ND	1		35	µg/L	08/31/26 14:30	09/01/26 12:13	PL	EPA 200.8 (DA)/EPA 200.8
Lead	ND	1		1.00	µg/L	08/31/26 14:30	09/01/26 12:13	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LGS-3/Rm 105 Room 105 Sink									
Lims Reference ID:				AE34612-03	Matrix: Drinking Water			Sampled: 08/26/26 06:13:00	
Metals									
Copper	110	1		35	µg/L	08/31/26 16:41	09/01/26 15:37	SE	EPA 200.8 (Dig)/EPA 200.8
Lead	2.21	1		1.00	µg/L	08/31/26 16:41	09/01/26 15:37	SE	EPA 200.8 (Dig)/EPA 200.8
Sample: LGF-4/Rm 105 Room 105 Fountain									
Lims Reference ID:				AE34612-04	Matrix: Drinking Water			Sampled: 08/26/26 06:13:00	
Metals									
Copper	ND	1		35	µg/L	08/31/26 14:30	09/01/26 12:15	PL	EPA 200.8 (DA)/EPA 200.8
Lead	ND	1		1.00	µg/L	08/31/26 14:30	09/01/26 12:15	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LGF-5/Rm 107 Room 107 Fountain									
Lims Reference ID:				AE34612-05	Matrix: Drinking Water			Sampled: 08/26/26 06:15:00	
Metals									
Copper	ND	1		35	µg/L	08/31/26 14:30	09/01/26 12:21	PL	EPA 200.8 (DA)/EPA 200.8
Lead	ND	1		1.00	µg/L	08/31/26 14:30	09/01/26 12:21	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LGS-6/Rm 107 Room 107 Sink									
Lims Reference ID:				AE34612-06	Matrix: Drinking Water			Sampled: 08/26/26 06:15:00	
Metals									
Copper	54	1		35	µg/L	08/31/26 16:41	09/01/26 15:27	SE	EPA 200.8 (Dig)/EPA 200.8
Lead	1.18	1		1.00	µg/L	08/31/26 16:41	09/01/26 15:27	SE	EPA 200.8 (Dig)/EPA 200.8
Sample: LGF-7/1st Floor Hallway Bottle Filler									
Lims Reference ID:				AE34612-07	Matrix: Drinking Water			Sampled: 08/26/26 06:18:00	
Metals									
Copper	ND	1		35	µg/L	08/31/26 14:30	09/01/26 12:23	PL	EPA 200.8 (DA)/EPA 200.8
Lead	ND	1		1.00	µg/L	08/31/26 14:30	09/01/26 12:23	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
 Telephone: 856-858-4800 Fax:cs@emsl.com
 EMSL-CIN-01

EMSL Order ID: 012634612

LIMS Reference ID: AE34612

EMSL Customer ID: RAMA51

Attention: Cathy DiNardo

EnviroVision Consultants, Inc [RAMA51]

20-21 Wagaraw Rd, Bldg 35E

Fair Lawn, NJ 07410

(973) 636-9145

envirovision@optonline.net

Project Name:

La Grande ES 26-324

Project ID:

_Master Project-RAMA51

Customer PO:

Sales Rep:

Sheryl Steinmetz

Received:

08/26/2026 09:30

Reported:

09/02/2026 17:01

Analytical Results

(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LGF-8/1st Floor Hallway Upper Fountain									
		Lims Reference ID:		AE34612-08		Matrix: Drinking Water		Sampled: 08/26/26 06:18:00	
Metals									
Copper	ND	1	35	µg/L	08/31/26 14:30	09/01/26 12:25	PL	EPA 200.8 (DA)/EPA 200.8	
Lead	ND	1	1.00	µg/L	08/31/26 14:30	09/01/26 12:25	PL	EPA 200.8 (DA)/EPA 200.8	
Sample: LGF-9/1st Floor Hallway Lower Fountain									
		Lims Reference ID:		AE34612-09		Matrix: Drinking Water		Sampled: 08/26/26 06:18:00	
Metals									
Copper	ND	1	35	µg/L	08/31/26 14:30	09/01/26 12:27	PL	EPA 200.8 (DA)/EPA 200.8	
Lead	ND	1	1.00	µg/L	08/31/26 14:30	09/01/26 12:27	PL	EPA 200.8 (DA)/EPA 200.8	
Sample: LGS-10/Rm 111 Sink									
		Lims Reference ID:		AE34612-10		Matrix: Drinking Water		Sampled: 08/26/26 06:20:00	
Metals									
Copper	140	1	35	µg/L	08/31/26 14:30	09/01/26 12:29	PL	EPA 200.8 (DA)/EPA 200.8	
Lead	1.42	1	1.00	µg/L	08/31/26 14:30	09/01/26 12:29	PL	EPA 200.8 (DA)/EPA 200.8	
Sample: LGF-11/Rm 111 Fountain									
		Lims Reference ID:		AE34612-11		Matrix: Drinking Water		Sampled: 08/26/26 06:20:00	
Metals									
Copper	ND	1	35	µg/L	08/31/26 14:30	09/01/26 12:31	PL	EPA 200.8 (DA)/EPA 200.8	
Lead	ND	1	1.00	µg/L	08/31/26 14:30	09/01/26 12:31	PL	EPA 200.8 (DA)/EPA 200.8	
Sample: LGS-12/Rm 112 Sink									
		Lims Reference ID:		AE34612-12		Matrix: Drinking Water		Sampled: 08/26/26 06:22:00	
Metals									
Copper	85	1	35	µg/L	08/31/26 16:41	09/01/26 15:42	SE	EPA 200.8 (Dig)/EPA 200.8	
Lead	1.35	1	1.00	µg/L	08/31/26 16:41	09/01/26 15:42	SE	EPA 200.8 (Dig)/EPA 200.8	
Sample: LGF-13/Rm 112 Fountain									
		Lims Reference ID:		AE34612-13		Matrix: Drinking Water		Sampled: 08/26/26 06:22:00	
Metals									
Copper	ND	1	35	µg/L	08/31/26 14:30	09/01/26 12:37	PL	EPA 200.8 (DA)/EPA 200.8	
Lead	ND	1	1.00	µg/L	08/31/26 14:30	09/01/26 12:37	PL	EPA 200.8 (DA)/EPA 200.8	
Sample: LGS-14/Rm 113 Sink									
		Lims Reference ID:		AE34612-14		Matrix: Drinking Water		Sampled: 08/26/26 06:25:00	
Metals									
Copper	ND	1	35	µg/L	08/31/26 14:30	09/01/26 12:39	PL	EPA 200.8 (DA)/EPA 200.8	
Lead	1.21	1	1.00	µg/L	08/31/26 14:30	09/01/26 12:39	PL	EPA 200.8 (DA)/EPA 200.8	

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012634612

LIMS Reference ID: AE34612

EMSL Customer ID: RAMA51

Attention: Cathy DiNardo

EnviroVision Consultants, Inc [RAMA51]

20-21 Wagaraw Rd, Bldg 35E

Fair Lawn, NJ 07410

(973) 636-9145

envirovision@optonline.net

Project Name: La Grande ES 26-324

Project ID: _Master Project-RAMA51

Customer PO:

Sales Rep: Sheryl Steinmetz

Received: 08/26/2026 09:30

Reported: 09/02/2026 17:01

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LGF-15/Rm 113 Fountain									
Lims Reference ID:				AE34612-15				Matrix: Drinking Water	
Sampled:				08/26/26 06:25:00					
Metals									
Copper	ND	1	35	µg/L	08/31/26 14:30	09/01/26 12:45	PL	EPA 200.8 (DA)/EPA 200.8	
Lead	ND	1	1.00	µg/L	08/31/26 14:30	09/01/26 12:45	PL	EPA 200.8 (DA)/EPA 200.8	
Sample: LGS-16/Rm 115 Sink									
Lims Reference ID:				AE34612-16				Matrix: Drinking Water	
Sampled:				08/26/26 06:27:00					
Metals									
Copper	54	1	35	µg/L	08/31/26 14:30	09/01/26 12:47	PL	EPA 200.8 (DA)/EPA 200.8	
Lead	1.61	1	1.00	µg/L	08/31/26 14:30	09/01/26 12:47	PL	EPA 200.8 (DA)/EPA 200.8	
Sample: LGF-17/Rm 115 Fountain									
Lims Reference ID:				AE34612-17				Matrix: Drinking Water	
Sampled:				08/26/26 06:27:00					
Metals									
Copper	ND	1	35	µg/L	08/31/26 14:30	09/01/26 12:49	PL	EPA 200.8 (DA)/EPA 200.8	
Lead	ND	1	1.00	µg/L	08/31/26 14:30	09/01/26 12:49	PL	EPA 200.8 (DA)/EPA 200.8	
Sample: LGS-18/Rm 116 Sink									
Lims Reference ID:				AE34612-18				Matrix: Drinking Water	
Sampled:				08/26/26 06:30:00					
Metals									
Copper	ND	1	35	µg/L	08/31/26 14:30	09/01/26 12:51	PL	EPA 200.8 (DA)/EPA 200.8	
Lead	ND	1	1.00	µg/L	08/31/26 14:30	09/01/26 12:51	PL	EPA 200.8 (DA)/EPA 200.8	
Sample: LGF-19/Rm 116 Fountain									
Lims Reference ID:				AE34612-19				Matrix: Drinking Water	
Sampled:				08/26/26 06:30:00					
Metals									
Copper	ND	1	35	µg/L	08/31/26 14:30	09/01/26 12:53	PL	EPA 200.8 (DA)/EPA 200.8	
Lead	ND	1	1.00	µg/L	08/31/26 14:30	09/01/26 12:53	PL	EPA 200.8 (DA)/EPA 200.8	
Sample: LGS-20/Rm 202 Sink									
Lims Reference ID:				AE34612-20				Matrix: Drinking Water	
Sampled:				08/26/26 06:32:00					
Metals									
Copper	160	1	35	µg/L	08/31/26 16:41	09/01/26 15:44	SE	EPA 200.8 (Dig)/EPA 200.8	
Lead	2.66	1	1.00	µg/L	08/31/26 16:41	09/01/26 15:44	SE	EPA 200.8 (Dig)/EPA 200.8	
Sample: LGF-21/Rm 202 Fountain									
Lims Reference ID:				AE34612-21				Matrix: Drinking Water	
Sampled:				08/26/26 06:32:00					
Metals									
Copper	ND	1	35	µg/L	08/31/26 14:30	09/01/26 12:55	PL	EPA 200.8 (DA)/EPA 200.8	
Lead	ND	1	1.00	µg/L	08/31/26 14:30	09/01/26 12:55	PL	EPA 200.8 (DA)/EPA 200.8	

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012634612

LIMS Reference ID: AE34612

EMSL Customer ID: RAMA51

Attention: Cathy DiNardo

EnviroVision Consultants, Inc [RAMA51]

20-21 Wagaraw Rd, Bldg 35E

Fair Lawn, NJ 07410

(973) 636-9145

envirovision@optonline.net

Project Name: La Grande ES 26-324

Project ID: _Master Project-RAMA51

Customer PO:

Sales Rep: Sheryl Steinmetz

Received: 08/26/2026 09:30

Reported: 09/02/2026 17:01

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LGS-22/Rm 203 Sink									
Lims Reference ID:				AE34612-22		Matrix: Drinking Water		Sampled: 08/26/26 06:35:00	
Metals									
Copper	ND	1		35	µg/L	08/31/26 14:30	09/01/26 12:57	PL	EPA 200.8 (DA)/EPA 200.8
Lead	1.82	1		1.00	µg/L	08/31/26 14:30	09/01/26 12:57	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LGF-23/Rm 203 Fountain									
Lims Reference ID:				AE34612-23		Matrix: Drinking Water		Sampled: 08/26/26 06:35:00	
Metals									
Copper	ND	1		35	µg/L	08/31/26 14:37	09/01/26 13:20	PL	EPA 200.8 (DA)/EPA 200.8
Lead	ND	1		1.00	µg/L	08/31/26 14:37	09/01/26 13:20	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LGF-24/2nd Floor Hallway Bottle Filler									
Lims Reference ID:				AE34612-24		Matrix: Drinking Water		Sampled: 08/26/26 06:37:00	
Metals									
Copper	37	1		35	µg/L	08/31/26 14:37	09/01/26 13:26	PL	EPA 200.8 (DA)/EPA 200.8
Lead	ND	1		1.00	µg/L	08/31/26 14:37	09/01/26 13:26	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LGF-25/2nd Floor Hallway Lower Fountain									
Lims Reference ID:				AE34612-25		Matrix: Drinking Water		Sampled: 08/26/26 06:40:00	
Metals									
Copper	ND	1		35	µg/L	08/31/26 14:37	09/01/26 13:28	PL	EPA 200.8 (DA)/EPA 200.8
Lead	ND	1		1.00	µg/L	08/31/26 14:37	09/01/26 13:28	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LGF-26/2nd Floor Hallway Upper Fountain									
Lims Reference ID:				AE34612-26		Matrix: Drinking Water		Sampled: 08/26/26 06:40:00	
Metals									
Copper	ND	1		35	µg/L	08/31/26 14:37	09/01/26 13:30	PL	EPA 200.8 (DA)/EPA 200.8
Lead	ND	1		1.00	µg/L	08/31/26 14:37	09/01/26 13:30	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LGS-27/Rm 306 Sink									
Lims Reference ID:				AE34612-27		Matrix: Drinking Water		Sampled: 08/26/26 06:43:00	
Metals									
Copper	83	1		35	µg/L	08/31/26 14:37	09/01/26 13:32	PL	EPA 200.8 (DA)/EPA 200.8
Lead	ND	1		1.00	µg/L	08/31/26 14:37	09/01/26 13:32	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LGF-28/3rd Floor Hallway Bottle Filler									
Lims Reference ID:				AE34612-28		Matrix: Drinking Water		Sampled: 08/26/26 06:45:00	
Metals									
Copper	52	1		35	µg/L	08/31/26 14:37	09/01/26 13:39	PL	EPA 200.8 (DA)/EPA 200.8
Lead	ND	1		1.00	µg/L	08/31/26 14:37	09/01/26 13:39	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012634612

LIMS Reference ID: AE34612

EMSL Customer ID: RAMA51

Attention: Cathy DiNardo

EnviroVision Consultants, Inc [RAMA51]

20-21 Wagaraw Rd, Bldg 35E

Fair Lawn, NJ 07410

(973) 636-9145

envirovision@optonline.net

Project Name:

La Grande ES 26-324

Project ID:

_Master Project-RAMA51

Customer PO:

Sales Rep:

Sheryl Steinmetz

Received:

08/26/2026 09:30

Reported:

09/02/2026 17:01

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: LGC-29/Rm 309 Water Cooler									
Lims Reference ID:				AE34612-29				Matrix: Drinking Water	
				Sampled: 08/26/26 06:48:00					
Metals									
Copper	ND	1		35	µg/L	08/31/26 14:37	09/01/26 13:41	PL	EPA 200.8 (DA)/EPA 200.8
Lead	ND	1		1.00	µg/L	08/31/26 14:37	09/01/26 13:41	PL	EPA 200.8 (DA)/EPA 200.8
Sample: LGB-30/Blank									
Lims Reference ID:				AE34612-30				Matrix: Drinking Water	
				Sampled: 08/26/26 06:55:00					
Metals									
Copper	ND	1		35	µg/L	08/31/26 14:37	09/01/26 13:43	PL	EPA 200.8 (DA)/EPA 200.8
Lead	ND	1		1.00	µg/L	08/31/26 14:37	09/01/26 13:43	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012634612

LIMS Reference ID: AE34612

EMSL Customer ID: RAMA51

Attention: Cathy DiNardo

EnviroVision Consultants, Inc [RAMA51]

20-21 Wagaraw Rd, Bldg 35E

Fair Lawn, NJ 07410

(973) 636-9145

envirovision@optonline.net

Project Name:

La Grande ES 26-324

Project ID:

_Master Project-RAMA51

Customer PO:

Sales Rep:

Sheryl Steinmetz

Received:

08/26/2026 09:30

Reported:

09/02/2026 17:01

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Copper	NJDEP
Lead	NJDEP

List of Certifications

Code	Description	Number	Expires
PADEP	Pennsylvania Department of Environmental Protection	68-00367	11/30/2026
NYSDOH	New York State Department of Health ELAP	10872	04/01/2027
NJDEP	New Jersey Department of Environmental Protection	03036	06/30/2027
MADEP	Massachusetts Department of Environmental Protection	M-NJ337	06/30/2027
HIDOH	Hawaii Department of Health	HI via NJ 03036	06/30/2027
CTDPH	Connecticut Department of Public Health	PH-0270	06/30/2028
California ELAP	California Water Boards	1877	06/30/2027
AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC)	100194	04/01/2027
A2LA	A2LA Environmental Certificate	2845.01	07/31/2028
21-A2LA	A2LA Food Chem/Mat Sci	2845.15	07/31/2028

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012634612

LIMS Reference ID: AE34612

EMSL Customer ID: RAMA51

Attention: Cathy DiNardo

EnviroVision Consultants, Inc [RAMA51]
20-21 Wagaraw Rd, Bldg 35E
Fair Lawn, NJ 07410
(973) 636-9145
envirovision@optonline.net

Project Name:

La Grande ES 26-324

Project ID:

_Master Project-RAMA51

Customer PO:**Sales Rep:**

Sheryl Steinmetz

Received:

08/26/2026 09:30

Reported:

09/02/2026 17:01


Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the reporting limit, or the mdl if provided.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

Owen McKenna Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



AE34612

20-21 Wagaraw Road - Bldg. 35E, Fair Lawn, NJ 07410
(973) 636-9145 / info@envirovisionconsultants.com
NJDOH IHEA Lic #: 1097

CLIENT	Scotch Plains Board of Education	ADDRESS	512 Cedar Street, Scotch Plains-Fanwood, NJ 07076
PROJECT	La Grande ES	ADDRESS	330 South Avenue, Fanwood, NJ 07023
TECH	L. Bitondo/C. DiNardo	SAMPLING DATE	8/26/2026
		PROJ #	26-324

LEAD AND COPPER IN DRINKING WATER DATA SHEET

Sample ID #	Date/Time Collected	Sample Location	Observations
UGWS-1	8/26/26 6:11am	nurse	Left sink
UGWS-2	8/26/26 6:11am	nurse	Right sink
UGWS-3	8/26/26 6:13am	Rm 105	Room 105 sink
UGF-4	8/26/26 6:13am	Rm 105	Room 105 Fountain
UGF-5	8/26/26 6:15am	Rm 107	Room 107 Fountain
UGS-6	8/26/26 6:15am	Rm 107	Room 107 sink
UGF-7	8/26/26 6:18am	1st Floor Hallway	Bottle Filler
UGF-8	8/26/26 6:18am	1st Floor Hallway	Upper Fountain
UGF-9	8/26/26 6:18am	1st Floor Hallway	Lower Fountain
UGS-10	8/26/26 6:20am	Rm 111	Sink
UGF-11	8/26/26 6:20am	Rm 111	Fountain
UGS-12	8/26/26 6:22am	Rm 112	Sink

CHAIN OF CUSTODY

Relinquished By:	Received By:	Date & Time
<i>C. DiNardo</i>	<i>Angie Mall</i>	8/26/26 0910
<i>Angie Mall</i>	<i>Monnelly (WT)</i>	8/26/26 0930

ANALYSIS:

X Unpreserved, Pb and Cu via EPA 200.8 ICP-MS
(0.001 mg/L (ppm))
— Preserved with HNO₃, Pb and Cu via EPA 200.8 ICP-MS
(0.001 mg/L (ppm))

Matrix: Drinking Water, Sample Type: Grab

Sample(s) Temperature Upon Receipt (Lab Only): _____

Bottle Size: 250 mL, wide mouth

TURNAROUND TIME 1 WEEK

EMAIL RESULTS TO info@envirovisionconsultants.com

HNO₃ added 0920 on 8/27-12*3D*

PAGE 1 OF 3

20.6.c/T-195



AE34612

20-21 Wagaraw Road - Bldg. 35E, Fair Lawn, NJ 07410
(973) 636-9145 / info@envirovisionconsultants.com
NJDOH IHEA Lic #: 1097

CLIENT	Scotch Plains Board of Education	ADDRESS	512 Cedar Street, Scotch Plains-Fanwood, NJ 07076
PROJECT	La Grande ES	ADDRESS	330 South Avenue, Fanwood, NJ 07023
TECH	L. Bitondo/C. DiNardo	SAMPLING DATE	8/26/2026
		PROJ #	26-324

LEAD AND COPPER IN DRINKING WATER DATA SHEET

Sample ID #	Date/Time Collected	Sample Location	Observations
LB-F-13	8/26/26 6:22am	Rm 112	Fountain
LB-S-14	8/26/26 6:25am	Rm 113	Sink
LB-F-15	8/26/26 6:25am	Rm 113	Fountain
LB-S-16	8/26/26 6:27am	Rm 115	Sink
LB-F-17	8/26/26 6:27am	Rm 115	Fountain
LB-S-18	8/26/26 6:30am	Rm 116	Sink
LB-F-19	8/26/26 6:30am	Rm 116	Fountain
LB-S-20	8/26/26 6:32am	Rm 202	Sink
LB-F-21	8/26/26 6:32am	Rm 202	Fountain
LB-S-22	8/26/26 6:35am	Rm 203	Sink
LB-F-23	8/26/26 6:35am	Rm 203	Fountain
LB-F-24	8/26/26 6:37am	2nd Floor Hallway	Bottle Filler

CHAIN OF CUSTODY

Relinquished By:	Received By:	Date & Time
CDiNardo	ho	8/26/26
ho	Monally (WT)	8/26/26 0930

ANALYSIS:

☒ Unpreserved, Pb and Cu via EPA 200.8 ICP-MS
(0.001 mg/L (ppm))
☐ Preserved with HNO₃, Pb and Cu via EPA 200.8 ICP-MS
(0.001 mg/L (ppm))

Matrix: Drinking Water, Sample Type: Grab


Sample(s) Temperature Upon Receipt (Lab Only): _____

Bottle Size: 250 mL, wide mouth

TURNAROUND TIME 1 WEEK

EMAIL RESULTS TO info@envirovisionconsultants.com

LABORATORY SUBMITTED TO:	
LAB ORDER #	



AE34612

20-21 Wagaraw Road - Bldg. 35E, Fair Lawn, NJ 07410
(973) 636-9145 / info@envirovisionconsultants.com
NJDOH IHEA Lic #: 1097

CLIENT	Scotch Plains Board of Education	ADDRESS	512 Cedar Street, Scotch Plains-Fanwood, NJ 07076
PROJECT	La Grande ES	ADDRESS	330 South Avenue, Fanwood, NJ 07023
TECH	L. Bitondo/C. DiNardo	SAMPLING DATE	8/26/2026
		PROJ #	26-324

LEAD AND COPPER IN DRINKING WATER DATA SHEET

Sample ID #	Date/Time Collected	Sample Location	Observations
LB-F-25	8/26/26 6:40am	2nd Floor Hallway	Lower Fountain
LB-F-26	8/26/26 6:40am	2nd Floor Hallway	Upper Fountain
LB-F-27	8/26/26 6:43am	Rm 306	Sink
LB-F-28	8/26/26 6:45am	3rd Floor Hallway	Bottle Filler
LB-F-29	8/26/26 6:45am	Rm 309	Water cooler
LB-B-30	8/26/26 6:55am	Blank	

CHAIN OF CUSTODY

Relinquished By:	Received By:	Date & Time
<i>DiNardo</i>	<i>As</i>	8/26/26
<i>As</i>	<i>Monrovia (WT)</i>	8/26/26 0930

ANALYSIS:

☒ Unpreserved, Pb and Cu via EPA 200.8 ICP-MS
(0.001 mg/L (ppm))

☐ Preserved with HNO₃, Pb and Cu via EPA 200.8 ICP-MS
(0.001 mg/L (ppm))

Matrix: Drinking Water, Sample Type: Grab

Sample(s) Temperature Upon Receipt (Lab Only): _____

Bottle Size: 250 mL, wide mouth

TURNAROUND TIME 1 WEEK

EMAIL RESULTS TO info@envirovisionconsultants.com

LABORATORY SUBMITTED TO:	
LAB ORDER #	

New Jersey Department of Health

Having met the requirements of N.J.A.C. 8:50

ENVIROVISION CONSULTANTS, INC

20-21 WAGARAW ROAD BLDG 35E

FAIR LAWN, NJ 07410

License Number: 1097

is licensed as an Indoor Environmental Consultant to conduct Indoor
Environmental Health Assessments of Child Care Centers and
Educational Facilities in New Jersey.

12/5/2024

Issue Date

12/5/2026

Expiration Date



Christina Tan, MD, MPH, Assistant Commissioner
Division of Epidemiology, Environmental and Occupational Health

This License is non-transferable and only valid for the licensee as indicated above.