



Lead in Water Sample Results

For

**Delano Public Schools
High School
FY2024 Testing**



137 23rd St. South Suite 201 Sartell, MN 56377
(320) 255-3236 | Toll Free (888) 447-7032
Fax (320) 255-2998 | www.resourcecoop-mn.gov

**MINNESOTA VALLEY TESTING LABORATORIES, INC.**

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com



Workorder: Delano High School (43069)
Account #: 19442

Client: Resource Training & Solutions

Josh Baumann
Resource Training & Solutions
137 23rd Street S
Suite 201
Sartell, MN 56377

Certificate of Analysis**Approval**

All data reported has been reviewed and approved by:

Dave Smahel, Inorganic Chemistry/Feed Lab Manager New Ulm, MN

Analyses performed under Minnesota Department of Health Accreditation conforms to the current TNI standards.

NEW ULM LAB CERTIFICATIONS:
MN LAB # 027-015-125ND WW/DW # R-040

BISMARCK LAB CERTIFICATIONS:
MN LAB # 038-999-267ND W/DW # ND-016

Workorder Comments

All samples were preserved with nitric acid upon receipt at the laboratory.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Thursday, March 28, 2024 4:08:13 PM

Page 1 of 16

**MINNESOTA VALLEY TESTING LABORATORIES, INC.**

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

**Workorder:** Delano High School (43069)**Client:** Resource Training & Solutions**Analytical Results**

Lab ID: 43069001 **Date Collected:** 03/08/2024 07:10 **Matrix:** Potable Water
Sample ID: DHS1 **Date Received:** 03/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Kitchen Sink 1/Back

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	3.60	ug/L	15	EPA 200.8	03/27/2024 15:31	

Lab ID: 43069002 **Date Collected:** 03/08/2024 07:10 **Matrix:** Potable Water
Sample ID: DHS2 **Date Received:** 03/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Kitchen Sink 2/Back

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	2.16	ug/L	15	EPA 200.8	03/27/2024 15:33	

Lab ID: 43069003 **Date Collected:** 03/08/2024 07:10 **Matrix:** Potable Water
Sample ID: DHS3 **Date Received:** 03/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Kitchen Sink Single by Sanitizer

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	03/27/2024 15:35	

Lab ID: 43069004 **Date Collected:** 03/08/2024 07:10 **Matrix:** Potable Water
Sample ID: DHS4 **Date Received:** 03/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Kitchen Faucet by Hoods

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	9.25	ug/L	15	EPA 200.8	03/27/2024 15:37	

Lab ID: 43069005 **Date Collected:** 03/08/2024 07:10 **Matrix:** Potable Water
Sample ID: DHS5 **Date Received:** 03/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: Kitchen Sink by Salad Bar

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	03/27/2024 15:39	

Lab ID: 43069006 **Date Collected:** 03/08/2024 07:10 **Matrix:** Potable Water
Sample ID: DHS6 **Date Received:** 03/14/2024 14:00
Temp @ Receipt (C):
Sample Desc: TAC Drinking Station P102

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	03/27/2024 15:40	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Thursday, March 28, 2024 4:08:13 PM

**MINNESOTA VALLEY TESTING LABORATORIES, INC.**

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

**Workorder:** Delano High School (43069)**Client:** Resource Training & Solutions**Analytical Results**

Lab ID:	43069007	Date Collected:	03/08/2024 07:10	Matrix:	Potable Water	
Sample ID:	DHS7	Date Received:	03/14/2024 14:00			
Temp @ Receipt (C):						
Sample Desc:	TAC Drinking Station T112					
Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	03/27/2024 15:42	

Lab ID:	43069008	Date Collected:	03/08/2024 07:10	Matrix:	Potable Water	
Sample ID:	DHS8	Date Received:	03/14/2024 14:00			
Temp @ Receipt (C):						
Sample Desc:	TAC Drinking Station T212					
Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	03/27/2024 15:44	

Lab ID:	43069009	Date Collected:	03/08/2024 07:10	Matrix:	Potable Water	
Sample ID:	DHS9	Date Received:	03/14/2024 14:00			
Temp @ Receipt (C):						
Sample Desc:	TAC Drinking Station by Bleacher					
Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	03/27/2024 15:46	

Lab ID:	43069010	Date Collected:	03/08/2024 07:28	Matrix:	Potable Water	
Sample ID:	DHS10	Date Received:	03/14/2024 14:00			
Temp @ Receipt (C):						
Sample Desc:	D.S. Locker T107					
Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	03/27/2024 15:48	

Lab ID:	43069011	Date Collected:	03/08/2024 07:30	Matrix:	Potable Water	
Sample ID:	DHS11	Date Received:	03/14/2024 14:00			
Temp @ Receipt (C):						
Sample Desc:	D.S. Locker T108					
Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	03/27/2024 16:02	

Lab ID:	43069012	Date Collected:	03/08/2024 07:30	Matrix:	Potable Water	
Sample ID:	DHS12	Date Received:	03/14/2024 14:00			
Temp @ Receipt (C):						
Sample Desc:	D.S. Locker T110					
Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	0.59	ug/L	15	EPA 200.8	03/27/2024 16:04	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Thursday, March 28, 2024 4:08:13 PM

Page 3 of 16

**MINNESOTA VALLEY TESTING LABORATORIES, INC.**

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

**Workorder:** Delano High School (43069)**Client:** Resource Training & Solutions**Analytical Results**

Lab ID:	43069013	Date Collected:	03/08/2024 07:30	Matrix:	Potable Water	
Sample ID:	DHS13	Date Received:	03/14/2024 14:00			
Temp @ Receipt (C):						
Sample Desc:	D.S. Locker T111					
Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	03/27/2024 16:06	

Lab ID:	43069014	Date Collected:	03/08/2024 07:30	Matrix:	Potable Water	
Sample ID:	DHS14	Date Received:	03/14/2024 14:00			
Temp @ Receipt (C):						
Sample Desc:	D.S. by Event Bathrooms					
Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	0.92	ug/L	15	EPA 200.8	03/27/2024 16:08	

Lab ID:	43069015	Date Collected:	03/08/2024 07:30	Matrix:	Potable Water	
Sample ID:	DHS15	Date Received:	03/14/2024 14:00			
Temp @ Receipt (C):						
Sample Desc:	D.S. by Track Bottle					
Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	03/27/2024 16:10	

Lab ID:	43069016	Date Collected:	03/08/2024 07:30	Matrix:	Potable Water	
Sample ID:	DHS16	Date Received:	03/14/2024 14:00			
Temp @ Receipt (C):						
Sample Desc:	D.S. by Track Bottle					
Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	03/27/2024 16:12	

Lab ID:	43069017	Date Collected:	03/08/2024 07:30	Matrix:	Potable Water	
Sample ID:	DHS17	Date Received:	03/14/2024 14:00			
Temp @ Receipt (C):						
Sample Desc:	D.S. by Vending Machine					
Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	03/27/2024 16:13	

Lab ID:	43069018	Date Collected:	03/08/2024 07:30	Matrix:	Potable Water	
Sample ID:	DHS18	Date Received:	03/14/2024 14:00			
Temp @ Receipt (C):						
Sample Desc:	Break Room 130					
Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	03/27/2024 16:15	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Thursday, March 28, 2024 4:08:13 PM

Page 4 of 16

**MINNESOTA VALLEY TESTING LABORATORIES, INC.**

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

**Workorder:** Delano High School (43069)**Client:** Resource Training & Solutions**Analytical Results**

Lab ID:	43069019	Date Collected:	03/08/2024 07:30	Matrix:	Potable Water	
Sample ID:	DHS19	Date Received:	03/14/2024 14:00			
Temp @ Receipt (C):						
Sample Desc:	D.S. White by 133					
Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	1.75	ug/L	15	EPA 200.8	03/27/2024 16:17	
Lab ID:	43069020	Date Collected:	03/08/2024 07:45	Matrix:	Potable Water	
Sample ID:	DHS20	Date Received:	03/14/2024 14:00			
Temp @ Receipt (C):						
Sample Desc:	D.S. Tiger Den					
Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	03/27/2024 16:19	
Lab ID:	43069021	Date Collected:	03/08/2024 07:50	Matrix:	Potable Water	
Sample ID:	DHS21	Date Received:	03/14/2024 14:00			
Temp @ Receipt (C):						
Sample Desc:	D.S. White by 335					
Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	1.09	ug/L	15	EPA 200.8	03/27/2024 16:33	
Lab ID:	43069022	Date Collected:	03/08/2024 07:50	Matrix:	Potable Water	
Sample ID:	DHS22	Date Received:	03/14/2024 14:00			
Temp @ Receipt (C):						
Sample Desc:	D.S. Bottle by 332					
Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	03/27/2024 16:35	
Lab ID:	43069023	Date Collected:	03/08/2024 07:50	Matrix:	Potable Water	
Sample ID:	DHS23	Date Received:	03/14/2024 14:00			
Temp @ Receipt (C):						
Sample Desc:	D.S. Bottle by W/Wing					
Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	03/27/2024 16:37	
Lab ID:	43069024	Date Collected:	03/08/2024 07:50	Matrix:	Potable Water	
Sample ID:	DHS24	Date Received:	03/14/2024 14:00			
Temp @ Receipt (C):						
Sample Desc:	D.S. Bottle by E/Wing					
Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	03/27/2024 16:39	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Thursday, March 28, 2024 4:08:13 PM

Page 5 of 16

**MINNESOTA VALLEY TESTING LABORATORIES, INC.**

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

**Workorder:** Delano High School (43069)**Client:** Resource Training & Solutions**Analytical Results**

Lab ID:	43069025	Date Collected:	03/08/2024 07:50	Matrix:	Potable Water	
Sample ID:	DHS25	Date Received:	03/14/2024 14:00			
Temp @ Receipt (C):						
Sample Desc:	FACS Yellow Kitchen					
Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	03/27/2024 16:41	

Lab ID:	43069026	Date Collected:	03/08/2024 07:50	Matrix:	Potable Water	
Sample ID:	DHS26	Date Received:	03/14/2024 14:00			
Temp @ Receipt (C):						
Sample Desc:	FACS Orange Kitchen					
Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	03/27/2024 16:43	

Lab ID:	43069027	Date Collected:	03/08/2024 07:50	Matrix:	Potable Water	
Sample ID:	DHS27	Date Received:	03/14/2024 14:00			
Temp @ Receipt (C):						
Sample Desc:	FACS Red Kitchen					
Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	03/27/2024 16:44	

Lab ID:	43069028	Date Collected:	03/08/2024 07:50	Matrix:	Potable Water	
Sample ID:	DHS28	Date Received:	03/14/2024 14:00			
Temp @ Receipt (C):						
Sample Desc:	FACS Green Kitchen					
Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	03/27/2024 16:46	

Lab ID:	43069029	Date Collected:	03/08/2024 07:50	Matrix:	Potable Water	
Sample ID:	DHS29	Date Received:	03/14/2024 14:00			
Temp @ Receipt (C):						
Sample Desc:	FACS Blue Kitchen					
Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	03/27/2024 16:48	

Lab ID:	43069030	Date Collected:	03/08/2024 08:10	Matrix:	Potable Water	
Sample ID:	DHS30	Date Received:	03/14/2024 14:00			
Temp @ Receipt (C):						
Sample Desc:	FACS Purple Kitchen					
Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	03/27/2024 16:50	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Thursday, March 28, 2024 4:08:13 PM

**MINNESOTA VALLEY TESTING LABORATORIES, INC.**

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

**Workorder:** Delano High School (43069)**Client:** Resource Training & Solutions**Analytical Results**

Lab ID:	43069031	Date Collected:	03/08/2024 07:20	Matrix:	Potable Water	
Sample ID:	DHS31	Date Received:	03/14/2024 14:00			
Temp @ Receipt (C):						
Sample Desc:	Band Room Fountain					
Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	03/27/2024 17:05	

Lab ID:	43069032	Date Collected:	03/08/2024 07:23	Matrix:	Potable Water	
Sample ID:	DHS32	Date Received:	03/14/2024 14:00			
Temp @ Receipt (C):						
Sample Desc:	Band Hallway Fountain					
Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	03/27/2024 17:06	

Lab ID:	43069033	Date Collected:	03/08/2024 07:24	Matrix:	Potable Water	
Sample ID:	DHS33	Date Received:	03/14/2024 14:00			
Temp @ Receipt (C):						
Sample Desc:	Hallway Between Fountain Door 10 & 11					
Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	03/27/2024 17:08	

Lab ID:	43069034	Date Collected:	03/08/2024 07:26	Matrix:	Potable Water	
Sample ID:	DHS34	Date Received:	03/14/2024 14:00			
Temp @ Receipt (C):						
Sample Desc:	Fountain Left Side by Middle School Bathroom					
Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	03/27/2024 17:10	

Lab ID:	43069035	Date Collected:	03/08/2024 07:26	Matrix:	Potable Water	
Sample ID:	DHS35	Date Received:	03/14/2024 14:00			
Temp @ Receipt (C):						
Sample Desc:	Fountain Rt Side M.S. Bathrooms					
Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	03/27/2024 17:12	

Lab ID:	43069036	Date Collected:	03/08/2024 07:30	Matrix:	Potable Water	
Sample ID:	DHS36	Date Received:	03/14/2024 14:00			
Temp @ Receipt (C):						
Sample Desc:	Fountain M.S. Hall Rt Side					
Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	03/27/2024 17:14	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Thursday, March 28, 2024 4:08:13 PM

Page 7 of 16

**MINNESOTA VALLEY TESTING LABORATORIES, INC.**

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

**Workorder:** Delano High School (43069)**Client:** Resource Training & Solutions**Analytical Results**

Lab ID:	43069037	Date Collected:	03/08/2024 07:33	Matrix:	Potable Water	
Sample ID:	DHS37	Date Received:	03/14/2024 14:00			
Temp @ Receipt (C):						
Sample Desc:	Fountain in Pool Area					
Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	03/27/2024 17:16	

Lab ID:	43069038	Date Collected:	03/08/2024 07:36	Matrix:	Potable Water	
Sample ID:	DHS38	Date Received:	03/14/2024 14:00			
Temp @ Receipt (C):						
Sample Desc:	Wrestling Room Fountain					
Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	03/27/2024 17:17	

Lab ID:	43069039	Date Collected:	03/08/2024 07:38	Matrix:	Potable Water	
Sample ID:	DHS39	Date Received:	03/14/2024 14:00			
Temp @ Receipt (C):						
Sample Desc:	Boy's Locker Rm H.S. Fountain					
Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	03/27/2024 17:19	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Thursday, March 28, 2024 4:08:13 PM



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Member
ACIL

Workorder: Delano High School (43069)

Client: Resource Training & Solutions



Minnesota Valley Testing Laboratories, Inc.
1126 North Front Street, Building 2
New Ulm, MN 56073

Phone: (507) 354-8517

Fax: (507) 359-2890

Toll Free: (800) 782-3557

Company Name and Address:

Resource Training and Solutions
137 23rd Street South Suite 201
Sartell MN 56377

Account #: 19442 Phone #: 3202553236 x316

Billing Address (indicate if different from above):

Resource Training and Solutions
137 23rd Street South Suite 201
Sartell MN 56377

Transferred by:

Date:

Time:

Sample Condition:

Received by:

Date:

Time:

Temp:

1.

2.

Comments:

Sample Information

Sample Type Codes: Drinking Water = DW, Groundwater = GW, Stormwater = ST, Surface Water = SW, Wastewater = WW, Solid = S, Compost = C

Lab Use Only	F= Fountain S= Sink B= Bottle Filler K= Kettle Describe any others	Sample ID Room/Location/Fixture	Sample Type	Date Sampled	Time Sampled	Number of Bottles	Analysis
1	DHS1	Kitchen sink 1/Back	DW	3/8	7:10	1	LEAD
2	DHS2	Kitchen sink 2/Back	DW	3/8		1	LEAD
3	DHS3	Kitchen sink single side	DW	3/8		1	LEAD
4	DHS4	Kitchen Faucet By Hand	DW	3/8		1	LEAD
5	DHS5	Kitchen sink By Salad Bar	DW	3/8		1	LEAD
6	DHS6	TAC Drinking station P102	DW	3/8		1	LEAD
7	DHS7	TAC Drinking station T112	DW	3/8		1	LEAD
8	DHS8	TAC Drinking station T212	DW	3/8		1	LEAD
9	DHS9	TAC Drinking station By Bleacher	DW	3/8		1	LEAD
10	DHS10	BS locker T107	DW	3/8	7:28	1	LEAD

Enclosed are your containers for your sampling event. Completely fill and label containers appropriately for the analyses to be conducted. Complete chain of custody and submit with samples. For questions regarding individual parameter holding times, chemical and thermal preservation and sample volumes please refer to our sample preservation guide on our website at www.mvtl.com or by contacting customer service at 1-800-782-3557. If samples show signs of contamination, inadequate preservation or are in any way compromised you will be contacted as to whether to proceed with analysis or submit a new sample.

Please submit the top copy with your samples. We will return the completed original with your results.

Form # 10-90053-0

See above for page number

Effective Date: 26 Feb 2021

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Thursday, March 28, 2024 4:08:13 PM

Page 9 of 16



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com



Workorder: Delano High School (43069)

Client: Resource Training & Solutions



Minnesota Valley Testing Laboratories, Inc.
1126 North Front Street, Building 2
New Ulm, MN 56073

Phone: (507) 354-8517
Fax: (507) 359-2890

Toll Free: (800) 782-3557

Company Name and Address:

Resource Training and Solutions
137 23rd Street South Suite 201
Sartell MN 56377

Account #: 19442 Phone #: 3202553236 x316

Billing Address (indicate if different from above):

Resource Training and Solutions
137 23rd Street South Suite 201
Sartell MN 56377

Lab Use Only

Chain of Custody Record
Page ____ of ____

Work Order # 43009

Email: jbaumann@resourcecoop-mn.gov

Contact (Report to): Josh Baumann

Name of Samplers:

Quote Number

Project Name/Number: Delano High School

Purchase Order #:

Date Submitted:

Transferred by: Date: Time: Sample Condition: Received by: Date: Time: Temp:

1.

2.

Comments:

Sample Information

Sample Type Codes: Drinking Water = DW, Groundwater = GW, Stormwater = ST, Surface Water = SW, Wastewater = WW, Solid = S, Compost = C

Lab Use Only	F= Fountain S= Sink B= Bottle Filler K= Kettle Describe any others	Sample ID	Room/Location/Fixture	Sample Type	Date Sampled	Time Sampled	Number of Bottles	Analysis
11	DHS11	D.S.	locker T108	DW	3/8	7:30		LEAD
12	DHS12	D.S.	locker T110	DW	3/8			LEAD
13	DHS13	D.S.	locker T111	DW	3/8			LEAD
14	DHS14	D.S.	By event Bathroom	DW	3/8			LEAD
15	DHS15	D.S.	By truck Bottle	DW	3/8			LEAD
16	DHS16	D.S.	By truck Bottle	DW	3/8			LEAD
17	DHS17	D.S.	By Washing Machine	DW	3/8			LEAD
18	DHS18	Break Room	130	DW	3/8			LEAD
19	DHS19	D.S.	white By 133	DW	3/8			LEAD
20	DHS20	D.S.	Tiger del	DW	3/8	7:45		LEAD

Enclosed are your containers for your sampling event. Completely fill and label containers appropriately for the analyses to be conducted. Complete chain of custody and submit with samples. For questions regarding individual parameter holding times, chemical and thermal preservation and sample volumes please refer to our sample preservation guide on our website at www.mvlt.com or by contacting customer service at 1-800-782-3557. If samples show signs of contamination, inadequate preservation or are in any way compromised you will be contacted as to whether to proceed with analysis or submit a new sample.

Form # 10-90053-0

Please submit the top copy with your samples. We will return the completed original with your results.

See above for page number

Effective Date: 26 Feb 2021

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Thursday, March 28, 2024 4:08:13 PM

Page 10 of 16



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Member
ACIL

Workorder: Delano High School (43069)

Client: Resource Training & Solutions



Minnesota Valley Testing Laboratories, Inc.
1126 North Front Street, Building 2
New Ulm, MN 56073

Phone: (507) 354-8517

Toll Free: (800) 782-3557 Fax: (507) 359-2890

Company Name and Address:

Resource Training and Solutions
137 23rd Street South Suite 201
Sartell MN 56377

Account #: 19442 Phone #: 3202553236 x316

Billing Address (indicate if different from above):

Resource Training and Solutions
137 23rd Street South Suite 201
Sartell MN 56377

Lab Use Only

Chain of Custody Record
Page ____ of ____

Work Order # **43069**

Email: **jbaumann@resourcecoop-mn.gov**

Josh Baumann

Contact (Report to):

Martina Lora 612.212.3915

Name of Samplers:

Martina Lora

June 3

Quote Number

Project Name/Number:

Delano High School

Date Submitted:

Purchase Order #:

Transferred by:

Date:

Time:

Sample Condition:

Received by:

Date:

Time:

Temp:

1.

2.

Comments:

Sample Information

Sample Type Codes: Drinking Water = DW, Groundwater = GW, Stormwater = ST, Surface Water = SW, Wastewater = WW, Solid = S, Compost = C

Lab Use Only	F= Fountain S= Sink B= Bottle Filler K= Kettle Describe any others						
Lab #	Sample ID Room/Location/Fixture	Sample Type	Date Sampled	Time Sampled	Number of Bottles	Analysis	
21	DHS21 D.S. white Bg 335	DW	3/8	7:50 am	1	LEAD	
22	DHS22 D.S. Bottle Bg 332	DW	3/8		1	LEAD	
23	DHS23 D.S. Bottle Bg 4/aring	DW	3/8		1	LEAD	
24	DHS24 D.S. Nickel Bg 4/aring	DW	3/8		1	LEAD	
25	DHS25 FACS yellow kitchen	DW	3/8		1	LEAD	
26	DHS26 FACS orange kitchen	DW	3/8		1	LEAD	
27	DHS27 FACS Red kitch	DW	3/8		1	LEAD	
28	DHS28 FACS green kitchen	DW	3/8		1	LEAD	
29	DHS29 FACS blue kitchen	DW	3/8		1	LEAD	
30	DHS30 FACS Rattle kitchen	DW	3/8	8:10 am	1	LEAD	

Enclosed are your containers for your sampling event. Completely fill and label containers appropriately for the analyses to be conducted. Complete chain of custody and submit with samples. For questions regarding individual parameter holding times, chemical and thermal preservation and sample volumes please refer to our sample preservation guide on our website at www.mvttl.com or by contacting customer service at 1-800-782-3557. If samples show signs of contamination, inadequate preservation or are in any way compromised you will be contacted as to whether to proceed with analysis or submit a new sample.

Form # 10-90053-0

Please submit the top copy with your samples. We will return the completed original with your results.
See above for page number

Effective Date: 26 Feb 2021

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Thursday, March 28, 2024 4:08:13 PM

Page 11 of 16



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Member
ACIL

Workorder: Delano High School (43069)

Client: Resource Training & Solutions



Minnesota Valley Testing Laboratories, Inc.
1126 North Front Street, Building 2
New Ulm, MN 56073

Phone: (507) 354-8517

Toll Free: (800) 782-3557 Fax: (507) 359-2890

Company Name and Address:

Resource Training and Solutions
137 23rd Street South Suite 201
Sartell MN 56377

Account #: 19442 Phone #: 3202553236 x316

Billing Address (indicate if different from above):

Resource Training and Solutions
137 23rd Street South Suite 201
Sartell MN 56377

Chain of Custody Record Page ____ of ____	
Work Order # <u>43069</u>	
Email: <u>jbaumann@resourcecoop-mn.gov</u>	
Contact (Report to): <u>Josh Baumann</u>	
Name of Samplers: <u>Marta Lara</u>	
Quote Number: <u>2024</u>	
Project Name/Number: <u>Delano High School</u>	
Purchase Order #:	
Transferred by: <u>Marta Lara</u>	Date: <u>3-12</u> Time: <u>7:26am</u>
Sample Condition: <u>Lead</u>	Received by: <u>Marta Lara</u> Date: <u>3-12</u> Time: <u>7:26am</u> Temp: <u>72</u>

Comments:

Sample Information

Sample Type Codes: Drinking Water = DW, Groundwater = GW, Stormwater = ST, Surface Water = SW, Wastewater = WW, Solid = S, Compost = C

Lab Use Only	F= Fountain S= Sink B= Bottle Filler K= Kettle Describe any others	Sample ID	Room/Location/Fixture	Sample Type	Date Sampled	Time Sampled	Number of Bottles	Analysis
31		DHS31	Band Room Fountain	DW	3-12	7:26am	1	LEAD
32		DHS32	Band hallway Fountain	DW	3-12	7:28am	1	LEAD
33		DHS33	Hallway between doors 10-11	DW	3-12	7:29am	1	LEAD
34		DHS34	Fountain left side by science building	DW	3-12	7:26	1	LEAD
35		DHS35	Fountain Rt side H.S. bathroom	DW	3-12	7:26	1	LEAD
36		DHS36	Fountain H.S. Hall Rt side	DW	3-12	7:30	1	LEAD
37		DHS37	Fountain in Pool Area	DW	3-12	7:33	1	LEAD
38		DHS38	Wrestling Room Fountain	DW	3-12	7:36	1	LEAD
39		DHS39	Boys locker room H.S. Fountain	DW	3-12	7:36	1	LEAD
		DHS40		DW				LEAD

Enclosed are your containers for your sampling event. Completely fill and label containers appropriately for the analyses to be conducted. Complete chain of custody and submit with samples. For questions regarding individual parameter holding times, chemical and thermal preservation and sample volumes please refer to our sample preservation guide on our website at www.mvtl.com or by contacting customer service at 1-800-782-3557. If samples show signs of contamination, inadequate preservation or are in any way compromised you will be contacted as to whether to proceed with analysis or submit a new sample.

Form # 10-90053-0

Please submit the top copy with your samples. We will return the completed original with your results.

See above for page number

Effective Date: 26 Feb 2021

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Thursday, March 28, 2024 4:08:13 PM

Page 12 of 16



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com



Workorder: Delano High School (43069)

Client: Resource Training & Solutions



Minnesota Valley Testing Laboratories, Inc.
1126 North Front Street, Building 2
New Ulm, MN 56073

Phone: (507) 354-8517

Toll Free: (800) 782-3557 Fax: (507) 359-2890


Company Name and Address:

Resource Training and Solutions
137 23rd Street South Suite 201
Sartell MN 56377

Account #: 19442 Phone #: 3202553236 x316

Billing Address (indicate if different from above):

Resource Training and Solutions
137 23rd Street South Suite 201
Sartell MN 56377



Chain of Custody Record
Page ____ of ____

Work Order #

Email:

jbaumann@resourcecoop-mn.gov

Contact (Report to):

Josh Baumann

Name of Samplers:

Quote Number

Date Submitted:

Project Name/Number:

Purchase Order #:

Delano High School

Transferred by:

Date:

Time:

Sample Condition:

Received by:

Date:

Time:

Temp:

1.

2.

Comments:

Sample Information

Sample Type Codes: Drinking Water = DW, Groundwater = GW, Stormwater = ST, Surface Water = SW, Wastewater = WW, Solid = S, Compost = C

Lab Use Only	F= Fountain S= Sink B= Bottle Filler K= Kettle Describe any others						
Lab #	Sample ID Room/Location/Fixture	Sample Type	Date Sampled	Time Sampled	Number of Bottles	Analysis	
	DHS41	DW				LEAD	
	DHS42	DW				LEAD	
	DHS43	DW				LEAD	
	DHS44	DW				LEAD	
	DHS45	DW				LEAD	
	DHS46	DW				LEAD	
	DHS47	DW				LEAD	
	DHS48	DW				LEAD	
	DHS49	DW				LEAD	
		DW				LEAD	

Enclosed are your containers for your sampling event. Completely fill and label containers appropriately for the analyses to be conducted. Complete chain of custody and submit with samples. For questions regarding individual parameter holding times, chemical and thermal preservation and sample volumes please refer to our sample preservation guide on our website at www.mvttl.com or by contacting customer service at 1-800-782-3557. If samples show signs of contamination, inadequate preservation or are in any way compromised you will be contacted as to whether to proceed with analysis or submit a new sample.

Form # 10-90053-0

Please submit the top copy with your samples. We will return the completed original with your results.

See above for page number

Effective Date: 26 Feb 2021

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Thursday, March 28, 2024 4:08:13 PM

Page 13 of 16



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com



Workorder: Delano High School (43069)

Client: Resource Training & Solutions



Minnesota Valley Testing Laboratories, Inc.
1126 North Front Street, Building 2
New Ulm, MN 56073

Phone: (507) 354-8517

Toll Free: (800) 782-3557 Fax: (507) 359-2890

Company Name and Address:

Resource Training and Solutions
137 23rd Street South Suite 201
Sartell MN 56377

Account #: 19442 Phone #: 3202553236 x316

Billing Address (indicate if different from above):

Resource Training and Solutions
137 23rd Street South Suite 201
Sartell MN 56377

Lab Use Only			Chain of Custody Record						
			Page ____ of ____						
Contact (Report to):			Work Order #						
			Email: jbaumann@resourcecoop-mn.gov						
Name of Samplers:			Josh Baumann						
Quote Number			Date Submitted:						
			Purchase Order #:						
Project Name/Number: Delano High School									
Transferred by:		Date:	Time:	Sample Condition:	Received by:	Date:	Time:	Temp:	
1.									
2.									

Comments:

Sample Information

Sample Type Codes: Drinking Water = DW, Groundwater = GW, Stormwater = ST, Surface Water = SW, Wastewater = WW, Solid = S, Compost = C

Lab Use Only	F= Fountain S= Sink B= Bottle Filler K= Kettle Describe any others						
Lab #	Sample ID Room/Location/Fixture	Sample Type	Date Sampled	Time Sampled	Number of Bottles	Analysis	
	DHS	DW				LEAD	
	DHS	DW				LEAD	
	DHS	DW				LEAD	
	DHS	DW				LEAD	
	DHS	DW				LEAD	
	DHS	DW				LEAD	
	DHS	DW				LEAD	
	DHS	DW				LEAD	
	DHS	DW				LEAD	
	DHS	DW				LEAD	

Enclosed are your containers for your sampling event. Completely fill and label containers appropriately for the analyses to be conducted. Complete chain of custody and submit with samples. For questions regarding individual parameter holding times, chemical and thermal preservation and sample volumes please refer to our sample preservation guide on our website at www.mvtl.com or by contacting customer service at 1-800-782-3557. If samples show signs of contamination, inadequate preservation or are in any way compromised you will be contacted as to whether to proceed with analysis or submit a new sample.

Form # 10-90053-0

Please submit the top copy with your samples. We will return the completed original with your results.

See above for page number

Effective Date: 26 Feb 2021

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Thursday, March 28, 2024 4:08:13 PM

Page 14 of 16

MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com



Workorder: Delano High School (43069)

Client: Resource Training & Solutions

1. Samples to be collected as a "first draw" mean that the sample should be taken prior to water being drawn or flushed from the fixture. The minimum contact time for the water to sit idle in the plumbing system is six hours or a maximum of 18 hours.
2. Flush water sample locations one day prior to or a minimum of six hours before the actual draw day.
3. Collect a sample by filling bottle to neck. Note: Initiate sampling at taps closest to where the water enters the building and work your way outward to prevent accidental flushing.
4. Fill out lab for sample and the chain of custody. (further instructions below)

SCHOOL DISTRICT WATER DRAW INSTRUCTIONS

High School

Minnesota Valley Testing Laboratories, Inc.

Chain of Custody Record
16. Page 1 of 1

1126 North From Street
New Ulm, MN 56073

Phone: (957) 554-8577

Work Order #

Lab Name: (800) 782-7626

Fax: (957) 556-2900

Account #:

Email: lab@mvt-lab.com

Company Name and Address:

Resource: Trainline and Solidos

Phone #: 320-953-2338 x. 316

132 2nd St South Suite 201

Start Here

Contact Report to:

Sartell, MN 55577

Contract Report to:

300 S. Main St
Sartell, MN 55577

Billing Address: (Indicate if different from above):

1. Sample's Signature transferred by: *John Doe*

Date:

Time:

Temp:

2. Comments:

Date:

Time:

Temp:

3. Sample's Signature transferred by:

Date:

Time:

Temp:

4. Sample's Signature transferred by:

Date:

Time:

Temp:

5. Sample's Signature transferred by:

Date:

Time:

Temp:

6. Sample's Signature transferred by:

Date:

Time:

Temp:

7. Sample's Signature transferred by:

Date:

Time:

Temp:

8. Sample's Signature transferred by:

Date:

Time:

Temp:

9. Sample's Signature transferred by:

Date:

Time:

Temp:

10. Sample's Signature transferred by:

Date:

Time:

Temp:

11. Sample's Signature transferred by:

Date:

Time:

Temp:

12. Sample's Signature transferred by:

Date:

Time:

Temp:

13. Sample's Signature transferred by:

Date:

Time:

Temp:

14. Sample's Signature transferred by:

Date:

Time:

Temp:

15. Sample's Signature transferred by:

Date:

Time:

Temp:

16. Sample's Signature transferred by:

Date:

Time:

Temp:

17. Sample's Signature transferred by:

Date:

Time:

Temp:

18. Sample's Signature transferred by:

Date:

Time:

Temp:

19. Sample's Signature transferred by:

Date:

Time:

Temp:

20. Sample's Signature transferred by:

Date:

Time:

Temp:

21. Sample's Signature transferred by:

Date:

Time:

Temp:

22. Sample's Signature transferred by:

Date:

Time:

Temp:

23. Sample's Signature transferred by:

Date:

Time:

5. Repeat Steps 3 and 4 until finished.
6. Get to lab within 10 days of water being collected. If possible schedule water pulls a couple days prior to Resource Specialist's visits, as we have reduced shipping option.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Thursday, March 28, 2024 4:08:13 PM

Page 15 of 16

**MINNESOTA VALLEY TESTING LABORATORIES, INC.**

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com

Member
ACIL

Workorder: Delano High School (43069)**Client:** Resource Training & Solutions

MVTL LABORATORIES, Inc. 1-800-782-3557

Date: 14 MAR 24 Time: 1400 ☐ AM ☒ PM

Account Name: Resource Training and Solutions - DHS By: SS

Account #: 19442

II of Lading #: _____ Cooler #: _____

Temp: 22.0 °C ROJ ☐ Ambient ☒ Tracking #: _____

TM#: 771 Ice Crystals Present in Sample ☐

MVTL Courier: Dan Other: _____

MVTL Route: metro Walk-In ☐ UPS Air ☐ FedEx Air ☐ Speedee ☐

Mall ☐ UPS Ground ☐ FedEx Ground ☐

Containers Supplied by MVTL: Yes ☒ No ☐ Designate customer supplied containers as "Other" in container size column

Comments	Containers Size (mL)	Container Type	Preservation	pH
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	NaHSO ₄ Na ₂ O ₃ S ₂ NONE HNO ₃ H ₂ SO ₄ NaOH HCl SUB*	<2 >9 >12 N/A Add
39	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	NaHSO ₄ Na ₂ O ₃ S ₂ NONE HNO ₃ H ₂ SO ₄ NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	NaHSO ₄ Na ₂ O ₃ S ₂ NONE HNO ₃ H ₂ SO ₄ NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	NaHSO ₄ Na ₂ O ₃ S ₂ NONE HNO ₃ H ₂ SO ₄ NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	NaHSO ₄ Na ₂ O ₃ S ₂ NONE HNO ₃ H ₂ SO ₄ NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	NaHSO ₄ Na ₂ O ₃ S ₂ NONE HNO ₃ H ₂ SO ₄ NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	NaHSO ₄ Na ₂ O ₃ S ₂ NONE HNO ₃ H ₂ SO ₄ NaOH HCl SUB*	<2 >9 >12 N/A Add
	(100) (120) (125) (250) (290) (500) (1000) Other	(G) (P) (AG) (AP)	NaHSO ₄ Na ₂ O ₃ S ₂ NONE HNO ₃ H ₂ SO ₄ NaOH HCl SUB*	<2 >9 >12 N/A Add
DO NOT OPEN THE PLASTIC BAGS HOLDING THE SAMPLE BOTTLES!				
Low Level Mercury Kit		Clear Amber	MeOH None	n/a
4 oz Jar		Clear Amber	MeOH None	n/a
2 oz Jar		Clear Amber	HCl H ₃ PO ₄ H ₂ SO ₄ None	n/a
Vials Individual Set of 2 Set of 3		Clear Amber	HCl H ₃ PO ₄ H ₂ SO ₄ None	n/a
Vials Individual Set of 2 Set of 3		Clear Amber	HCl H ₃ PO ₄ H ₂ SO ₄ None	n/a
Trip Blank Individual Set of 2 Set of 3				n/a
Moisture Vial				n/a
Manure Bottle				n/a

ANY CONTAINER SENT TO A SUBCONTRACT LABORATORY WILL NOT BE CHECKED FOR PRESERVATION!

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Thursday, March 28, 2024 4:08:13 PM

Page 16 of 16



**Minnesota Department of Health
Environmental Laboratory Accreditation Program**



Issues accreditation to

State Laboratory ID: 027-015-125

EPA Lab Code: MN00008

Minnesota Valley Testing Laboratories, Inc.

1126 N Front St

New Ulm, MN 56073

**for fields of accreditation listed on the laboratory's accompanying Scope of Certification
in accordance with the provisions in Minnesota Laws and Rules.**

Continued accreditation is contingent upon successful on-going compliance with Minnesota Statutes 144.97 to 144.98, 2016 TNI Standard and applicable Minnesota Rules 4740.2010 to 4740.2120. The laboratory's Scope of Certification cites the specific programs, methods, analytes and matrices for which MDH issues this accreditation.

This certificate is valid proof of accreditation only when associated with its accompanying Scope of Certification.

**The Scope of Certification and reports of on-site assessments are on file at the Minnesota Department of Health,
601 Robert Street North, Saint Paul, Minnesota. Customers may verify the laboratory's accreditation status in
Minnesota by contacting MNELAP at (651) 201-5324.**

Effective Date: 12/01/2023

Expires: 12/31/2024

Certificate Number: 2603495

**Issued under the authority
delegated by the
Commissioner of Health,
State of Minnesota**