

Lead in School Drinking Water Report

Discovery Primary School



EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreekids@doh.wa.gov.

DEFINITIONS

Fixture Housing
Location

Room/space where
fixture is located
(i.e. room number,
gym, playground)

Fixture Housing Type

Structure that contains
the individual fixtures
where water samples
were collected from.
Fixture housing may
contain one or more
individual fixture for
sampling.

Fixture Location
Details

Location within a
room or space where
fixture housing is
located, starting to the
left of the entrance and
rotating clockwise, of
the total number of
fixture housings in a
room or space
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water
Fountain, Water Bottle
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2026-03-24

Date(s) analyzed: 2026-03-31, 2026-04-01, 2026-04-03

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	419746	2026-03-24	Main Building K-1	Fountain Tap Combo	Room 201	1 of 1	Tap	center	82
2	419726	2026-03-24	Main Building K-1	Fountain Tap Combo	Room 223	1 of 1	Tap	center	79
3	419766	2026-03-24	Main Building K-1	Fountain Tap Combo	Room 108	1 of 1	Water Fountain	right	73
4	419756	2026-03-24	Main Building K-1	Fountain Tap Combo	Room 104	1 of 1	Tap	center	71
5	419765	2026-03-24	Main Building K-1	Fountain Tap Combo	Room 108	1 of 1	Tap	center	70
6	419722	2026-03-24	Main Building K-1	Fountain Tap Combo	Room 227	1 of 1	Tap	center	69
7	419758	2026-03-24	Main Building K-1	Fountain Tap Combo	Room 103	1 of 1	Tap	center	67
8	419728	2026-03-24	Main Building K-1	Fountain Tap Combo	Room 221	1 of 1	Tap	center	66
9	419733	2026-03-24	Main Building K-1	Fountain Tap Combo	Room 217	1 of 1	Tap	center	66
10	419736	2026-03-24	Main Building K-1	Fountain Tap Combo	Room 215	1 of 1	Water Fountain	right	64

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
11	419739	2026-03-24	Main Building K-1	Fountain Tap Combo	Room 207	1 of 1	Tap	center	61
12	419762	2026-03-24	Main Building K-1	Fountain Tap Combo	Room 105	1 of 1	Tap	center	61
13	419735	2026-03-24	Main Building K-1	Fountain Tap Combo	Room 215	1 of 1	Tap	center	59
14	419751	2026-03-24	Main Building K-1	Fountain Tap Combo	Room 100	1 of 1	Tap	center	57
15	419769	2026-03-24	Main Building K-1	Fountain Tap Combo	Room 112	1 of 1	Tap	center	56
16	419725	2026-03-24	Main Building K-1	Fountain Tap Combo	Room 225	1 of 1	Water Fountain	right	55
17	419724	2026-03-24	Main Building K-1	Fountain Tap Combo	Room 225	1 of 1	Tap	center	53
18	419747	2026-03-24	Main Building K-1	Fountain Tap Combo	Room 201	1 of 1	Water Fountain	right	45
19	419741	2026-03-24	Main Building K-1	Fountain Tap Combo	Room 205	1 of 1	Tap	center	44
20	419775	2026-03-24	Main Building K-1	Fountain Tap Combo	Room 118	1 of 1	Tap	center	43
21	419737	2026-03-24	Main Building K-1	Fountain Tap Combo	Room 209	1 of 1	Tap	center	42

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
22	419745	2026-03-24	Main Building K-1	Fountain Tap Combo	Room 203	1 of 1	Water Fountain	right	42
23	419773	2026-03-24	Main Building K-1	Fountain Tap Combo	Room 116	1 of 1	Tap	center	42
24	419744	2026-03-24	Main Building K-1	Fountain Tap Combo	Room 203	1 of 1	Tap	center	41
25	419772	2026-03-24	Main Building K-1	Fountain Tap Combo	Room 114	1 of 1	Water Fountain	right	41
26	419768	2026-03-24	Main Building K-1	Fountain Tap Combo	Room 110	1 of 1	Water Fountain	right	40
27	419767	2026-03-24	Main Building K-1	Fountain Tap Combo	Room 110	1 of 1	Tap	center	38
28	419740	2026-03-24	Main Building K-1	Fountain Tap Combo	Room 207	1 of 1	Water Fountain	right	36
29	419729	2026-03-24	Main Building K-1	Fountain Tap Combo	Room 221	1 of 1	Water Fountain	right	34
30	419763	2026-03-24	Main Building K-1	Fountain Tap Combo	Room 105	1 of 1	Water Fountain	right	31
31	419771	2026-03-24	Main Building K-1	Fountain Tap Combo	Room 114	1 of 1	Tap	center	31
32	419742	2026-03-24	Main Building K-1	Fountain Tap Combo	Room 205	1 of 1	Water Fountain	right	30

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
33	419759	2026-03-24	Main Building K-1	Fountain Tap Combo	Room 103	1 of 1	Water Fountain	right	30
34	419734	2026-03-24	Main Building K-1	Fountain Tap Combo	Room 217	1 of 1	Water Fountain	right	29
35	419770	2026-03-24	Main Building K-1	Fountain Tap Combo	Room 112	1 of 1	Water Fountain	right	28
36	419731	2026-03-24	Main Building K-1	Fountain Tap Combo	Room 219	1 of 1	Tap	center	27
37	419753	2026-03-24	Main Building K-1	Fountain Tap Combo	Room 102	1 of 1	Tap	center	24
38	419730	2026-03-24	Main Building K-1	Fountain Tap Combo	Moon Room	1 of 1	Tap	center	23
39	419738	2026-03-24	Main Building K-1	Fountain Tap Combo	Room 209	1 of 1	Water Fountain	right	23
40	419774	2026-03-24	Main Building K-1	Fountain Tap Combo	Room 116	1 of 1	Water Fountain	right	23
41	419732	2026-03-24	Main Building K-1	Fountain Tap Combo	Room 219	1 of 1	Water Fountain	right	20
42	419754	2026-03-24	Main Building K-1	Fountain Tap Combo	Room 102	1 of 1	Water Fountain	right	20
43	419721	2026-03-24	Main Building K-1	Sink	Kitchen	Kitchen	Tap	center	19

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
44	419727	2026-03-24	Main Building K-1	Fountain Tap Combo	Room 223	1 of 1	Water Fountain	right	19
45	419776	2026-03-24	Main Building K-1	Fountain Tap Combo	Room 118	1 of 1	Water Fountain	right	19
46	419757	2026-03-24	Main Building K-1	Fountain Tap Combo	Room 104	1 of 1	Water Fountain	right	18
47	419723	2026-03-24	Main Building K-1	Fountain Tap Combo	Room 227	1 of 1	Water Fountain	right	15
48	419761	2026-03-24	Main Building K-1	Sink	Nurses Office	1 of 1	Tap	center	15
49	419760	2026-03-24	Main Building K-1	Sink	Staff Lounge	1 of 1	Tap	center	14
50	419743	2026-03-24	Main Building K-1	Fountain	Fountain Next To Room 205	1 of 1	Water Fountain	left	8
51	419764	2026-03-24	Main Building K-1	Fountain	Hallway Across From Library	1 of 1	Water Fountain	right	6
52	419749	2026-03-24	Portable A/B	Fountain Tap Combo	Room A	1 of 1	Tap	center	5
53	419752	2026-03-24	Main Building K-1	Fountain Tap Combo	Room 100	1 of 1	Water Fountain	right	5
54	419750	2026-03-24	Portable A/B	Fountain Tap Combo	Room B	1 of 1	Tap	center	4

.	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
55	419755	2026-03-24	Main Building K-1	Fountain	Fountain Outside Of Room 104	1 of 1	Water Fountain	right	4
56	419748	2026-03-24	Portable C/D	Sink	Kitchen	1 of 1	Tap	center	2
57	419720	2026-03-24	Main Building K-1	Fountain	Hallway Outside Of Music Room	1 of 1	Water Fountain	left	<1