

Lead in School Drinking Water Report

Hedden Elementary School



EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreekids@doh.wa.gov.

DEFINITIONS

Fixture Housing
Location

Room/space where
fixture is located
(i.e. room number,
gym, playground)

Fixture Housing Type

Structure that contains
the individual fixtures
where water samples
were collected from.
Fixture housing may
contain one or more
individual fixture for
sampling.

Fixture Location
Details

Location within a
room or space where
fixture housing is
located, starting to the
left of the entrance and
rotating clockwise, of
the total number of
fixture housings in a
room or space
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water
Fountain, Water Bottle
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2026-03-11

Date(s) analyzed: 2026-03-17

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	419049	2026-03-11	Main Building	Sink	Workroom 117	1 of 1	Tap	center	40
2	419064	2026-03-11	Main Building	Fountain Tap Combo	Room 407	1 of 1	Water Fountain	right	10
3	419055	2026-03-11	Main Building	Fountain Tap Combo	Blue Pod	2 of 2. Kitchenette	Water Fountain	left	8
4	419060	2026-03-11	Main Building	Fountain Tap Combo	Room 129	1 of 1	Water Fountain	right	8
5	419065	2026-03-11	Main Building	Fountain Tap Combo	Room 409	1 of 1	Water Fountain	right	8
6	419058	2026-03-11	Main Building	Fountain - Multi-level	Hallway Next To Storage 124	1 of 1	Water Fountain	left	6
7	419042	2026-03-11	Main Building	Fountain Tap Combo	Room 210	1 of 1	Water Fountain	right	4
8	419046	2026-03-11	Main Building	Fountain - Multi-level	Hallway Outside Of Office. East Main Hallway	1 of 1	Water Fountain	right	4
9	419070	2026-03-11	Main Building	Fountain Tap Combo	Music Room 501	1 of 1	Water Fountain	right	4
10	419048	2026-03-11	Main Building	Fountain Tap Combo	Room 120	1 of 1	Water Fountain	right	3

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
11	419050	2026-03-11	Main Building	Fountain Tap Combo	Blue Pod	1 of 2. Lower sink	Water Fountain	right	3
12	419056	2026-03-11	Main Building	Fountain Tap Combo	Room 306	1 of 1	Water Fountain	right	3
13	419045	2026-03-11	Main Building	Fountain - Multi-level	Hallway Outside Of Office. East Main Hallway	1 of 1	Water Fountain	left	2
14	419047	2026-03-11	Main Building	Sink - Multi-compartment	Staff Lounge	1 of 1	Tap	center	2
15	419051	2026-03-11	Main Building	Fountain Tap Combo	Room 307	1 of 1	Water Fountain	right	2
16	419054	2026-03-11	Main Building	Fountain Tap Combo	Room 308	1 of 1	Water Fountain	right	2
17	419057	2026-03-11	Main Building	Fountain Tap Combo	Room 305	1 of 1	Water Fountain	right	2
18	419061	2026-03-11	Main Building	Fountain Tap Combo	Room 129	1 of 1	Water Fountain	left	2
19	419062	2026-03-11	Main Building	Sink	Kitchen	1 of 1	Tap	center	2
20	419063	2026-03-11	Main Building	Fountain Tap Combo	Yellow Pod	1 of 1	Water Fountain	right	2
21	419067	2026-03-11	Main Building	Fountain Tap Combo	Room 408	1 of 1	Water Fountain	right	2

.	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
22	419040	2026-03-11	Main Building	Sink	Nurses Office	1 of 1	Tap	center	1
23	419043	2026-03-11	Main Building	Fountain Tap Combo	Room 208	1 of 1	Water Fountain	right	1
24	419052	2026-03-11	Main Building	Fountain Tap Combo	Room 309	1 of 1	Water Fountain	right	1
25	419059	2026-03-11	Main Building	Fountain - Multi-level	Hallway Next To Storage 124	1 of 1	Water Fountain	right	1
26	419068	2026-03-11	Main Building	Fountain Tap Combo	Room 405	1 of 1	Water Fountain	right	1
27	419041	2026-03-11	Main Building	Fountain Tap Combo	Room 209	1 of 1	Water Fountain	right	<1
28	419044	2026-03-11	Main Building	Fountain Tap Combo	Room 206	1 of 1	Water Fountain	right	<1
29	419053	2026-03-11	Main Building	Fountain Tap Combo	Room 310	1 of 1	Water Fountain	right	<1
30	419066	2026-03-11	Main Building	Fountain Tap Combo	Room 410	1 of 1	Water Fountain	right	<1
31	419069	2026-03-11	Main Building	Fountain - Multi-level	Hallway Next To Custodian 158	1 of 1	Water Fountain	right	<1