

Lead in School Drinking Water Report

Fife High School



EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreekids@doh.wa.gov.

DEFINITIONS

Fixture Housing
Location

Room/space where
fixture is located
(i.e. room number,
gym, playground)

Fixture Housing Type

Structure that contains
the individual fixtures
where water samples
were collected from.
Fixture housing may
contain one or more
individual fixture for
sampling.

Fixture Location
Details

Location within a
room or space where
fixture housing is
located, starting to the
left of the entrance and
rotating clockwise, of
the total number of
fixture housings in a
room or space
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water
Fountain, Water Bottle
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2026-03-21

Date(s) analyzed: 2026-03-31, 2026-04-03

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	419714	2026-03-21	Building V 500 Main	Sink	Staff Lounge	1 of 2	Tap	center	33
2	419690	2026-03-21	Building VII 700 Cafeteria	Pot Filler	Kitchen	2 of 3	Tap	center	10
3	419716	2026-03-21	Building V 500 Main	Fountain	Hallway Next To Room 508	1 of 1	Water Fountain	right	8
4	419682	2026-03-21	Building VI 600 Gyms	Sink	Concessions	1 of 1	Tap	center	6
5	419684	2026-03-21	Building VI 600 Gyms	Sink	Training Room	2 of 2	Tap	center	6
6	419694	2026-03-21	Building IV 400 Library	Sink	Room 408	1 of 1	Tap	center	6
7	419688	2026-03-21	Building VI 600 Gyms	Fountain	Cafeteria	1 of 1	Water Fountain	right	5
8	419715	2026-03-21	Building V 500 Main	Sink - Multi-compartment	Staff Lounge	2 of 2	Tap	center	5
9	419717	2026-03-21	Building V 500 Main	Sink	Room 521	1 of 1	Tap	center	5
10	419692	2026-03-21	Building VII 700 Cafeteria	Ice Machine	Snack Bar	1 of 1	Ice Machine	center	4

.	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
11	419695	2026-03-21	Building IV 400 Library	Sink	Room 402	1 of 1	Tap	center	4
12	419696	2026-03-21	Building IV 400 Library	Sink	Room 401	1 of 1	Tap	center	4
13	419697	2026-03-21	Building IV 400 Library	Fountain	Hallway Next To Room 401	1 of 1	Water Fountain	right	4
14	419709	2026-03-21	Building V 500 Main	Sink	Mail Room	1 of 1	Tap	center	4
15	419687	2026-03-21	Building VI 600 Gyms	Sink	Room 601	1 of 1	Tap	center	3
16	419702	2026-03-21	Building IV 400 Library	Sink - Multi-compartment	Room 403	5 of 7. Station 4	Tap	center	3
17	419718	2026-03-21	Building VIII 800 Shop	Fountain	Foyer	1 of 1	Water Fountain	right	3
18	419719	2026-03-21	Building X Stadium	Sink	Concessions	1 of 1	Tap	center	3
19	419689	2026-03-21	Building VII 700 Cafeteria	Sink	Kitchen	1 of 3. Closest to room 752	Tap	center	2
20	419691	2026-03-21	Building VII 700 Cafeteria	Sink	Kitchen	3 of 3	Tap	center	2

.	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
21	419693	2026-03-21	Building IV 400 Library	Sink	Library Office	1 of 1	Tap	center	2
22	419698	2026-03-21	Building IV 400 Library	Sink - Multi-compartment	Room 403	1 of 7. Demons tration sink	Tap	center	2
23	419710	2026-03-21	Building V 500 Main	Sink	Work Room 591	1 of 1	Tap	center	2
24	419713	2026-03-21	Building V 500 Main	Sink	Nurses Office	1 of 1	Tap	center	2
25	419699	2026-03-21	Building IV 400 Library	Sink - Multi-compartment	Room 403	2 of 7. Station 1	Tap	center	1
26	419700	2026-03-21	Building IV 400 Library	Sink - Multi-compartment	Room 403	3 of 7. Station 2	Tap	center	1
27	419701	2026-03-21	Building IV 400 Library	Sink - Multi-compartment	Room 403	4 of 7. Station 3	Tap	center	1
28	419704	2026-03-21	Building IV 400 Library	Sink - Multi-compartment	Room 403	7 of 7. Station 6	Tap	center	1
29	419705	2026-03-21	Building IV 400 Library	Sink	Room 405	1 of 1	Tap	center	1
30	419680	2026-03-21	Building VI 600 Gyms	Fountain With Bottle Filler	West Entrance Hallway	1 of 1	Water Bottle Filler	center	<1

	Sample ID	Sample Collected Date	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
31	419681	2026-03-21	Building VI 600 Gyms	Fountain With Bottle Filler	West Entrance Hallway	1 of 1	Water Fountain	right	<1
32	419683	2026-03-21	Building VI 600 Gyms	Ice Machine	Training Room	1 of 2	Ice Machine	center	<1
33	419685	2026-03-21	Building VI 600 Gyms	Fountain - Multi-level	Weight Room	1 of 1	Water Fountain	left	<1
34	419686	2026-03-21	Building VI 600 Gyms	Fountain - Multi-level	Weight Room	1 of 1	Water Fountain	right	<1
35	419703	2026-03-21	Building IV 400 Library	Sink - Multi-compartment	Room 403	6 of 7. Station 5	Tap	center	<1
36	419706	2026-03-21	Building IV 400 Library	Sink - Multi-compartment	Resource Center	1 of 1	Tap	center	<1
37	419707	2026-03-21	Building IV 400 Library	Fountain With Bottle Filler	Hallway Next To Room 404	1 of 1	Water Bottle Filler	center	<1
38	419708	2026-03-21	Building IV 400 Library	Fountain With Bottle Filler	Hallway Next To Room 404	1 of 1	Water Fountain	right	<1
39	419711	2026-03-21	Building V 500 Main	Fountain With Bottle Filler	Hallway Across From Room 504	1 of 1	Water Bottle Filler	center	<1
40	419712	2026-03-21	Building V 500 Main	Fountain With Bottle Filler	Hallway Across From Room 504	1 of 1	Water Fountain	right	<1