



June 12, 2025

Victoria Kaptein
Lozier Environmental Consulting, Inc
2011 E. Main St.
Rochester, NY 14609

RE: Project: RCSD - School No. 74 - SOTA
Pace Project No.: 70357877

Dear Victoria Kaptein:

Enclosed are the analytical results for sample(s) received by the laboratory on June 02, 2025. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Newburgh

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in cursive script that reads 'Renee Cusack'.

Renee Cusack
renee.cusack@pacelabs.com
(845)562-0890
Project Manager

Enclosures

cc: Amy Pusateri, Lozier Environmental Consulting Inc.



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



CERTIFICATIONS

Project: RCSD - School No. 74 - SOTA

Pace Project No.: 70357877

Pace Analytical Services, LLC- Newburgh, NY

315 Fullerton Avenue, Newburgh, NY 12550

New York Certification #: 10142 Primary Accrediting Body

New Jersey Certification #: NY015

Connecticut Certification #: PH-0823

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE SUMMARY

Project: RCSD - School No. 74 - SOTA

Pace Project No.: 70357877

Lab ID	Sample ID	Matrix	Date Collected	Date Received
70357877001	SOTA-B-HA-BY-A028-BF	Drinking Water	05/28/25 05:40	06/02/25 13:50
70357877002	SOTA-B-HA-BY-A028-FR	Drinking Water	05/28/25 05:40	06/02/25 13:50
70357877003	SOTA-B-CR-IN-A023-TR	Drinking Water	05/28/25 05:44	06/02/25 13:50
70357877004	SOTA-B-CR-IN-A023-TL	Drinking Water	05/28/25 05:44	06/02/25 13:50
70357877005	SOTA-B-CR-IN-A022C-T	Drinking Water	05/28/25 05:47	06/02/25 13:50
70357877006	SOTA-B-CR-IN-A033D-T	Drinking Water	05/28/25 05:50	06/02/25 13:50
70357877007	SOTA-01-HA-BY-A181-FL	Drinking Water	05/28/25 05:55	06/02/25 13:50
70357877008	SOTA-01-HA-BY-A181-FR	Drinking Water	05/28/25 05:55	06/02/25 13:50
70357877009	SOTA-01-HA-BY-A181-BF	Drinking Water	05/28/25 05:56	06/02/25 13:50
70357877010	SOTA-01-HA-BY-N117-BF	Drinking Water	05/28/25 06:08	06/02/25 13:50
70357877011	SOTA-01-KL-IN-N139-TL	Drinking Water	05/28/25 06:13	06/02/25 13:50
70357877012	SOTA-01-KL-IN-N139-TM1	Drinking Water	05/28/25 06:15	06/02/25 13:50
70357877013	SOTA-01-KL-IN-N139-TM2	Drinking Water	05/28/25 06:15	06/02/25 13:50
70357877014	SOTA-01-KL-IN-N139-TR	Drinking Water	05/28/25 06:16	06/02/25 13:50
70357877015	SOTA-01-NO-IN-M144-T	Drinking Water	05/28/25 06:20	06/02/25 13:50
70357877016	SOTA-01-CR-IN-M160-T	Drinking Water	05/28/25 06:27	06/02/25 13:50
70357877017	SOTA-02-HA-BY-M233-FL	Drinking Water	05/28/25 06:33	06/02/25 13:50
70357877018	SOTA-02-HA-BY-M233-BF	Drinking Water	05/28/25 06:34	06/02/25 13:50
70357877019	SOTA-02-HA-BY-M233-FR	Drinking Water	05/28/25 06:34	06/02/25 13:50
70357877020	SOTA-02-HA-BY-A243-FL	Drinking Water	05/28/25 06:40	06/02/25 13:50
70357877021	SOTA-02-HA-BY-A243-BF	Drinking Water	05/28/25 06:41	06/02/25 13:50
70357877022	SOTA-02-HA-BY-A243-FR	Drinking Water	05/28/25 06:41	06/02/25 13:50
70357877023	SOTA-02-CR-IN-A242-T	Drinking Water	05/28/25 06:44	06/02/25 13:50
70357877024	SOTA-03-HA-BY-A343-FL	Drinking Water	05/28/25 06:52	06/02/25 13:50
70357877025	SOTA-03-HA-BY-A343-BF	Drinking Water	05/28/25 06:52	06/02/25 13:50
70357877026	SOTA-03-HA-BY-A343-FR	Drinking Water	05/28/25 06:52	06/02/25 13:50
70357877027	SOTA-03-CR-IN-A342-T	Drinking Water	05/28/25 06:57	06/02/25 13:50
70357877028	SOTA-03-HA-BY-N317-F	Drinking Water	05/28/25 07:05	06/02/25 13:50
70357877029	SOTA-03-HA-BY-N317-BF	Drinking Water	05/28/25 07:05	06/02/25 13:50
70357877030	SOTA-03-HA-BY-N321-FL	Drinking Water	05/28/25 07:09	06/02/25 13:50
70357877031	SOTA-03-HA-BY-N321-BF	Drinking Water	05/28/25 07:09	06/02/25 13:50
70357877032	SOTA-03-HA-BY-N321-FR	Drinking Water	05/28/25 07:09	06/02/25 13:50
70357877033	SOTA-04-HA-BY-M415-FL	Drinking Water	05/28/25 07:14	06/02/25 13:50
70357877034	SOTA-04-HA-BY-M415-BF	Drinking Water	05/28/25 07:14	06/02/25 13:50
70357877035	SOTA-04-HA-BY-M415-FR	Drinking Water	05/28/25 07:14	06/02/25 13:50
70357877036	SOTA-04-HA-BY-A426-F	Drinking Water	05/28/25 07:20	06/02/25 13:50
70357877037	SOTA-04-HA-BY-A426-BF	Drinking Water	05/28/25 07:20	06/02/25 13:50

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE SUMMARY

Project: RCSD - School No. 74 - SOTA

Pace Project No.: 70357877

Lab ID	Sample ID	Matrix	Date Collected	Date Received
70357877038	SOTA-04-CR-IN-A425-T	Drinking Water	05/28/25 07:24	06/02/25 13:50
70357877039	SOTA-01-HA-BY-N127-F	Drinking Water	05/28/25 07:30	06/02/25 13:50
70357877040	SOTA-01-HA-BY-N127-BF	Drinking Water	05/28/25 07:30	06/02/25 13:50

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE ANALYTE COUNT

Project: RCSD - School No. 74 - SOTA

Pace Project No.: 70357877

Lab ID	Sample ID	Method	Analysts	Analytes Reported
70357877001	SOTA-B-HA-BY-A028-BF	EPA 200.8, Rev. 5.4	MZ	1
70357877002	SOTA-B-HA-BY-A028-FR	EPA 200.8, Rev. 5.4	MZ	1
70357877003	SOTA-B-CR-IN-A023-TR	EPA 200.8, Rev. 5.4	MZ	1
70357877004	SOTA-B-CR-IN-A023-TL	EPA 200.8, Rev. 5.4	MZ	1
70357877005	SOTA-B-CR-IN-A022C-T	EPA 200.8, Rev. 5.4	MZ	1
70357877006	SOTA-B-CR-IN-A033D-T	EPA 200.8, Rev. 5.4	MZ	1
70357877007	SOTA-01-HA-BY-A181-FL	EPA 200.8, Rev. 5.4	MZ	1
70357877008	SOTA-01-HA-BY-A181-FR	EPA 200.8, Rev. 5.4	MZ	1
70357877009	SOTA-01-HA-BY-A181-BF	EPA 200.8, Rev. 5.4	MZ	1
70357877010	SOTA-01-HA-BY-N117-BF	EPA 200.8, Rev. 5.4	MZ	1
70357877011	SOTA-01-KL-IN-N139-TL	EPA 200.8, Rev. 5.4	MZ	1
70357877012	SOTA-01-KL-IN-N139-TM1	EPA 200.8, Rev. 5.4	MZ	1
70357877013	SOTA-01-KL-IN-N139-TM2	EPA 200.8, Rev. 5.4	MZ	1
70357877014	SOTA-01-KL-IN-N139-TR	EPA 200.8, Rev. 5.4	MZ	1
70357877015	SOTA-01-NO-IN-M144-T	EPA 200.8, Rev. 5.4	MZ	1
70357877016	SOTA-01-CR-IN-M160-T	EPA 200.8, Rev. 5.4	MZ	1
70357877017	SOTA-02-HA-BY-M233-FL	EPA 200.8, Rev. 5.4	MZ	1
70357877018	SOTA-02-HA-BY-M233-BF	EPA 200.8, Rev. 5.4	MZ	1
70357877019	SOTA-02-HA-BY-M233-FR	EPA 200.8, Rev. 5.4	MZ	1
70357877020	SOTA-02-HA-BY-A243-FL	EPA 200.8, Rev. 5.4	MZ	1
70357877021	SOTA-02-HA-BY-A243-BF	EPA 200.8, Rev. 5.4	MZ	1
70357877022	SOTA-02-HA-BY-A243-FR	EPA 200.8, Rev. 5.4	MZ	1
70357877023	SOTA-02-CR-IN-A242-T	EPA 200.8, Rev. 5.4	MZ	1
70357877024	SOTA-03-HA-BY-A343-FL	EPA 200.8, Rev. 5.4	MZ	1
70357877025	SOTA-03-HA-BY-A343-BF	EPA 200.8, Rev. 5.4	MZ	1
70357877026	SOTA-03-HA-BY-A343-FR	EPA 200.8, Rev. 5.4	MZ	1
70357877027	SOTA-03-CR-IN-A342-T	EPA 200.8, Rev. 5.4	MZ	1
70357877028	SOTA-03-HA-BY-N317-F	EPA 200.8, Rev. 5.4	MZ	1
70357877029	SOTA-03-HA-BY-N317-BF	EPA 200.8, Rev. 5.4	MZ	1
70357877030	SOTA-03-HA-BY-N321-FL	EPA 200.8, Rev. 5.4	MZ	1
70357877031	SOTA-03-HA-BY-N321-BF	EPA 200.8, Rev. 5.4	MZ	1
70357877032	SOTA-03-HA-BY-N321-FR	EPA 200.8, Rev. 5.4	MZ	1
70357877033	SOTA-04-HA-BY-M415-FL	EPA 200.8, Rev. 5.4	MZ	1
70357877034	SOTA-04-HA-BY-M415-BF	EPA 200.8, Rev. 5.4	MZ	1
70357877035	SOTA-04-HA-BY-M415-FR	EPA 200.8, Rev. 5.4	MZ	1
70357877036	SOTA-04-HA-BY-A426-F	EPA 200.8, Rev. 5.4	MZ	1
70357877037	SOTA-04-HA-BY-A426-BF	EPA 200.8, Rev. 5.4	MZ	1

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE ANALYTE COUNT

Project: RCSD - School No. 74 - SOTA

Pace Project No.: 70357877

Lab ID	Sample ID	Method	Analysts	Analytes Reported
70357877038	SOTA-04-CR-IN-A425-T	EPA 200.8, Rev. 5.4	MZ	1
70357877039	SOTA-01-HA-BY-N127-F	EPA 200.8, Rev. 5.4	MZ	1
70357877040	SOTA-01-HA-BY-N127-BF	EPA 200.8, Rev. 5.4	MZ	1

PASI-NB = Pace Analytical Services - Newburgh

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



PROJECT NARRATIVE

Project: RCSD - School No. 74 - SOTA

Pace Project No.: 70357877

Method: EPA 200.8, Rev. 5.4

Description: NB 200.8 ICPMS DW No Prep

Client: Lozier Environmental Consulting, Inc.

Date: June 12, 2025

General Information:

40 samples were analyzed for EPA 200.8, Rev. 5.4 by Pace Analytical Services Newburgh. All samples were received in acceptable condition with any exceptions noted below or on the chain-of custody and/or the sample condition upon receipt form (SCUR) attached at the end of this report.

Hold Time:

The samples were analyzed within the method required hold times with any exceptions noted below.

Initial Calibrations (including MS Tune as applicable):

All criteria were within method requirements with any exceptions noted below.

Continuing Calibration:

All criteria were within method requirements with any exceptions noted below.

Internal Standards:

All internal standards were within QC limits with any exceptions noted below.

Surrogates:

All surrogates were within QC limits with any exceptions noted below.

Method Blank:

All analytes were below the report limit in the method blank, where applicable, with any exceptions noted below.

Laboratory Control Spike:

All laboratory control spike compounds were within QC limits with any exceptions noted below.

Matrix Spikes:

All percent recoveries and relative percent differences (RPDs) were within acceptance criteria with any exceptions noted below.

Duplicate Sample:

All duplicate sample results were within method acceptance criteria with any exceptions noted below.

Additional Comments:

This data package has been reviewed for quality and completeness and is approved for release.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD - School No. 74 - SOTA

Pace Project No.: 70357877

Sample: SOTA-B-HA-BY-A028-BF Lab ID: 70357877001 Collected: 05/28/25 05:40 Received: 06/02/25 13:50 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	1.0	ug/L	1.0	15	1		06/11/25 16:33	7439-92-1	

Sample: SOTA-B-HA-BY-A028-FR Lab ID: 70357877002 Collected: 05/28/25 05:40 Received: 06/02/25 13:50 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		06/11/25 16:39	7439-92-1	

Sample: SOTA-B-CR-IN-A023-TR Lab ID: 70357877003 Collected: 05/28/25 05:44 Received: 06/02/25 13:50 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	1.3	ug/L	1.0	15	1		06/11/25 16:40	7439-92-1	

Sample: SOTA-B-CR-IN-A023-TL Lab ID: 70357877004 Collected: 05/28/25 05:44 Received: 06/02/25 13:50 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	1.2	ug/L	1.0	15	1		06/11/25 16:42	7439-92-1	

Sample: SOTA-B-CR-IN-A022C-T Lab ID: 70357877005 Collected: 05/28/25 05:47 Received: 06/02/25 13:50 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	10.8	ug/L	1.0	15	1		06/11/25 16:46	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD - School No. 74 - SOTA

Pace Project No.: 70357877

Sample: SOTA-B-CR-IN-A033D-T Lab ID: 70357877006 Collected: 05/28/25 05:50 Received: 06/02/25 13:50 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	4.4	ug/L	1.0	15	1		06/11/25 16:47	7439-92-1	

Sample: SOTA-01-HA-BY-A181-FL Lab ID: 70357877007 Collected: 05/28/25 05:55 Received: 06/02/25 13:50 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		06/11/25 16:49	7439-92-1	

Sample: SOTA-01-HA-BY-A181-FR Lab ID: 70357877008 Collected: 05/28/25 05:55 Received: 06/02/25 13:50 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		06/11/25 16:50	7439-92-1	

Sample: SOTA-01-HA-BY-A181-BF Lab ID: 70357877009 Collected: 05/28/25 05:56 Received: 06/02/25 13:50 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		06/11/25 16:52	7439-92-1	

Sample: SOTA-01-HA-BY-N117-BF Lab ID: 70357877010 Collected: 05/28/25 06:08 Received: 06/02/25 13:50 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		06/11/25 16:53	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD - School No. 74 - SOTA

Pace Project No.: 70357877

Sample: SOTA-01-KL-IN-N139-TL Lab ID: 70357877011 Collected: 05/28/25 06:13 Received: 06/02/25 13:50 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	1.2	ug/L	1.0	15	1		06/11/25 16:55	7439-92-1	

Sample: SOTA-01-KL-IN-N139-TM1 Lab ID: 70357877012 Collected: 05/28/25 06:15 Received: 06/02/25 13:50 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	1.2	ug/L	1.0	15	1		06/11/25 16:57	7439-92-1	

Sample: SOTA-01-KL-IN-N139-TM2 Lab ID: 70357877013 Collected: 05/28/25 06:15 Received: 06/02/25 13:50 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		06/11/25 16:59	7439-92-1	

Sample: SOTA-01-KL-IN-N139-TR Lab ID: 70357877014 Collected: 05/28/25 06:16 Received: 06/02/25 13:50 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	1.7	ug/L	1.0	15	1		06/11/25 17:03	7439-92-1	

Sample: SOTA-01-NO-IN-M144-T Lab ID: 70357877015 Collected: 05/28/25 06:20 Received: 06/02/25 13:50 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		06/11/25 17:04	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD - School No. 74 - SOTA

Pace Project No.: 70357877

Sample: SOTA-01-CR-IN-M160-T Lab ID: 70357877016 Collected: 05/28/25 06:27 Received: 06/02/25 13:50 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	1.4	ug/L	1.0	15	1		06/11/25 17:06	7439-92-1	

Sample: SOTA-02-HA-BY-M233-FL Lab ID: 70357877017 Collected: 05/28/25 06:33 Received: 06/02/25 13:50 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		06/11/25 17:07	7439-92-1	

Sample: SOTA-02-HA-BY-M233-BF Lab ID: 70357877018 Collected: 05/28/25 06:34 Received: 06/02/25 13:50 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		06/11/25 17:09	7439-92-1	

Sample: SOTA-02-HA-BY-M233-FR Lab ID: 70357877019 Collected: 05/28/25 06:34 Received: 06/02/25 13:50 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		06/11/25 17:10	7439-92-1	

Sample: SOTA-02-HA-BY-A243-FL Lab ID: 70357877020 Collected: 05/28/25 06:40 Received: 06/02/25 13:50 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		06/11/25 17:12	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD - School No. 74 - SOTA

Pace Project No.: 70357877

Sample: SOTA-02-HA-BY-A243-BF Lab ID: 70357877021 Collected: 05/28/25 06:41 Received: 06/02/25 13:50 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		06/11/25 17:16	7439-92-1	

Sample: SOTA-02-HA-BY-A243-FR Lab ID: 70357877022 Collected: 05/28/25 06:41 Received: 06/02/25 13:50 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		06/11/25 17:24	7439-92-1	

Sample: SOTA-02-CR-IN-A242-T Lab ID: 70357877023 Collected: 05/28/25 06:44 Received: 06/02/25 13:50 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		06/11/25 17:26	7439-92-1	

Sample: SOTA-03-HA-BY-A343-FL Lab ID: 70357877024 Collected: 05/28/25 06:52 Received: 06/02/25 13:50 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		06/11/25 17:27	7439-92-1	

Sample: SOTA-03-HA-BY-A343-BF Lab ID: 70357877025 Collected: 05/28/25 06:52 Received: 06/02/25 13:50 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		06/11/25 17:28	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD - School No. 74 - SOTA

Pace Project No.: 70357877

Sample: SOTA-03-HA-BY-A343-FR Lab ID: 70357877026 Collected: 05/28/25 06:52 Received: 06/02/25 13:50 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		06/11/25 17:30	7439-92-1	

Sample: SOTA-03-CR-IN-A342-T Lab ID: 70357877027 Collected: 05/28/25 06:57 Received: 06/02/25 13:50 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		06/11/25 17:31	7439-92-1	

Sample: SOTA-03-HA-BY-N317-F Lab ID: 70357877028 Collected: 05/28/25 07:05 Received: 06/02/25 13:50 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		06/11/25 17:33	7439-92-1	

Sample: SOTA-03-HA-BY-N317-BF Lab ID: 70357877029 Collected: 05/28/25 07:05 Received: 06/02/25 13:50 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		06/11/25 17:37	7439-92-1	

Sample: SOTA-03-HA-BY-N321-FL Lab ID: 70357877030 Collected: 05/28/25 07:09 Received: 06/02/25 13:50 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		06/11/25 17:38	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD - School No. 74 - SOTA

Pace Project No.: 70357877

Sample: SOTA-03-HA-BY-N321-BF Lab ID: 70357877031 Collected: 05/28/25 07:09 Received: 06/02/25 13:50 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		06/11/25 17:40	7439-92-1	

Sample: SOTA-03-HA-BY-N321-FR Lab ID: 70357877032 Collected: 05/28/25 07:09 Received: 06/02/25 13:50 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		06/11/25 17:43	7439-92-1	

Sample: SOTA-04-HA-BY-M415-FL Lab ID: 70357877033 Collected: 05/28/25 07:14 Received: 06/02/25 13:50 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		06/11/25 17:44	7439-92-1	

Sample: SOTA-04-HA-BY-M415-BF Lab ID: 70357877034 Collected: 05/28/25 07:14 Received: 06/02/25 13:50 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		06/11/25 17:45	7439-92-1	

Sample: SOTA-04-HA-BY-M415-FR Lab ID: 70357877035 Collected: 05/28/25 07:14 Received: 06/02/25 13:50 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<2.0	ug/L	2.0	15	2		06/12/25 12:48	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD - School No. 74 - SOTA

Pace Project No.: 70357877

Sample: SOTA-04-HA-BY-A426-F Lab ID: 70357877036 Collected: 05/28/25 07:20 Received: 06/02/25 13:50 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		06/11/25 17:48	7439-92-1	

Sample: SOTA-04-HA-BY-A426-BF Lab ID: 70357877037 Collected: 05/28/25 07:20 Received: 06/02/25 13:50 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		06/11/25 17:50	7439-92-1	

Sample: SOTA-04-CR-IN-A425-T Lab ID: 70357877038 Collected: 05/28/25 07:24 Received: 06/02/25 13:50 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		06/11/25 17:54	7439-92-1	

Sample: SOTA-01-HA-BY-N127-F Lab ID: 70357877039 Collected: 05/28/25 07:30 Received: 06/02/25 13:50 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		06/11/25 17:55	7439-92-1	

Sample: SOTA-01-HA-BY-N127-BF Lab ID: 70357877040 Collected: 05/28/25 07:30 Received: 06/02/25 13:50 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		06/11/25 17:57	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: RCSD - School No. 74 - SOTA

Pace Project No.: 70357877

QC Batch:	403620	Analysis Method:	EPA 200.8, Rev. 5.4
QC Batch Method:	EPA 200.8, Rev. 5.4	Analysis Description:	NB 200.8 ICPMS DW No Prep
		Laboratory:	Pace Analytical Services - Newburgh
Associated Lab Samples:	70357877001, 70357877002, 70357877003, 70357877004, 70357877005, 70357877006, 70357877007, 70357877008, 70357877009, 70357877010, 70357877011, 70357877012, 70357877013, 70357877014, 70357877015, 70357877016, 70357877017, 70357877018, 70357877019, 70357877020		

METHOD BLANK:	2134013	Matrix:	Water
Associated Lab Samples:	70357877001, 70357877002, 70357877003, 70357877004, 70357877005, 70357877006, 70357877007, 70357877008, 70357877009, 70357877010, 70357877011, 70357877012, 70357877013, 70357877014, 70357877015, 70357877016, 70357877017, 70357877018, 70357877019, 70357877020		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	06/11/25 16:30	

LABORATORY CONTROL SAMPLE:	2134014					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	47.4	95	85-115	

MATRIX SPIKE SAMPLE:		2134016					
		70357877001	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	1.0	50	50.0	98	70-130	

MATRIX SPIKE SAMPLE:		2134018					
		70357877011	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	1.2	50	50.6	99	70-130	

SAMPLE DUPLICATE:	2134015					
Parameter	Units	70357877001 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	1.0	<1.0		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: RCSD - School No. 74 - SOTA

Pace Project No.: 70357877

QC Batch:	403825	Analysis Method:	EPA 200.8, Rev. 5.4
QC Batch Method:	EPA 200.8, Rev. 5.4	Analysis Description:	NB 200.8 ICPMS DW No Prep
		Laboratory:	Pace Analytical Services - Newburgh
Associated Lab Samples:	70357877021, 70357877022, 70357877023, 70357877024, 70357877025, 70357877026, 70357877027, 70357877028, 70357877029, 70357877030, 70357877031, 70357877032, 70357877033, 70357877034, 70357877035, 70357877036, 70357877037, 70357877038, 70357877039, 70357877040		

METHOD BLANK:	2135248	Matrix:	Water
Associated Lab Samples:	70357877021, 70357877022, 70357877023, 70357877024, 70357877025, 70357877026, 70357877027, 70357877028, 70357877029, 70357877030, 70357877031, 70357877032, 70357877033, 70357877034, 70357877035, 70357877036, 70357877037, 70357877038, 70357877039, 70357877040		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	06/11/25 17:13	

LABORATORY CONTROL SAMPLE:	2135249					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	48.6	97	85-115	

MATRIX SPIKE SAMPLE:		2135251					
		70357877021	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	51.0	100	70-130	

MATRIX SPIKE SAMPLE:		2135253					
		70357877031	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	49.4	98	70-130	

SAMPLE DUPLICATE:	2135250					
Parameter	Units	70357877021 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALIFIERS

Project: RCSD - School No. 74 - SOTA
Pace Project No.: 70357877

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: RCSD - School No. 74 - SOTA

Pace Project No.: 70357877

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70357877001	SOTA-B-HA-BY-A028-BF	EPA 200.8, Rev. 5.4	403620		
70357877002	SOTA-B-HA-BY-A028-FR	EPA 200.8, Rev. 5.4	403620		
70357877003	SOTA-B-CR-IN-A023-TR	EPA 200.8, Rev. 5.4	403620		
70357877004	SOTA-B-CR-IN-A023-TL	EPA 200.8, Rev. 5.4	403620		
70357877005	SOTA-B-CR-IN-A022C-T	EPA 200.8, Rev. 5.4	403620		
70357877006	SOTA-B-CR-IN-A033D-T	EPA 200.8, Rev. 5.4	403620		
70357877007	SOTA-01-HA-BY-A181-FL	EPA 200.8, Rev. 5.4	403620		
70357877008	SOTA-01-HA-BY-A181-FR	EPA 200.8, Rev. 5.4	403620		
70357877009	SOTA-01-HA-BY-A181-BF	EPA 200.8, Rev. 5.4	403620		
70357877010	SOTA-01-HA-BY-N117-BF	EPA 200.8, Rev. 5.4	403620		
70357877011	SOTA-01-KL-IN-N139-TL	EPA 200.8, Rev. 5.4	403620		
70357877012	SOTA-01-KL-IN-N139-TM1	EPA 200.8, Rev. 5.4	403620		
70357877013	SOTA-01-KL-IN-N139-TM2	EPA 200.8, Rev. 5.4	403620		
70357877014	SOTA-01-KL-IN-N139-TR	EPA 200.8, Rev. 5.4	403620		
70357877015	SOTA-01-NO-IN-M144-T	EPA 200.8, Rev. 5.4	403620		
70357877016	SOTA-01-CR-IN-M160-T	EPA 200.8, Rev. 5.4	403620		
70357877017	SOTA-02-HA-BY-M233-FL	EPA 200.8, Rev. 5.4	403620		
70357877018	SOTA-02-HA-BY-M233-BF	EPA 200.8, Rev. 5.4	403620		
70357877019	SOTA-02-HA-BY-M233-FR	EPA 200.8, Rev. 5.4	403620		
70357877020	SOTA-02-HA-BY-A243-FL	EPA 200.8, Rev. 5.4	403620		
70357877021	SOTA-02-HA-BY-A243-BF	EPA 200.8, Rev. 5.4	403825		
70357877022	SOTA-02-HA-BY-A243-FR	EPA 200.8, Rev. 5.4	403825		
70357877023	SOTA-02-CR-IN-A242-T	EPA 200.8, Rev. 5.4	403825		
70357877024	SOTA-03-HA-BY-A343-FL	EPA 200.8, Rev. 5.4	403825		
70357877025	SOTA-03-HA-BY-A343-BF	EPA 200.8, Rev. 5.4	403825		
70357877026	SOTA-03-HA-BY-A343-FR	EPA 200.8, Rev. 5.4	403825		
70357877027	SOTA-03-CR-IN-A342-T	EPA 200.8, Rev. 5.4	403825		
70357877028	SOTA-03-HA-BY-N317-F	EPA 200.8, Rev. 5.4	403825		
70357877029	SOTA-03-HA-BY-N317-BF	EPA 200.8, Rev. 5.4	403825		
70357877030	SOTA-03-HA-BY-N321-FL	EPA 200.8, Rev. 5.4	403825		
70357877031	SOTA-03-HA-BY-N321-BF	EPA 200.8, Rev. 5.4	403825		
70357877032	SOTA-03-HA-BY-N321-FR	EPA 200.8, Rev. 5.4	403825		
70357877033	SOTA-04-HA-BY-M415-FL	EPA 200.8, Rev. 5.4	403825		
70357877034	SOTA-04-HA-BY-M415-BF	EPA 200.8, Rev. 5.4	403825		
70357877035	SOTA-04-HA-BY-M415-FR	EPA 200.8, Rev. 5.4	403825		
70357877036	SOTA-04-HA-BY-A426-F	EPA 200.8, Rev. 5.4	403825		
70357877037	SOTA-04-HA-BY-A426-BF	EPA 200.8, Rev. 5.4	403825		
70357877038	SOTA-04-CR-IN-A425-T	EPA 200.8, Rev. 5.4	403825		
70357877039	SOTA-01-HA-BY-N127-F	EPA 200.8, Rev. 5.4	403825		
70357877040	SOTA-01-HA-BY-N127-BF	EPA 200.8, Rev. 5.4	403825		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



Lozier
Environmental Consulting, Inc.

REPORT TO:		INVOICE TO:	
Company:	Lozier Environmental Consulting, Inc.	Company: (SAME)	
Address:	2011 East Main Street	Address:	
City/State Zip:	Rochester NY 14609	City/State Zip:	
Phone:	585-654-9080	Phone:	
Fax:	585-654-9662	Fax:	
E-Mail:	support@lozierenv.com	Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS
1	SOTA-B-HA-BY-A028-BF	5/28/2025	5:40		DW			attached fountain doesn't work	Lead
2	SOTA-B-HA-BY-A028-FR	5/28/2025	5:40		DW				
3	SOTA-B-CR-IN-A023-TR	5/28/2025	5:44		DW				
4	SOTA-B-CR-IN-A023-TL	5/28/2025	5:44		DW				
5	SOTA-B-CR-IN-A022C-T	5/28/2025	5:47		DW				
6	SOTA-B-CR-IN-A033D-T	5/28/2025	5:50		DW				
7	SOTA-01-HA-BY-A181-FL	5/28/2025	5:55		DW				
8	SOTA-01-HA-BY-A181-FR	5/28/2025	5:55		DW				
9	SOTA-01-HA-BY-A181-BF	5/28/2025	5:56		DW				
10	SOTA-01-HA-BY-N117-BF	5/28/2025	6:08		DW			attached fountain doesn't work	

Container Type (Circle One): Plastic Glass Sterile Other _____ Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

SAMPLED BY*: Joe Savioe

RELINQUISHED BY*: Joe Savioe DATE: 5/29/2025 TIME: _____

RECEIVED BY*: *Mike Hsu* DATE: 6/4/25 TIME: 1:55P

RELINQUISHED BY*: _____ DATE: _____ TIME: _____

RECEIVED BY*: _____ DATE: _____ TIME: _____

RELINQUISHED BY*: _____ DATE: _____ TIME: _____

RECEIVED BY*: _____ DATE: _____ TIME: _____

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FED EX CARD
8816 2353 9419

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDE: HNO3-	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINERS: 40	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES	Present Absent
SAMPLE ON ICE? NO	If Present, Date Client is
TEMPERATURE: 18.7c	contacted with result:
SAMPLE IN COMPLIANCE: YES	Date: _____
	Contacted By: _____

REQUESTED ANALYSIS

MO#: 70357877

70357877



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 2 of 4

Page 21 of 24

LAB ID: M38168		Company: Lozier Environmental Consulting, Inc.		REPORT TO:		INVOICE TO:	
PROJECT NAME: RCSD - School No. 74 - SOTA		Address: 2011 East Main Street		City/State Zip: Rochester NY 14609		Company: (SAME)	
TURNAROUND TIME: Standard Rush		Phone: 585-654-9080		Fax: 585-654-9662		City/State Zip:	
Other:		E-Mail: support@lozierenv.com		Purchase Order #:		Fax:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS
11	SOTA-01-KI-IN-N139-TL	5/28/2025	6:13		DW			hand sink	x
12	SOTA-01-KI-IN-N139-TM1	5/28/2025	6:15		DW			dish sink left	x
13	SOTA-01-KI-IN-N139-TM2	5/28/2025	6:15		DW			dish sink right	x
14	SOTA-01-KI-IN-N139-TR	5/28/2025	6:16		DW			hand sink	x
15	SOTA-01-NO-IN-M144-T	5/28/2025	6:20		DW				x
16	SOTA-01-CR-IN-M160-T	5/28/2025	6:27		DW				x
17	SOTA-02-HA-BY-M233-FL	5/28/2025	6:33		DW				x
18	SOTA-02-HA-BY-M233-BF	5/28/2025	6:34		DW				x
19	SOTA-02-HA-BY-M233-FR	5/28/2025	6:34		DW				x
20	SOTA-02-HA-BY-A243-FL	5/28/2025	6:40		DW				x

Container Type (Circle One): Plastic Glass Sterile Other _____ Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

SAMPLED BY*: Joe Savioe	DATE: 5/29/2025	TIME: 1350
RECEIVED BY*: Joe Savioe	DATE: 6/4/25	TIME: 1350
RELINQUISHED BY*: Joe Savioe	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:
RELINQUISHED BY:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FOR LAB USE ONLY		FOR POTABLE WATER ONLY:	
PRESERVATIVE/BIOCIDE: HNO3-	TOTAL NUMBER OF CONTAINERS: 40	COLIFORM BACTERIA:	
CUSTODY SEAL INTACT? YES	SAMPLE ON ICE? NO	Present Absent	
TEMPERATURE: 8.2 C	SAMPLE IN COMPLIANCE: YES	If Present, Date Client is contacted with result:	
		Date: _____	
		Contacted By: _____	

1750 54 6100
8816 2353 9419

MO#: 70357877
PM: RC1 Due Date: 06/16/25
CLIENT: NB-LOZIER



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 3 of 4

Page 22 of 24

LAB ID: M38168		Company: Lozier Environmental Consulting, Inc.		REPORT TO:		INVOICE TO:	
PROJECT NAME: RCSD - School No. 74 - SOTA		Address: 2011 East Main Street		City/State Zip: Rochester NY 14609		Company: (SAME)	
TURNAROUND TIME: Standard Rush		Phone: 585-654-9080		Fax: 585-654-9662		Address:	
Other:		E-Mail: support@lozierenv.com		Purchase Order #:		City/State Zip:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS				
21	SOTA-02-HA-BY-A243-BF	5/28/2025	6:41		DW			Lead					
22	SOTA-02-HA-BY-A243-FR	5/28/2025	6:41		DW								
23	SOTA-02-CR-IN-A242-T	5/28/2025	6:44		DW								
24	SOTA-03-HA-BY-A343-FL	5/28/2025	6:52		DW								
25	SOTA-03-HA-BY-A343-BF	5/28/2025	6:52		DW								
26	SOTA-03-HA-BY-A343-FR	5/28/2025	6:52		DW								
27	SOTA-03-CR-IN-A342-T	5/28/2025	6:57		DW								
28	SOTA-03-HA-BY-N317-F	5/28/2025	7:05		DW								
29	SOTA-03-HA-BY-N317-BF	5/28/2025	7:05		DW								
30	SOTA-03-HA-BY-N321-FL	5/28/2025	7:09		DW								

Container Type (Circle One): Plastic Glass Sterile Other _____ Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

SAMPLED BY*: Joe Savioe

RELINQUISHED BY*: Joe Savioe DATE: 5/29/2025 TIME: _____

RECEIVED BY*: Mike Iru DATE: 6/2/25 TIME: 1350

RELINQUISHED BY*: _____ DATE: _____ TIME: _____

RECEIVED BY*: _____ DATE: _____ TIME: _____

RELINQUISHED BY*: _____ DATE: _____ TIME: _____

RECEIVED BY*: _____ DATE: _____ TIME: _____

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

REC'D EX 6060
0806 2353 9419

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDE: HNO3-	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINERS: 40	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES	Present Absent
SAMPLE ON ICE? NO	If Present, Date Client is
TEMPERATURE: 18.2 C	contacted with result:
SAMPLE IN COMPLIANCE: YES	Date: _____
	Contacted By: _____

MO#: 70357877
PM: RC1 Due Date: 06/16/25
CLIENT: NB-LOZIER



Lozier
Environmental Consulting, Inc.

2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 4 of 4

Page 23 of 24

LAB ID: M38168		Company: Lozier Environmental Consulting, Inc.		REPORT TO:		INVOICE TO:	
PROJECT NAME: RCSD - School No. 74 - SOTA		Address: 2011 East Main Street		City/State Zip: Rochester NY 14609		Company: (SAME)	
TURNAROUND TIME: Standard Rush		Phone: 585-654-9080		Fax: 585-654-9662		Address:	
Other:		E-Mail: support@lozierenv.com		Purchase Order #:		City/State Zip:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS			
31	SOTA-03-HA-BY-N321-BF	5/28/2025	7:09		DW				x			
32	SOTA-03-HA-BY-N321-FR	5/28/2025	7:09		DW				x			
33	SOTA-04-HA-BY-M415-FL	5/28/2025	7:14		DW				x			
34	SOTA-04-HA-BY-M415-BF	5/28/2025	7:14		DW				x			
35	SOTA-04-HA-BY-M415-FR	5/28/2025	7:14		DW				x			
36	SOTA-04-HA-BY-A426-F	5/28/2025	7:20		DW				x			
37	SOTA-04-HA-BY-A426-BF	5/28/2025	7:20		DW				x			
38	SOTA-04-CR-IN-A425-T	5/28/2025	7:24		DW				x			
39	SOTA-01-HA-BY-N127-F	5/28/2025	7:30		DW				x			
40	SOTA-01-HA-BY-N127-BF	5/28/2025	7:30		DW				x			

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

SAMPLED BY*: Joe Savioe	DATE: 5/29/2025	TIME:
RELINQUISHED BY*: Joe Savioe	DATE: 6/17/25	TIME: 1350
RECEIVED BY*: <i>[Signature]</i>	DATE:	TIME:
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

ED 5256P

8806 2353 9419

FOR LAB USE ONLY		FOR POTABLE WATER ONLY:	
PRESERVATIVE/BIOCIDE: HNO3-		COLIFORM BACTERIA:	
TOTAL NUMBER OF CONTAINERS: 40		Present	Absent
CUSTODY SEAL INTACT? YES		If Present, Date Client is contacted with result:	
SAMPLE ON ICE? NO		Date: _____	
TEMPERATURE: 8.7 C		Contacted By: _____	
SAMPLE IN COMPLIANCE: YES			

MO#: 70357877
PM: RC1 Due Date: 06/16/25
CLIENT: NB-LOZIER

WO#: 70357877

Project #

PM: RC1

Due Date: 06/16/25

Client:

CLIENT: NB-LOZIER

SCUR)

Date and Initials of person:

Examining contents: _____

Label: _____

Deliver to location: _____

pH: _____

Thermometer Used: IRG4

Date: 6/2

Time: 1350

Initials: _____

State of Origin: NY

Cooler #1 Temp. °C 18.7 (Visual) 0.2 @ 0.0°C, -0.5 @ 20.0°C (Correction Factor) (Actual) ☒ Samples on ice, cooling process has begun

Courier: ☒ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☐ Pace ☐ Other _____

Shipping Method: ☐ First Overnight ☐ Priority Overnight ☐ Standard Overnight ☒ Ground

☐ Other _____

Tracking # _____

Custody Seal on Cooler/Box Present: ☐ Yes ☐ No

Seals intact: ☐ Yes ☐ No

Ice: ☒ Wet ☐ Blue ☐ Melted ☒ None

Packing Material: ☐ Bubble Wrap ☐ Bubble Bags ☐ None ☐ Other _____

Samples were collected by Pace employee ☐ Yes ☐ No ☐ N/A

Comments:

Chain of Custody Present	☒ Yes ☐ No ☐ N/A	
Chain of Custody Filled Out	☒ Yes ☐ No ☐ N/A	
Relinquished Signature on COC	☒ Yes ☐ No ☐ N/A	
Sampler Name and Signature on COC	☒ Yes ☐ No ☐ N/A	
Samples Arrived within Hold Time	☒ Yes ☐ No ☐ N/A	
Rush TAT requested on COC	☐ Yes ☐ No ☐ N/A	
Sufficient Volume	☒ Yes ☐ No ☐ N/A	
Correct Containers Used	☒ Yes ☐ No ☐ N/A	
Containers Intact	☒ Yes ☐ No ☐ N/A	
Sample Labels match COC (sample IDs & date/time of collection)	☒ Yes ☐ No ☐ N/A	
All containers needing acid/base preservation have been checked.	☐ Yes ☐ No ☒ N/A	Preservation Information:
All Containers needing preservation are found to be in compliance with EPA recommendation:	☐ Yes ☐ No ☒ N/A	Preservative: _____
Exceptions: Vials, Microbiology, O&G, Metals		Lot #/Trace #: _____
		Date: _____ Time: _____
		Initials: _____
Headspace in VOA Vials? (>6mm):	☐ Yes ☐ No ☒ N/A	
Trip Blank Present:	☐ Yes ☐ No ☒ N/A	

Additional Login Comments:

Client notification/ Resolution

Person Contacted:

Date/Time:

Comments/Resolution: