


May 15, 2024

V Kaptein
NB-Lozier Environmental Consulting, Inc
2011 E Main Street
Rochester, NY 14609

Project Location: RCSD-School 52
Project Number: Lozier Environmental Consulting
Laboratory Work Order Number: 24E0537

Enclosed are results of analyses for samples received by the laboratory on May 3, 2024. If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Project Manager



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

NB-Lozier Environmental Consulting, Inc
2011 E Main Street
Rochester, NY 14609
ATTN: V Kaptein

REPORT DATE: 5/15/2024

PURCHASE ORDER NUMBER: RCSD-School 52

PROJECT NUMBER: Lozier Environmental Consulting

ANALYTICAL SUMMARY

WORK ORDER NUMBER: 24E0537

The results of analyses performed on the following samples submitted to Pace Analytical Services, LLC - Newburgh are found in this report.

PROJECT LOCATION: RCSD-School 52

FIELD SAMPLE #	LAB ID:	MATRIX	SAMPLE DESCRIPTION	TEST	SUB LAB
(1) 52-01-HA-BY-104-F	24E0537-01	Drinking Water		EPA 200.8 Rev 5.4	
(2) 52-01-HA-BY-104-BF	24E0537-02	Drinking Water		EPA 200.8 Rev 5.4	
(3) 52-01-CR-IN-109-T	24E0537-03	Drinking Water		EPA 200.8 Rev 5.4	
(4) 52-01-CR-IN-107-T	24E0537-04	Drinking Water		EPA 200.8 Rev 5.4	
(5) 52-01-CR-IN-106-T	24E0537-05	Drinking Water		EPA 200.8 Rev 5.4	
(6) 52-01-HA-BY-105-F	24E0537-06	Drinking Water		EPA 200.8 Rev 5.4	
(7) 52-01-HA-BY-105-BF	24E0537-07	Drinking Water		EPA 200.8 Rev 5.4	
(8) 52-01-CR-IN-104-T	24E0537-08	Drinking Water		EPA 200.8 Rev 5.4	
(9) 52-01-CR-IN-101-T	24E0537-09	Drinking Water		EPA 200.8 Rev 5.4	
(10) 52-01-MO-IN-100-T	24E0537-10	Drinking Water		EPA 200.8 Rev 5.4	
(11) 52-01-NO-IN-113-T	24E0537-11	Drinking Water		EPA 200.8 Rev 5.4	
(12) 52-01-CR-IN-112C-T	24E0537-12	Drinking Water		EPA 200.8 Rev 5.4	
(13) 52-01-CR-IN-115-T	24E0537-13	Drinking Water		EPA 200.8 Rev 5.4	
(14) 52-01-CR-IN-115-B	24E0537-14	Drinking Water		EPA 200.8 Rev 5.4	
(15) 52-01-CR-IN-116-T	24E0537-15	Drinking Water		EPA 200.8 Rev 5.4	
(16) 52-01-CR-IN-114-T	24E0537-16	Drinking Water		EPA 200.8 Rev 5.4	
(17) 52-02-CR-IN-220-T	24E0537-17	Drinking Water		EPA 200.8 Rev 5.4	
(18) 52-02-HA-BY-219-F	24E0537-18	Drinking Water		EPA 200.8 Rev 5.4	
(19) 52-02-HA-BY-219-BF	24E0537-19	Drinking Water		EPA 200.8 Rev 5.4	
(20) 52-02-HA-BY-216-F	24E0537-20	Drinking Water		EPA 200.8 Rev 5.4	
(21) 52-02-HA-BY-216-BF	24E0537-21	Drinking Water		EPA 200.8 Rev 5.4	
(22) 52-02-RM-IN-210A-T	24E0537-22	Drinking Water		EPA 200.8 Rev 5.4	
(23) 52-					

CASE NARRATIVE SUMMARY

All reported results are within defined laboratory quality control objectives unless listed below or otherwise qualified in this report.

EPA 200.8 Rev 5.4

Qualifications:

Z-01

#


Analyte & Samples(s) Qualified:

Lead

24E0537-04[(4) 52-01-CR-IN-107-T], 24E0537-09[(9) 52-01-CR-IN-101-T], 24E0537-12[(12) 52-01-CR-IN-112C-T], 24E0537-16[(16) 52-01-CR-IN-114-T],
24E0537-17[(17) 52-02-CR-IN-220-T], 24E0537-22[(22) 52-02-RM-IN-210A-T]

The results of analyses reported only relate to samples submitted to the Pace Analytical Services, LLC - Newburgh for testing.

I certify that the analyses listed above, unless specifically listed as subcontracted, if any, were performed under my direction according to the approved methodologies listed in this document, and that based upon my inquiry of those individuals immediately responsible for obtaining the information, the material contained in this report is, to the best of my knowledge and belief, accurate and complete.



Renee Cusack
PM



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School 52

Sample Description:

Work Order: 24E0537

Date Received: 5/3/2024

Field Sample #: (1) 52-01-HA-BY-104-F

Sampled: 4/25/2024 06:39

Sample ID: 24E0537-01

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	5/14/24	5/14/24 14:23	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School 52

Sample Description:

Work Order: 24E0537

Date Received: 5/3/2024

Field Sample #: (2) 52-01-HA-BY-104-BF

Sampled: 4/25/2024 06:39

Sample ID: 24E0537-02

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	5/14/24	5/14/24 14:34	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School 52

Sample Description:

Work Order: 24E0537

Date Received: 5/3/2024

Field Sample #: (3) 52-01-CR-IN-109-T

Sampled: 4/25/2024 06:41

Sample ID: 24E0537-03

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	11	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	5/14/24	5/14/24 14:37	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School 52

Sample Description:

Work Order: 24E0537

Date Received: 5/3/2024

Field Sample #: (4) 52-01-CR-IN-107-T

Sampled: 4/25/2024 06:43

Sample ID: 24E0537-04

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	33	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	5/14/24	5/14/24 14:40	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School 52

Sample Description:

Work Order: 24E0537

Date Received: 5/3/2024

Field Sample #: (5) 52-01-CR-IN-106-T

Sampled: 4/25/2024 06:45

Sample ID: 24E0537-05

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	2.3	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	5/14/24	5/14/24 14:49	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School 52

Sample Description:

Work Order: 24E0537

Date Received: 5/3/2024

Field Sample #: (6) 52-01-HA-BY-105-F

Sampled: 4/25/2024 06:46

Sample ID: 24E0537-06

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	5/14/24	5/14/24 14:52	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School 52

Sample Description:

Work Order: 24E0537

Date Received: 5/3/2024

Field Sample #: (7) 52-01-HA-BY-105-BF

Sampled: 4/25/2024 06:46

Sample ID: 24E0537-07

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	5/14/24	5/14/24 14:55	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School 52

Sample Description:

Work Order: 24E0537

Date Received: 5/3/2024

Field Sample #: (8) 52-01-CR-IN-104-T

Sampled: 4/25/2024 06:48

Sample ID: 24E0537-08

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	2.5	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	5/14/24	5/14/24 14:58	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School 52

Sample Description:

Work Order: 24E0537

Date Received: 5/3/2024

Field Sample #: (9) 52-01-CR-IN-101-T

Sampled: 4/25/2024 06:49

Sample ID: 24E0537-09

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	56	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	5/14/24	5/14/24 15:01	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School 52

Sample Description:

Work Order: 24E0537

Date Received: 5/3/2024

Field Sample #: (10) 52-01-MO-IN-100-T

Sampled: 4/25/2024 06:52

Sample ID: 24E0537-10

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	5/14/24	5/14/24 15:04	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School 52

Sample Description:

Work Order: 24E0537

Date Received: 5/3/2024

Field Sample #: (11) 52-01-NO-IN-113-T

Sampled: 4/25/2024 06:56

Sample ID: 24E0537-11

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	5/14/24	5/14/24 15:06	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School 52

Sample Description:

Work Order: 24E0537

Date Received: 5/3/2024

Field Sample #: (12) 52-01-CR-IN-112C-T

Sampled: 4/25/2024 06:58

Sample ID: 24E0537-12

Sample Matrix: Drinking Water



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School 52

Sample Description:

Work Order: 24E0537

Date Received: 5/3/2024

Field Sample #: (13) 52-01-CR-IN-115-T

Sampled: 4/25/2024 07:02

Sample ID: 24E0537-13

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	5/14/24	5/14/24 15:15	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School 52

Sample Description:

Work Order: 24E0537

Date Received: 5/3/2024

Field Sample #: (14) 52-01-CR-IN-115-B

Sampled: 4/25/2024 07:03

Sample ID: 24E0537-14

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	1.3	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	5/14/24	5/14/24 15:24	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School 52

Sample Description:

Work Order: 24E0537

Date Received: 5/3/2024

Field Sample #: (15) 52-01-CR-IN-116-T

Sampled: 4/25/2024 07:05

Sample ID: 24E0537-15

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	5/14/24	5/14/24 15:27	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School 52

Sample Description:

Work Order: 24E0537

Date Received: 5/3/2024

Field Sample #: (16) 52-01-CR-IN-114-T

Sampled: 4/25/2024 07:07

Sample ID: 24E0537-16

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	19	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	5/14/24	5/14/24 15:30	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School 52

Sample Description:

Work Order: 24E0537

Date Received: 5/3/2024

Field Sample #: (17) 52-02-CR-IN-220-T

Sampled: 4/25/2024 07:13

Sample ID: 24E0537-17

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	26	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	5/14/24	5/14/24 15:33	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School 52

Sample Description:

Work Order: 24E0537

Date Received: 5/3/2024

Field Sample #: (18) 52-02-HA-BY-219-F

Sampled: 4/25/2024 07:16

Sample ID: 24E0537-18

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	5/14/24	5/14/24 15:36	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School 52

Sample Description:

Work Order: 24E0537

Date Received: 5/3/2024

Field Sample #: (19) 52-02-HA-BY-219-BF

Sampled: 4/25/2024 07:17

Sample ID: 24E0537-19

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	5/14/24	5/14/24 15:39	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School 52

Sample Description:

Work Order: 24E0537

Date Received: 5/3/2024

Field Sample #: (20) 52-02-HA-BY-216-F

Sampled: 4/25/2024 07:28

Sample ID: 24E0537-20

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	5/14/24	5/14/24 15:42	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School 52

Sample Description:

Work Order: 24E0537

Date Received: 5/3/2024

Field Sample #: (21) 52-02-HA-BY-216-BF

Sampled: 4/25/2024 07:29

Sample ID: 24E0537-21

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	5/14/24	5/14/24 15:44	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School 52

Sample Description:

Work Order: 24E0537

Date Received: 5/3/2024

Field Sample #: (22) 52-02-RM-IN-210A-T

Sampled: 4/25/2024 07:33

Sample ID: 24E0537-22

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	48	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	5/14/24	5/14/24 16:02	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School 52

Sample Description:

Work Order: 24E0537

Date Received: 5/3/2024

Field Sample #: (23) 52-02-CR-IN-201-T

Sampled: 4/25/2024 07:35

Sample ID: 24E0537-23

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	12	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	5/14/24	5/14/24 16:05	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School 52

Sample Description:

Work Order: 24E0537

Date Received: 5/3/2024

Field Sample #: (24) 52-02-HA-BY-203-FL

Sampled: 4/25/2024 07:38

Sample ID: 24E0537-24

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	5/14/24	5/14/24 16:08	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School 52

Sample Description:

Work Order: 24E0537

Date Received: 5/3/2024

Field Sample #: (25) 52-02-HA-BY-203-FR

Sampled: 4/25/2024 07:38

Sample ID: 24E0537-25

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	5/14/24	5/14/24 16:11	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School 52

Sample Description:

Work Order: 24E0537

Date Received: 5/3/2024

Field Sample #: (26) 52-02-HA-BY-203-BF

Sampled: 4/25/2024 07:39

Sample ID: 24E0537-26

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	5/14/24	5/14/24 16:14	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School 52

Sample Description:

Work Order: 24E0537

Date Received: 5/3/2024

Field Sample #: (27) 52-02-HA-BY-205A-F

Sampled: 4/25/2024 07:42

Sample ID: 24E0537-27

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	5/14/24	5/14/24 16:17	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School 52

Sample Description:

Work Order: 24E0537

Date Received: 5/3/2024

Field Sample #: (28) 52-02-HA-BY-205A-BF

Sampled: 4/25/2024 07:43

Sample ID: 24E0537-28

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	5/14/24	5/14/24 16:20	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School 52

Sample Description:

Work Order: 24E0537

Date Received: 5/3/2024

Field Sample #: (29) 52-B-CF-IN-4-F

Sampled: 4/25/2024 07:53

Sample ID: 24E0537-29

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	5/14/24	5/14/24 16:23	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School 52

Sample Description:

Work Order: 24E0537

Date Received: 5/3/2024

Field Sample #: (30) 52-B-CF-IN-4-BF

Sampled: 4/25/2024 07:54

Sample ID: 24E0537-30

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	5/14/24	5/14/24 16:25	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School 52

Sample Description:

Work Order: 24E0537

Date Received: 5/3/2024

Field Sample #: (31) 52-B-K1-IN-2-T1

Sampled: 4/25/2024 07:57

Sample ID: 24E0537-31

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	5/14/24	5/14/24 16:34	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School 52

Sample Description:

Work Order: 24E0537

Date Received: 5/3/2024

Field Sample #: (32) 52-B-K1-IN-2-T2

Sampled: 4/25/2024 07:58

Sample ID: 24E0537-32

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	5/14/24	5/14/24 16:40	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School 52

Sample Description:

Work Order: 24E0537

Date Received: 5/3/2024

Field Sample #: (33) 52-B-K1-IN-2-T3

Sampled: 4/25/2024 07:59

Sample ID: 24E0537-33

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	5/14/24	5/14/24 16:43	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School 52

Sample Description:

Work Order: 24E0537

Date Received: 5/3/2024

Field Sample #: (34) 52-B-CR-IN-1-T

Sampled: 4/25/2024 08:00

Sample ID: 24E0537-34

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	4.6	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	5/14/24	5/14/24 16:46	JC

FLAG/QUALIFIER SUMMARY

*	QC result is outside of established limits.
†	Wide recovery limits established for difficult compound.
‡	Wide RPD limits established for difficult compound.
#	Data exceeded client recommended or regulatory level
ND	Not Detected
RL	Reporting Limit is at the level of quantitation (LOQ)
DL	Detection Limit is the lower limit of detection determined by the MDL study
MCL	Maximum Contaminant Level
	Percent recoveries and relative percent differences (RPDs) are determined by the software using values in the calculation which have not been rounded.
	No results have been blank subtracted unless specified in the case narrative section.
Z-01	#

CERTIFICATIONS

Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 200.8 Rev 5.4 in Drinking Water</i>	

Lead NB-CT,NB-NJ,NB-NY

Pace Analytical Services, LCC operates under the following certifications and accreditations:

Code	Description	Number	Expires
NB-CT	Connecticut Department of Public Health	PH-0823	09/30/2024
NB-NJ	New Jersey DEP	NY015 NELAP	06/30/2024
NB-NY	New York State Department of Health	10142 NELAP	03/31/2025



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 1 of 4
2480537-1

LAB ID: M34234		REPORT TO:		INVOICE TO:	
PROJECT NAME: RCSD - School 52		Company: Lozier Environmental Consulting, Inc.		Company: SAME	
TURNAROUND TIME: Standard Rush		Address: 2011 East Main Street		Address:	
Other:		City, State Zip: Rochester, New York 14609		City, State Zip:	
		Phone:		Phone:	
		Fax:		Fax:	
		E-Mail: vkaptein@lozierenv.com		Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS			
									LEAD			
1	52-01-HA-BY-104-F	4/25/2024	639		DW				X			
2	52-01-HA-BY-104-BF	4/25/2024	639		DW				X			
3	52-01-CR-IN-109-T	4/25/2024	641		DW				X			
4	52-01-CR-IN-107-T	4/25/2024	643		DW				X			
5	52-01-CR-IN-106-T	4/25/2024	645		DW				X			
6	52-01-HA-BY-105-F	4/25/2024	646		DW				X			
7	52-01-HA-BY-105-BF	4/25/2024	646		DW				X			
8	52-01-CR-IN-104-T	4/25/2024	648		DW				X			
9	52-01-CR-IN-101-T	4/25/2024	649		DW				X			
10	52-01-MO-IN-100-T	4/25/2024	652		DW				X			

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # 77610734 4418)

FED EX 6RD



24E0537



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com
Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 2 of 4
2460537

LAB ID: M34234		REPORT TO:		INVOICE TO:	
PROJECT NAME: RCSD - School 52		Company: Lozier Environmental Consulting, Inc.		Company: SAME	
TURNAROUND TIME: Standard Rush		Address: 2011 East Main Street		Address:	
Other:		City/State Zip: Rochester, New York 14609		City/State Zip:	
		Phone:		Phone:	
		Fax:		Fax:	
		E-Mail: vkaptein@lozierenv.com		Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS				
									LEAD				
11	52-01-NO-IN-113-T	4/25/2024	656		DW				X				
12	52-01-CR-IN-112C-T	4/25/2024	658		DW				X				
13	52-01-CR-IN-115-T	4/25/2024	702		DW				X				
14	52-01-CR-IN-115-B	4/25/2024	703		DW				X				
15	52-01-CR-IN-116-T	4/25/2024	705		DW				X				
16	52-01-CR-IN-114-T	4/25/2024	707		DW				X				
17	52-02-CR-IN-220-T	4/25/2024	713		DW				X				
18	52-02-HA-BY-219-F	4/25/2024	716		DW				X				
19	52-02-HA-BY-219-BF	4/25/2024	717		DW				X				
20	52-02-HA-BY-216-F	4/25/2024	728		DW				X				

Container Type (Circle One): Plastic Glass Sterile Other _____
Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

SAMPLED BY*: J. Savoie		DATE: 5/1/24		TIME: 1035	
RELINQUISHED BY*: VKaptein		DATE: 5/3/24		TIME: 1120	



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 3 of 4
2460537

LAB ID: M34234		REPORT TO:		INVOICE TO:	
PROJECT NAME: RCSD - School 52		Company: Lozier Environmental Consulting, Inc.		Company: SAME	
TURNAROUND TIME: Standard Rush		Address: 2011 East Main Street		Address:	
Other:		City/State Zip: Rochester, New York 14609		City/State Zip:	
		Phone:		Phone:	
		Fax:		Fax:	
		E-Mail: vkaptein@lozierenv.com		Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS			
									LEAD			
21	52-02-HA-BY-216-BF	4/25/2024	729		DW				X			
22	52-02-RM-IN-210A-T	4/25/2024	733		DW				X			
23	52-02-CR-IN-201-T	4/25/2024	735		DW				X			
24	52-02-HA-BY-203-FL	4/25/2024	738		DW				X			
25	52-02-HA-BY-203-FR	4/25/2024	738		DW				X			
26	52-02-HA-BY-203-BF	4/25/2024	739		DW				X			
27	52-02-HA-BY-205A-F	4/25/2024	742		DW				X			
28	52-02-HA-BY-205A-BF	4/25/2024	743		DW				X			
29	52-B-CF-IN-4-F	4/25/2024	753		DW				X			
30	52-B-CF-IN-4-BF	4/25/2024	754		DW				X			

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

SAMPLED BY*: J. Savoie

RELINQUISHED BY*: V. Kaptein DATE: 5/1/24 TIME: 1035

RECEIVED BY: *[Signature]* DATE: 5/3/24 TIME: 1120

RELINQUISHED BY*: DATE: TIME:</

Sample Condition Upon Receipt Form (SCUR)

Project # 2480537
Client: Lozier

Date and Initials of person:
Examining contents: _____
Label: _____
Deliver to location: _____
pH: _____

Thermometer Used: IRG4 Date: 5/3 Time: 1120 Initials: _____

State of Origin: NY

Cooler #1 Temp. °C 21.7 (Visual) 0.2 @ 0.0°C, -0.5 @ 20.0°C (Correction Factor) 21.9 (Actual) ☒ Samples on ice, cooling process has begun

Courier: ☒ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☐ Pace ☐ Other _____

Shipping Method: ☐ First Overnight ☐ Priority Overnight ☐ Standard Overnight ☒ Ground

☐ Other _____

Tracking # 7761 8734 4418

Custody Seal on Cooler/Box Present: ☐ Yes ☐ No Seals intact: ☐ Yes ☐ No Ice: Wet Blue Melted None

Packing Material: ☐ Bubble Wrap ☐ Bubble Bags ☐ None ☐ Other _____

Samples were collected by Pace employee ☐ Yes ☐ No ☐ N/A

Comments:

Chain of Custody Present	☒ Yes ☐ No ☐ N/A	
Chain of Custody Filled Out	☒ Yes ☐ No ☐ N/A	
Relinquished Signature on COC	☒ Yes ☐ No ☐ N/A	
Sampler Name and Signature on COC	☒ Yes ☐ No ☐ N/A	
Samples Arrived within Hold Time	☒ Yes ☐ No ☐ N/A	
Rush TAT requested on COC	☐ Yes ☐ No ☐ N/A	
Sufficient Volume	☒ Yes ☐ No ☐ N/A	
Correct Containers Used	☒ Yes ☐ No ☐ N/A	
Containers Intact	☒ Yes ☐ No ☐ N/A	
Sample Labels match COC (sample IDs & date/time of collection)	☒ Yes ☐ No ☐ N/A	
All containers needing acid/base preservation have been checked.	☐ Yes ☐ No ☐ N/A	Preservation Information:
All Containers needing preservation are found to be in compliance with EPA recommendation:	☐ Yes ☐ No ☐ N/A	Preservative: _____
Exceptions: Vials, Microbiology, O&G, Metals		Lot #/Trace #: _____
		Date: _____ Time: _____
		Initials: _____
Headspace in VOA Vials? (>6mm):	☐ Yes ☐ No ☐ N/A	
Trip Blank Present:	☐ Yes ☐ No ☐ N/A	

Additional Login Comments:

Client notification/ Resolution

Person Contacted: _____ Date/Time: _____
Comments/Resolution: _____