


May 8, 2024

V Kaptein
NB-Lozier Environmental Consulting, Inc
2011 E Main Street
Rochester, NY 14609

Project Location: RCSD-School Without Walls
Project Number: RCSD-School Without Walls
Laboratory Work Order Number: 24D3242

Enclosed are results of analyses for samples received by the laboratory on April 26, 2024. If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Project Manager



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

NB-Lozier Environmental Consulting, Inc
2011 E Main Street
Rochester, NY 14609
ATTN: V Kaptein

REPORT DATE: 5/8/2024

PURCHASE ORDER NUMBER: M34158

PROJECT NUMBER: RCSD-School Without Walls

ANALYTICAL SUMMARY

WORK ORDER NUMBER: 24D3242

The results of analyses performed on the following samples submitted to Pace Analytical Services, LLC - Newburgh are found in this report.

PROJECT LOCATION: RCSD-School Without Walls

FIELD SAMPLE #	LAB ID:	MATRIX	SAMPLE DESCRIPTION	TEST	SUB LAB
SWW-01-IN-MO-101-T	24D3242-01	Drinking Water		EPA 200.8 Rev 5.4	
SWW-01-IN-RM-104-T1	24D3242-02	Drinking Water		EPA 200.8 Rev 5.4	
SWW-01-IN-RM-104-T2	24D3242-03	Drinking Water		EPA 200.8 Rev 5.4	
SWW-01-IN-RM-104-T3	24D3242-04	Drinking Water		EPA 200.8 Rev 5.4 (1994)	
SWW-01-IN-RM-202-T	24D3242-05	Drinking Water		EPA 200.8 Rev 5.4	
SWW-01-HA-BY-203-FL	24D3242-06	Drinking Water		EPA 200.8 Rev 5.4	
SWW-01-HA-BY-203-FR	24D3242-07	Drinking Water		EPA 200.8 Rev 5.4	
SWW-01-HA-BY-203-BF	24D3242-08	Drinking Water		EPA 200.8 Rev 5.4	
SWW-01-IN-RM-109-T	24D3242-09	Drinking Water		EPA 200.8 Rev 5.4	
SWW-01-HA-BY-109-F	24D3242-10	Drinking Water		EPA 200.8 Rev 5.4	
SWW-01-HA-BY-109-BF	24D3242-11	Drinking Water		EPA 200.8 Rev 5.4	
SWW-01-HA-BY-119-F	24D3242-12	Drinking Water		EPA 200.8 Rev 5.4	
SWW-01-HA-BY-119-BF	24D3242-13	Drinking Water		EPA 200.8 Rev 5.4	
SWW-01-IN-RM-130-T	24D3242-14	Drinking Water		EPA 200.8 Rev 5.4	
SWW-01-IN-RM-137-T	24D3242-15	Drinking Water		EPA 200.8 Rev 5.4	
SWW-01-IN-KI-105-T1	24D3242-16	Drinking Water		EPA 200.8 Rev 5.4	
SWW-01-IN-KI-105-T2	24D3242-17	Drinking Water		EPA 200.8 Rev 5.4	
SWW-01-IN-KI-105-T3	24D3242-18	Drinking Water		EPA 200.8 Rev 5.4	
SWW-01-IN-KI-105-T4	24D3242-19	Drinking Water		EPA 200.8 Rev 5.4	

CASE NARRATIVE SUMMARY

All reported results are within defined laboratory quality control objectives unless listed below or otherwise qualified in this report.

EPA 200.8 Rev 5.4

Qualifications:

Z-01

#

Analyte & Samples(s) Qualified:

Lead

24D3242-17[SWW-01-IN-KI-105-T2]

EPA 200.8 Rev 5.4 (1994)

Qualifications:

Z-01

#


Analyte & Samples(s) Qualified:

Lead

24D3242-04[SWW-01-IN-RM-104-T3]

The results of analyses reported only relate to samples submitted to the Pace Analytical Services, LLC - Newburgh for testing.

I certify that the analyses listed above, unless specifically listed as subcontracted, if any, were performed under my direction according to the approved methodologies listed in this document, and that based upon my inquiry of those individuals immediately responsible for obtaining the information, the material contained in this report is, to the best of my knowledge and belief, accurate and complete.



Renee Cusack
PM



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School Without Walls

Sample Description:

Work Order: 24D3242

Date Received: 4/26/2024

Sampled: 4/24/2024 06:37

Field Sample #: SWW-01-IN-MO-101-T

Sample ID: 24D3242-01

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/29/24	4/30/24 15:54	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School Without Walls

Sample Description:

Work Order: 24D3242

Date Received: 4/26/2024

Sampled: 4/24/2024 06:45

Field Sample #: SWW-01-IN-RM-104-T1

Sample ID: 24D3242-02

Sample Matrix: Drinking Water

Metals Analyses (Total)											
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL							Prepared	Analyzed	
Lead	1.4	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	4/29/24	4/30/24 15:56	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School Without Walls

Sample Description:

Work Order: 24D3242

Date Received: 4/26/2024

Field Sample #: SWW-01-IN-RM-104-T2

Sampled: 4/24/2024 06:47

Sample ID: 24D3242-03

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	3.4	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/29/24	4/30/24 15:58	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School Without Walls

Sample Description:

Work Order: 24D3242

Date Received: 4/26/2024

Field Sample #: SWW-01-IN-RM-104-T3

Sampled: 4/24/2024 06:48

Sample ID: 24D3242-04

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	15	1.5		µg/L	1	Z-01	EPA 200.8 Rev 5.4 (1994)	4/29/24	5/7/24 18:51	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School Without Walls

Sample Description:

Work Order: 24D3242

Date Received: 4/26/2024

Field Sample #: SWW-01-IN-RM-202-T

Sampled: 4/24/2024 06:53

Sample ID: 24D3242-05

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/29/24	4/30/24 16:00	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School Without Walls

Sample Description:

Work Order: 24D3242

Date Received: 4/26/2024

Field Sample #: SWW-01-HA-BY-203-FL

Sampled: 4/24/2024 06:56

Sample ID: 24D3242-06

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/29/24	4/30/24 16:02	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School Without Walls

Sample Description:

Work Order: 24D3242

Date Received: 4/26/2024

Sampled: 4/24/2024 06:57

Field Sample #: SWW-01-HA-BY-203-FR

Sample ID: 24D3242-07

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/29/24	4/30/24 16:04	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School Without Walls

Sample Description:

Work Order: 24D3242

Date Received: 4/26/2024

Field Sample #: SWW-01-HA-BY-203-BF

Sampled: 4/24/2024 06:57

Sample ID: 24D3242-08

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/29/24	4/30/24 16:06	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School Without Walls

Sample Description:

Work Order: 24D3242

Date Received: 4/26/2024

Sampled: 4/24/2024 07:02

Field Sample #: SWW-01-IN-RM-109-T

Sample ID: 24D3242-09

Sample Matrix: Drinking Water

Metals Analyses (Total)											
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time	
		RL							Prepared	Analyzed	Analyst
Lead	1.9	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	4/29/24	4/30/24 16:08	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School Without Walls

Sample Description:

Work Order: 24D3242

Date Received: 4/26/2024

Field Sample #: SWW-01-HA-BY-109-F

Sampled: 4/24/2024 07:04

Sample ID: 24D3242-10

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/29/24	4/30/24 16:19	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School Without Walls

Sample Description:

Work Order: 24D3242

Date Received: 4/26/2024

Field Sample #: SWW-01-HA-BY-109-BF

Sampled: 4/24/2024 07:04

Sample ID: 24D3242-11

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/29/24	4/30/24 16:21	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School Without Walls

Sample Description:

Work Order: 24D3242

Date Received: 4/26/2024

Field Sample #: SWW-01-HA-BY-119-F

Sampled: 4/24/2024 07:08

Sample ID: 24D3242-12

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/29/24	4/30/24 16:23	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School Without Walls

Sample Description:

Work Order: 24D3242

Date Received: 4/26/2024

Field Sample #: SWW-01-HA-BY-119-BF

Sampled: 4/24/2024 07:09

Sample ID: 24D3242-13

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/29/24	4/30/24 16:25	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School Without Walls

Sample Description:

Work Order: 24D3242

Date Received: 4/26/2024

Field Sample #: SWW-01-IN-RM-130-T

Sampled: 4/24/2024 07:13

Sample ID: 24D3242-14

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	1.2	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/29/24	4/30/24 16:27	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School Without Walls

Sample Description:

Work Order: 24D3242

Date Received: 4/26/2024

Field Sample #: SWW-01-IN-RM-137-T

Sampled: 4/24/2024 07:16

Sample ID: 24D3242-15

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	1.3	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/29/24	4/30/24 16:29	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School Without Walls

Sample Description:

Work Order: 24D3242

Date Received: 4/26/2024

Sampled: 4/24/2024 07:19

Field Sample #: SWW-01-IN-KI-105-T1

Sample ID: 24D3242-16

Sample Matrix: Drinking Water

Metals Analyses (Total)											
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time	
		RL							Prepared	Analyzed	Analyst
Lead	2.2	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	4/29/24	4/30/24 16:31	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School Without Walls

Sample Description:

Work Order: 24D3242

Date Received: 4/26/2024

Field Sample #: SWW-01-IN-KI-105-T2

Sampled: 4/24/2024 07:21

Sample ID: 24D3242-17

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	21	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	4/29/24	4/30/24 16:33	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School Without Walls

Sample Description:

Work Order: 24D3242

Date Received: 4/26/2024

Field Sample #: SWW-01-IN-KI-105-T3

Sampled: 4/24/2024 07:22

Sample ID: 24D3242-18

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	2.4	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/29/24	4/30/24 16:35	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School Without Walls

Sample Description:

Work Order: 24D3242

Date Received: 4/26/2024

Field Sample #: SWW-01-IN-KI-105-T4

Sampled: 4/24/2024 07:22

Sample ID: 24D3242-19

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	1.5	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	4/29/24	4/30/24 16:41	JC

FLAG/QUALIFIER SUMMARY

*	QC result is outside of established limits.
†	Wide recovery limits established for difficult compound.
‡	Wide RPD limits established for difficult compound.
#	Data exceeded client recommended or regulatory level
ND	Not Detected
RL	Reporting Limit is at the level of quantitation (LOQ)
DL	Detection Limit is the lower limit of detection determined by the MDL study
MCL	Maximum Contaminant Level
	Percent recoveries and relative percent differences (RPDs) are determined by the software using values in the calculation which have not been rounded.
	No results have been blank subtracted unless specified in the case narrative section.
Z-01	#

CERTIFICATIONS

Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 200.8 Rev 5.4 in Drinking Water</i>	
Lead	NB-CT,NB-NJ,NB-NY
<i>EPA 200.8 Rev 5.4 (1994) in Water</i>	
Lead	NB-CT,NB-NJ,NB-NY

Pace Analytical Services, LCC operates under the following certifications and accreditations:

Code	Description	Number	Expires
NB-CT	Connecticut Department of Public Health	PH-0823	09/30/2024
NB-NJ	New Jersey DEP	NY015 NELAP	06/30/2024
NB-NY	New York State Department of Health	10142 NELAP	03/31/2025



LAB ID: M34158		REPORT TO:		INVOICE TO:	
PROJECT NAME: RCSD - School Without Walls		Company: Lozier Environmental Consulting, Inc.		Company: SAME	
TURNAROUND TIME: Standard Rush		Address: 2011 East Main Street		Address:	
Other:		City/State Zip: Rochester, New York 14609		City/State Zip:	
		Phone:		Phone:	
		E-Mail: vkaptein@lozierenv.com		Fax:	
				Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	LEAD	REQUESTED ANALYSIS			
1	SWW-01-IN-MO-101-T	4/24/2024	637		DW				X				
2	SWW-01-IN-RM-104-T1	4/24/2024	645		DW				X				
3	SWW-01-IN-RM-104-T2	4/24/2024	647		DW				X				
4	SWW-01-IN-RM-104-T3	4/24/2024	648		DW				X				
5	SWW-01-IN-RM-202-T	4/24/2024	653		DW				X				
6	SWW-01-HA-BY-203-FL	4/24/2024	656		DW				X				
7	SWW-01-HA-BY-203-FR	4/24/2024	657		DW				X				
8	SWW-01-HA-BY-203-BF	4/24/2024	657		DW				X				
9	SWW-01-IN-RM-109-T	4/24/2024	702		DW				X				
10	SWW-01-HA-BY-109-F	4/24/2024	704		DW				X				



Container Type (Circle One): Plastic Glass Sterile Other _____
Delivery (Circle One): Client Drop-Off / Courier (Tracking # 776087743383)

SAMPLED BY: J. Savoie
RELINQUISHED BY: V. Kaptein
RECEIVED BY: [Signature]
RELINQUISHED BY: [Signature]

DATE: 4/24/24	TIME: 1020
DATE: 4/24/24	TIME: 1100
DATE:	TIME:
DATE:	TIME:
DATE:	TIME:
DATE:	TIME:

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDE: HNO3-	FOR POTABLE WATER ON COLIFORM BACTERIA:
TOTAL NUMBER OF CONTAINERS: 19	Present Absent
CUSTODY SEAL INTACT? YES NO	If Present, Date Client is contacted with result:
SAMPLE ON ICE? YES (NO)	Date:
TEMPERATURE: 14.8 C	Contacted By:
SAMPLE IN COMPLIANCE: YES NO	



2011 East Main Street, Rochester, NY 14609 Phone (585) 654-9080 Fax (585) 654-9662
Web: LozierEnv.com E-Mail: support@lozierenv.com

REPORT TO:		INVOICE TO:	
Company:	Lozier Environmental Consulting, Inc.	Company:	SAME
Address:	2011 East Main Street	Address:	
City, State Zip:	Rochester, New York 14609	City, State Zip:	
Phone:		Phone:	
Fax:		Fax:	
E-Mail:	vkaptein@lozierenv.com	Purchase Order #:	

LAB ID: M34158	PROJECT NAME: RCSD - School Without Walls	TURNAROUND TIME: Standard Rush
Other:		

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS			
									LEAD			
11	SWW-01-HA-BY-109-BF	4/24/2024	704		DW				X			
12	SWW-01-HA-BY-119-F	4/24/2024	708		DW				X			
13	SWW-01-HA-BY-119-BF	4/24/2024	709		DW				X			
14	SWW-01-IN-RM-130-T	4/24/2024	713		DW				X			
15	SWW-01-IN-RM-137-T	4/24/2024	716		DW				X			
16	SWW-01-IN-KI-105-T1	4/24/2024	719		DW				X			
17	SWW-01-IN-KI-105-T2	4/24/2024	721		DW				X			
18	SWW-01-IN-KI-105-T3	4/24/2024	722		DW				X			
19	SWW-01-IN-KI-105-T4	4/24/2024	722		DW				X			

Container Type (Circle One): Plastic Glass Sterile Other _____
Delivery (Circle One): Client Drop-Off / Courier (Tracking # 77608774 3383)

SAMPLED BY: J. Savoie

RELINQUISHED BY: V. Kaptein	DATE: 4/24/24	TIME: 1020
RECEIVED BY: <i>[Signature]</i>	DATE: 4/26/24	TIME: 1100
RELINQUISHED BY:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:
RELINQUISHED BY:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDE: _____ HNO3- _____	FOR POTABLE WATER ON
TOTAL NUMBER OF CONTAINERS: 19	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES NO	Present Absent
SAMPLE ON ICE? YES <u>NO</u>	If Present, Date Client is
TEMPERATURE: 40.2 C	contacted with result:
SAMPLE IN COMPLIANCE: YES NO	Date: _____
	Contacted By: _____

Sample Condition Upon Receipt Form (SCUR)

Project # 2403242

Client: LOZIER

Date and Initials of person:

Examining contents: _____

Label: _____

Deliver to location: _____

pH: _____

Thermometer Used: 1RG4

Date: 4/26

Time: 1100

Initials: _____

State of Origin: NY

Cooler #1 Temp.°C 14.8 (Visual) 0.2 (Correction Factor) _____ (Actual)

☐ Samples on ice, cooling process has begun

Courier: ☒ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☐ Pace

☐ Other _____

Shipping Method: ☐ First Overnight ☐ Priority Overnight ☐ Standard Overnight ☒ Ground

☐ Other _____

Tracking # 7760 8774 3383

Custody Seal on Cooler/Box Present: ☐ Yes ☐ No

Seals intact: ☐ Yes ☐ No

Ice: Wet Blue Melted None

Packing Material: ☐ Bubble Wrap ☐ Bubble Bags ☐ None ☐ Other _____

Samples were collected by Pace employee ☐ Yes ☐ No ☐ N/A

Comments:

Chain of Custody Present	☒ Yes ☐ No ☐ N/A	
Chain of Custody Filled Out	☒ Yes ☐ No ☐ N/A	
Relinquished Signature on COC	☒ Yes ☐ No ☐ N/A	
Sampler Name and Signature on COC	☒ Yes ☐ No ☐ N/A	
Samples Arrived within Hold Time	☒ Yes ☐ No ☐ N/A	
Rush TAT requested on COC	☐ Yes ☒ No ☐ N/A	
Sufficient Volume	☒ Yes ☐ No ☐ N/A	
Correct Containers Used	☒ Yes ☐ No ☐ N/A	
Containers Intact	☒ Yes ☐ No ☐ N/A	
Sample Labels match COC (sample IDs & date/time of collection)	☒ Yes ☐ No ☐ N/A	
All containers needing acid/base preservation have been checked.	☐ Yes ☐ No ☐ N/A	Preservation Information: Preservative: _____
All Containers needing preservation are found to be in compliance with EPA recommendation:	☐ Yes ☐ No ☐ N/A	Lot #/Trace #: _____
Exceptions: Vials, Microbiology, O&G, Metals		Date: _____ Time: _____
		Initials: _____
Headspace in VOA Vials? (>6mm):	☐ Yes ☐ No ☐ N/A	
Trip Blank Present:	☐ Yes ☐ No ☐ N/A	

Additional Login Comments:

Client notification/ Resolution

Person Contacted: _____ Date/Time: _____

Comments/Resolution: _____