



January 27, 2025

Amy Kaptein
Lozier Environmental Consulting, Inc
2011 E. Main St.
Rochester, NY 14609

RE: Project: RCSD - Wilson HS
Pace Project No.: 70331629

Dear Amy Kaptein:

Enclosed are the analytical results for sample(s) received by the laboratory on January 08, 2025. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Newburgh

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in cursive script that reads "Renee Cusack".

Renee Cusack
renee.cusack@pacelabs.com
(845)562-0890
Project Manager

Enclosures

cc: Amy Pusateri, Lozier Environmental Consulting Inc.



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



CERTIFICATIONS

Project: RCSD - Wilson HS

Pace Project No.: 70331629

Pace Analytical Services, LLC- Newburgh, NY

315 Fullerton Avenue, Newburgh, NY 12550

New York Certification #: 10142 Primary Accrediting Body

New Jersey Certification #: NY015

Connecticut Certification #: PH-0823

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE SUMMARY

Project: RCSD - Wilson HS

Pace Project No.: 70331629

Lab ID	Sample ID	Matrix	Date Collected	Date Received
70331629001	WHS-03-HA-BY-324-F	Drinking Water	12/11/24 06:10	01/08/25 10:30
70331629002	WHS-03-HA-BY-324-BF	Drinking Water	12/11/24 06:10	01/08/25 10:30
70331629003	WHS-03-HA-BY-304-F	Drinking Water	12/11/24 06:22	01/08/25 10:30
70331629004	WHS-03-HA-BY-304-BF	Drinking Water	12/11/24 06:22	01/08/25 10:30
70331629005	WHS-02-HA-BY-204-F	Drinking Water	12/11/24 06:26	01/08/25 10:30
70331629006	WHS-02-HA-BY-204-F	Drinking Water	12/11/24 06:33	01/08/25 10:30
70331629007	WHS-02-HA-BY-204-BF	Drinking Water	12/11/24 06:33	01/08/25 10:30
70331629008	WHS-01-HA-BY-124-F	Drinking Water	12/11/24 06:35	01/08/25 10:30
70331629009	WHS-01-HA-BY-124-BF	Drinking Water	12/11/24 06:35	01/08/25 10:30
70331629010	WHS-01-CR-IN-121-TL	Drinking Water	12/11/24 06:39	01/08/25 10:30
70331629011	WHS-01-CR-IN-121-TR	Drinking Water	12/11/24 06:39	01/08/25 10:30
70331629012	WHS-01-CR-IN-121-SR	Drinking Water	12/11/24 06:39	01/08/25 10:30
70331629013	WHS-01-MO-IN-105-T	Drinking Water	12/11/24 06:50	01/08/25 10:30
70331629014	WHS-01-CR-IN-113-T	Drinking Water	12/11/24 06:54	01/08/25 10:30
70331629015	WHS-01-HA-BY-104-F	Drinking Water	12/11/24 06:56	01/08/25 10:30
70331629016	WHS-01-HA-BY-105-BF	Drinking Water	12/11/24 06:56	01/08/25 10:30
70331629017	WHS-01-HA-BY-166-F	Drinking Water	12/11/24 07:01	01/08/25 10:30
70331629018	WHS-01-HA-BY-166-BF	Drinking Water	12/11/24 07:01	01/08/25 10:30
70331629019	WHS-B-IN-NO-B5-TL	Drinking Water	12/11/24 07:07	01/08/25 10:30
70331629020	WHS-B-IN-NO-B5-TR	Drinking Water	12/11/24 07:07	01/08/25 10:30
70331629021	WHS-B-CR-IN-B5C-T	Drinking Water	12/11/24 07:08	01/08/25 10:30
70331629022	WHS-B-CR-IN-B4-T	Drinking Water	12/11/24 07:10	01/08/25 10:30
70331629023	WHS-B-CR-IN-B2-T	Drinking Water	12/11/24 07:11	01/08/25 10:30
70331629024	WHS-B-CR-IN-B1-T	Drinking Water	12/11/24 07:13	01/08/25 10:30
70331629025	WHS-B-CAFE-IN-B41-T	Drinking Water	12/12/24 06:17	01/08/25 10:30
70331629026	WHS-B-CAFE-IN-B43-T1	Drinking Water	12/12/24 06:19	01/08/25 10:30
70331629027	WHS-B-CAFE-IN-B43B-T2	Drinking Water	12/12/24 06:20	01/08/25 10:30
70331629028	WHS-B-CAFE-IN-B434B-T3	Drinking Water	12/12/24 06:21	01/08/25 10:30
70331629029	WHS-B-CAFE-IN-B45-F	Drinking Water	12/12/24 06:23	01/08/25 10:30
70331629030	WHS-B-CAFE-IN-B45-BF	Drinking Water	12/12/24 06:23	01/08/25 10:30
70331629031	WHS-B-IN-BM-B44A-T	Drinking Water	12/12/24 06:25	01/08/25 10:30
70331629032	WHS-B-CR-IN-B44-T	Drinking Water	12/12/24 06:25	01/08/25 10:30
70331629033	WHS-B-CR-IN-B46-F	Drinking Water	12/12/24 06:26	01/08/25 10:30
70331629034	WHS-B-CR-IN-B6-TM	Drinking Water	12/12/24 06:39	01/08/25 10:30
70331629035	WHS-B-CR-IN-B6-TR	Drinking Water	12/12/24 06:40	01/08/25 10:30
70331629036	WHS-B-HA-BY-070-FL	Drinking Water	12/12/24 06:44	01/08/25 10:30
70331629037	WHS-B-HA-BY-070-FR	Drinking Water	12/12/24 06:44	01/08/25 10:30

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE ANALYTE COUNT

Project: RCSD - Wilson HS

Pace Project No.: 70331629

Lab ID	Sample ID	Method	Analysts	Analytes Reported
70331629001	WHS-03-HA-BY-324-F	EPA 200.8, Rev. 5.4	JC1	1
70331629002	WHS-03-HA-BY-324-BF	EPA 200.8, Rev. 5.4	JC1	1
70331629003	WHS-03-HA-BY-304-F	EPA 200.8, Rev. 5.4	JC1	1
70331629004	WHS-03-HA-BY-304-BF	EPA 200.8, Rev. 5.4	JC1	1
70331629005	WHS-02-HA-BY-204-F	EPA 200.8, Rev. 5.4	JC1	1
70331629006	WHS-02-HA-BY-204-F	EPA 200.8, Rev. 5.4	JC1	1
70331629007	WHS-02-HA-BY-204-BF	EPA 200.8, Rev. 5.4	JC1	1
70331629008	WHS-01-HA-BY-124-F	EPA 200.8, Rev. 5.4	JC1	1
70331629009	WHS-01-HA-BY-124-BF	EPA 200.8, Rev. 5.4	JC1	1
70331629010	WHS-01-CR-IN-121-TL	EPA 200.8, Rev. 5.4	JC1	1
70331629011	WHS-01-CR-IN-121-TR	EPA 200.8, Rev. 5.4	JC1	1
70331629012	WHS-01-CR-IN-121-SR	EPA 200.8, Rev. 5.4	JC1	1
70331629013	WHS-01-MO-IN-105-T	EPA 200.8, Rev. 5.4	JC1	1
70331629014	WHS-01-CR-IN-113-T	EPA 200.8, Rev. 5.4	JC1	1
70331629015	WHS-01-HA-BY-104-F	EPA 200.8, Rev. 5.4	JC1	1
70331629016	WHS-01-HA-BY-105-BF	EPA 200.8, Rev. 5.4	JC1	1
70331629017	WHS-01-HA-BY-166-F	EPA 200.8, Rev. 5.4	JC1	1
70331629018	WHS-01-HA-BY-166-BF	EPA 200.8, Rev. 5.4	JC1	1
70331629019	WHS-B-IN-NO-B5-TL	EPA 200.8, Rev. 5.4	JC1	1
70331629020	WHS-B-IN-NO-B5-TR	EPA 200.8, Rev. 5.4	JC1	1
70331629021	WHS-B-CR-IN-B5C-T	EPA 200.8, Rev. 5.4	JC1	1
70331629022	WHS-B-CR-IN-B4-T	EPA 200.8, Rev. 5.4	JC1	1
70331629023	WHS-B-CR-IN-B2-T	EPA 200.8, Rev. 5.4	JC1	1
70331629024	WHS-B-CR-IN-B1-T	EPA 200.8, Rev. 5.4	JC1	1
70331629025	WHS-B-CAFE-IN-B41-T	EPA 200.8, Rev. 5.4	JC1	1
70331629026	WHS-B-CAFE-IN-B43-T1	EPA 200.8, Rev. 5.4	JC1	1
70331629027	WHS-B-CAFE-IN-B43B-T2	EPA 200.8, Rev. 5.4	JC1	1
70331629028	WHS-B-CAFE-IN-B434B-T3	EPA 200.8, Rev. 5.4	JC1	1
70331629029	WHS-B-CAFE-IN-B45-F	EPA 200.8, Rev. 5.4	JC1	1
70331629030	WHS-B-CAFE-IN-B45-BF	EPA 200.8, Rev. 5.4	JC1	1
70331629031	WHS-B-IN-BM-B44A-T	EPA 200.8, Rev. 5.4	JC1	1
70331629032	WHS-B-CR-IN-B44-T	EPA 200.8, Rev. 5.4	JC1	1
70331629033	WHS-B-CR-IN-B46-F	EPA 200.8, Rev. 5.4	JC1	1
70331629034	WHS-B-CR-IN-B6-TM	EPA 200.8, Rev. 5.4	JC1	1
70331629035	WHS-B-CR-IN-B6-TR	EPA 200.8, Rev. 5.4	JC1	1
70331629036	WHS-B-HA-BY-070-FL	EPA 200.8, Rev. 5.4	JC1	1
70331629037	WHS-B-HA-BY-070-FR	EPA 200.8, Rev. 5.4	JC1	1

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE ANALYTE COUNT

Project: RCSD - Wilson HS

Pace Project No.: 70331629

Lab ID	Sample ID	Method	Analysts	Analytes Reported
PASI-NB = Pace Analytical Services - Newburgh				

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



PROJECT NARRATIVE

Project: RCSD - Wilson HS

Pace Project No.: 70331629

Method: EPA 200.8, Rev. 5.4

Description: NB 200.8 ICPMS, DW Digestion

Client: Lozier Environmental Consulting, Inc.

Date: January 27, 2025

General Information:

1 sample was analyzed for EPA 200.8, Rev. 5.4 by Pace Analytical Services Newburgh. All samples were received in acceptable condition with any exceptions noted below or on the chain-of custody and/or the sample condition upon receipt form (SCUR) attached at the end of this report.

Hold Time:

The samples were analyzed within the method required hold times with any exceptions noted below.

Sample Preparation:

The samples were prepared in accordance with EPA 200.8, Rev. 5.4 with any exceptions noted below.

Initial Calibrations (including MS Tune as applicable):

All criteria were within method requirements with any exceptions noted below.

Continuing Calibration:

All criteria were within method requirements with any exceptions noted below.

Internal Standards:

All internal standards were within QC limits with any exceptions noted below.

Surrogates:

All surrogates were within QC limits with any exceptions noted below.

Method Blank:

All analytes were below the report limit in the method blank, where applicable, with any exceptions noted below.

Laboratory Control Spike:

All laboratory control spike compounds were within QC limits with any exceptions noted below.

Matrix Spikes:

All percent recoveries and relative percent differences (RPDs) were within acceptance criteria with any exceptions noted below.

Duplicate Sample:

All duplicate sample results were within method acceptance criteria with any exceptions noted below.

Additional Comments:

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



PROJECT NARRATIVE

Project: RCSD - Wilson HS

Pace Project No.: 70331629

Method: EPA 200.8, Rev. 5.4

Description: NB 200.8 ICPMS DW No Prep

Client: Lozier Environmental Consulting, Inc.

Date: January 27, 2025

General Information:

36 samples were analyzed for EPA 200.8, Rev. 5.4 by Pace Analytical Services Newburgh. All samples were received in acceptable condition with any exceptions noted below or on the chain-of custody and/or the sample condition upon receipt form (SCUR) attached at the end of this report.

Hold Time:

The samples were analyzed within the method required hold times with any exceptions noted below.

Initial Calibrations (including MS Tune as applicable):

All criteria were within method requirements with any exceptions noted below.

Continuing Calibration:

All criteria were within method requirements with any exceptions noted below.

Internal Standards:

All internal standards were within QC limits with any exceptions noted below.

Surrogates:

All surrogates were within QC limits with any exceptions noted below.

Method Blank:

All analytes were below the report limit in the method blank, where applicable, with any exceptions noted below.

Laboratory Control Spike:

All laboratory control spike compounds were within QC limits with any exceptions noted below.

Matrix Spikes:

All percent recoveries and relative percent differences (RPDs) were within acceptance criteria with any exceptions noted below.

Duplicate Sample:

All duplicate sample results were within method acceptance criteria with any exceptions noted below.

Additional Comments:

This data package has been reviewed for quality and completeness and is approved for release.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD - Wilson HS

Pace Project No.: 70331629

Sample: WHS-03-HA-BY-324-F Lab ID: 70331629001 Collected: 12/11/24 06:10 Received: 01/08/25 10:30 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		01/17/25 17:03	7439-92-1	

Sample: WHS-03-HA-BY-324-BF Lab ID: 70331629002 Collected: 12/11/24 06:10 Received: 01/08/25 10:30 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		01/17/25 17:06	7439-92-1	

Sample: WHS-03-HA-BY-304-F Lab ID: 70331629003 Collected: 12/11/24 06:22 Received: 01/08/25 10:30 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	3.2	ug/L	1.0	15	1		01/17/25 17:09	7439-92-1	

Sample: WHS-03-HA-BY-304-BF Lab ID: 70331629004 Collected: 12/11/24 06:22 Received: 01/08/25 10:30 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	4.0	ug/L	1.0	15	1		01/17/25 17:11	7439-92-1	

Sample: WHS-02-HA-BY-204-F Lab ID: 70331629005 Collected: 12/11/24 06:26 Received: 01/08/25 10:30 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		01/17/25 17:14	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD - Wilson HS

Pace Project No.: 70331629

Sample: WHS-02-HA-BY-204-F		Lab ID: 70331629006		Collected: 12/11/24 06:33		Received: 01/08/25 10:30		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/17/25 17:17	7439-92-1	
Sample: WHS-02-HA-BY-204-BF		Lab ID: 70331629007		Collected: 12/11/24 06:33		Received: 01/08/25 10:30		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/17/25 17:19	7439-92-1	
Sample: WHS-01-HA-BY-124-F		Lab ID: 70331629008		Collected: 12/11/24 06:35		Received: 01/08/25 10:30		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/17/25 17:22	7439-92-1	
Sample: WHS-01-HA-BY-124-BF		Lab ID: 70331629009		Collected: 12/11/24 06:35		Received: 01/08/25 10:30		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/17/25 17:38	7439-92-1	
Sample: WHS-01-CR-IN-121-TL		Lab ID: 70331629010		Collected: 12/11/24 06:39		Received: 01/08/25 10:30		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS, DW Digestion		Analytical Method: EPA 200.8, Rev. 5.4 Preparation Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	64.7	ug/L	1.0	15	1	01/16/25 09:44	01/22/25 17:30	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD - Wilson HS
Pace Project No.: 70331629

Sample: WHS-01-CR-IN-121-TR		Lab ID: 70331629011		Collected: 12/11/24 06:39		Received: 01/08/25 10:30		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	9.8	ug/L	1.0	15	1		01/17/25 17:41	7439-92-1	
Sample: WHS-01-CR-IN-121-SR		Lab ID: 70331629012		Collected: 12/11/24 06:39		Received: 01/08/25 10:30		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	4.8	ug/L	1.0	15	1		01/17/25 17:44	7439-92-1	
Sample: WHS-01-MO-IN-105-T		Lab ID: 70331629013		Collected: 12/11/24 06:50		Received: 01/08/25 10:30		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	11.3	ug/L	1.0	15	1		01/17/25 17:47	7439-92-1	
Sample: WHS-01-CR-IN-113-T		Lab ID: 70331629014		Collected: 12/11/24 06:54		Received: 01/08/25 10:30		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	10.8	ug/L	1.0	15	1		01/17/25 17:49	7439-92-1	
Sample: WHS-01-HA-BY-104-F		Lab ID: 70331629015		Collected: 12/11/24 06:56		Received: 01/08/25 10:30		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/17/25 17:52	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD - Wilson HS

Pace Project No.: 70331629

Sample: WHS-01-HA-BY-105-BF Lab ID: 70331629016 Collected: 12/11/24 06:56 Received: 01/08/25 10:30 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		01/17/25 17:55	7439-92-1	

Sample: WHS-01-HA-BY-166-F Lab ID: 70331629017 Collected: 12/11/24 07:01 Received: 01/08/25 10:30 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		01/17/25 17:57	7439-92-1	

Sample: WHS-01-HA-BY-166-BF Lab ID: 70331629018 Collected: 12/11/24 07:01 Received: 01/08/25 10:30 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		01/17/25 18:00	7439-92-1	

Sample: WHS-B-IN-NO-B5-TL Lab ID: 70331629019 Collected: 12/11/24 07:07 Received: 01/08/25 10:30 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	2.4	ug/L	1.0	15	1		01/17/25 18:08	7439-92-1	

Sample: WHS-B-IN-NO-B5-TR Lab ID: 70331629020 Collected: 12/11/24 07:07 Received: 01/08/25 10:30 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	4.7	ug/L	1.0	15	1		01/17/25 18:14	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD - Wilson HS

Pace Project No.: 70331629

Sample: WHS-B-CR-IN-B5C-T Lab ID: 70331629021 Collected: 12/11/24 07:08 Received: 01/08/25 10:30 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	4.5	ug/L	1.0	15	1		01/17/25 18:16	7439-92-1	

Sample: WHS-B-CR-IN-B4-T Lab ID: 70331629022 Collected: 12/11/24 07:10 Received: 01/08/25 10:30 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	1.2	ug/L	1.0	15	1		01/17/25 18:19	7439-92-1	

Sample: WHS-B-CR-IN-B2-T Lab ID: 70331629023 Collected: 12/11/24 07:11 Received: 01/08/25 10:30 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	1.0	ug/L	1.0	15	1		01/17/25 18:22	7439-92-1	

Sample: WHS-B-CR-IN-B1-T Lab ID: 70331629024 Collected: 12/11/24 07:13 Received: 01/08/25 10:30 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	3.0	ug/L	1.0	15	1		01/17/25 18:24	7439-92-1	

Sample: WHS-B-CAFE-IN-B41-T Lab ID: 70331629025 Collected: 12/12/24 06:17 Received: 01/08/25 10:30 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	4.5	ug/L	1.0	15	1		01/17/25 18:27	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD - Wilson HS

Pace Project No.: 70331629

Sample: WHS-B-CAFE-IN-B43-T1 Lab ID: 70331629026 Collected: 12/12/24 06:19 Received: 01/08/25 10:30 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	9.5	ug/L	1.0	15	1		01/17/25 18:30	7439-92-1	

Sample: WHS-B-CAFE-IN-B43B-T2 Lab ID: 70331629027 Collected: 12/12/24 06:20 Received: 01/08/25 10:30 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	3.4	ug/L	1.0	15	1		01/17/25 18:33	7439-92-1	

Sample: WHS-B-CAFE-IN-B434B-T3 Lab ID: 70331629028 Collected: 12/12/24 06:21 Received: 01/08/25 10:30 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	3.5	ug/L	1.0	15	1		01/17/25 18:41	7439-92-1	

Sample: WHS-B-CAFE-IN-B45-F Lab ID: 70331629029 Collected: 12/12/24 06:23 Received: 01/08/25 10:30 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	4.6	ug/L	1.0	15	1		01/17/25 18:43	7439-92-1	

Sample: WHS-B-CAFE-IN-B45-BF Lab ID: 70331629030 Collected: 12/12/24 06:23 Received: 01/08/25 10:30 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	4.9	ug/L	1.0	15	1		01/17/25 18:54	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD - Wilson HS

Pace Project No.: 70331629

Sample: WHS-B-IN-BM-B44A-T Lab ID: 70331629031 Collected: 12/12/24 06:25 Received: 01/08/25 10:30 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	3.9	ug/L	1.0	15	1		01/17/25 18:57	7439-92-1	

Sample: WHS-B-CR-IN-B44-T Lab ID: 70331629032 Collected: 12/12/24 06:25 Received: 01/08/25 10:30 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	1.5	ug/L	1.0	15	1		01/17/25 19:00	7439-92-1	

Sample: WHS-B-CR-IN-B46-F Lab ID: 70331629033 Collected: 12/12/24 06:26 Received: 01/08/25 10:30 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		01/17/25 19:02	7439-92-1	

Sample: WHS-B-CR-IN-B6-TM Lab ID: 70331629034 Collected: 12/12/24 06:39 Received: 01/08/25 10:30 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	1.3	ug/L	1.0	15	1		01/17/25 19:05	7439-92-1	

Sample: WHS-B-CR-IN-B6-TR Lab ID: 70331629035 Collected: 12/12/24 06:40 Received: 01/08/25 10:30 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	7.4	ug/L	1.0	15	1		01/17/25 19:13	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD - Wilson HS

Pace Project No.: 70331629

Sample: WHS-B-HA-BY-070-FL		Lab ID: 70331629036		Collected: 12/12/24 06:44		Received: 01/08/25 10:30		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	1.2	ug/L	1.0	15	1		01/17/25 19:16	7439-92-1	

Sample: WHS-B-HA-BY-070-FR		Lab ID: 70331629037		Collected: 12/12/24 06:44		Received: 01/08/25 10:30		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	1.1	ug/L	1.0	15	1		01/17/25 19:19	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: RCSD - Wilson HS

Pace Project No.: 70331629

QC Batch: 380241

Analysis Method: EPA 200.8, Rev. 5.4

QC Batch Method: EPA 200.8, Rev. 5.4

Analysis Description: NB 200.8 ICPMS, DW Digestion

Laboratory: Pace Analytical Services - Newburgh

Associated Lab Samples: 70331629010

METHOD BLANK: 1995409

Matrix: Drinking Water

Associated Lab Samples: 70331629010

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	01/21/25 14:52	

LABORATORY CONTROL SAMPLE: 1995411

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	49.0	98	85-115	

MATRIX SPIKE SAMPLE: 1995415

Parameter	Units	70332019014 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	15.3	50	64.8	99	70-130	

SAMPLE DUPLICATE: 1995413

Parameter	Units	70332019014 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	15.3	15.2	1	20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: RCSD - Wilson HS

Pace Project No.: 70331629

QC Batch:	380494	Analysis Method:	EPA 200.8, Rev. 5.4
QC Batch Method:	EPA 200.8, Rev. 5.4	Analysis Description:	NB 200.8 ICPMS DW No Prep
		Laboratory:	Pace Analytical Services - Newburgh

Associated Lab Samples: 70331629001, 70331629002, 70331629003, 70331629004, 70331629005, 70331629006, 70331629007

METHOD BLANK: 1996884

Matrix: Water

Associated Lab Samples: 70331629001, 70331629002, 70331629003, 70331629004, 70331629005, 70331629006, 70331629007

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	01/17/25 16:01	

LABORATORY CONTROL SAMPLE: 1996885

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	46.9	94	85-115	

MATRIX SPIKE SAMPLE: 1996887

Parameter	Units	70332019001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	6.2	50	57.3	102	70-130	

MATRIX SPIKE SAMPLE: 1996889

Parameter	Units	70332019011 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.2	50	52.8	103	70-130	

SAMPLE DUPLICATE: 1996886

Parameter	Units	70332019001 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	6.2	6.2	0	20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: RCSD - Wilson HS
Pace Project No.: 70331629

QC Batch:	380495	Analysis Method:	EPA 200.8, Rev. 5.4
QC Batch Method:	EPA 200.8, Rev. 5.4	Analysis Description:	NB 200.8 ICPMS DW No Prep
		Laboratory:	Pace Analytical Services - Newburgh
Associated Lab Samples:	70331629008, 70331629009, 70331629011, 70331629012, 70331629013, 70331629014, 70331629015, 70331629016, 70331629017, 70331629018, 70331629019, 70331629020, 70331629021, 70331629022, 70331629023, 70331629024, 70331629025, 70331629026, 70331629027, 70331629028		

METHOD BLANK:	1996891	Matrix:	Water
Associated Lab Samples:	70331629008, 70331629009, 70331629011, 70331629012, 70331629013, 70331629014, 70331629015, 70331629016, 70331629017, 70331629018, 70331629019, 70331629020, 70331629021, 70331629022, 70331629023, 70331629024, 70331629025, 70331629026, 70331629027, 70331629028		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	01/17/25 16:01	

LABORATORY CONTROL SAMPLE:	1996892					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	46.9	94	85-115	

MATRIX SPIKE SAMPLE:		1996894					
		70331629008	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	49.4	99	70-130	

MATRIX SPIKE SAMPLE:		1996896					
		70331629019	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	2.4	50	52.3	100	70-130	

SAMPLE DUPLICATE:	1996893					
Parameter	Units	70331629008 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: RCSD - Wilson HS

Pace Project No.: 70331629

QC Batch:	380572	Analysis Method:	EPA 200.8, Rev. 5.4
QC Batch Method:	EPA 200.8, Rev. 5.4	Analysis Description:	NB 200.8 ICPMS DW No Prep
		Laboratory:	Pace Analytical Services - Newburgh
Associated Lab Samples:	70331629029, 70331629030, 70331629031, 70331629032, 70331629033, 70331629034, 70331629035, 70331629036, 70331629037		

METHOD BLANK:	1997482	Matrix:	Water
Associated Lab Samples:	70331629029, 70331629030, 70331629031, 70331629032, 70331629033, 70331629034, 70331629035, 70331629036, 70331629037		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	01/17/25 16:01	

LABORATORY CONTROL SAMPLE:	1997483					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	46.9	94	85-115	

MATRIX SPIKE SAMPLE:	1997485						
Parameter	Units	70331629029 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	4.6	50	53.7	98	70-130	

SAMPLE DUPLICATE: 1997484						
Parameter	Units	70331629029 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	4.6	4.5	2	20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALIFIERS

Project: RCSD - Wilson HS
Pace Project No.: 70331629

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: RCSD - Wilson HS

Pace Project No.: 70331629

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70331629010	WHS-01-CR-IN-121-TL	EPA 200.8, Rev. 5.4	380241	EPA 200.8, Rev. 5.4	380975
70331629001	WHS-03-HA-BY-324-F	EPA 200.8, Rev. 5.4	380494		
70331629002	WHS-03-HA-BY-324-BF	EPA 200.8, Rev. 5.4	380494		
70331629003	WHS-03-HA-BY-304-F	EPA 200.8, Rev. 5.4	380494		
70331629004	WHS-03-HA-BY-304-BF	EPA 200.8, Rev. 5.4	380494		
70331629005	WHS-02-HA-BY-204-F	EPA 200.8, Rev. 5.4	380494		
70331629006	WHS-02-HA-BY-204-F	EPA 200.8, Rev. 5.4	380494		
70331629007	WHS-02-HA-BY-204-BF	EPA 200.8, Rev. 5.4	380494		
70331629008	WHS-01-HA-BY-124-F	EPA 200.8, Rev. 5.4	380495		
70331629009	WHS-01-HA-BY-124-BF	EPA 200.8, Rev. 5.4	380495		
70331629011	WHS-01-CR-IN-121-TR	EPA 200.8, Rev. 5.4	380495		
70331629012	WHS-01-CR-IN-121-SR	EPA 200.8, Rev. 5.4	380495		
70331629013	WHS-01-MO-IN-105-T	EPA 200.8, Rev. 5.4	380495		
70331629014	WHS-01-CR-IN-113-T	EPA 200.8, Rev. 5.4	380495		
70331629015	WHS-01-HA-BY-104-F	EPA 200.8, Rev. 5.4	380495		
70331629016	WHS-01-HA-BY-105-BF	EPA 200.8, Rev. 5.4	380495		
70331629017	WHS-01-HA-BY-166-F	EPA 200.8, Rev. 5.4	380495		
70331629018	WHS-01-HA-BY-166-BF	EPA 200.8, Rev. 5.4	380495		
70331629019	WHS-B-IN-NO-B5-TL	EPA 200.8, Rev. 5.4	380495		
70331629020	WHS-B-IN-NO-B5-TR	EPA 200.8, Rev. 5.4	380495		
70331629021	WHS-B-CR-IN-B5C-T	EPA 200.8, Rev. 5.4	380495		
70331629022	WHS-B-CR-IN-B4-T	EPA 200.8, Rev. 5.4	380495		
70331629023	WHS-B-CR-IN-B2-T	EPA 200.8, Rev. 5.4	380495		
70331629024	WHS-B-CR-IN-B1-T	EPA 200.8, Rev. 5.4	380495		
70331629025	WHS-B-CAFE-IN-B41-T	EPA 200.8, Rev. 5.4	380495		
70331629026	WHS-B-CAFE-IN-B43-T1	EPA 200.8, Rev. 5.4	380495		
70331629027	WHS-B-CAFE-IN-B43B-T2	EPA 200.8, Rev. 5.4	380495		
70331629028	WHS-B-CAFE-IN-B434B-T3	EPA 200.8, Rev. 5.4	380495		
70331629029	WHS-B-CAFE-IN-B45-F	EPA 200.8, Rev. 5.4	380572		
70331629030	WHS-B-CAFE-IN-B45-BF	EPA 200.8, Rev. 5.4	380572		
70331629031	WHS-B-IN-BM-B44A-T	EPA 200.8, Rev. 5.4	380572		
70331629032	WHS-B-CR-IN-B44-T	EPA 200.8, Rev. 5.4	380572		
70331629033	WHS-B-CR-IN-B46-F	EPA 200.8, Rev. 5.4	380572		
70331629034	WHS-B-CR-IN-B6-TM	EPA 200.8, Rev. 5.4	380572		
70331629035	WHS-B-CR-IN-B6-TR	EPA 200.8, Rev. 5.4	380572		
70331629036	WHS-B-HA-BY-070-FL	EPA 200.8, Rev. 5.4	380572		
70331629037	WHS-B-HA-BY-070-FR	EPA 200.8, Rev. 5.4	380572		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



Lozier
Environmental Consulting, Inc.

2011 East Main Street, Rochester, NY 14609 Phone (585) 654-9080 Fax (585) 654-9662 Page 1 of 4
Web: LozierEnv.com E-Mail: support@lozierenv.com

LAB ID: M36981		REPORT TO:		INVOICE TO:	
PROJECT NAME: RCSD - Wilson HS		Company: Lozier Environmental Consulting, Inc.		Company: (SAME)	
TURNAROUND TIME: Standard Rush		Address: 2011 East Main Street		Address:	
Other:		City/State Zip: Rochester NY 14609		City/State Zip:	
		Phone: 585-654-9080		Phone:	
		Fax: 585-654-9662		Fax:	
		E-Mail: support@lozierenv.com		Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS									
1	WHS-03-HA-BY-324-F	12/11/2024	6:10		DW				Lead									
2	WHS-03-HA-BY-324-BF	12/11/2024	6:10		DW				X									
3	WHS-03-HA-BY-304-F	12/11/2024	6:22		DW				X									
4	WHS-03-HA-BY-304-BF	12/11/2024	6:22		DW				X									
5	WHS-02-HA-BY-204-F	12/11/2024	6:26		DW			bottle filler disabled	X									
6	WHS-02-HA-BY-204-F	12/11/2024	6:33		DW				X									
7	WHS-02-HA-BY-204-BF	12/11/2024	6:33		DW				X									
8	WHS-01-HA-BY-124-F	12/11/2024	6:35		DW				X									
9	WHS-01-HA-BY-124-BF	12/11/2024	6:35		DW				X									
10	WHS-01-CR-IN-121-TL	12/11/2024	6:39		DW			slow and gurgling	X									

Container Type (Circle One): Plastic Glass Sterile Other _____ Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

SAMPLED BY* Joe Savioe & Steph Ketterl

RELINQUISHED BY* Steph Ketterl DATE: 1/3/25 TIME: 16:15

RECEIVED BY: Mike Itur DATE: 1/8/25 TIME: 10:30

RELINQUISHED BY*: DATE: TIME:

RECEIVED BY: DATE: TIME:

RELINQUISHED BY*: DATE: TIME:

RECEIVED BY: DATE: TIME:

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FEED SIX 6545
7712 35873672

FOR LAB USE ONLY		FOR POTABLE WATER ONLY:	
PRESERVATIVE/BIOCIDE: HNO3-		COLIFORM BACTERIA:	
TOTAL NUMBER OF CONTAINERS: 37		Present	Absent
CUSTODY SEAL INTACT? YES		If Present, Date Client is contacted with result:	
SAMPLE ON ICE? <u>NO</u>		Date: _____	Contacted By: _____
TEMPERATURE: <u>12.7</u> C			
SAMPLE IN COMPLIANCE: YES			

MO#: 70331629

70331629



2011 East Main Street, Rochester, NY 14609 Phone (585) 654-9080 Fax (585) 654-9662
Web: LozierEnv.com E-Mail: support@lozierenv.com

Page 2 of 4

Page 23 of 26

REPORT TO:		INVOICE TO:	
Company:	Lozier Environmental Consulting, Inc.	Company: (SAME)	
Address:	2011 East Main Street	Address:	
City/State Zip:	Rochester NY 14609	City/State Zip:	
Phone:	585-654-9080	Phone:	
Fax:	585-654-9662	Fax:	
E-Mail:	support@lozierenv.com	Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS
11	WHS-01-CR-IN-121-TR	12/11/2024	6:39		DW			slow and gurgling	Lead
12	WHS-01-CR-IN-121-SR	12/11/2024	6:39		DW				
13	WHS-01-MO-IN-105-T	12/11/2024	6:50		DW				
14	WHS-01-CR-IN-113-T	12/11/2024	6:54		DW				
15	WHS-01-HA-BY-104-F	12/11/2024	6:56		DW				
16	WHS-01-HA-BY-105-BF	12/11/2024	6:56		DW				
17	WHS-01-HA-BY-166-F	12/11/2024	7:01		DW				
18	WHS-01-HA-BY-166-BF	12/11/2024	7:01		DW				
19	WHS-B-IN-NO-B5-TL	12/11/2024	7:07		DW				
20	WHS-B-IN-NO-B5-TR	12/11/2024	7:07		DW				

Container Type (Circle One): Plastic Glass Sterile Other _____ Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

SAMPLED BY*	Joe Savioe & Steph Ketterl
RELINQUISHED BY*	Steph Ketterl
RECEIVED BY:	DATE: 1/3/25 TIME: 16:15
RELINQUISHED BY*	DATE: 1/8/25 TIME: 10:30
RECEIVED BY:	DATE: TIME:
RELINQUISHED BY*	DATE: TIME:
RECEIVED BY:	DATE: TIME:

FOR LAB USE ONLY		FOR POTABLE WATER ONLY:	
PRESERVATIVE/BIOCIDES: HNO3-		COLIFORM BACTERIA:	
TOTAL NUMBER OF CONTAINERS:	37	Present	Absent
CUSTODY SEAL INTACT?	YES	If Present, Date Client is contacted with result:	
SAMPLE ON ICE? (NO)		Date:	
TEMPERATURE: 62.7 C		Contacted By:	
SAMPLE IN COMPLIANCE:	YES		

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

MO#: 70331629
PM: RC1 Due Date: 01/22/25
CLIENT: NB-LOZIER



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 3 of 4
70331629

LAB ID: M36981		Company: Lozier Environmental Consulting, Inc.		REPORT TO:	
PROJECT NAME: RCSD - Wilson HS		Address: 2011 East Main Street		Company: (SAME)	
TURNAROUND TIME: Standard Rush		City/State Zip: Rochester NY 14609		Address:	
Other:		Phone: 585-654-9080 Fax: 585-654-9662		City/State Zip:	
		E-Mail: support@lozierenv.com		Phone: Fax:	
				Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS				
21	WHS-B-CR-IN-B5C-T	12/11/2024	7:08		DW				per				
22	WHS-B-CR-IN-B4-T	12/11/2024	7:10		DW				x				
23	WHS-B-CR-IN-B2-T	12/11/2024	7:11		DW				x				
24	WHS-B-CR-IN-B1-T	12/11/2024	7:13		DW				x				
25	WHS-B-CAFE-IN-B41-T	12/12/2024	6:17		DW			prep sink	x				
26	WHS-B-CAFE-IN-B43-T1	12/12/2024	6:19		DW			hand wash sink	x				
27	WHS-B-CAFE-IN-B43B-T2	12/12/2024	6:20		DW			dish spray	x				
28	WHS-B-CAFE-IN-B434B-T3	12/12/2024	6:21		DW			dish tap	x				
29	WHS-B-CAFE-IN-B45-F	12/12/2024	6:23		DW				x				
30	WHS-B-CAFE-IN-B45-BF	12/12/2024	6:23		DW				x				

Container Type (Circle One): Plastic Glass Sterile Other _____
Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

SAMPLED BY: Joe Savice & Steph Ketterl

RELINQUISHED BY: Steph Ketterl DATE: 1/3/25 TIME: 16:15

RECEIVED BY: *Alvin* DATE: 1/8/25 TIME: 10:30

RELINQUISHED BY: DATE: TIME:


RECEIVED BY: DATE: TIME:

RELINQUISHED BY: DATE: TIME:

RECEIVED BY: DATE: TIME:

FOR LAB USE ONLY		FOR POTABLE WATER ONLY:	
PRESERVATIVE/BIOCIDE: HNO3-		COLIFORM BACTERIA:	
TOTAL NUMBER OF CONTAINERS: 37		Present	Absent
CUSTODY SEAL INTACT? YES		If Present, Date Client is contacted with result:	
SAMPLE ON ICE? <u>NO</u>		Date:	Contacted By:
TEMPERATURE: <u>12.7c</u>			
SAMPLE IN COMPLIANCE: YES			

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis



4

26

INVOICE TO:

Company: (SAME)

Address:

City, State Zip:

Fax: 585-654-9662

Phone:

Purchase Order #:

Page 25 of 26

[illegible]

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

SAMPLED BY* Joe Savio & Steph Ketterl

RELINQUISHED BY: Steph Ketter / DATE: 1/3/25 TIME: 16:15

RECEIVED BY: W. H. H. H. DATE: 1/8/25 TIME: 0300

RELINQUISHED BY*: _____ DATE: _____ TIME: _____

RECEIVED BY: DATE: TIME:

RELINQUISHED BY*: DATE: TIME:

RECEIVED BY: _____ DATE: _____ TIME: _____

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDES: HNO ₃	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINERS: 37	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES	Present Absent
SAMPLE ON ICE? <u>NO</u>	If Present, Date Client is
TEMPERATURE: <u>12-70</u>	contacted with result:
SAMPLE IN COMPLIANCE: YES	Date: _____
	Contacted By: _____

W0#: 70331629

CUR)

Project #

PM: RC1

Due Date: 01/22/25

Client:

CLIENT: NB-LOZIER

Date and Initials of person:

Examining contents: _____

Label: _____

Deliver to location: _____

pH: _____

Thermometer Used: IRG4

Date: 1/8

Time: 1030

Initials: _____

State of Origin: NY

Cooler #1 Temp. °C 12.7 (Visual) 0.2 @ 0.0°C -0.5 @ 20.0°C (Correction Factor) (Actual) ☒ Samples on ice, cooling process has begun

Courier: ☒ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☐ Pace ☐ Other _____

Shipping Method: ☐ First Overnight ☐ Priority Overnight ☐ Standard Overnight ☒ Ground

☐ Other _____

Tracking # _____

Custody Seal on Cooler/Box Present: ☐ Yes ☐ No

Seals intact: ☐ Yes ☐ No

Ice: ☒ Wet ☐ Blue ☐ Melted ☐ None

Packing Material: ☐ Bubble Wrap ☐ Bubble Bags ☐ None ☐ Other _____

Samples were collected by Pace employee ☐ Yes ☐ No ☐ N/A

Comments:

Chain of Custody Present	☒ Yes ☐ No ☐ N/A	
Chain of Custody Filled Out	☒ Yes ☐ No ☐ N/A	
Relinquished Signature on COC	☒ Yes ☐ No ☐ N/A	
Sampler Name and Signature on COC	☒ Yes ☐ No ☐ N/A	
Samples Arrived within Hold Time	☒ Yes ☐ No ☐ N/A	
Rush TAT requested on COC	☐ Yes ☐ No ☐ N/A	
Sufficient Volume	☒ Yes ☐ No ☐ N/A	
Correct Containers Used	☒ Yes ☐ No ☐ N/A	
Containers Intact	☒ Yes ☐ No ☐ N/A	
Sample Labels match COC (sample IDs & date/time of collection)	☒ Yes ☐ No ☐ N/A	
All containers needing acid/base preservation have been checked.	☐ Yes ☐ No ☐ N/A	Preservation Information:
All Containers needing preservation are found to be in compliance with EPA recommendation:	☐ Yes ☐ No ☐ N/A	Preservative: _____
Exceptions: Vials, Microbiology, O&G, Metals		Lot #/Trace #: _____
		Date: _____ Time: _____
		Initials: _____
Headspace in VOA Vials? (>6mm):	☐ Yes ☐ No ☐ N/A	
Trip Blank Present:	☐ Yes ☐ No ☐ N/A	

Additional Login Comments:

Client notification/ Resolution

Person Contacted:

Date/Time:

Comments/Resolution: