



January 02, 2025

Amy Kaptein
Lozier Environmental Consulting, Inc
2011 E. Main St.
Rochester, NY 14609

RE: Project: RCSD -School No. 45
Pace Project No.: 70324924

Dear Amy Kaptein:

Enclosed are the analytical results for sample(s) received by the laboratory on December 02, 2024. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Newburgh

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in cursive script that reads "Renee Cusack".

Renee Cusack
renee.cusack@pacelabs.com
(845)562-0890
Project Manager

Enclosures

cc: Amy Pusateri, Lozier Environmental Consulting Inc.



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



CERTIFICATIONS

Project: RCSD -School No. 45

Pace Project No.: 70324924

Pace Analytical Services, LLC- Newburgh, NY

315 Fullerton Avenue, Newburgh, NY 12550

New York Certification #: 10142 Primary Accrediting Body

New Jersey Certification #: NY015

Connecticut Certification #: PH-0823

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE SUMMARY

Project: RCSD -School No. 45

Pace Project No.: 70324924

Lab ID	Sample ID	Matrix	Date Collected	Date Received
70324924001	45-01-HA-BY-103-F	Drinking Water	11/19/24 06:11	12/02/24 10:10
70324924002	45-01-HA-BY-103-BF	Drinking Water	11/19/24 06:11	12/02/24 10:10
70324924003	45-01-KI-IN-106-T1	Drinking Water	11/19/24 06:18	12/02/24 10:10
70324924004	45-01-KI-IN-106-T2	Drinking Water	11/19/24 06:19	12/02/24 10:10
70324924005	45-01-KI-IN-106-T3	Drinking Water	11/19/24 06:19	12/02/24 10:10
70324924006	45-01-HA-BY-121-F	Drinking Water	11/19/24 06:25	12/02/24 10:10
70324924007	45-01-HA-BY-121-BF	Drinking Water	11/19/24 06:25	12/02/24 10:10
70324924008	45-01-HA-BY-108-F	Drinking Water	11/19/24 06:30	12/02/24 10:10
70324924009	45-01-HA-BY-108-BF	Drinking Water	11/19/24 06:31	12/02/24 10:10
70324924010	45-01-TL-IN-128-T	Drinking Water	11/19/24 06:40	12/02/24 10:10
70324924011	45-01-CR-IN-130-T	Drinking Water	11/19/24 06:42	12/02/24 10:10
70324924012	45-01-CR-IN-131-B	Drinking Water	11/19/24 06:43	12/02/24 10:10
70324924013	45-01-CR-IN-131-T	Drinking Water	11/19/24 06:44	12/02/24 10:10
70324924014	45-01-CR-IN-132-T	Drinking Water	11/19/24 06:46	12/02/24 10:10
70324924015	45-01HA-BY-134-F	Drinking Water	11/19/24 06:48	12/02/24 10:10
70324924016	45-01HA-BY-134-BF	Drinking Water	11/19/24 06:49	12/02/24 10:10
70324924017	45-01-CR-IN-137-B	Drinking Water	11/19/24 06:53	12/02/24 10:10
70324924018	45-01-CR-IN-137-T	Drinking Water	11/19/24 06:54	12/02/24 10:10
70324924019	45-01-NO-IN-150-T	Drinking Water	11/19/24 06:57	12/02/24 10:10
70324924020	45-01-OF-IN-162-T	Drinking Water	11/19/24 07:01	12/02/24 10:10
70324924021	45-01-CR-IN-166-T	Drinking Water	11/19/24 07:03	12/02/24 10:10
70324924022	45-01-CR-IN-167-B	Drinking Water	11/19/24 07:05	12/02/24 10:10
70324924023	45-01-CR-IN-167-T	Drinking Water	11/19/24 07:05	12/02/24 10:10
70324924024	45-01-CR-IN-168-B	Drinking Water	11/19/24 07:09	12/02/24 10:10
70324924025	45-01-CR-IN-168-T	Drinking Water	11/19/24 07:10	12/02/24 10:10
70324924026	45-01-CR-IN-169-T	Drinking Water	11/19/24 07:12	12/02/24 10:10
70324924027	45-01-CR-IN-170-B	Drinking Water	11/19/24 07:12	12/02/24 10:10
70324924028	45-01-CR-IN-170-T	Drinking Water	11/19/24 07:13	12/02/24 10:10
70324924029	45-01-CR-IN-176-B	Drinking Water	11/19/24 07:16	12/02/24 10:10
70324924030	45-01-CR-IN-176-T	Drinking Water	11/19/24 07:16	12/02/24 10:10
70324924031	45-01-CR-IN-177-B	Drinking Water	11/19/24 07:18	12/02/24 10:10
70324924032	45-01-CR-IN-177-T	Drinking Water	11/19/24 07:19	12/02/24 10:10
70324924033	45-01-HA-BY-175-F	Drinking Water	11/19/24 07:23	12/02/24 10:10
70324924034	45-01-HA-BY-175-BF	Drinking Water	11/19/24 07:24	12/02/24 10:10
70324924035	45-01-CR-IN-178-B	Drinking Water	11/19/24 07:26	12/02/24 10:10
70324924036	45-01-CR-IN-178-T	Drinking Water	11/19/24 07:27	12/02/24 10:10
70324924037	45-01-CR-IN-180-B	Drinking Water	11/19/24 07:28	12/02/24 10:10

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE SUMMARY

Project: RCSD -School No. 45

Pace Project No.: 70324924

Lab ID	Sample ID	Matrix	Date Collected	Date Received
70324924038	45-01-CR-IN-180-T	Drinking Water	11/19/24 07:28	12/02/24 10:10
70324924039	45-01-CR-IN-186-T	Drinking Water	11/19/24 07:30	12/02/24 10:10
70324924040	45-02-CR-IN-202-T-NORTH	Drinking Water	11/20/24 06:03	12/02/24 10:10
70324924041	45-02-CR-IN-205-B	Drinking Water	11/20/24 06:05	12/02/24 10:10
70324924042	45-02-CR-IN-205-T	Drinking Water	11/20/24 06:06	12/02/24 10:10
70324924043	45-02-CR-IN-204-B	Drinking Water	11/20/24 06:08	12/02/24 10:10
70324924044	45-02-CR-IN-204-T	Drinking Water	11/20/24 06:08	12/02/24 10:10
70324924045	45-02-CR-IN-206-B	Drinking Water	11/20/24 06:11	12/02/24 10:10
70324924046	45-02-CR-IN-206-T	Drinking Water	11/20/24 06:12	12/02/24 10:10
70324924047	45-02-HA-BY-204-F	Drinking Water	11/20/24 06:14	12/02/24 10:10
70324924048	45-02-HA-BY-204-BF	Drinking Water	11/20/24 06:14	12/02/24 10:10
70324924049	45-02-CR-IN-209-B	Drinking Water	11/20/24 06:16	12/02/24 10:10
70324924050	45-02-CR-IN-209-T	Drinking Water	11/20/24 06:17	12/02/24 10:10
70324924051	45-02-CR-IN-207-B	Drinking Water	11/20/24 06:19	12/02/24 10:10
70324924052	45-02-CR-IN-207-T	Drinking Water	11/20/24 06:20	12/02/24 10:10
70324924053	45-02-CR-IN-208-B	Drinking Water	11/20/24 06:22	12/02/24 10:10
70324924054	45-02-CR-IN-208-T	Drinking Water	11/20/24 06:23	12/02/24 10:10
70324924055	45-02-CR-IN-215-B	Drinking Water	11/20/24 06:26	12/02/24 10:10
70324924056	45-02-CR-IN-215-T	Drinking Water	11/20/24 06:27	12/02/24 10:10
70324924057	45-02-CR-IN-214-B	Drinking Water	11/20/24 06:29	12/02/24 10:10
70324924058	45-02-CR-IN-214-T	Drinking Water	11/20/24 06:29	12/02/24 10:10
70324924059	45-02-CR-IN-217-B	Drinking Water	11/20/24 06:31	12/02/24 10:10
70324924060	45-02-CR-IN-217-T	Drinking Water	11/20/24 06:31	12/02/24 10:10
70324924061	45-02-CR-IN-219-B	Drinking Water	11/20/24 06:33	12/02/24 10:10
70324924062	45-02N-219-T	Drinking Water	11/20/24 06:34	12/02/24 10:10
70324924063	45-02-CR-IN-218-B	Drinking Water	11/20/24 06:37	12/02/24 10:10
70324924064	45-02-CR-IN-218-T	Drinking Water	11/20/24 06:37	12/02/24 10:10
70324924065	45-02-HA-BY-220-F	Drinking Water	11/20/24 06:40	12/02/24 10:10
70324924066	45-02-HA-BY-220-BF	Drinking Water	11/20/24 06:40	12/02/24 10:10
70324924067	45-02-CR-IN-223-B	Drinking Water	11/20/24 06:42	12/02/24 10:10
70324924068	45-02-CR-IN-223-T	Drinking Water	11/20/24 06:43	12/02/24 10:10
70324924069	45-02-CR-IN-224-TL	Drinking Water	11/20/24 06:44	12/02/24 10:10
70324924070	45-02-CR-IN-224-TR	Drinking Water	11/20/24 06:45	12/02/24 10:10
70324924071	45-02-CR-IN-225-T	Drinking Water	11/20/24 06:47	12/02/24 10:10
70324924072	45-02-CR-IN-230-B	Drinking Water	11/20/24 06:52	12/02/24 10:10
70324924073	45-02-CR-IN-230-T	Drinking Water	11/20/24 06:54	12/02/24 10:10
70324924074	45-02-CR-IN-228-B	Drinking Water	11/20/24 06:54	12/02/24 10:10

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE SUMMARY

Project: RCSD -School No. 45

Pace Project No.: 70324924

Lab ID	Sample ID	Matrix	Date Collected	Date Received
70324924075	45-02-CR-IN-228-T	Drinking Water	11/20/24 06:55	12/02/24 10:10
70324924076	45-02-CR-IN-231-B	Drinking Water	11/20/24 06:58	12/02/24 10:10
70324924077	45-02-CR-IN-231-T	Drinking Water	11/20/24 06:58	12/02/24 10:10
70324924078	45-02-CR-IN-232-B	Drinking Water	11/20/24 07:01	12/02/24 10:10
70324924079	45-02-CR-IN-232-T	Drinking Water	11/20/24 07:01	12/02/24 10:10
70324924080	45-02-CR-IN-234-B	Drinking Water	11/20/24 07:04	12/02/24 10:10
70324924081	45-02-CR-IN-234-T	Drinking Water	11/20/24 07:04	12/02/24 10:10
70324924082	45-02-CR-IN-233-B	Drinking Water	11/20/24 07:08	12/02/24 10:10
70324924083	45-02-CR-IN-233-T	Drinking Water	11/20/24 07:09	12/02/24 10:10
70324924084	45-02-CR-IN-239-B	Drinking Water	11/20/24 07:11	12/02/24 10:10
70324924085	45-02-CR-IN-239-T	Drinking Water	11/20/24 07:11	12/02/24 10:10
70324924086	45-02-CR-IN-240-B	Drinking Water	11/20/24 07:12	12/02/24 10:10
70324924087	45-02-CR-IN-240-T	Drinking Water	11/20/24 07:13	12/02/24 10:10
70324924088	45-02-CR-IN-238-B	Drinking Water	11/20/24 07:15	12/02/24 10:10
70324924089	45-02-CR-IN-238-T	Drinking Water	11/20/24 07:16	12/02/24 10:10
70324924090	45-02-HA-BY-238-F	Drinking Water	11/20/24 07:19	12/02/24 10:10
70324924091	45-02-HA-BY-238-BF	Drinking Water	11/20/24 07:19	12/02/24 10:10
70324924092	45-02-CR-IN-241-B	Drinking Water	11/20/24 07:22	12/02/24 10:10
70324924093	45-02-CR-IN-241-T	Drinking Water	11/20/24 07:23	12/02/24 10:10
70324924094	45-02-CR-IN-242-B	Drinking Water	11/20/24 07:25	12/02/24 10:10
70324924095	45-02-CR-IN-242-T	Drinking Water	11/20/24 07:26	12/02/24 10:10

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE ANALYTE COUNT

Project: RCSD -School No. 45

Pace Project No.: 70324924

Lab ID	Sample ID	Method	Analysts	Analytes Reported
70324924001	45-01-HA-BY-103-F	EPA 200.8, Rev. 5.4	AR	1
70324924002	45-01-HA-BY-103-BF	EPA 200.8, Rev. 5.4	AR	1
70324924003	45-01-KI-IN-106-T1	EPA 200.8, Rev. 5.4	AR	1
70324924004	45-01-KI-IN-106-T2	EPA 200.8, Rev. 5.4	AR	1
70324924005	45-01-KI-IN-106-T3	EPA 200.8, Rev. 5.4	AR	1
70324924006	45-01-HA-BY-121-F	EPA 200.8, Rev. 5.4	AR	1
70324924007	45-01-HA-BY-121-BF	EPA 200.8, Rev. 5.4	AR	1
70324924008	45-01-HA-BY-108-F	EPA 200.8, Rev. 5.4	AR	1
70324924009	45-01-HA-BY-108-BF	EPA 200.8, Rev. 5.4	AR	1
70324924010	45-01-TL-IN-128-T	EPA 200.8, Rev. 5.4	AR	1
70324924011	45-01-CR-IN-130-T	EPA 200.8, Rev. 5.4	AR	1
70324924012	45-01-CR-IN-131-B	EPA 200.8, Rev. 5.4	AR	1
70324924013	45-01-CR-IN-131-T	EPA 200.8, Rev. 5.4	AR	1
70324924014	45-01-CR-IN-132-T	EPA 200.8, Rev. 5.4	AR	1
70324924015	45-01HA-BY-134-F	EPA 200.8, Rev. 5.4	AR	1
70324924016	45-01HA-BY-134-BF	EPA 200.8, Rev. 5.4	AR	1
70324924017	45-01-CR-IN-137-B	EPA 200.8, Rev. 5.4	AR	1
70324924018	45-01-CR-IN-137-T	EPA 200.8, Rev. 5.4	AR	1
70324924019	45-01-NO-IN-150-T	EPA 200.8, Rev. 5.4	AR	1
70324924020	45-01-OF-IN-162-T	EPA 200.8, Rev. 5.4	AR	1
70324924021	45-01-CR-IN-166-T	EPA 200.8, Rev. 5.4	AR	1
70324924022	45-01-CR-IN-167-B	EPA 200.8, Rev. 5.4	AR	1
70324924023	45-01-CR-IN-167-T	EPA 200.8, Rev. 5.4	AR	1
70324924024	45-01-CR-IN-168-B	EPA 200.8, Rev. 5.4	AR	1
70324924025	45-01-CR-IN-168-T	EPA 200.8, Rev. 5.4	AR	1
70324924026	45-01-CR-IN-169-T	EPA 200.8, Rev. 5.4	AR	1
70324924027	45-01-CR-IN-170-B	EPA 200.8, Rev. 5.4	AR	1
70324924028	45-01-CR-IN-170-T	EPA 200.8, Rev. 5.4	AR	1
70324924029	45-01-CR-IN-176-B	EPA 200.8, Rev. 5.4	AR	1
70324924030	45-01-CR-IN-176-T	EPA 200.8, Rev. 5.4	AR	1
70324924031	45-01-CR-IN-177-B	EPA 200.8, Rev. 5.4	AR	1
70324924032	45-01-CR-IN-177-T	EPA 200.8, Rev. 5.4	AR	1
70324924033	45-01-HA-BY-175-F	EPA 200.8, Rev. 5.4	AR	1
70324924034	45-01-HA-BY-175-BF	EPA 200.8, Rev. 5.4	AR	1
70324924035	45-01-CR-IN-178-B	EPA 200.8, Rev. 5.4	AR	1
70324924036	45-01-CR-IN-178-T	EPA 200.8, Rev. 5.4	AR	1
70324924037	45-01-CR-IN-180-B	EPA 200.8, Rev. 5.4	AR	1

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE ANALYTE COUNT

Project: RCSD -School No. 45

Pace Project No.: 70324924

Lab ID	Sample ID	Method	Analysts	Analytes Reported
70324924038	45-01-CR-IN-180-T	EPA 200.8, Rev. 5.4	AR	1
70324924039	45-01-CR-IN-186-T	EPA 200.8, Rev. 5.4	AR	1
70324924040	45-02-CR-IN-202-T-NORTH	EPA 200.8, Rev. 5.4	AR	1
70324924041	45-02-CR-IN-205-B	EPA 200.8, Rev. 5.4	AR	1
70324924042	45-02-CR-IN-205-T	EPA 200.8, Rev. 5.4	AR	1
70324924043	45-02-CR-IN-204-B	EPA 200.8, Rev. 5.4	AR	1
70324924044	45-02-CR-IN-204-T	EPA 200.8, Rev. 5.4	AR	1
70324924045	45-02-CR-IN-206-B	EPA 200.8, Rev. 5.4	AR	1
70324924046	45-02-CR-IN-206-T	EPA 200.8, Rev. 5.4	AR	1
70324924047	45-02-HA-BY-204-F	EPA 200.8, Rev. 5.4	AR	1
70324924048	45-02-HA-BY-204-BF	EPA 200.8, Rev. 5.4	AR	1
70324924049	45-02-CR-IN-209-B	EPA 200.8, Rev. 5.4	AR	1
70324924050	45-02-CR-IN-209-T	EPA 200.8, Rev. 5.4	AR	1
70324924051	45-02-CR-IN-207-B	EPA 200.8, Rev. 5.4	AR	1
70324924052	45-02-CR-IN-207-T	EPA 200.8, Rev. 5.4	AR	1
70324924053	45-02-CR-IN-208-B	EPA 200.8, Rev. 5.4	AR	1
70324924054	45-02-CR-IN-208-T	EPA 200.8, Rev. 5.4	AR	1
70324924055	45-02-CR-IN-215-B	EPA 200.8, Rev. 5.4	AR	1
70324924056	45-02-CR-IN-215-T	EPA 200.8, Rev. 5.4	AR	1
70324924057	45-02-CR-IN-214-B	EPA 200.8, Rev. 5.4	AR	1
70324924058	45-02-CR-IN-214-T	EPA 200.8, Rev. 5.4	AR	1
70324924059	45-02-CR-IN-217-B	EPA 200.8, Rev. 5.4	AR	1
70324924060	45-02-CR-IN-217-T	EPA 200.8, Rev. 5.4	AR	1
70324924061	45-02-CR-IN-219-B	EPA 200.8, Rev. 5.4	AR	1
70324924062	45-02N-219-T	EPA 200.8, Rev. 5.4	AR	1
70324924063	45-02-CR-IN-218-B	EPA 200.8, Rev. 5.4	AR	1
70324924064	45-02-CR-IN-218-T	EPA 200.8, Rev. 5.4	AR	1
70324924065	45-02-HA-BY-220-F	EPA 200.8, Rev. 5.4	AR	1
70324924066	45-02-HA-BY-220-BF	EPA 200.8, Rev. 5.4	AR	1
70324924067	45-02-CR-IN-223-B	EPA 200.8, Rev. 5.4	AR	1
70324924068	45-02-CR-IN-223-T	EPA 200.8, Rev. 5.4	AR	1
70324924069	45-02-CR-IN-224-TL	EPA 200.8, Rev. 5.4	AR	1
70324924070	45-02-CR-IN-224-TR	EPA 200.8, Rev. 5.4	AR	1
70324924071	45-02-CR-IN-225-T	EPA 200.8, Rev. 5.4	AR	1
70324924072	45-02-CR-IN-230-B	EPA 200.8, Rev. 5.4	AR	1
70324924073	45-02-CR-IN-230-T	EPA 200.8, Rev. 5.4	AR	1
70324924074	45-02-CR-IN-228-B	EPA 200.8, Rev. 5.4	AR	1

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE ANALYTE COUNT

Project: RCSD -School No. 45

Pace Project No.: 70324924

Lab ID	Sample ID	Method	Analysts	Analytes Reported
70324924075	45-02-CR-IN-228-T	EPA 200.8, Rev. 5.4	AR	1
70324924076	45-02-CR-IN-231-B	EPA 200.8, Rev. 5.4	AR	1
70324924077	45-02-CR-IN-231-T	EPA 200.8, Rev. 5.4	AR	1
70324924078	45-02-CR-IN-232-B	EPA 200.8, Rev. 5.4	AR	1
70324924079	45-02-CR-IN-232-T	EPA 200.8, Rev. 5.4	AR	1
70324924080	45-02-CR-IN-234-B	EPA 200.8, Rev. 5.4	AR	1
70324924081	45-02-CR-IN-234-T	EPA 200.8, Rev. 5.4	AR	1
70324924082	45-02-CR-IN-233-B	EPA 200.8, Rev. 5.4	AR	1
70324924083	45-02-CR-IN-233-T	EPA 200.8, Rev. 5.4	AR	1
70324924084	45-02-CR-IN-239-B	EPA 200.8, Rev. 5.4	AR	1
70324924085	45-02-CR-IN-239-T	EPA 200.8, Rev. 5.4	AR	1
70324924086	45-02-CR-IN-240-B	EPA 200.8, Rev. 5.4	AR	1
70324924087	45-02-CR-IN-240-T	EPA 200.8, Rev. 5.4	AR	1
70324924088	45-02-CR-IN-238-B	EPA 200.8, Rev. 5.4	AR	1
70324924089	45-02-CR-IN-238-T	EPA 200.8, Rev. 5.4	AR	1
70324924090	45-02-HA-BY-238-F	EPA 200.8, Rev. 5.4	AR	1
70324924091	45-02-HA-BY-238-BF	EPA 200.8, Rev. 5.4	AR	1
70324924092	45-02-CR-IN-241-B	EPA 200.8, Rev. 5.4	AR	2
70324924093	45-02-CR-IN-241-T	EPA 200.8, Rev. 5.4	AR	1
70324924094	45-02-CR-IN-242-B	EPA 200.8, Rev. 5.4	AR	1
70324924095	45-02-CR-IN-242-T	EPA 200.8, Rev. 5.4	AR	1

PASI-NB = Pace Analytical Services - Newburgh

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



PROJECT NARRATIVE

Project: RCSD -School No. 45

Pace Project No.: 70324924

Method: EPA 200.8, Rev. 5.4

Description: NB 200.8 ICPMS DW No Prep

Client: Lozier Environmental Consulting, Inc.

Date: January 02, 2025

General Information:

95 samples were analyzed for EPA 200.8, Rev. 5.4 by Pace Analytical Services Newburgh. All samples were received in acceptable condition with any exceptions noted below or on the chain-of custody and/or the sample condition upon receipt form (SCUR) attached at the end of this report.

Hold Time:

The samples were analyzed within the method required hold times with any exceptions noted below.

Initial Calibrations (including MS Tune as applicable):

All criteria were within method requirements with any exceptions noted below.

Continuing Calibration:

All criteria were within method requirements with any exceptions noted below.

Internal Standards:

All internal standards were within QC limits with any exceptions noted below.

Surrogates:

All surrogates were within QC limits with any exceptions noted below.

Method Blank:

All analytes were below the report limit in the method blank, where applicable, with any exceptions noted below.

Laboratory Control Spike:

All laboratory control spike compounds were within QC limits with any exceptions noted below.

Matrix Spikes:

All percent recoveries and relative percent differences (RPDs) were within acceptance criteria with any exceptions noted below.

Duplicate Sample:

All duplicate sample results were within method acceptance criteria with any exceptions noted below.

QC Batch: 374325

D6: The precision between the sample and sample duplicate exceeded laboratory control limits.

- DUP (Lab ID: 1960295)
- Lead

Additional Comments:

This data package has been reviewed for quality and completeness and is approved for release.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD -School No. 45

Pace Project No.: 70324924

Sample: 45-01-HA-BY-103-F		Lab ID: 70324924001		Collected: 11/19/24 06:11		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		12/12/24 14:07	7439-92-1	
Sample: 45-01-HA-BY-103-BF		Lab ID: 70324924002		Collected: 11/19/24 06:11		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		12/12/24 14:07	7439-92-1	
Sample: 45-01-KI-IN-106-T1		Lab ID: 70324924003		Collected: 11/19/24 06:18		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	5.4	ug/L	1.0	15	1		12/12/24 14:07	7439-92-1	
Sample: 45-01-KI-IN-106-T2		Lab ID: 70324924004		Collected: 11/19/24 06:19		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	2.5	ug/L	1.0	15	1		12/12/24 14:07	7439-92-1	
Sample: 45-01-KI-IN-106-T3		Lab ID: 70324924005		Collected: 11/19/24 06:19		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	2.3	ug/L	1.0	15	1		12/12/24 14:07	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD -School No. 45

Pace Project No.: 70324924

Sample: 45-01-HA-BY-121-F		Lab ID: 70324924006		Collected: 11/19/24 06:25		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		12/12/24 14:07	7439-92-1	
Sample: 45-01-HA-BY-121-BF		Lab ID: 70324924007		Collected: 11/19/24 06:25		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		12/12/24 14:07	7439-92-1	
Sample: 45-01-HA-BY-108-F		Lab ID: 70324924008		Collected: 11/19/24 06:30		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		12/12/24 14:07	7439-92-1	
Sample: 45-01-HA-BY-108-BF		Lab ID: 70324924009		Collected: 11/19/24 06:31		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		12/12/24 14:07	7439-92-1	
Sample: 45-01-TL-IN-128-T		Lab ID: 70324924010		Collected: 11/19/24 06:40		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	4.3	ug/L	1.0	15	1		12/12/24 14:07	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD -School No. 45

Pace Project No.: 70324924

Sample: 45-01-CR-IN-130-T		Lab ID: 70324924011		Collected: 11/19/24 06:42		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		12/12/24 14:07	7439-92-1	
Sample: 45-01-CR-IN-131-B		Lab ID: 70324924012		Collected: 11/19/24 06:43		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		12/12/24 15:02	7439-92-1	
Sample: 45-01-CR-IN-131-T		Lab ID: 70324924013		Collected: 11/19/24 06:44		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		12/12/24 15:02	7439-92-1	
Sample: 45-01-CR-IN-132-T		Lab ID: 70324924014		Collected: 11/19/24 06:46		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	1.8	ug/L	1.0	15	1		12/12/24 15:02	7439-92-1	
Sample: 45-01HA-BY-134-F		Lab ID: 70324924015		Collected: 11/19/24 06:48		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		12/12/24 15:02	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD -School No. 45

Pace Project No.: 70324924

Sample: 45-01HA-BY-134-BF Lab ID: 70324924016 Collected: 11/19/24 06:49 Received: 12/02/24 10:10 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		12/12/24 15:02	7439-92-1	

Sample: 45-01-CR-IN-137-B Lab ID: 70324924017 Collected: 11/19/24 06:53 Received: 12/02/24 10:10 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	2.0	ug/L	1.0	15	1		12/12/24 15:02	7439-92-1	

Sample: 45-01-CR-IN-137-T Lab ID: 70324924018 Collected: 11/19/24 06:54 Received: 12/02/24 10:10 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	2.7	ug/L	1.0	15	1		12/12/24 15:02	7439-92-1	

Sample: 45-01-NO-IN-150-T Lab ID: 70324924019 Collected: 11/19/24 06:57 Received: 12/02/24 10:10 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		12/12/24 15:02	7439-92-1	

Sample: 45-01-OF-IN-162-T Lab ID: 70324924020 Collected: 11/19/24 07:01 Received: 12/02/24 10:10 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	3.2	ug/L	1.0	15	1		12/12/24 15:02	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD -School No. 45

Pace Project No.: 70324924

Sample: 45-01-CR-IN-166-T		Lab ID: 70324924021		Collected: 11/19/24 07:03		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	3.2	ug/L	1.0	15	1		12/12/24 15:02	7439-92-1	
Sample: 45-01-CR-IN-167-B		Lab ID: 70324924022		Collected: 11/19/24 07:05		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		12/12/24 15:02	7439-92-1	
Sample: 45-01-CR-IN-167-T		Lab ID: 70324924023		Collected: 11/19/24 07:05		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	8.8	ug/L	1.0	15	1		12/12/24 15:02	7439-92-1	
Sample: 45-01-CR-IN-168-B		Lab ID: 70324924024		Collected: 11/19/24 07:09		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	6.0	ug/L	1.0	15	1		12/12/24 15:02	7439-92-1	
Sample: 45-01-CR-IN-168-T		Lab ID: 70324924025		Collected: 11/19/24 07:10		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		12/12/24 15:02	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD -School No. 45

Pace Project No.: 70324924

Sample: 45-01-CR-IN-169-T		Lab ID: 70324924026		Collected: 11/19/24 07:12		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	3.2	ug/L	1.0	15	1		12/12/24 15:02	7439-92-1	
Sample: 45-01-CR-IN-170-B		Lab ID: 70324924027		Collected: 11/19/24 07:12		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		12/12/24 15:02	7439-92-1	
Sample: 45-01-CR-IN-170-T		Lab ID: 70324924028		Collected: 11/19/24 07:13		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	2.8	ug/L	1.0	15	1		12/12/24 15:02	7439-92-1	
Sample: 45-01-CR-IN-176-B		Lab ID: 70324924029		Collected: 11/19/24 07:16		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		12/12/24 15:02	7439-92-1	
Sample: 45-01-CR-IN-176-T		Lab ID: 70324924030		Collected: 11/19/24 07:16		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	4.5	ug/L	1.0	15	1		12/12/24 15:02	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD -School No. 45

Pace Project No.: 70324924

Sample: 45-01-CR-IN-177-B Lab ID: 70324924031 Collected: 11/19/24 07:18 Received: 12/02/24 10:10 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	2.5	ug/L	1.0	15	1		12/12/24 15:02	7439-92-1	

Sample: 45-01-CR-IN-177-T Lab ID: 70324924032 Collected: 11/19/24 07:19 Received: 12/02/24 10:10 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		12/12/24 16:45	7439-92-1	

Sample: 45-01-HA-BY-175-F Lab ID: 70324924033 Collected: 11/19/24 07:23 Received: 12/02/24 10:10 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		12/12/24 16:45	7439-92-1	

Sample: 45-01-HA-BY-175-BF Lab ID: 70324924034 Collected: 11/19/24 07:24 Received: 12/02/24 10:10 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		12/12/24 16:45	7439-92-1	

Sample: 45-01-CR-IN-178-B Lab ID: 70324924035 Collected: 11/19/24 07:26 Received: 12/02/24 10:10 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	1.1	ug/L	1.0	15	1		12/12/24 16:45	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD -School No. 45

Pace Project No.: 70324924

Sample: 45-01-CR-IN-178-T		Lab ID: 70324924036		Collected: 11/19/24 07:27		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	12.2	ug/L	1.0	15	1		12/12/24 16:45	7439-92-1	
Sample: 45-01-CR-IN-180-B		Lab ID: 70324924037		Collected: 11/19/24 07:28		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		12/12/24 16:45	7439-92-1	
Sample: 45-01-CR-IN-180-T		Lab ID: 70324924038		Collected: 11/19/24 07:28		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		12/12/24 16:45	7439-92-1	
Sample: 45-01-CR-IN-186-T		Lab ID: 70324924039		Collected: 11/19/24 07:30		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	3.6	ug/L	1.0	15	1		12/12/24 16:45	7439-92-1	
Sample: 45-02-CR-IN-202-T-NORTH		Lab ID: 70324924040		Collected: 11/20/24 06:03		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	2.8	ug/L	1.0	15	1		12/12/24 16:45	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD -School No. 45

Pace Project No.: 70324924

Sample: 45-02-CR-IN-205-B Lab ID: 70324924041 Collected: 11/20/24 06:05 Received: 12/02/24 10:10 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	2.8	ug/L	1.0	15	1		12/12/24 16:45	7439-92-1	

Sample: 45-02-CR-IN-205-T Lab ID: 70324924042 Collected: 11/20/24 06:06 Received: 12/02/24 10:10 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		12/12/24 16:45	7439-92-1	

Sample: 45-02-CR-IN-204-B Lab ID: 70324924043 Collected: 11/20/24 06:08 Received: 12/02/24 10:10 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	49.5	ug/L	1.0	15	1		12/12/24 16:45	7439-92-1	

Sample: 45-02-CR-IN-204-T Lab ID: 70324924044 Collected: 11/20/24 06:08 Received: 12/02/24 10:10 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	3.9	ug/L	1.0	15	1		12/12/24 16:45	7439-92-1	

Sample: 45-02-CR-IN-206-B Lab ID: 70324924045 Collected: 11/20/24 06:11 Received: 12/02/24 10:10 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	3.6	ug/L	1.0	15	1		12/12/24 16:45	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD -School No. 45

Pace Project No.: 70324924

Sample: 45-02-CR-IN-206-T		Lab ID: 70324924046		Collected: 11/20/24 06:12		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	3.5	ug/L	1.0	15	1		12/12/24 16:45	7439-92-1	
Sample: 45-02-HA-BY-204-F		Lab ID: 70324924047		Collected: 11/20/24 06:14		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		12/12/24 16:45	7439-92-1	
Sample: 45-02-HA-BY-204-BF		Lab ID: 70324924048		Collected: 11/20/24 06:14		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		12/12/24 16:45	7439-92-1	
Sample: 45-02-CR-IN-209-B		Lab ID: 70324924049		Collected: 11/20/24 06:16		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	4.6	ug/L	1.0	15	1		12/12/24 16:45	7439-92-1	
Sample: 45-02-CR-IN-209-T		Lab ID: 70324924050		Collected: 11/20/24 06:17		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		12/12/24 16:45	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD -School No. 45

Pace Project No.: 70324924

Sample: 45-02-CR-IN-207-B		Lab ID: 70324924051		Collected: 11/20/24 06:19		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	4.3	ug/L	1.0	15	1		12/12/24 16:45	7439-92-1	
Sample: 45-02-CR-IN-207-T		Lab ID: 70324924052		Collected: 11/20/24 06:20		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	3.7	ug/L	1.0	15	1		12/12/24 15:03	7439-92-1	
Sample: 45-02-CR-IN-208-B		Lab ID: 70324924053		Collected: 11/20/24 06:22		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		12/12/24 15:03	7439-92-1	
Sample: 45-02-CR-IN-208-T		Lab ID: 70324924054		Collected: 11/20/24 06:23		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	4.0	ug/L	1.0	15	1		12/12/24 15:03	7439-92-1	
Sample: 45-02-CR-IN-215-B		Lab ID: 70324924055		Collected: 11/20/24 06:26		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	3.6	ug/L	1.0	15	1		12/12/24 15:03	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD -School No. 45

Pace Project No.: 70324924

Sample: 45-02-CR-IN-215-T		Lab ID: 70324924056		Collected: 11/20/24 06:27		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	3.6	ug/L	1.0	15	1		12/12/24 15:03	7439-92-1	
Sample: 45-02-CR-IN-214-B		Lab ID: 70324924057		Collected: 11/20/24 06:29		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	4.4	ug/L	1.0	15	1		12/12/24 15:03	7439-92-1	
Sample: 45-02-CR-IN-214-T		Lab ID: 70324924058		Collected: 11/20/24 06:29		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		12/12/24 15:03	7439-92-1	
Sample: 45-02-CR-IN-217-B		Lab ID: 70324924059		Collected: 11/20/24 06:31		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		12/12/24 15:03	7439-92-1	
Sample: 45-02-CR-IN-217-T		Lab ID: 70324924060		Collected: 11/20/24 06:31		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		12/12/24 15:03	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD -School No. 45

Pace Project No.: 70324924

Sample: 45-02-CR-IN-219-B		Lab ID: 70324924061		Collected: 11/20/24 06:33		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	3.4	ug/L	1.0	15	1		12/12/24 15:03	7439-92-1	
Sample: 45-02N-219-T		Lab ID: 70324924062		Collected: 11/20/24 06:34		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		12/12/24 15:03	7439-92-1	
Sample: 45-02-CR-IN-218-B		Lab ID: 70324924063		Collected: 11/20/24 06:37		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	2.9	ug/L	1.0	15	1		12/12/24 15:03	7439-92-1	
Sample: 45-02-CR-IN-218-T		Lab ID: 70324924064		Collected: 11/20/24 06:37		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		12/12/24 15:03	7439-92-1	
Sample: 45-02-HA-BY-220-F		Lab ID: 70324924065		Collected: 11/20/24 06:40		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	2.0	ug/L	1.0	15	1		12/12/24 15:03	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD -School No. 45

Pace Project No.: 70324924

Sample: 45-02-HA-BY-220-BF		Lab ID: 70324924066		Collected: 11/20/24 06:40		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		12/12/24 15:03	7439-92-1	
Sample: 45-02-CR-IN-223-B		Lab ID: 70324924067		Collected: 11/20/24 06:42		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	3.8	ug/L	1.0	15	1		12/12/24 15:03	7439-92-1	
Sample: 45-02-CR-IN-223-T		Lab ID: 70324924068		Collected: 11/20/24 06:43		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		12/12/24 15:03	7439-92-1	
Sample: 45-02-CR-IN-224-TL		Lab ID: 70324924069		Collected: 11/20/24 06:44		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	2.8	ug/L	1.0	15	1		12/12/24 15:03	7439-92-1	
Sample: 45-02-CR-IN-224-TR		Lab ID: 70324924070		Collected: 11/20/24 06:45		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		12/12/24 15:03	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD -School No. 45

Pace Project No.: 70324924

Sample: 45-02-CR-IN-225-T		Lab ID: 70324924071		Collected: 11/20/24 06:47		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		12/12/24 15:03	7439-92-1	
Sample: 45-02-CR-IN-230-B		Lab ID: 70324924072		Collected: 11/20/24 06:52		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	1.7	ug/L	1.0	15	1		12/12/24 17:29	7439-92-1	D6
Sample: 45-02-CR-IN-230-T		Lab ID: 70324924073		Collected: 11/20/24 06:54		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	1.3	ug/L	1.0	15	1		12/12/24 17:29	7439-92-1	
Sample: 45-02-CR-IN-228-B		Lab ID: 70324924074		Collected: 11/20/24 06:54		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	1.3	ug/L	1.0	15	1		12/12/24 17:29	7439-92-1	
Sample: 45-02-CR-IN-228-T		Lab ID: 70324924075		Collected: 11/20/24 06:55		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		12/12/24 17:29	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD -School No. 45

Pace Project No.: 70324924

Sample: 45-02-CR-IN-231-B Lab ID: 70324924076 Collected: 11/20/24 06:58 Received: 12/02/24 10:10 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		12/12/24 17:29	7439-92-1	

Sample: 45-02-CR-IN-231-T Lab ID: 70324924077 Collected: 11/20/24 06:58 Received: 12/02/24 10:10 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		12/12/24 17:29	7439-92-1	

Sample: 45-02-CR-IN-232-B Lab ID: 70324924078 Collected: 11/20/24 07:01 Received: 12/02/24 10:10 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		12/12/24 17:29	7439-92-1	

Sample: 45-02-CR-IN-232-T Lab ID: 70324924079 Collected: 11/20/24 07:01 Received: 12/02/24 10:10 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	5.4	ug/L	1.0	15	1		12/12/24 17:29	7439-92-1	

Sample: 45-02-CR-IN-234-B Lab ID: 70324924080 Collected: 11/20/24 07:04 Received: 12/02/24 10:10 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		12/12/24 17:29	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD -School No. 45

Pace Project No.: 70324924

Sample: 45-02-CR-IN-234-T Lab ID: 70324924081 Collected: 11/20/24 07:04 Received: 12/02/24 10:10 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		12/12/24 17:29	7439-92-1	

Sample: 45-02-CR-IN-233-B Lab ID: 70324924082 Collected: 11/20/24 07:08 Received: 12/02/24 10:10 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	3.9	ug/L	1.0	15	1		12/12/24 17:29	7439-92-1	

Sample: 45-02-CR-IN-233-T Lab ID: 70324924083 Collected: 11/20/24 07:09 Received: 12/02/24 10:10 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	2.4	ug/L	1.0	15	1		12/12/24 17:29	7439-92-1	

Sample: 45-02-CR-IN-239-B Lab ID: 70324924084 Collected: 11/20/24 07:11 Received: 12/02/24 10:10 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		12/12/24 17:29	7439-92-1	

Sample: 45-02-CR-IN-239-T Lab ID: 70324924085 Collected: 11/20/24 07:11 Received: 12/02/24 10:10 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		12/12/24 17:29	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD -School No. 45

Pace Project No.: 70324924

Sample: 45-02-CR-IN-240-B		Lab ID: 70324924086		Collected: 11/20/24 07:12		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	1.6	ug/L	1.0	15	1		12/12/24 17:29	7439-92-1	
Sample: 45-02-CR-IN-240-T		Lab ID: 70324924087		Collected: 11/20/24 07:13		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	7.7	ug/L	1.0	15	1		12/12/24 17:29	7439-92-1	
Sample: 45-02-CR-IN-238-B		Lab ID: 70324924088		Collected: 11/20/24 07:15		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	2.8	ug/L	1.0	15	1		12/12/24 17:29	7439-92-1	
Sample: 45-02-CR-IN-238-T		Lab ID: 70324924089		Collected: 11/20/24 07:16		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		12/12/24 17:29	7439-92-1	
Sample: 45-02-HA-BY-238-F		Lab ID: 70324924090		Collected: 11/20/24 07:19		Received: 12/02/24 10:10		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		12/12/24 17:29	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD -School No. 45

Pace Project No.: 70324924

Sample: 45-02-HA-BY-238-BF Lab ID: 70324924091 Collected: 11/20/24 07:19 Received: 12/02/24 10:10 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		12/12/24 17:29	7439-92-1	

Sample: 45-02-CR-IN-241-B Lab ID: 70324924092 Collected: 11/20/24 07:22 Received: 12/02/24 10:10 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Copper	400	ug/L	10.0	1300	1		12/12/24 18:05	7440-50-8	
Lead	<1.0	ug/L	1.0	15	1		12/12/24 18:05	7439-92-1	

Sample: 45-02-CR-IN-241-T Lab ID: 70324924093 Collected: 11/20/24 07:23 Received: 12/02/24 10:10 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	2.3	ug/L	1.0	15	1		12/12/24 18:05	7439-92-1	

Sample: 45-02-CR-IN-242-B Lab ID: 70324924094 Collected: 11/20/24 07:25 Received: 12/02/24 10:10 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	2.5	ug/L	1.0	15	1		12/12/24 18:05	7439-92-1	

Sample: 45-02-CR-IN-242-T Lab ID: 70324924095 Collected: 11/20/24 07:26 Received: 12/02/24 10:10 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		12/12/24 18:05	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: RCSD -School No. 45

Pace Project No.: 70324924

QC Batch:	374318	Analysis Method:	EPA 200.8, Rev. 5.4
QC Batch Method:	EPA 200.8, Rev. 5.4	Analysis Description:	NB 200.8 ICPMS DW No Prep
		Laboratory:	Pace Analytical Services - Newburgh
Associated Lab Samples:	70324924001, 70324924002, 70324924003, 70324924004, 70324924005, 70324924006, 70324924007, 70324924008, 70324924009, 70324924010, 70324924011		

METHOD BLANK:	1960244	Matrix:	Water
Associated Lab Samples:	70324924001, 70324924002, 70324924003, 70324924004, 70324924005, 70324924006, 70324924007, 70324924008, 70324924009, 70324924010, 70324924011		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/12/24 14:07	

LABORATORY CONTROL SAMPLE:	1960245					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	46.9	94	85-115	

MATRIX SPIKE SAMPLE:	1960247						
		70324371001	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	49.7	99	70-130	

MATRIX SPIKE SAMPLE:		1960249					
		70324924002	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	49.1	98	70-130	

SAMPLE DUPLICATE:	1960246					
Parameter	Units	70324371001 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: RCSD -School No. 45
Pace Project No.: 70324924

QC Batch:	374321	Analysis Method:	EPA 200.8, Rev. 5.4
QC Batch Method:	EPA 200.8, Rev. 5.4	Analysis Description:	NB 200.8 ICPMS DW No Prep
		Laboratory:	Pace Analytical Services - Newburgh
Associated Lab Samples:	70324924012, 70324924013, 70324924014, 70324924015, 70324924016, 70324924017, 70324924018, 70324924019, 70324924020, 70324924021, 70324924022, 70324924023, 70324924024, 70324924025, 70324924026, 70324924027, 70324924028, 70324924029, 70324924030, 70324924031		

METHOD BLANK:	1960265	Matrix:	Water
Associated Lab Samples:	70324924012, 70324924013, 70324924014, 70324924015, 70324924016, 70324924017, 70324924018, 70324924019, 70324924020, 70324924021, 70324924022, 70324924023, 70324924024, 70324924025, 70324924026, 70324924027, 70324924028, 70324924029, 70324924030, 70324924031		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/12/24 15:02	

LABORATORY CONTROL SAMPLE:	1960266					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	46.9	94	85-115	

MATRIX SPIKE SAMPLE:		1960268					
		70324924012	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	53.0	104	70-130	

MATRIX SPIKE SAMPLE:		1960270					
		70324924022	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	50.2	99	70-130	

SAMPLE DUPLICATE:	1960267					
Parameter	Units	70324924012 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: RCSD -School No. 45
Pace Project No.: 70324924

QC Batch:	374322	Analysis Method:	EPA 200.8, Rev. 5.4
QC Batch Method:	EPA 200.8, Rev. 5.4	Analysis Description:	NB 200.8 ICPMS DW No Prep
		Laboratory:	Pace Analytical Services - Newburgh
Associated Lab Samples:	70324924032, 70324924033, 70324924034, 70324924035, 70324924036, 70324924037, 70324924038, 70324924039, 70324924040, 70324924041, 70324924042, 70324924043, 70324924044, 70324924045, 70324924046, 70324924047, 70324924048, 70324924049, 70324924050, 70324924051		

METHOD BLANK:	1960271	Matrix:	Water
Associated Lab Samples:	70324924032, 70324924033, 70324924034, 70324924035, 70324924036, 70324924037, 70324924038, 70324924039, 70324924040, 70324924041, 70324924042, 70324924043, 70324924044, 70324924045, 70324924046, 70324924047, 70324924048, 70324924049, 70324924050, 70324924051		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/12/24 16:45	

LABORATORY CONTROL SAMPLE:	1960272					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	46.9	94	85-115	

MATRIX SPIKE SAMPLE:		1960274					
		70324924032	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	51.0	101	70-130	

MATRIX SPIKE SAMPLE:		1960276					
		70324924042	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	<1.0	-1	70-130	

SAMPLE DUPLICATE:	1960273					
Parameter	Units	70324924032 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: RCSD -School No. 45
Pace Project No.: 70324924

QC Batch:	374323	Analysis Method:	EPA 200.8, Rev. 5.4
QC Batch Method:	EPA 200.8, Rev. 5.4	Analysis Description:	NB 200.8 ICPMS DW No Prep
		Laboratory:	Pace Analytical Services - Newburgh
Associated Lab Samples:	70324924052, 70324924053, 70324924054, 70324924055, 70324924056, 70324924057, 70324924058, 70324924059, 70324924060, 70324924061, 70324924062, 70324924063, 70324924064, 70324924065, 70324924066, 70324924067, 70324924068, 70324924069, 70324924070, 70324924071		

METHOD BLANK:	1960277	Matrix:	Water
Associated Lab Samples:	70324924052, 70324924053, 70324924054, 70324924055, 70324924056, 70324924057, 70324924058, 70324924059, 70324924060, 70324924061, 70324924062, 70324924063, 70324924064, 70324924065, 70324924066, 70324924067, 70324924068, 70324924069, 70324924070, 70324924071		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/12/24 15:03	

LABORATORY CONTROL SAMPLE:	1960278					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	46.9	94	85-115	

MATRIX SPIKE SAMPLE:		1960280					
		70324924052	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	3.7	50	52.6	98	70-130	

MATRIX SPIKE SAMPLE:		1960282					
		70324924062	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	53.7	107	70-130	

SAMPLE DUPLICATE:	1960279					
Parameter	Units	70324924052 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	3.7	<1.0		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: RCSD -School No. 45
Pace Project No.: 70324924

QC Batch:	374325	Analysis Method:	EPA 200.8, Rev. 5.4
QC Batch Method:	EPA 200.8, Rev. 5.4	Analysis Description:	NB 200.8 ICPMS DW No Prep
		Laboratory:	Pace Analytical Services - Newburgh
Associated Lab Samples:	70324924072, 70324924073, 70324924074, 70324924075, 70324924076, 70324924077, 70324924078, 70324924079, 70324924080, 70324924081, 70324924082, 70324924083, 70324924084, 70324924085, 70324924086, 70324924087, 70324924088, 70324924089, 70324924090, 70324924091		

METHOD BLANK:	1960293	Matrix:	Water
Associated Lab Samples:	70324924072, 70324924073, 70324924074, 70324924075, 70324924076, 70324924077, 70324924078, 70324924079, 70324924080, 70324924081, 70324924082, 70324924083, 70324924084, 70324924085, 70324924086, 70324924087, 70324924088, 70324924089, 70324924090, 70324924091		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/12/24 17:29	

LABORATORY CONTROL SAMPLE:	1960294					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	46.7	93	85-115	

MATRIX SPIKE SAMPLE:		1960296					
		70324924072	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	1.7	50	51.6	100	70-130	

MATRIX SPIKE SAMPLE:	1960298						
		70324924082	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	3.9	50	53.3	99	70-130	

SAMPLE DUPLICATE:	1960295					
Parameter	Units	70324924072 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	1.7	2.6	41	20	D6

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: RCSD -School No. 45

Pace Project No.: 70324924

QC Batch:	374326	Analysis Method:	EPA 200.8, Rev. 5.4
QC Batch Method:	EPA 200.8, Rev. 5.4	Analysis Description:	NB 200.8 ICPMS DW No Prep
		Laboratory:	Pace Analytical Services - Newburgh

Associated Lab Samples: 70324924092, 70324924093, 70324924094, 70324924095

METHOD BLANK: 1960299 Matrix: Water

Associated Lab Samples: 70324924092, 70324924093, 70324924094, 70324924095

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Copper	ug/L	<10.0	10.0	12/12/24 18:05	
Lead	ug/L	<1.0	1.0	12/12/24 18:05	

LABORATORY CONTROL SAMPLE: 1960300

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Copper	ug/L	50	41.9	84	85-115	L5
Lead	ug/L	50	46.7	93	85-115	

MATRIX SPIKE SAMPLE: 1960302

Parameter	Units	70324924092 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Copper	ug/L	400	50	450	101	70-130	
Lead	ug/L	<1.0	50	51.3	102	70-130	

SAMPLE DUPLICATE: 1960301

Parameter	Units	70324924092 Result	Dup Result	RPD	Max RPD	Qualifiers
Copper	ug/L	400	400	0	20	
Lead	ug/L	<1.0	<1.0		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALIFIERS

Project: RCSD -School No. 45
Pace Project No.: 70324924

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

ANALYTE QUALIFIERS

D6 The precision between the sample and sample duplicate exceeded laboratory control limits.

L5 LCS recovery exceeded QC limits. Batch accepted based on matrix spike recovery within LCS limits.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: RCSD -School No. 45

Pace Project No.: 70324924

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70324924001	45-01-HA-BY-103-F	EPA 200.8, Rev. 5.4	374318		
70324924002	45-01-HA-BY-103-BF	EPA 200.8, Rev. 5.4	374318		
70324924003	45-01-KI-IN-106-T1	EPA 200.8, Rev. 5.4	374318		
70324924004	45-01-KI-IN-106-T2	EPA 200.8, Rev. 5.4	374318		
70324924005	45-01-KI-IN-106-T3	EPA 200.8, Rev. 5.4	374318		
70324924006	45-01-HA-BY-121-F	EPA 200.8, Rev. 5.4	374318		
70324924007	45-01-HA-BY-121-BF	EPA 200.8, Rev. 5.4	374318		
70324924008	45-01-HA-BY-108-F	EPA 200.8, Rev. 5.4	374318		
70324924009	45-01-HA-BY-108-BF	EPA 200.8, Rev. 5.4	374318		
70324924010	45-01-TL-IN-128-T	EPA 200.8, Rev. 5.4	374318		
70324924011	45-01-CR-IN-130-T	EPA 200.8, Rev. 5.4	374318		
70324924012	45-01-CR-IN-131-B	EPA 200.8, Rev. 5.4	374321		
70324924013	45-01-CR-IN-131-T	EPA 200.8, Rev. 5.4	374321		
70324924014	45-01-CR-IN-132-T	EPA 200.8, Rev. 5.4	374321		
70324924015	45-01HA-BY-134-F	EPA 200.8, Rev. 5.4	374321		
70324924016	45-01HA-BY-134-BF	EPA 200.8, Rev. 5.4	374321		
70324924017	45-01-CR-IN-137-B	EPA 200.8, Rev. 5.4	374321		
70324924018	45-01-CR-IN-137-T	EPA 200.8, Rev. 5.4	374321		
70324924019	45-01-NO-IN-150-T	EPA 200.8, Rev. 5.4	374321		
70324924020	45-01-OF-IN-162-T	EPA 200.8, Rev. 5.4	374321		
70324924021	45-01-CR-IN-166-T	EPA 200.8, Rev. 5.4	374321		
70324924022	45-01-CR-IN-167-B	EPA 200.8, Rev. 5.4	374321		
70324924023	45-01-CR-IN-167-T	EPA 200.8, Rev. 5.4	374321		
70324924024	45-01-CR-IN-168-B	EPA 200.8, Rev. 5.4	374321		
70324924025	45-01-CR-IN-168-T	EPA 200.8, Rev. 5.4	374321		
70324924026	45-01-CR-IN-169-T	EPA 200.8, Rev. 5.4	374321		
70324924027	45-01-CR-IN-170-B	EPA 200.8, Rev. 5.4	374321		
70324924028	45-01-CR-IN-170-T	EPA 200.8, Rev. 5.4	374321		
70324924029	45-01-CR-IN-176-B	EPA 200.8, Rev. 5.4	374321		
70324924030	45-01-CR-IN-176-T	EPA 200.8, Rev. 5.4	374321		
70324924031	45-01-CR-IN-177-B	EPA 200.8, Rev. 5.4	374321		
70324924032	45-01-CR-IN-177-T	EPA 200.8, Rev. 5.4	374322		
70324924033	45-01-HA-BY-175-F	EPA 200.8, Rev. 5.4	374322		
70324924034	45-01-HA-BY-175-BF	EPA 200.8, Rev. 5.4	374322		
70324924035	45-01-CR-IN-178-B	EPA 200.8, Rev. 5.4	374322		
70324924036	45-01-CR-IN-178-T	EPA 200.8, Rev. 5.4	374322		
70324924037	45-01-CR-IN-180-B	EPA 200.8, Rev. 5.4	374322		
70324924038	45-01-CR-IN-180-T	EPA 200.8, Rev. 5.4	374322		
70324924039	45-01-CR-IN-186-T	EPA 200.8, Rev. 5.4	374322		
70324924040	45-02-CR-IN-202-T-NORTH	EPA 200.8, Rev. 5.4	374322		
70324924041	45-02-CR-IN-205-B	EPA 200.8, Rev. 5.4	374322		
70324924042	45-02-CR-IN-205-T	EPA 200.8, Rev. 5.4	374322		
70324924043	45-02-CR-IN-204-B	EPA 200.8, Rev. 5.4	374322		
70324924044	45-02-CR-IN-204-T	EPA 200.8, Rev. 5.4	374322		
70324924045	45-02-CR-IN-206-B	EPA 200.8, Rev. 5.4	374322		
70324924046	45-02-CR-IN-206-T	EPA 200.8, Rev. 5.4	374322		
70324924047	45-02-HA-BY-204-F	EPA 200.8, Rev. 5.4	374322		
70324924048	45-02-HA-BY-204-BF	EPA 200.8, Rev. 5.4	374322		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: RCSD -School No. 45

Pace Project No.: 70324924

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70324924049	45-02-CR-IN-209-B	EPA 200.8, Rev. 5.4	374322		
70324924050	45-02-CR-IN-209-T	EPA 200.8, Rev. 5.4	374322		
70324924051	45-02-CR-IN-207-B	EPA 200.8, Rev. 5.4	374322		
70324924052	45-02-CR-IN-207-T	EPA 200.8, Rev. 5.4	374323		
70324924053	45-02-CR-IN-208-B	EPA 200.8, Rev. 5.4	374323		
70324924054	45-02-CR-IN-208-T	EPA 200.8, Rev. 5.4	374323		
70324924055	45-02-CR-IN-215-B	EPA 200.8, Rev. 5.4	374323		
70324924056	45-02-CR-IN-215-T	EPA 200.8, Rev. 5.4	374323		
70324924057	45-02-CR-IN-214-B	EPA 200.8, Rev. 5.4	374323		
70324924058	45-02-CR-IN-214-T	EPA 200.8, Rev. 5.4	374323		
70324924059	45-02-CR-IN-217-B	EPA 200.8, Rev. 5.4	374323		
70324924060	45-02-CR-IN-217-T	EPA 200.8, Rev. 5.4	374323		
70324924061	45-02-CR-IN-219-B	EPA 200.8, Rev. 5.4	374323		
70324924062	45-02N-219-T	EPA 200.8, Rev. 5.4	374323		
70324924063	45-02-CR-IN-218-B	EPA 200.8, Rev. 5.4	374323		
70324924064	45-02-CR-IN-218-T	EPA 200.8, Rev. 5.4	374323		
70324924065	45-02-HA-BY-220-F	EPA 200.8, Rev. 5.4	374323		
70324924066	45-02-HA-BY-220-BF	EPA 200.8, Rev. 5.4	374323		
70324924067	45-02-CR-IN-223-B	EPA 200.8, Rev. 5.4	374323		
70324924068	45-02-CR-IN-223-T	EPA 200.8, Rev. 5.4	374323		
70324924069	45-02-CR-IN-224-TL	EPA 200.8, Rev. 5.4	374323		
70324924070	45-02-CR-IN-224-TR	EPA 200.8, Rev. 5.4	374323		
70324924071	45-02-CR-IN-225-T	EPA 200.8, Rev. 5.4	374323		
70324924072	45-02-CR-IN-230-B	EPA 200.8, Rev. 5.4	374325		
70324924073	45-02-CR-IN-230-T	EPA 200.8, Rev. 5.4	374325		
70324924074	45-02-CR-IN-228-B	EPA 200.8, Rev. 5.4	374325		
70324924075	45-02-CR-IN-228-T	EPA 200.8, Rev. 5.4	374325		
70324924076	45-02-CR-IN-231-B	EPA 200.8, Rev. 5.4	374325		
70324924077	45-02-CR-IN-231-T	EPA 200.8, Rev. 5.4	374325		
70324924078	45-02-CR-IN-232-B	EPA 200.8, Rev. 5.4	374325		
70324924079	45-02-CR-IN-232-T	EPA 200.8, Rev. 5.4	374325		
70324924080	45-02-CR-IN-234-B	EPA 200.8, Rev. 5.4	374325		
70324924081	45-02-CR-IN-234-T	EPA 200.8, Rev. 5.4	374325		
70324924082	45-02-CR-IN-233-B	EPA 200.8, Rev. 5.4	374325		
70324924083	45-02-CR-IN-233-T	EPA 200.8, Rev. 5.4	374325		
70324924084	45-02-CR-IN-239-B	EPA 200.8, Rev. 5.4	374325		
70324924085	45-02-CR-IN-239-T	EPA 200.8, Rev. 5.4	374325		
70324924086	45-02-CR-IN-240-B	EPA 200.8, Rev. 5.4	374325		
70324924087	45-02-CR-IN-240-T	EPA 200.8, Rev. 5.4	374325		
70324924088	45-02-CR-IN-238-B	EPA 200.8, Rev. 5.4	374325		
70324924089	45-02-CR-IN-238-T	EPA 200.8, Rev. 5.4	374325		
70324924090	45-02-HA-BY-238-F	EPA 200.8, Rev. 5.4	374325		
70324924091	45-02-HA-BY-238-BF	EPA 200.8, Rev. 5.4	374325		
70324924092	45-02-CR-IN-241-B	EPA 200.8, Rev. 5.4	374326		
70324924093	45-02-CR-IN-241-T	EPA 200.8, Rev. 5.4	374326		
70324924094	45-02-CR-IN-242-B	EPA 200.8, Rev. 5.4	374326		
70324924095	45-02-CR-IN-242-T	EPA 200.8, Rev. 5.4	374326		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 1 of 10

REPORT TO:				INVOICE TO:			
Company: Lozier Environmental Consulting, Inc.				Company: (SAME)			
Address: 2011 East Main Street				Address:			
City, State Zip: Rochester NY 14609				City, State Zip:			
Phone: 585-654-9080 Fax: 585-654-9662				Phone: Fax:			
E-Mail: support@lozierenv.com				Purchase Order #:			

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	Lead					
1	45-01-HA-BY-103-F	11/19/2024	6:11		DW				x					
2	45-01-HA-BY-103-BF	11/19/2024	6:11		DW				x					
3	45-01-KI-IN-106-T1	11/19/2024	6:18		DW				x					
4	45-01-KI-IN-106-T2	11/19/2024	6:19		DW				x					
5	45-01-KI-IN-106-T3	11/19/2024	6:19		DW				x					
6	45-01-HA-BY-121-F	11/19/2024	6:25		DW				x					
7	45-01-HA-BY-121-BF	11/19/2024	6:25		DW				x					
8	45-01-HA-BY-108-F	11/19/2024	6:30		DW				x					
9	45-01-HA-BY-108-BF	11/19/2024	6:31		DW				x					
10	45-01-TL-IN-128-T	11/19/2024	6:40		DW				x					

W0#: 70324924

70324924

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

SAMPLED BY*: Joe Savioe

RELINQUISHED BY*: Joe Savioe

DATE: TIME:

RECEIVED BY:

DATE: 12/2 TIME: 1010

RELINQUISHED BY*:

DATE: TIME:

RECEIVED BY:

DATE: TIME:

RELINQUISHED BY*:

DATE: TIME:

RECEIVED BY:

DATE: TIME:

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDE: HNO3-	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINERS: 95	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES	Present Absent
SAMPLE ON ICE? NO	If Present, Date Client is
TEMPERATURE: 17.0 C	contacted with result:
SAMPLE IN COMPLIANCE: YES	Date: _____
	Contacted By: _____



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 2 of 10

70324924

REPORT TO:		INVOICE TO:	
Company:	Lozier Environmental Consulting, Inc.	Company:	(SAME)
Address:	2011 East Main Street	Address:	
City, State Zip:	Rochester NY 14609	City, State Zip:	
Phone:	585-654-9080	Phone:	
Fax:	585-654-9662	Fax:	
E-Mail:	support@lozierenv.com	Purchase Order #:	

LAB ID: M36789	LAB ID: M36789
PROJECT NAME: RCSD - School No. 45	PROJECT NAME: RCSD - School No. 45
TURNAROUND TIME: Standard Rush	TURNAROUND TIME: Standard Rush
Other:	Other:

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS					
									Lead					
11	45-01-CR-IN-130-T	11/19/2024	6:42		DW				x					
12	45-01-CR-IN-131-B	11/19/2024	6:43		DW				x					
13	45-01-CR-IN-131-T	11/19/2024	6:44		DW				x					
14	45-01-CR-IN-132-T	11/19/2024	6:46		DW				x					
15	45-01-HA-BY-134-F	11/19/2024	6:48		DW				x					
16	45-01-HA-BY-134-BF	11/19/2024	6:49		DW				x					
17	45-01-CR-IN-137-B	11/19/2024	6:53		DW				x					
18	45-01-CR-IN-137-T	11/19/2024	6:54		DW				x					
19	45-01-NO-IN-150-T	11/19/2024	6:57		DW				x					
20	45-01-OF-IN-162-T	11/19/2024	7:01		DW				x					

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

SAMPLED BY* Joe Savioe

RELINQUISHED BY*: Joe Savioe	DATE:	TIME:
RECEIVED BY: <i>AP</i>	DATE: 12/2	TIME: 1010
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDE: HNO3-	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINERS: 95	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES	Present Absent
SAMPLE ON ICE? NO	If Present, Date Client is
TEMPERATURE: 17.0C	contacted with result:
SAMPLE IN COMPLIANCE: YES	Date: _____
	Contacted By: _____



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 3 of 10

70324924

REPORT TO:		INVOICE TO:	
Company:	Lozier Environmental Consulting, Inc.	Company:	(SAME)
Address:	2011 East Main Street	Address:	
City, State Zip:	Rochester NY 14609	City, State Zip:	
Phone:	585-654-9080	Fax:	585-654-9662
Other:	E-Mail: support@lozierenv.com	Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS					
									Lead					
21	45-01-CR-IN-166-T	11/19/2024	7:03		DW				x					
22	45-01-CR-IN-167-B	11/19/2024	7:05		DW				x					
23	45-01-CR-IN-167-T	11/19/2024	7:05		DW				x					
24	45-01-CR-IN-168-B	11/19/2024	7:09		DW				x					
25	45-01-CR-IN-168-T	11/19/2024	7:10		DW				x					
26	45-01-CR-IN-169-T	11/19/2024	7:12		DW				x					
27	45-01-CR-IN-170-B	11/19/2024	7:12		DW				x					
28	45-01-CR-IN-170-T	11/19/2024	7:13		DW				x					
29	45-01-CR-IN-176-B	11/19/2024	7:16		DW				x					
30	45-01-CR-IN-176-T	11/19/2024	7:16		DW				x					

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

SAMPLED BY* Joe Savioe

RELINQUISHED BY*: Joe Savioe	DATE:	TIME:
RECEIVED BY: <i>AP</i>	DATE: 12/2	TIME: 1010
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDE: HNO3-	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINERS 95	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES	Present Absent
SAMPLE ON ICE? <i>NO</i>	If Present, Date Client is
TEMPERATURE: 17.0 C	contacted with result:
SAMPLE IN COMPLIANCE: YES	Date: _____
	Contacted By: _____



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 4 of 10
70324924

REPORT TO:		INVOICE TO:	
Company:	Lozier Environmental Consulting, Inc.	Company:	(SAME)
Address:	2011 East Main Street	Address:	
City, State Zip:	Rochester NY 14609	City, State Zip:	
Phone:	585-654-9080	Fax:	585-654-9662
Other:	E-Mail: support@lozierenv.com	Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS					
									Lead					
31	45-01-CR-IN-177-B	11/19/2024	7:18		DW				x					
32	45-01-CR-IN-177-T	11/19/2024	7:19		DW				x					
33	45-01-HA-BY-175-F	11/19/2024	7:23		DW				x					
34	45-01-HA-BY-175-BF	11/19/2024	7:24		DW				x					
35	45-01-CR-IN-178-B	11/19/2024	7:26		DW				x					
36	45-01-CR-IN-178-T	11/19/2024	7:27		DW				x					
37	45-01-CR-IN-180-B	11/19/2024	7:28		DW				x					
38	45-01-CR-IN-180-T	11/19/2024	7:28		DW				x					
39	45-01-CR-IN-186-T	11/19/2024	7:30		DW				x					
40	45-02-CR-IN-202-T-NORTH	11/20/2024	6:03		DW				x					

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

SAMPLED BY* Joe Savioe

RELINQUISHED BY*: Joe Savioe	DATE:	TIME:
RECEIVED BY: <i>[Signature]</i>	DATE: 12/2	TIME: 1010
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDE: HNO3-	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINER: 95	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES	Present Absent
SAMPLE ON ICE? NO	If Present, Date Client is
TEMPERATURE: 17.0 C	contacted with result:
SAMPLE IN COMPLIANCE: YES	Date: _____
	Contacted By: _____



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 5 of 10
7032492

REPORT TO:		INVOICE TO:	
Company:	Lozier Environmental Consulting, Inc.	Company:	(SAME)
Address:	2011 East Main Street	Address:	
City, State Zip:	Rochester NY 14609	City, State Zip:	
Phone:	585-654-9080	Fax:	585-654-9662
Other:	E-Mail: support@lozierenv.com	Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS					
									Lead					
41	45-02-CR-IN-205-B	11/20/2024	6:05		DW				x					
42	45-02-CR-IN-205-T	11/20/2024	6:06		DW				x					
43	45-02-CR-IN-204-B	11/20/2024	6:08		DW				x					
44	45-02-CR-IN-204-T	11/20/2024	6:08		DW				x					
45	45-02-CR-IN-206-B	11/20/2024	6:11		DW				x					
46	45-02-CR-IN-206-T	11/20/2024	6:12		DW				x					
47	45-02-HA-BY-204-F	11/20/2024	6:14		DW				x					
48	45-02-HA-BY-204-BF	11/20/2024	6:14		DW				x					
49	45-02-CR-IN-209-B	11/20/2024	6:16		DW				x					
50	45-02-CR-IN-209-T	11/20/2024	6:17		DW				x					

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

SAMPLED BY* Joe Savioe

RELINQUISHED BY*: Joe Savioe	DATE:	TIME:
RECEIVED BY: <i>[Signature]</i>	DATE: 12/2	TIME: 1800
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDE: HNO3-	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINER 95	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES	Present Absent
SAMPLE ON ICE? NO	If Present, Date Client is
TEMPERATURE: 17.0 C	contacted with result:
SAMPLE IN COMPLIANCE: YES	Date: _____
	Contacted By: _____

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 6 of 10
70324924

REPORT TO:		INVOICE TO:	
Company:	Lozier Environmental Consulting, Inc.	Company:	(SAME)
Address:	2011 East Main Street	Address:	
City, State Zip:	Rochester NY 14609	City, State Zip:	
Phone:	585-654-9080	Phone:	
Fax:	585-654-9662	Fax:	
E-Mail:	support@lozierenv.com	Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS					
									Lead					
51	45-02-CR-IN-207-B	11/20/2024	6:19		DW				x					
52	45-02-CR-IN-207-T	11/20/2024	6:20		DW				x					
53	45-02-CR-IN-208-B	11/20/2024	6:22		DW				x					
54	45-02-CR-IN-208-T	11/20/2024	6:23		DW				x					
55	45-02-CR-IN-215-B	11/20/2024	6:26		DW				x					
56	45-02-CR-IN-215-T	11/20/2024	6:27		DW				x					
57	45-02-CR-IN-214-B	11/20/2024	6:29		DW				x					
58	45-02-CR-IN-214-T	11/20/2024	6:29		DW				x					
59	45-02-CR-IN-217-B	11/20/2024	6:31		DW				x					
60	45-02-CR-IN-217-T	11/20/2024	6:31		DW				x					

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

SAMPLED BY* Joe Savioe

RELINQUISHED BY*: Joe Savioe

DATE: TIME:

RECEIVED BY: PP

DATE: 12/2 TIME: 1010

RELINQUISHED BY*:

DATE: TIME:

RECEIVED BY:

DATE: TIME:

RELINQUISHED BY*:

DATE: TIME:

RECEIVED BY:

DATE: TIME:

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDE: HNO3-	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINER: 95	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES	Present Absent
SAMPLE ON ICE? <u>NO</u>	If Present, Date Client is
TEMPERATURE: <u>17.0</u> C	contacted with result:
SAMPLE IN COMPLIANCE: YES	Date: _____
	Contacted By: _____



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 7 of 10
70324924

REPORT TO:				INVOICE TO:			
Company: Lozier Environmental Consulting, Inc.				Company: (SAME)			
Address: 2011 East Main Street				Address:			
City, State Zip: Rochester NY 14609				City, State Zip:			
Phone: 585-654-9080 Fax: 585-654-9662				Phone: Fax:			
E-Mail: support@lozierenv.com				Purchase Order #:			

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS					
									Lead					
61	45-02-CR-IN-219-B	11/20/2024	6:33		DW				x					
62	45-02N-219-T	11/20/2024	6:34		DW				x					
63	45-02-CR-IN-218-B	11/20/2024	6:37		DW				x					
64	45-02-CR-IN-218-T	11/20/2024	6:37		DW				x					
65	45-02-HA-BY-220-F	11/20/2024	6:40		DW				x					
66	45-02-HA-BY-220-BF	11/20/2024	6:40		DW				x					
67	45-02-CR-IN-223-B	11/20/2024	6:42		DW				x					
68	45-02-CR-IN-223-T	11/20/2024	6:43		DW				x					
69	45-02-CR-IN-224-TL	11/20/2024	6:44		DW				x					
70	45-02-CR-IN-224-TR	11/20/2024	6:45		DW				x					

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

SAMPLED BY* Joe Savioe

RELINQUISHED BY*: Joe Savioe	DATE:	TIME:
RECEIVED BY: <i>PR</i>	DATE: 12/2	TIME: 1010
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDE: HNO3-	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINERS: 95	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES	Present Absent
SAMPLE ON ICE? <i>NO</i>	If Present, Date Client is
TEMPERATURE: 17.0 C	contacted with result:
SAMPLE IN COMPLIANCE: YES	Date: _____
	Contacted By: _____



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 8 of 10

70324924

REPORT TO:		INVOICE TO:	
Company:	Lozier Environmental Consulting, Inc.	Company:	(SAME)
Address:	2011 East Main Street	Address:	
City, State Zip:	Rochester NY 14609	City, State Zip:	
Phone:	585-654-9080	Phone:	
Fax:	585-654-9662	Fax:	
E-Mail:	support@lozierenv.com	Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS					
									Lead					
71	45-02-CR-IN-225-T	11/20/2024	6:47		DW				x					
72	45-02-CR-IN-230-B	11/20/2024	6:52		DW				x					
73	45-02-CR-IN-230-T	11/20/2024	6:54		DW				x					
74	45-02-CR-IN-228-B	11/20/2024	6:54		DW				x					
75	45-02-CR-IN-228-T	11/20/2024	6:55		DW				x					
76	45-02-CR-IN-231-B	11/20/2024	6:58		DW				x					
77	45-02-CR-IN-231-T	11/20/2024	6:58		DW				x					
78	45-02-CR-IN-232-B	11/20/2024	7:01		DW				x					
79	45-02-CR-IN-232-T	11/20/2024	7:01		DW				x					
80	45-02-CR-IN-234-B	11/20/2024	7:04		DW				x					

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

SAMPLED BY* Joe Savioe

RELINQUISHED BY*: Joe Savioe

DATE: TIME:

RECEIVED BY: *[Signature]*

DATE: 12/2 TIME: 10/0

RELINQUISHED BY*:

DATE: TIME:

RECEIVED BY:

DATE: TIME:

RELINQUISHED BY*:

DATE: TIME:

RECEIVED BY:

DATE: TIME:

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDE: HNO3-	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINERS: 95	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES	Present Absent
SAMPLE ON ICE? NO	If Present, Date Client is
TEMPERATURE: 17.0 C	contacted with result:
SAMPLE IN COMPLIANCE: YES	Date: _____
	Contacted By: _____



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 9 of 10
70324924

REPORT TO:		INVOICE TO:	
Company:	Lozier Environmental Consulting, Inc.	Company:	(SAME)
Address:	2011 East Main Street	Address:	
City, State Zip:	Rochester NY 14609	City, State Zip:	
Phone:	585-654-9080	Phone:	
Fax:	585-654-9662	Fax:	
E-Mail:	support@lozierenv.com	Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS					
									Lead					
81	45-02-CR-IN-234-T	11/20/2024	7:04		DW				x					
82	45-02-CR-IN-233-B	11/20/2024	7:08		DW				x					
83	45-02-CR-IN-233-T	11/20/2024	7:09		DW				x					
84	45-02-CR-IN-239-B	11/20/2024	7:11		DW				x					
85	45-02-CR-IN-239-T	11/20/2024	7:11		DW				x					
86	45-02-CR-IN-240-B	11/20/2024	7:12		DW				x					
87	45-02-CR-IN-240-T	11/20/2024	7:13		DW				x					
88	45-02-CR-IN-238-B	11/20/2024	7:15		DW				x					
89	45-02-CR-IN-238-T	11/20/2024	7:16		DW				x					
90	45-02-HA-BY-238-F	11/20/2024	7:19		DW				x					

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

SAMPLED BY* Joe Savioe

RELINQUISHED BY*: Joe Savioe DATE: TIME:

RECEIVED BY: DATE: 12/2 TIME: 1010

RELINQUISHED BY*: DATE: TIME:

RECEIVED BY: DATE: TIME:

RELINQUISHED BY*: DATE: TIME:

RECEIVED BY: DATE: TIME:

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDE: HNO3-	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINERS 95	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES	Present Absent
SAMPLE ON ICE? NO	If Present, Date Client is
TEMPERATURE: 17.0C	contacted with result:
SAMPLE IN COMPLIANCE: YES	Date: _____
	Contacted By: _____

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 10 of 10

70324924

REPORT TO:		INVOICE TO:	
Company: Lozier Environmental Consulting, Inc.	Company: (SAME)		
Address: 2011 East Main Street	Address:		
City, State Zip: Rochester NY 14609	City, State Zip:		
Phone: 585-654-9080 Fax: 585-654-9662	Phone: Fax:		
E-Mail: support@lozierenv.com	Purchase Order #:		

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS					
									Lead					
91	45-02-HA-BY-238-BF	11/20/2024	7:19		DW				x					
92	45-02-CR-IN-241-B	11/20/2024	7:22		DW				x					
93	45-02-CR-IN-241-T	11/20/2024	7:23		DW				x					
94	45-02-CR-IN-242-B	11/20/2024	7:25		DW				x					
95	45-02-CR-IN-242-T	11/20/2024	7:26		DW				x					

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

SAMPLED BY* Joe Savioe

RELINQUISHED BY*: Joe Savioe	DATE:	TIME:
RECEIVED BY: <i>(Signature)</i>	DATE: 12/2	TIME: 1010
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDE: HNO3-	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINER 95	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES	Present Absent
SAMPLE ON ICE? NO	If Present, Date Client is
TEMPERATURE: 17.0 C	contacted with result:
SAMPLE IN COMPLIANCE: YES	Date: _____
	Contacted By: _____

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

Sample ID: (UR)
W0#: 70324924

Project #

PM: RC1 Due Date: 12/16/24

Client:

CLIENT: NB-LOZIER

Date and Initials of person:

Examining contents: Label: _____

Deliver to location: _____

pH: _____

Thermometer Used: IRG4

Date: 12/2

Time: 1010

Initials: _____

State of Origin: NY

Cooler #1 Temp. °C 17.0 (Visual) 0.2 @ 0.0°C, -0.5 @ 20.0°C (Correction Factor) _____ (Actual) ☒ Samples on ice, cooling process has begun

Courier: ☒ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☐ Pace ☐ Other _____

Shipping Method: ☐ First Overnight ☐ Priority Overnight ☐ Standard Overnight ☒ Ground

☐ Other _____

Tracking # 7702 5068 4277, 7702 5068 5295, 7702 5068 4531

Custody Seal on Cooler/Box Present: ☐ Yes ☐ No Seals intact: ☐ Yes ☐ No Ice: ☒ Wet ☐ Blue ☐ Melted ☐ None

Packing Material: ☐ Bubble Wrap ☐ Bubble Bags ☐ None ☐ Other _____

Samples were collected by Pace employee ☐ Yes ☐ No ☐ N/A

Comments:

Chain of Custody Present	☒ Yes	☐ No	☐ N/A
Chain of Custody Filled Out	☒ Yes	☐ No	☐ N/A
Relinquished Signature on COC	☒ Yes	☐ No	☐ N/A
Sampler Name and Signature on COC	☒ Yes	☐ No	☐ N/A
Samples Arrived within Hold Time	☒ Yes	☐ No	☐ N/A
Rush TAT requested on COC	☐ Yes	☐ No	☐ N/A
Sufficient Volume	☒ Yes	☐ No	☐ N/A
Correct Containers Used	☒ Yes	☐ No	☐ N/A
Containers Intact	☒ Yes	☐ No	☐ N/A
Sample Labels match COC (sample IDs & date/time of collection)	☒ Yes	☐ No	☐ N/A
All containers needing acid/base preservation have been checked.	☐ Yes	☐ No	☐ N/A
All Containers needing preservation are found to be in compliance with EPA recommendation:	☐ Yes	☐ No	☐ N/A
Exceptions: Vials, Microbiology, O&G, Metals			
Headspace in VOA Vials? (>6mm):	☐ Yes	☐ No	☐ N/A
Trip Blank Present:	☐ Yes	☐ No	☐ N/A

Additional Login Comments:

Client notification/ Resolution

Person Contacted:

Date/Time:

Comments/Resolution: