



March 28, 2024

V Kaptein
NB-Lozier Environmental Consulting, Inc
2011 E Main Street
Rochester, NY 14609

Project Location: RCSD-Theo Roosevelt Sch. 43
Project Number: RCSD-Theo Roosevelt Sch. 43
Laboratory Work Order Number: 24C2896

Enclosed are results of analyses for samples received by the laboratory on March 26, 2024. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in black ink that reads "Benjamin M. Cusack".

Project Manager



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

NB-Lozier Environmental Consulting, Inc
2011 E Main Street
Rochester, NY 14609
ATTN: V Kaptein

REPORT DATE: 3/28/2024

PURCHASE ORDER NUMBER:

PROJECT NUMBER: RCSD-Theo Roosevelt Sch. 43

ANALYTICAL SUMMARY

WORK ORDER NUMBER: 24C2896

The results of analyses performed on the following samples submitted to Pace Analytical Services, LLC - Newburgh are found in this report.

PROJECT LOCATION: RCSD-Theo Roosevelt Sch. 43

FIELD SAMPLE #	LAB ID:	MATRIX	SAMPLE DESCRIPTION	TEST	SUB LAB
43-01-CR- IN -113 -T (1)	24C2896-01	Drinking Water		EPA 200.8 Rev 5.4	
43-01 - HA -BY -109A-F (2)	24C2896-02	Drinking Water		EPA 200.8 Rev 5.4	
43-01-HA-BY-113-T (5)	24C2896-03	Drinking Water		EPA 200.8 Rev 5.4	
43-01-HA-BY-122A-F (6)	24C2896-04	Drinking Water		EPA 200.8 Rev 5.4	
43-01-NO-IN-102-T (9)	24C2896-05	Drinking Water		EPA 200.8 Rev 5.4	
43-02-HA-BY-215A-F (13)	24C2896-06	Drinking Water		EPA 200.8 Rev 5.4	
43-02-HA-BY-215A-T (14)	24C2896-07	Drinking Water		EPA 200.8 Rev 5.4	
43-02-HA-BY-222A-T (16)	24C2896-08	Drinking Water		EPA 200.8 Rev 5.4	
43-B-KIT-IN-3A-T1 (18)	24C2896-09	Drinking Water		EPA 200.8 Rev 5.4	
43-B-KIT-IN-3A-T2 (19)	24C2896-10	Drinking Water		EPA 200.8 Rev 5.4	
43-B-KIT-IN-3A-T3 (20)	24C2896-11	Drinking Water		EPA 200.8 Rev 5.4	
43-01-HA-BY-109A-BF (21)	24C2896-12	Drinking Water		EPA 200.8 Rev 5.4	
43-01-HA-BY-109A-T (22)	24C2896-13	Drinking Water		EPA 200.8 Rev 5.4	
43-01-HA-BY-122A-BF (26)	24C2896-14	Drinking Water		EPA 200.8 Rev 5.4	
43-01-HA-BY-122A-F (27)	24C2896-15	Drinking Water		EPA 200.8 Rev 5.4	
43-02-HA-BY-215A-F (41)	24C2896-16	Drinking Water		EPA 200.8 Rev 5.4	
43-02-HA-BY-222A-BF (42)	24C2896-17	Drinking Water		EPA 200.8 Rev 5.4	
43-02-HA-BY-222A-F (43)	24C2896-18	Drinking Water		EPA 200.8 Rev 5.4	
43-B-HA-BY-7A-BF (50)	24C2896-19	Drinking Water		EPA 200.8 Rev 5.4	
43-B-HA-BY-7A-F (51)	24C2896-20	Drinking Water		EPA 200.8 Rev 5.4	
43-B-CR-IN-10-T1 (52)	24C2896-21	Drinking Water		EPA 200.8 Rev 5.4	
43-B-CR-IN-10-T2 (53)	24C2896-22	Drinking Water		EPA 200.8 Rev 5.4	

CASE NARRATIVE SUMMARY

All reported results are within defined laboratory quality control objectives unless listed below or otherwise qualified in this report.

EPA 200.8 Rev 5.4

Qualifications:

Z-01

#


Analyte & Samples(s) Qualified:

Lead

24C2896-01[43-01-CR- IN -113 -T (1)], 24C2896-21[43-B-CR-IN-10-T1 (52)]

The results of analyses reported only relate to samples submitted to the Pace Analytical Services, LLC - Newburgh for testing.

I certify that the analyses listed above, unless specifically listed as subcontracted, if any, were performed under my direction according to the approved methodologies listed in this document, and that based upon my inquiry of those individuals immediately responsible for obtaining the information, the material contained in this report is, to the best of my knowledge and belief, accurate and complete.



Renee Cusack
PM



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-Theo Roosevelt Sch. 43

Sample Description:

Work Order: 24C2896

Date Received: 3/26/2024

Sampled: 3/13/2024 06:05

Field Sample #: 43-01-CR- IN -113 -T (1)

Sample ID: 24C2896-01

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	22	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	3/27/24	3/27/24 16:47	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-Theo Roosevelt Sch. 43

Sample Description:

Work Order: 24C2896

Date Received: 3/26/2024

Field Sample #: 43-01 - HA -BY -109A-F (2)

Sampled: 3/13/2024 06:09

Sample ID: 24C2896-02

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	3.9	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	3/27/24	3/27/24 16:55	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-Theo Roosevelt Sch. 43

Sample Description:

Work Order: 24C2896

Date Received: 3/26/2024

Field Sample #: 43-01-HA-BY-113-T (5)

Sampled: 3/13/2024 06:07

Sample ID: 24C2896-03

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	7.5	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	3/27/24	3/27/24 16:57	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-Theo Roosevelt Sch. 43

Sample Description:

Work Order: 24C2896

Date Received: 3/26/2024

Field Sample #: 43-01-HA-BY-122A-F (6)

Sampled: 3/13/2024 06:28

Sample ID: 24C2896-04

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	3/27/24	3/27/24 16:59	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-Theo Roosevelt Sch. 43

Sample Description:

Work Order: 24C2896

Date Received: 3/26/2024

Field Sample #: 43-01-NO-IN-102-T (9)

Sampled: 3/13/2024 06:23

Sample ID: 24C2896-05

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	1.7	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	3/27/24	3/27/24 17:05	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-Theo Roosevelt Sch. 43

Sample Description:

Work Order: 24C2896

Date Received: 3/26/2024

Field Sample #: 43-02-HA-BY-215A-F (13)

Sampled: 3/13/2024 07:03

Sample ID: 24C2896-06

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	4.2	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	3/27/24	3/27/24 17:06	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-Theo Roosevelt Sch. 43

Sample Description:

Work Order: 24C2896

Date Received: 3/26/2024

Sampled: 3/13/2024 07:05

Field Sample #: 43-02-HA-BY-215A-T (14)

Sample ID: 24C2896-07

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	6.4	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	3/27/24	3/27/24 17:08	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-Theo Roosevelt Sch. 43

Sample Description:

Work Order: 24C2896

Date Received: 3/26/2024

Field Sample #: 43-02-HA-BY-222A-T (16)

Sampled: 3/13/2024 06:54

Sample ID: 24C2896-08

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	3/27/24	3/27/24 17:10	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-Theo Roosevelt Sch. 43

Sample Description:

Work Order: 24C2896

Date Received: 3/26/2024

Field Sample #: 43-B-KIT-IN-3A-T1 (18)

Sampled: 3/14/2024 06:37

Sample ID: 24C2896-09

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	1.3	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	3/27/24	3/27/24 17:12	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-Theo Roosevelt Sch. 43

Sample Description:

Work Order: 24C2896

Date Received: 3/26/2024

Field Sample #: 43-B-KIT-IN-3A-T2 (19)

Sampled: 3/14/2024 06:38

Sample ID: 24C2896-10

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	1.2	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	3/27/24	3/27/24 17:14	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-Theo Roosevelt Sch. 43

Sample Description:

Work Order: 24C2896

Date Received: 3/26/2024

Field Sample #: 43-B-KIT-IN-3A-T3 (20)

Sampled: 3/14/2024 06:39

Sample ID: 24C2896-11

Sample Matrix: Drinking Water

Metals Analyses (Total)											
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time	
		RL							Prepared	Analyzed	Analyst
Lead	1.7	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	3/27/24	3/27/24 17:16	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-Theo Roosevelt Sch. 43

Sample Description:

Work Order: 24C2896

Date Received: 3/26/2024

Field Sample #: 43-01-HA-BY-109A-BF (21)

Sampled: 3/13/2024 06:11

Sample ID: 24C2896-12

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	3.7	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	3/27/24	3/27/24 17:20	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-Theo Roosevelt Sch. 43

Sample Description:

Work Order: 24C2896

Date Received: 3/26/2024

Field Sample #: 43-01-HA-BY-109A-T (22)

Sampled: 3/13/2024 06:12

Sample ID: 24C2896-13

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	3.2	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	3/27/24	3/27/24 17:22	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-Theo Roosevelt Sch. 43

Sample Description:

Work Order: 24C2896

Date Received: 3/26/2024

Field Sample #: 43-01-HA-BY-122A-BF (26)

Sampled: 3/13/2024 06:29

Sample ID: 24C2896-14

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	3/27/24	3/27/24 17:28	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-Theo Roosevelt Sch. 43

Sample Description:

Work Order: 24C2896

Date Received: 3/26/2024

Field Sample #: 43-01-HA-BY-122A-F (27)

Sampled: 3/13/2024 06:29

Sample ID: 24C2896-15

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	3/27/24	3/27/24 17:30	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-Theo Roosevelt Sch. 43

Sample Description:

Work Order: 24C2896

Date Received: 3/26/2024

Field Sample #: 43-02-HA-BY-215A-F (41)

Sampled: 3/13/2024 07:05

Sample ID: 24C2896-16

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	4.1	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	3/27/24	3/27/24 17:32	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-Theo Roosevelt Sch. 43

Sample Description:

Work Order: 24C2896

Date Received: 3/26/2024

Field Sample #: 43-02-HA-BY-222A-BF (42)

Sampled: 3/13/2024 06:57

Sample ID: 24C2896-17

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	3/27/24	3/27/24 17:34	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-Theo Roosevelt Sch. 43

Sample Description:

Work Order: 24C2896

Date Received: 3/26/2024

Field Sample #: 43-02-HA-BY-222A-F (43)

Sampled: 3/13/2024 06:57

Sample ID: 24C2896-18

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	3/27/24	3/27/24 17:36	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-Theo Roosevelt Sch. 43

Sample Description:

Work Order: 24C2896

Date Received: 3/26/2024

Sampled: 3/13/2024 06:25

Field Sample #: 43-B-HA-BY-7A-BF (50)

Sample ID: 24C2896-19

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	3/27/24	3/27/24 17:37	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-Theo Roosevelt Sch. 43

Sample Description:

Work Order: 24C2896

Date Received: 3/26/2024

Sampled: 3/13/2024 06:27

Field Sample #: 43-B-HA-BY-7A-F (51)

Sample ID: 24C2896-20

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	3/27/24	3/27/24 17:39	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-Theo Roosevelt Sch. 43

Sample Description:

Work Order: 24C2896

Date Received: 3/26/2024

Field Sample #: 43-B-CR-IN-10-T1 (52)

Sampled: 3/14/2024 06:23

Sample ID: 24C2896-21

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	17	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	3/27/24	3/27/24 17:41	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-Theo Roosevelt Sch. 43

Sample Description:

Work Order: 24C2896

Date Received: 3/26/2024

Field Sample #: 43-B-CR-IN-10-T2 (53)

Sampled: 3/14/2024 06:23

Sample ID: 24C2896-22

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	5.6	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	3/27/24	3/27/24 17:43	JC

FLAG/QUALIFIER SUMMARY

*	QC result is outside of established limits.
†	Wide recovery limits established for difficult compound.
‡	Wide RPD limits established for difficult compound.
#	Data exceeded client recommended or regulatory level
ND	Not Detected
RL	Reporting Limit is at the level of quantitation (LOQ)
DL	Detection Limit is the lower limit of detection determined by the MDL study
MCL	Maximum Contaminant Level
	Percent recoveries and relative percent differences (RPDs) are determined by the software using values in the calculation which have not been rounded.
	No results have been blank subtracted unless specified in the case narrative section.
Z-01	#

CERTIFICATIONS

Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 200.8 Rev 5.4 in Drinking Water</i>	
Lead	NB-CT,NB-NJ,NB-NY

Pace Analytical Services, LCC operates under the following certifications and accreditations:

Code	Description	Number	Expires
NB-CT	Connecticut Department of Public Health	PH-0823	09/30/2024
NB-NJ	New Jersey DEP	NY015 NELAP	06/30/2023
NB-NY	New York State Department of Health	10142 NELAP	04/1/2024



2011 East Main Street, Rochester, NY 14609 Phone (585) 654-9080 Fax (585) 654-9662
Web: LozierEnv.com E-Mail: Support@Lozierenv.com

Page 1 of 3
24C2896

REPORT TO:		INVOICE TO:	
Company:	Lozier Environmental Consulting, Inc.	Company:	SAME
Address:	2011 East Main Street	Address:	
City/State Zip:	Rochester, New York 14609	City/State Zip:	
Phone:		Phone:	
Fax:		Fax:	
E-Mail:	vkaptain@lozierenv.com	Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	LEAD	REQUESTED ANALYSIS			
1	43-01-CR-IN-113-T	3/13/2024	605		DW				X				
2	43-01-HA-BY-109A-F	3/13/2024	609		DW				X				
5	43-01-HA-BY-113-T	3/13/2024	607		DW				X				
6	43-01-HA-BY-122A-F	3/13/2024	628		DW				X				
9	43-01-NO-IN-102-T	3/13/2024	623		DW				X				
13	43-02-HA-BY-215A-F	3/13/2024	703		DW				X				
14	43-02-HA-BY-215A-T	3/13/2024	705		DW				X				
16	43-02-HA-BY-222A-T	3/13/2024	654		DW				X				
18	43-B-KIT-IN-3A-T1	3/14/2024	637		DW				X				
19	43-B-KIT-IN-3A-T2	3/14/2024	638		DW				X				



Container Type (Circle One): Plastic Glass Sterile Other _____
Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

SAMPLED BY*: J. Savoie

REINQUISHED BY*: V. Kaptein DATE: 3/14/24 TIME: 10:00

RECEIVED BY*: Anna Loser DATE: 3/20 TIME: 11:05

REINQUISHED BY*: DATE: TIME:

RECEIVED BY*: DATE: TIME:

REINQUISHED BY*: DATE: TIME:

RECEIVED BY*: DATE: TIME:

FOR LAB USE ONLY	
PRESERVATIVE: HNO3	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINERS: 22	COLIFORM BACTERIA:
SAMPLE ON ICE? YES (NO)	Present Absent
TEMPERATURE: 14.6 C	If Present, Date Client is contacted with result:
SAMPLE IN COMPLIANCE: YES NO	Date: _____
BOTTLE SUPPLIED BY LAB: YES NO N/A	Contacted By: _____

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

ORIGINAL - LAB COPY YELLOW - CUSTOMER COPY PINK - SAMPLER COPY

CONFIDENTIAL INFORMATION



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: Support@Lozierenv.com

Page 2 of 3
24C2896

Page 29 of 31

LAB ID: M33905		REPORT TO:		INVOICE TO:	
PROJECT NAME: RCSD - Theo Roosevelt School 43		Company: Lozier Environmental Consulting, Inc.		Company: SAME	
TURNAROUND TIME: Standard Rush		Address: 2011 East Main Street		Address: SAME	
Other:		City/State Zip: Rochester, New York 14609		City/State Zip: SAME	
		Phone:		Phone: SAME	
		Fax:		Fax: SAME	
		E-Mail: vkaptein@lozierenv.com		Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS			
									LEAD			
20	43-B-KIT-IN-3A-T3	3/14/2024	639		DW				X			
21	43-01-HA-BY-109A-BF	3/13/2024	611		DW				X			
22	43-01-HA-BY-109A-T	3/13/2024	612		DW				X			
26	43-01-HA-BY-122A-BF	3/13/2024	629		DW				X			
27	43-01-HA-BY-122A-F	3/13/2024	629		DW				X			
41	43-02-HA-BY-215A-F	3/13/2024	705		DW				X			
42	43-02-HA-BY-222A-BF	3/13/2024	657		DW				X			
43	43-02-HA-BY-222A-F	3/13/2024	657		DW				X			
50	43-B-HA-BY-7A-BF	3/13/2024	625		DW				X			
51	43-B-HA-BY-7A-F	3/13/2024	627		DW				X			

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

SAMPLED BY*: J. Savoie

RELINQUISHED BY*: V. Kaptein

RECEIVED BY*: *Samu Lopez*

RELINQUISHED BY*:

RECEIVED BY:

RELINQUISHED BY*:

RECEIVED BY:

ORIGINAL - LAB COPY YELLOW - CUSTOMER COPY PINK - SAMPLER COPY

FOR LAB USE ONLY

PRESERVATIVE: HNO3

TOTAL NUMBER OF CONTAINERS: 22

SAMPLE ON ICE? YES NO

TEMPERATURE: 146 C

SAMPLE IN COMPLIANCE: YES NO

BOTTLE SUPPLIED BY LAB: YES NO N/A

FOR POTABLE WATER ONLY:

COLIFORM BACTERIA:

Present Absent

If Present, Date Client is

contacted with result:

Date:

Contacted By:

CONFIDENTIAL INFORMATION

Sample Condition Upon Receipt Form (SCUR)

Project # 24C2896
Client: Lozier

Date and Initials of person:
Examining contents: _____
Label: _____
Deliver to location: _____
pH: _____

Thermometer Used: IRG4

Date: 3/26

Time: 1105

Initials: _____

State of Origin: NY

Cooler #1 Temp. °C 14.6 (Visual) 0.2 @ 0.0°C -0.5 @ 20.0°C (Correction Factor) _____ (Actual) ☒ Samples on ice, cooling process has begun

Courier: ☒ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☐ Pace ☐ Other _____

Shipping Method: ☐ First Overnight ☐ Priority Overnight ☐ Standard Overnight ☒ Ground

☐ Other _____

Tracking # 7755 4332 0688

Custody Seal on Cooler/Box Present: ☐ Yes ☐ No

Seals intact: ☐ Yes ☐ No

Ice: ☒ Wet ☐ Blue ☐ Melted ☐ None

Packing Material: ☐ Bubble Wrap ☐ Bubble Bags ☐ None ☐ Other _____

Samples were collected by Pace employee ☐ Yes ☐ No ☐ N/A

Comments:

Chain of Custody Present	☒ Yes ☐ No ☐ N/A	
Chain of Custody Filled Out	☒ Yes ☐ No ☐ N/A	
Relinquished Signature on COC	☒ Yes ☐ No ☐ N/A	
Sampler Name and Signature on COC	☒ Yes ☐ No ☐ N/A	
Samples Arrived within Hold Time	☒ Yes ☐ No ☐ N/A	
Rush TAT requested on COC	☐ Yes ☐ No ☐ N/A	
Sufficient Volume	☒ Yes ☐ No ☐ N/A	
Correct Containers Used	☒ Yes ☐ No ☐ N/A	
Containers Intact	☒ Yes ☐ No ☐ N/A	
Sample Labels match COC (sample IDs & date/time of collection)	☒ Yes ☐ No ☐ N/A	
All containers needing acid/base preservation have been checked.	☐ Yes ☐ No ☐ N/A	Preservation Information:
All Containers needing preservation are found to be in compliance with EPA recommendation:	☐ Yes ☐ No ☐ N/A	Preservative: _____
Exceptions: Vials, Microbiology, O&G, Metals		Lot #/Trace #: _____
		Date: _____ Time: _____
		Initials: _____
Headspace in VOA Vials? (>6mm):	☐ Yes ☐ No ☐ N/A	
Trip Blank Present:	☐ Yes ☐ No ☐ N/A	

Additional Login Comments:

Client notification/ Resolution

Person Contacted: _____ Date/Time: _____
Comments/Resolution: _____