


October 12, 2023

V Kaptein
NB-Lozier Environmental Consulting, Inc
2011 E Main Street
Rochester, NY 14609

Project Location: School No. 46- Charles Carroll
Project Number: School No. 46 - Charles Carroll
Laboratory Work Order Number: 23J0268

Enclosed are results of analyses for samples received by the laboratory on October 3, 2023. If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Project Manager

NB-Lozier Environmental Consulting, Inc
2011 E Main Street
Rochester, NY 14609
ATTN: V Kaptein

REPORT DATE: 10/12/2023

ANALYTICAL SUMMARY

The results of analyses performed on the following samples submitted to Pace Analytical Services, LLC - Newburgh are found in this report.

FIELD SAMPLE #	LAB ID:	MATRIX	SAMPLE DESCRIPTION	TEST	SUB LAB
46-01-CR-IN-104-T	23J0268-01	Drinking Water		EPA 200.8 Rev 5.4	
46-01-CR-IN-118-B	23J0268-02	Drinking Water		EPA 200.8 Rev 5.4	
46-01-CR-IN-118-T	23J0268-03	Drinking Water		EPA 200.8 Rev 5.4	
46-01-CR-IN-119-B	23J0268-04	Drinking Water		EPA 200.8 Rev 5.4	
46-01-CR-IN-119-T	23J0268-05	Drinking Water		EPA 200.8 Rev 5.4	
46-01-HA-BY-103-F	23J0268-06	Drinking Water		EPA 200.8 Rev 5.4	
46-01-HA-BY-103-BF	23J0268-07	Drinking Water		EPA 200.8 Rev 5.4	
46-01-HA-BY-111-F	23J0268-08	Drinking Water		EPA 200.8 Rev 5.4	
46-01-HA-BY-111-BF	23J0268-09	Drinking Water		EPA 200.8 Rev 5.4	
46-01-HA-BY-120-F	23J0268-10	Drinking Water		EPA 200.8 Rev 5.4	
46-01-HA-BY-120-BF	23J0268-11	Drinking Water		EPA 200.8 Rev 5.4	
46-02-HA-BY-207-B	23J0268-12	Drinking Water		EPA 200.8 Rev 5.4	
46-02-HA-BY-207-BF	23J0268-13	Drinking Water		EPA 200.8 Rev 5.4	
46-02-HA-BY-213-B	23J0268-14	Drinking Water		EPA 200.8 Rev 5.4	
46-02-HA-BY-213-BF	23J0268-15	Drinking Water		EPA 200.8 Rev 5.4	
46-02-TC-IN-214-T	23J0268-16	Drinking Water		EPA 200.8 Rev 5.4	
46-B-CF-IN-3-T	23J0268-17	Drinking Water		EPA 200.8 Rev 5.4	
46-B-KI-IN-3A-T	23J0268-18	Drinking Water		EPA 200.8 Rev 5.4	

CASE NARRATIVE SUMMARY

All reported results are within defined laboratory quality control objectives unless listed below or otherwise qualified in this report.

EPA 200.8 Rev 5.4

Qualifications:

Z-01

#


Analyte & Samples(s) Qualified:

Lead

23J0268-04[46-01-CR-IN-119-B], 23J0268-05[46-01-CR-IN-119-T]

The results of analyses reported only relate to samples submitted to the Pace Analytical Services, LLC - Newburgh for testing.

I certify that the analyses listed above, unless specifically listed as subcontracted, if any, were performed under my direction according to the approved methodologies listed in this document, and that based upon my inquiry of those individuals immediately responsible for obtaining the information, the material contained in this report is, to the best of my knowledge and belief, accurate and complete.



Renee Cusack
PM

Project Location: School No. 46- Charles Carroll

Sample Description:

Work Order: 23J0268

Date Received: 10/3/2023

Field Sample #: 46-01-CR-IN-104-T

Sampled: 9/28/2023 06:23

Sample ID: 23J0268-01

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	12	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/9/23	10/10/23 22:35	EMC

Project Location: School No. 46- Charles Carroll

Sample Description:

Work Order: 23J0268

Date Received: 10/3/2023

Field Sample #: 46-01-CR-IN-118-B

Sampled: 9/28/2023 06:11

Sample ID: 23J0268-02

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	4.2	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/9/23	10/10/23 22:37	EMC

Project Location: School No. 46- Charles Carroll

Sample Description:

Work Order: 23J0268

Date Received: 10/3/2023

Field Sample #: 46-01-CR-IN-118-T

Sampled: 9/28/2023 06:11

Sample ID: 23J0268-03

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	11	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/9/23	10/10/23 22:44	EMC

Project Location: School No. 46- Charles Carroll

Sample Description:

Work Order: 23J0268

Date Received: 10/3/2023

Field Sample #: 46-01-CR-IN-119-B

Sampled: 9/28/2023 06:13

Sample ID: 23J0268-04

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
# Lead	21	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	10/9/23	10/10/23 22:47	EMC

Project Location: School No. 46- Charles Carroll

Sample Description:

Work Order: 23J0268

Date Received: 10/3/2023

Field Sample #: 46-01-CR-IN-119-T

Sampled: 9/28/2023 06:13

Sample ID: 23J0268-05

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
# Lead	17	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	10/9/23	10/10/23 22:52	EMC

Project Location: School No. 46- Charles Carroll

Sample Description:

Work Order: 23J0268

Date Received: 10/3/2023

Field Sample #: 46-01-HA-BY-103-F

Sampled: 9/28/2023 06:19

Sample ID: 23J0268-06

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/9/23	10/10/23 22:54	EMC

Project Location: School No. 46- Charles Carroll

Sample Description:

Work Order: 23J0268

Date Received: 10/3/2023

Field Sample #: 46-01-HA-BY-103-BF

Sampled: 9/28/2023 06:19

Sample ID: 23J0268-07

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/9/23	10/10/23 22:56	EMC

Project Location: School No. 46- Charles Carroll

Sample Description:

Work Order: 23J0268

Date Received: 10/3/2023

Field Sample #: 46-01-HA-BY-111-F

Sampled: 9/28/2023 06:14

Sample ID: 23J0268-08

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/9/23	10/10/23 22:59	EMC

Project Location: School No. 46- Charles Carroll

Sample Description:

Work Order: 23J0268

Date Received: 10/3/2023

Field Sample #: 46-01-HA-BY-111-BF

Sampled: 9/28/2023 06:14

Sample ID: 23J0268-09

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/9/23	10/10/23 23:01	EMC

Project Location: School No. 46- Charles Carroll

Sample Description:

Work Order: 23J0268

Date Received: 10/3/2023

Field Sample #: 46-01-HA-BY-120-F

Sampled: 9/28/2023 06:07

Sample ID: 23J0268-10

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/9/23	10/10/23 23:04	EMC

Project Location: School No. 46- Charles Carroll

Sample Description:

Work Order: 23J0268

Date Received: 10/3/2023

Field Sample #: 46-01-HA-BY-120-BF

Sampled: 9/28/2023 06:07

Sample ID: 23J0268-11

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/9/23	10/10/23 23:06	EMC

Project Location: School No. 46- Charles Carroll

Sample Description:

Work Order: 23J0268

Date Received: 10/3/2023

Field Sample #: 46-02-HA-BY-207-B

Sampled: 9/28/2023 06:37

Sample ID: 23J0268-12

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/9/23	10/10/23 23:13	EMC

Project Location: School No. 46- Charles Carroll

Sample Description:

Work Order: 23J0268

Date Received: 10/3/2023

Field Sample #: 46-02-HA-BY-207-BF

Sampled: 9/28/2023 06:38

Sample ID: 23J0268-13

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/9/23	10/11/23 16:58	EMC

Project Location: School No. 46- Charles Carroll

Sample Description:

Work Order: 23J0268

Date Received: 10/3/2023

Field Sample #: 46-02-HA-BY-213-B

Sampled: 9/28/2023 06:36

Sample ID: 23J0268-14

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/10/23	10/11/23 13:48	EMC

Project Location: School No. 46- Charles Carroll

Sample Description:

Work Order: 23J0268

Date Received: 10/3/2023

Field Sample #: 46-02-HA-BY-213-BF

Sampled: 9/28/2023 06:36

Sample ID: 23J0268-15

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/10/23	10/11/23 13:58	EMC

Project Location: School No. 46- Charles Carroll

Sample Description:

Work Order: 23J0268

Date Received: 10/3/2023

Field Sample #: 46-02-TC-IN-214-T

Sampled: 9/28/2023 06:36

Sample ID: 23J0268-16

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	4.8	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/10/23	10/11/23 14:00	EMC

Project Location: School No. 46- Charles Carroll

Sample Description:

Work Order: 23J0268

Date Received: 10/3/2023

Field Sample #: 46-B-CF-IN-3-T

Sampled: 9/28/2023 06:28

Sample ID: 23J0268-17

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	4.2	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/10/23	10/11/23 14:03	EMC

Project Location: School No. 46- Charles Carroll

Sample Description:

Work Order: 23J0268

Date Received: 10/3/2023

Field Sample #: 46-B-KI-IN-3A-T

Sampled: 9/28/2023 06:28

Sample ID: 23J0268-18

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	3.1	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/10/23	10/11/23 14:05	EMC

Sample Extraction Data

Prep Method: NB EPA 200.8 Analytical Method: EPA 200.8 Rev 5.4

Lab Number [Field ID]	Batch	Initial [mL]	Final [mL]	Date
23J0268-01 [46-01-CR-IN-104-T]	B354484	50.0	50.0	10/09/23
23J0268-02 [46-01-CR-IN-118-B]	B354484	50.0	50.0	10/09/23
23J0268-03 [46-01-CR-IN-118-T]	B354484	50.0	50.0	10/09/23
23J0268-04 [46-01-CR-IN-119-B]	B354484	50.0	50.0	10/09/23
23J0268-05 [46-01-CR-IN-119-T]	B354484	50.0	50.0	10/09/23
23J0268-06 [46-01-HA-BY-103-F]	B354484	50.0	50.0	10/09/23
23J0268-07 [46-01-HA-BY-103-BF]	B354484	50.0	50.0	10/09/23
23J0268-08 [46-01-HA-BY-111-F]	B354484	50.0	50.0	10/09/23
23J0268-09 [46-01-HA-BY-111-BF]	B354484	50.0	50.0	10/09/23
23J0268-10 [46-01-HA-BY-120-F]	B354484	50.0	50.0	10/09/23
23J0268-11 [46-01-HA-BY-120-BF]	B354484	50.0	50.0	10/09/23
23J0268-12 [46-02-HA-BY-207-B]	B354484	50.0	50.0	10/09/23
23J0268-13 [46-02-HA-BY-207-BF]	B354484	50.0	50.0	10/09/23

Prep Method: NB EPA 200.8 Analytical Method: EPA 200.8 Rev 5.4

Lab Number [Field ID]	Batch	Initial [mL]	Final [mL]	Date
23J0268-14 [46-02-HA-BY-213-B]	B354583	50.0	50.0	10/10/23
23J0268-15 [46-02-HA-BY-213-BF]	B354583	50.0	50.0	10/10/23
23J0268-16 [46-02-TC-IN-214-T]	B354583	50.0	50.0	10/10/23
23J0268-17 [46-B-CF-IN-3-T]	B354583	50.0	50.0	10/10/23
23J0268-18 [46-B-KI-IN-3A-T]	B354583	50.0	50.0	10/10/23

QUALITY CONTROL

Metals Analyses (Total) - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
---------	--------	--------------------	-------	----------------	------------------	------	----------------	-----	--------------	-------

Batch B354484 - NB EPA 200.8

Matrix Spike (B354484-MS4)

Source: 23J0268-04

Prepared: 10/09/23 Analyzed: 10/10/23

Lead	73.1	1.0	µg/L	50.0	21.5	103	70-130			
------	------	-----	------	------	------	-----	--------	--	--	--

Batch B354583 - NB EPA 200.8

Duplicate (B354583-DUP1)

Source: 23J0268-14

Prepared: 10/10/23 Analyzed: 10/11/23

Lead	ND	1.0	µg/L		ND			NC	20	
------	----	-----	------	--	----	--	--	----	----	--

Matrix Spike (B354583-MS1)

Source: 23J0268-14

Prepared: 10/10/23 Analyzed: 10/11/23

Lead	47.9	1.0	µg/L	50.0	ND	95.8	70-130			
------	------	-----	------	------	----	------	--------	--	--	--

FLAG/QUALIFIER SUMMARY

*	QC result is outside of established limits.
†	Wide recovery limits established for difficult compound.
‡	Wide RPD limits established for difficult compound.
#	Data exceeded client recommended or regulatory level
ND	Not Detected
RL	Reporting Limit is at the level of quantitation (LOQ)
DL	Detection Limit is the lower limit of detection determined by the MDL study
MCL	Maximum Contaminant Level
	Percent recoveries and relative percent differences (RPDs) are determined by the software using values in the calculation which have not been rounded.
	No results have been blank subtracted unless specified in the case narrative section.
Z-01	#

CERTIFICATIONS

Certified Analyses included in this Report

Analyte	Certifications
---------	----------------

EPA 200.8 Rev 5.4 in Drinking Water

Lead	NB-CT,NB-NJ,NB-NY
------	-------------------

Pace Analytical Services, LCC operates under the following certifications and accreditations:

Code	Description	Number	Expires
NB-CT	Connecticut Department of Public Health	PH-0823	09/30/2024
NB-NJ	New Jersey DEP	NY015 NELAP	06/30/2023
NB-NY	New York State Department of Health	10142 NELAP	04/1/2024



2011 East Main Street, Rochester, NY 14609 Phone (585) 654-9080 Fax (585) 654-9662
LozierEnv@aol.com

Page 1 of 2
2350268

LAB ID: M33047	REPORT TO:	INVOICE TO:
PROJECT NAME: School No. 46 - Charles Carroll	Company: Lozier Environmental Consulting, Inc.	Company: SAME
TURNAROUND TIME: STANDARD, RUSH or OTHER	Address: 2011 East Main Street	Address:
	City, State Zip: Rochester, New York 14609	City, State Zip:
	Phone: Fax:	Phone: Fax:
	E-Mail: vkaptein@lozierenv.com	Purchase Order #:

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS
1	46-01-CR-IN-104-T	9/28/23	0623		PV			LEAD	X
2	46-01-CR-IN-118-B		0611						
3	46-01-CR-IN-118-T		0611						
4	46-01-CR-IN-119-B		0613						
5	46-01-CR-IN-119-T		0613						
6	46-01-HA-BY-103-F		0619						
7	46-01-HA-BY-103-BF		0619						
8	46-01-HA-BY-111-F		0614						
9	46-01-HA-BY-111-BF		0614						
10	46-01-HA-BY-120-F		0607						



Container Type (Circle One): Plastic Glass Sterile Other _____
Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

K. Sercu / J. Savoie

SAMPLED BY*: _____

RELINQUISHED BY*: V. Kaptein DATE: 9/28/23 TIME: 1312

RECEIVED BY: _____ DATE: 10/3/23 TIME: 1100

RELINQUISHED BY*: _____ DATE: _____ TIME: _____

RECEIVED BY: _____ DATE: _____ TIME: _____

FOR LAB USE ONLY	
PRESERVATIVE: Nitric Acid	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINERS: _____	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES NO	Present Absent
SAMPLE ON ICE? YES NO	If Present, Date Client is
TEMPERATURE: 21.0 C	contacted with result:
SAMPLE IN COMPLIANCE: YES NO	Date: _____
	Contacted By: _____

FBP 6x 6BP
M2C 7.33 0.117

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis



2011 East Main Street, Rochester, NY 14609 Phone (585) 654-9080 Fax (585) 654-9662
LozierEnv@aol.com

Page 2 of 2
23562688

LAB ID: M33047	REPORT TO:	INVOICE TO:
PROJECT NAME: School No. 46 - Charles Carroll	Company: Lozier Environmental Consulting, Inc.	Company: SAME
	Address: 2011 East Main Street	Address:
	City/State/Zip: Rochester, New York 14609	City/State/Zip:
TURNAROUND TIME: STANDARD,	Phone:	Phone:
RUSH or OTHER:	Fax:	Fax:
	E-Mail: vkaptein@lozierenv.com	Purchase Order #:

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE		REQUESTED ANALYSIS	
								COMMENTS			
12	46-01-HA-BY-120-BF	9/28/23	0607		PW				LEAD	X	
14	46-02-HA-BY-207-B		0637								
15	46-02-HA-BY-207-BF		0638								
16	46-02-HA-BY-213-B		0636								
17	46-02-HA-BY-213-BF		0636								
18	46-02-TC-IN-214-T		0636								
19	46-B-CF-IN-3-T		0628								
20	46-B-KI-IN-3A-T		0628								

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

K. Sercu / J. Savoie

SAMPLED BY:

RELINQUISHED BY: N. Kaptein DATE: 9/28/23 TIME: 1312
RECEIVED BY: [Signature] DATE: 10/3/23 TIME: 1100
RELINQUISHED BY: _____ DATE: _____ TIME: _____
RECEIVED BY: _____ DATE: _____ TIME: _____

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FOR LAB USE ONLY		FOR POTABLE WATER ONLY:	
PRESERVATIVE: Nitric Acid		COLIFORM BACTERIA:	Present Absent
TOTAL NUMBER OF CONTAINERS: _____		If Present, Date Client is contacted with result:	
CUSTODY SEAL INTACT? YES NO		Date: _____	
SAMPLE ON ICE? YES <u>NO</u>		Contacted By: _____	
TEMPERATURE: 21.1 C			
SAMPLE IN COMPLIANCE: YES NO			

CLIENT SAMPLE ID	RESULT	DATE ANALYZED	TIME COLLECTED
025-1 23-1	15.9	07/24/2021	11:29
025-10 23-10	4.79	07/24/2021	12:25
025-11 23-11	4.56	07/24/2021	12:30
025-12 23-12	27.4	07/24/2021	12:44
025-13 23-13	<1.00	07/24/2021	12:50
025-14 23-14	7.97	07/24/2021	12:57
025-15 23-15	<1.00	07/24/2021	01:06
025-16 23-16	5.84	07/24/2021	01:09
025-17 23-17	79.6	07/24/2021	01:12
025-18 23-18	7.95	07/24/2021	01:13
025-19 23-19	5.00	07/24/2021	01:22
025-2 23-2	3.85	07/24/2021	11:36
025-20 23-20	5.11	07/24/2021	01:25
025-21 23-21	<1.00	07/24/2021	01:28
025-22 23-22	9.82	07/24/2021	01:35
025-3 23-3	16.1	07/24/2021	11:40
025-4 23-4	245	07/24/2021	11:55
025-5 23-5	3.11	07/24/2021	12:00
025-6 23-6	<1.00	07/24/2021	12:08
025-7 23-7	9.89	07/24/2021	12:11
025-8 23-8	11.2	07/24/2021	12:24
025-9 23-9	11.9	07/24/2021	12:25

Please send the Excel spreadsheet (like
this example) with the report
Thank you!!!



Sample Condition Upon Receipt Form (SCUR)

Project # 2350268
Client: Lozier

Date and Initials of person:
Examining contents: EC
Label: EC
Deliver to location: EC
pH: EC

Thermometer Used: IRG4 Date: 10/3 Time: 1100 Initials: EC

State of Origin: NY

Cooler #1 Temp. °C 21.1 (Visual) 2 (Correction Factor) 21.3 (Actual) ☒ Samples on ice, cooling process has begun

Courier: ☒ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☐ Pace ☐ Other

Shipping Method: ☐ First Overnight ☐ Priority Overnight ☐ Standard Overnight ☐ Ground
☐ Other

Tracking # 7735 76328118

Custody Seal on Cooler/Box Present: ☐ Yes ☐ No Seals intact: ☐ Yes ☐ No Ice: ☒ Wet ☐ Blue ☐ Melted ☐ None

Packing Material: ☐ Bubble Wrap ☐ Bubble Bags ☐ None ☐ Other

Samples were collected by Pace employee ☐ Yes ☐ No ☐ N/A

Comments:

Chain of Custody Present	☒ Yes ☐ No ☐ N/A	
Chain of Custody Filled Out	☒ Yes ☐ No ☐ N/A	
Relinquished Signature on COC	☒ Yes ☐ No ☐ N/A	
Sampler Name and Signature on COC	☒ Yes ☐ No ☐ N/A	
Samples Arrived within Hold Time	☒ Yes ☐ No ☐ N/A	
Rush TAT requested on COC	☐ Yes ☐ No ☐ N/A	
Sufficient Volume	☐ Yes ☐ No ☐ N/A	
Correct Containers Used	☒ Yes ☐ No ☐ N/A	
Containers Intact	☒ Yes ☐ No ☐ N/A	
Sample Labels match COC (sample IDs & date/time of collection)	☒ Yes ☐ No ☐ N/A	
All containers needing acid/base preservation have been checked.	☐ Yes ☐ No ☐ N/A	Preservation Information: Preservative: _____
All Containers needing preservation are found to be in compliance with EPA recommendation:	☐ Yes ☐ No ☐ N/A	Lot #/Trace #: _____ Date: _____ Time: _____ Initials: _____
Exceptions: Vials, Microbiology, O&G, Metals		
Headspace in VOA Vials? (>6mm):	☐ Yes ☐ No ☐ N/A	
Trip Blank Present:	☐ Yes ☐ No ☐ N/A	

Additional Login Comments:

Client notification/ Resolution

Person Contacted: _____ Date/Time: _____
Comments/Resolution: _____