



January 29, 2025

Amy Kaptein
Lozier Environmental Consulting, Inc
2011 E. Main St.
Rochester, NY 14609

RE: Project: RCSD - School No.22
Pace Project No.: 70333473

Dear Amy Kaptein:

Enclosed are the analytical results for sample(s) received by the laboratory on January 17, 2025. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Newburgh

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in cursive script that reads "Renee Cusack".

Renee Cusack
renee.cusack@pacelabs.com
(845)562-0890
Project Manager

Enclosures

cc: Amy Pusateri, Lozier Environmental Consulting Inc.



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



CERTIFICATIONS

Project: RCSD - School No.22

Pace Project No.: 70333473

Pace Analytical Services, LLC- Newburgh, NY

315 Fullerton Avenue, Newburgh, NY 12550

New York Certification #: 10142 Primary Accrediting Body

New Jersey Certification #: NY015

Connecticut Certification #: PH-0823

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE SUMMARY

Project: RCSD - School No.22

Pace Project No.: 70333473

Lab ID	Sample ID	Matrix	Date Collected	Date Received
70333473001	06-01-HA-BY-121-FL	Drinking Water	01/15/25 06:11	01/17/25 12:00
70333473002	06-01-HA-BY-121-FR	Drinking Water	01/15/25 06:11	01/17/25 12:00
70333473003	06-01-HA-BY-121-BF	Drinking Water	01/15/25 06:12	01/17/25 12:00
70333473004	06-01-CR-IN-128-B	Drinking Water	01/15/25 06:16	01/17/25 12:00
70333473005	06-01-CR-IN-128-T	Drinking Water	01/15/25 06:17	01/17/25 12:00
70333473006	06-01-CR-IN-130-B	Drinking Water	01/15/25 06:20	01/17/25 12:00
70333473007	06-01-CR-IN-130-T	Drinking Water	01/15/25 06:21	01/17/25 12:00
70333473008	06-01-CR-IN-131-B	Drinking Water	01/15/25 06:22	01/17/25 12:00
70333473009	06-01-CR-IN-131-T	Drinking Water	01/15/25 06:22	01/17/25 12:00
70333473010	06-01-CR-IN-132-B	Drinking Water	01/15/25 06:24	01/17/25 12:00
70333473011	06-01-CR-IN-132-T	Drinking Water	01/15/25 06:24	01/17/25 12:00
70333473012	06-01-CR-IN-133-B	Drinking Water	01/15/25 06:27	01/17/25 12:00
70333473013	06-01-CR-IN-133-T	Drinking Water	01/15/25 06:27	01/17/25 12:00
70333473014	06-01-CR-IN-134-B	Drinking Water	01/15/25 06:28	01/17/25 12:00
70333473015	06-01-CR-IN-134-T	Drinking Water	01/15/25 06:28	01/17/25 12:00
70333473016	06-01-CR-IN-135-B	Drinking Water	01/15/25 06:30	01/17/25 12:00
70333473017	06-01-CR-IN-135-T	Drinking Water	01/15/25 06:30	01/17/25 12:00
70333473018	06-01-CR-IN-138-B	Drinking Water	01/15/25 06:33	01/17/25 12:00
70333473019	06-01-CR-IN-138-T	Drinking Water	01/15/25 06:33	01/17/25 12:00
70333473020	06-01-CR-IN-139-B	Drinking Water	01/15/25 06:35	01/17/25 12:00
70333473021	06-01-CR-IN-139-T	Drinking Water	01/15/25 06:35	01/17/25 12:00
70333473022	06-01-CR-IN-140-B	Drinking Water	01/15/25 06:37	01/17/25 12:00
70333473023	06-01-CR-IN-140-T	Drinking Water	01/15/25 06:37	01/17/25 12:00
70333473024	06-01-CR-IN-141-B	Drinking Water	01/15/25 06:40	01/17/25 12:00
70333473025	06-01-CR-IN-141-T	Drinking Water	01/15/25 06:40	01/17/25 12:00
70333473026	06-01-CR-IN-142-B	Drinking Water	01/15/25 06:44	01/17/25 12:00
70333473027	06-01-CR-IN-142-T	Drinking Water	01/15/25 06:44	01/17/25 12:00
70333473028	06-01-CR-IN-143-B	Drinking Water	01/15/25 06:49	01/17/25 12:00
70333473029	06-01-CR-IN-143-T	Drinking Water	01/15/25 06:50	01/17/25 12:00
70333473030	06-01-CR-IN-137-B	Drinking Water	01/15/25 06:51	01/17/25 12:00
70333473031	06-01-CR-IN-137-T	Drinking Water	01/15/25 06:52	01/17/25 12:00
70333473032	06-01-HA-BY-82E-FL	Drinking Water	01/15/25 06:55	01/17/25 12:00
70333473033	06-01-HA-BY-82E-FR	Drinking Water	01/15/25 06:56	01/17/25 12:00
70333473034	06-01-HA-BY-82E-BF	Drinking Water	01/15/25 06:56	01/17/25 12:00
70333473035	06-01-KI-IN-82-T1	Drinking Water	01/15/25 06:59	01/17/25 12:00
70333473036	06-01-KI-IN-82-T2	Drinking Water	01/15/25 06:59	01/17/25 12:00
70333473037	06-01-KI-IN-82-T3	Drinking Water	01/15/25 07:00	01/17/25 12:00

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE SUMMARY

Project: RCSD - School No.22

Pace Project No.: 70333473

Lab ID	Sample ID	Matrix	Date Collected	Date Received
70333473038	06-01-KI-IN-82-T4	Drinking Water	01/15/25 07:02	01/17/25 12:00
70333473039	06-01-KI-IN-82F-T5	Drinking Water	01/15/25 07:04	01/17/25 12:00
70333473040	06-01-KI-IN-82F-T6	Drinking Water	01/15/25 07:04	01/17/25 12:00
70333473041	06-01-KI-IN-82F-T7	Drinking Water	01/15/25 07:05	01/17/25 12:00
70333473042	06-01-KI-IN-82F-T8	Drinking Water	01/15/25 07:05	01/17/25 12:00
70333473043	06-01-OF-IN-83-T	Drinking Water	01/15/25 07:07	01/17/25 12:00
70333473044	06-01-CR-IN-86-B	Drinking Water	01/15/25 07:10	01/17/25 12:00
70333473045	06-01-CR-IN-86-T	Drinking Water	01/15/25 07:10	01/17/25 12:00
70333473046	06-01-CR-IN-102-B	Drinking Water	01/15/25 07:13	01/17/25 12:00
70333473047	06-01-CR-IN-102-T	Drinking Water	01/15/25 07:13	01/17/25 12:00
70333473048	06-01-CR-IN-101-B	Drinking Water	01/15/25 07:14	01/17/25 12:00
70333473049	06-01-CR-IN-101-T	Drinking Water	01/15/25 07:22	01/17/25 12:00
70333473050	06-01-CR-IN-104-B	Drinking Water	01/15/25 07:26	01/17/25 12:00
70333473051	06-01-CR-IN-104-T	Drinking Water	01/15/25 07:27	01/17/25 12:00
70333473052	06-01-CR-IN-103-B	Drinking Water	01/15/25 07:29	01/17/25 12:00
70333473053	06-01-CR-IN-103-T	Drinking Water	01/15/25 07:29	01/17/25 12:00
70333473054	06-01-CR-IN-106-B	Drinking Water	01/15/25 07:31	01/17/25 12:00
70333473055	06-01-CR-IN-106-T	Drinking Water	01/15/25 07:31	01/17/25 12:00
70333473056	06-01-CR-IN-105-B	Drinking Water	01/15/25 07:32	01/17/25 12:00
70333473057	06-01-CR-IN-105-T	Drinking Water	01/15/25 07:33	01/17/25 12:00
70333473058	06-01-CR-IN-144-B	Drinking Water	01/15/25 07:36	01/17/25 12:00
70333473059	06-01-CR-IN-144-T	Drinking Water	01/15/25 07:36	01/17/25 12:00
70333473060	06-01-CR-IN-145-B	Drinking Water	01/15/25 07:42	01/17/25 12:00
70333473061	06-01-CR-IN-145-T	Drinking Water	01/15/25 07:42	01/17/25 12:00
70333473062	06-01-CR-IN-147-B	Drinking Water	01/15/25 07:46	01/17/25 12:00
70333473063	06-01-CR-IN-147-T	Drinking Water	01/15/25 07:46	01/17/25 12:00
70333473064	06-01-CR-IN-148-B	Drinking Water	01/15/25 07:48	01/17/25 12:00
70333473065	06-01-CR-IN-148-T	Drinking Water	01/15/25 07:48	01/17/25 12:00
70333473066	06-01-CR-IN-146-B	Drinking Water	01/15/25 07:50	01/17/25 12:00
70333473067	06-01-CR-IN-146-T	Drinking Water	01/15/25 07:50	01/17/25 12:00
70333473068	06-01-CR-IN-122-B	Drinking Water	01/15/25 07:53	01/17/25 12:00
70333473069	06-01-CR-IN-122-T	Drinking Water	01/15/25 07:53	01/17/25 12:00
70333473070	06-02-HA-BY-216-FL	Drinking Water	01/15/25 08:00	01/17/25 12:00
70333473071	06-02-HA-BY-216-FR	Drinking Water	01/15/25 08:00	01/17/25 12:00
70333473072	06-02-HA-BY-216-BF	Drinking Water	01/15/25 08:00	01/17/25 12:00
70333473073	06-02-TC-IN-216-B	Drinking Water	01/15/25 08:01	01/17/25 12:00
70333473074	06-02-TC-IN-216-T	Drinking Water	01/15/25 08:01	01/17/25 12:00

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE SUMMARY

Project: RCSD - School No.22

Pace Project No.: 70333473

Lab ID	Sample ID	Matrix	Date Collected	Date Received
70333473075	06-02-TC-IN-214-B	Drinking Water	01/15/25 08:05	01/17/25 12:00
70333473076	06-02-TC-IN-214-T	Drinking Water	01/15/25 08:05	01/17/25 12:00
70333473077	06-02-TC-IN-213-B	Drinking Water	01/15/25 08:07	01/17/25 12:00
70333473078	06-02-TC-IN-213-T	Drinking Water	01/15/25 08:07	01/17/25 12:00
70333473079	06-02-TC-IN-212-B	Drinking Water	01/15/25 08:09	01/17/25 12:00
70333473080	06-02-TC-IN-212-T	Drinking Water	01/15/25 08:09	01/17/25 12:00
70333473081	06-02-TC-IN-210-B	Drinking Water	01/15/25 08:11	01/17/25 12:00
70333473082	06-02-TC-IN-210-T	Drinking Water	01/15/25 08:11	01/17/25 12:00
70333473083	06-02-TC-IN-206-B	Drinking Water	01/15/25 08:14	01/17/25 12:00
70333473084	06-02-TC-IN-206-T	Drinking Water	01/15/25 08:14	01/17/25 12:00
70333473085	06-02-TC-IN-204-B	Drinking Water	01/15/25 08:18	01/17/25 12:00
70333473086	06-02-TC-IN-204-T	Drinking Water	01/15/25 08:18	01/17/25 12:00
70333473087	06-02-TC-IN-203-B	Drinking Water	01/15/25 08:20	01/17/25 12:00
70333473088	06-02-TC-IN-203-T	Drinking Water	01/15/25 08:20	01/17/25 12:00
70333473089	06-02-TC-IN-201-B	Drinking Water	01/15/25 08:23	01/17/25 12:00
70333473090	06-02-TC-IN-201-T	Drinking Water	01/15/25 08:23	01/17/25 12:00
70333473091	06-01-NO-IN-107-T	Drinking Water	01/15/25 08:27	01/17/25 12:00
70333473092	06-01-OF-IN-112E-T	Drinking Water	01/15/25 08:29	01/17/25 12:00

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE ANALYTE COUNT

Project: RCSD - School No.22

Pace Project No.: 70333473

Lab ID	Sample ID	Method	Analysts	Analytes Reported
70333473001	06-01-HA-BY-121-FL	EPA 200.8, Rev. 5.4	JC1	1
70333473002	06-01-HA-BY-121-FR	EPA 200.8, Rev. 5.4	JC1	1
70333473003	06-01-HA-BY-121-BF	EPA 200.8, Rev. 5.4	JC1	1
70333473004	06-01-CR-IN-128-B	EPA 200.8, Rev. 5.4	JC1	1
70333473005	06-01-CR-IN-128-T	EPA 200.8, Rev. 5.4	JC1	1
70333473006	06-01-CR-IN-130-B	EPA 200.8, Rev. 5.4	JC1	1
70333473007	06-01-CR-IN-130-T	EPA 200.8, Rev. 5.4	JC1	1
70333473008	06-01-CR-IN-131-B	EPA 200.8, Rev. 5.4	JC1	1
70333473009	06-01-CR-IN-131-T	EPA 200.8, Rev. 5.4	JC1	1
70333473010	06-01-CR-IN-132-B	EPA 200.8, Rev. 5.4	JC1	1
70333473011	06-01-CR-IN-132-T	EPA 200.8, Rev. 5.4	JC1	1
70333473012	06-01-CR-IN-133-B	EPA 200.8, Rev. 5.4	JC1	1
70333473013	06-01-CR-IN-133-T	EPA 200.8, Rev. 5.4	JC1	1
70333473014	06-01-CR-IN-134-B	EPA 200.8, Rev. 5.4	JC1	1
70333473015	06-01-CR-IN-134-T	EPA 200.8, Rev. 5.4	JC1	1
70333473016	06-01-CR-IN-135-B	EPA 200.8, Rev. 5.4	JC1	1
70333473017	06-01-CR-IN-135-T	EPA 200.8, Rev. 5.4	JC1	1
70333473018	06-01-CR-IN-138-B	EPA 200.8, Rev. 5.4	JC1	1
70333473019	06-01-CR-IN-138-T	EPA 200.8, Rev. 5.4	JC1	1
70333473020	06-01-CR-IN-139-B	EPA 200.8, Rev. 5.4	JC1	1
70333473021	06-01-CR-IN-139-T	EPA 200.8, Rev. 5.4	JC1	1
70333473022	06-01-CR-IN-140-B	EPA 200.8, Rev. 5.4	JC1	1
70333473023	06-01-CR-IN-140-T	EPA 200.8, Rev. 5.4	JC1	1
70333473024	06-01-CR-IN-141-B	EPA 200.8, Rev. 5.4	JC1	1
70333473025	06-01-CR-IN-141-T	EPA 200.8, Rev. 5.4	JC1	1
70333473026	06-01-CR-IN-142-B	EPA 200.8, Rev. 5.4	JC1	1
70333473027	06-01-CR-IN-142-T	EPA 200.8, Rev. 5.4	JC1	1
70333473028	06-01-CR-IN-143-B	EPA 200.8, Rev. 5.4	JC1	1
70333473029	06-01-CR-IN-143-T	EPA 200.8, Rev. 5.4	JC1	1
70333473030	06-01-CR-IN-137-B	EPA 200.8, Rev. 5.4	JC1	1
70333473031	06-01-CR-IN-137-T	EPA 200.8, Rev. 5.4	JC1	1
70333473032	06-01-HA-BY-82E-FL	EPA 200.8, Rev. 5.4	JC1	1
70333473033	06-01-HA-BY-82E-FR	EPA 200.8, Rev. 5.4	JC1	1
70333473034	06-01-HA-BY-82E-BF	EPA 200.8, Rev. 5.4	JC1	1
70333473035	06-01-KI-IN-82-T1	EPA 200.8, Rev. 5.4	JC1	1
70333473036	06-01-KI-IN-82-T2	EPA 200.8, Rev. 5.4	JC1	1
70333473037	06-01-KI-IN-82-T3	EPA 200.8, Rev. 5.4	JC1	1

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE ANALYTE COUNT

Project: RCSD - School No.22

Pace Project No.: 70333473

Lab ID	Sample ID	Method	Analysts	Analytes Reported
70333473038	06-01-KI-IN-82-T4	EPA 200.8, Rev. 5.4	JC1	1
70333473039	06-01-KI-IN-82F-T5	EPA 200.8, Rev. 5.4	JC1	1
70333473040	06-01-KI-IN-82F-T6	EPA 200.8, Rev. 5.4	JC1	1
70333473041	06-01-KI-IN-82F-T7	EPA 200.8, Rev. 5.4	JC1	1
70333473042	06-01-KI-IN-82F-T8	EPA 200.8, Rev. 5.4	JC1	1
70333473043	06-01-OF-IN-83-T	EPA 200.8, Rev. 5.4	JC1	1
70333473044	06-01-CR-IN-86-B	EPA 200.8, Rev. 5.4	JC1	1
70333473045	06-01-CR-IN-86-T	EPA 200.8, Rev. 5.4	JC1	1
70333473046	06-01-CR-IN-102-B	EPA 200.8, Rev. 5.4	JC1	1
70333473047	06-01-CR-IN-102-T	EPA 200.8, Rev. 5.4	JC1	1
70333473048	06-01-CR-IN-101-B	EPA 200.8, Rev. 5.4	JC1	1
70333473049	06-01-CR-IN-101-T	EPA 200.8, Rev. 5.4	JC1	1
70333473050	06-01-CR-IN-104-B	EPA 200.8, Rev. 5.4	JC1	1
70333473051	06-01-CR-IN-104-T	EPA 200.8, Rev. 5.4	JC1	1
70333473052	06-01-CR-IN-103-B	EPA 200.8, Rev. 5.4	JC1	1
70333473053	06-01-CR-IN-103-T	EPA 200.8, Rev. 5.4	JC1	1
70333473054	06-01-CR-IN-106-B	EPA 200.8, Rev. 5.4	JC1	1
70333473055	06-01-CR-IN-106-T	EPA 200.8, Rev. 5.4	JC1	1
70333473056	06-01-CR-IN-105-B	EPA 200.8, Rev. 5.4	JC1	1
70333473057	06-01-CR-IN-105-T	EPA 200.8, Rev. 5.4	JC1	1
70333473058	06-01-CR-IN-144-B	EPA 200.8, Rev. 5.4	JC1	1
70333473059	06-01-CR-IN-144-T	EPA 200.8, Rev. 5.4	JC1	1
70333473060	06-01-CR-IN-145-B	EPA 200.8, Rev. 5.4	JC1	1
70333473061	06-01-CR-IN-145-T	EPA 200.8, Rev. 5.4	JC1	1
70333473062	06-01-CR-IN-147-B	EPA 200.8, Rev. 5.4	JC1	1
70333473063	06-01-CR-IN-147-T	EPA 200.8, Rev. 5.4	JC1	1
70333473064	06-01-CR-IN-148-B	EPA 200.8, Rev. 5.4	JC1	1
70333473065	06-01-CR-IN-148-T	EPA 200.8, Rev. 5.4	JC1	1
70333473066	06-01-CR-IN-146-B	EPA 200.8, Rev. 5.4	JC1	1
70333473067	06-01-CR-IN-146-T	EPA 200.8, Rev. 5.4	JC1	1
70333473068	06-01-CR-IN-122-B	EPA 200.8, Rev. 5.4	JC1	1
70333473069	06-01-CR-IN-122-T	EPA 200.8, Rev. 5.4	JC1	1
70333473070	06-02-HA-BY-216-FL	EPA 200.8, Rev. 5.4	JC1	1
70333473071	06-02-HA-BY-216-FR	EPA 200.8, Rev. 5.4	JC1	1
70333473072	06-02-HA-BY-216-BF	EPA 200.8, Rev. 5.4	JC1	1
70333473073	06-02-TC-IN-216-B	EPA 200.8, Rev. 5.4	JC1	1
70333473074	06-02-TC-IN-216-T	EPA 200.8, Rev. 5.4	JC1	1

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE ANALYTE COUNT

Project: RCSD - School No.22

Pace Project No.: 70333473

Lab ID	Sample ID	Method	Analysts	Analytes Reported
70333473075	06-02-TC-IN-214-B	EPA 200.8, Rev. 5.4	JC1	1
70333473076	06-02-TC-IN-214-T	EPA 200.8, Rev. 5.4	JC1	1
70333473077	06-02-TC-IN-213-B	EPA 200.8, Rev. 5.4	JC1	1
70333473078	06-02-TC-IN-213-T	EPA 200.8, Rev. 5.4	JC1	1
70333473079	06-02-TC-IN-212-B	EPA 200.8, Rev. 5.4	JC1	1
70333473080	06-02-TC-IN-212-T	EPA 200.8, Rev. 5.4	JC1	1
70333473081	06-02-TC-IN-210-B	EPA 200.8, Rev. 5.4	JC1	1
70333473082	06-02-TC-IN-210-T	EPA 200.8, Rev. 5.4	JC1	1
70333473083	06-02-TC-IN-206-B	EPA 200.8, Rev. 5.4	JC1	1
70333473084	06-02-TC-IN-206-T	EPA 200.8, Rev. 5.4	JC1	1
70333473085	06-02-TC-IN-204-B	EPA 200.8, Rev. 5.4	JC1	1
70333473086	06-02-TC-IN-204-T	EPA 200.8, Rev. 5.4	JC1	1
70333473087	06-02-TC-IN-203-B	EPA 200.8, Rev. 5.4	JC1	1
70333473088	06-02-TC-IN-203-T	EPA 200.8, Rev. 5.4	JC1	1
70333473089	06-02-TC-IN-201-B	EPA 200.8, Rev. 5.4	JC1	1
70333473090	06-02-TC-IN-201-T	EPA 200.8, Rev. 5.4	JC1	1
70333473091	06-01-NO-IN-107-T	EPA 200.8, Rev. 5.4	JC1	1
70333473092	06-01-OF-IN-112E-T	EPA 200.8, Rev. 5.4	JC1	1

PASI-NB = Pace Analytical Services - Newburgh

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



PROJECT NARRATIVE

Project: RCSD - School No.22

Pace Project No.: 70333473

Method: EPA 200.8, Rev. 5.4

Description: NB 200.8 ICPMS DW No Prep

Client: Lozier Environmental Consulting, Inc.

Date: January 29, 2025

General Information:

92 samples were analyzed for EPA 200.8, Rev. 5.4 by Pace Analytical Services Newburgh. All samples were received in acceptable condition with any exceptions noted below or on the chain-of custody and/or the sample condition upon receipt form (SCUR) attached at the end of this report.

Hold Time:

The samples were analyzed within the method required hold times with any exceptions noted below.

Initial Calibrations (including MS Tune as applicable):

All criteria were within method requirements with any exceptions noted below.

Continuing Calibration:

All criteria were within method requirements with any exceptions noted below.

Internal Standards:

All internal standards were within QC limits with any exceptions noted below.

Surrogates:

All surrogates were within QC limits with any exceptions noted below.

Method Blank:

All analytes were below the report limit in the method blank, where applicable, with any exceptions noted below.

Laboratory Control Spike:

All laboratory control spike compounds were within QC limits with any exceptions noted below.

Matrix Spikes:

All percent recoveries and relative percent differences (RPDs) were within acceptance criteria with any exceptions noted below.

Duplicate Sample:

All duplicate sample results were within method acceptance criteria with any exceptions noted below.

Additional Comments:

This data package has been reviewed for quality and completeness and is approved for release.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD - School No.22

Pace Project No.: 70333473

Sample: 06-01-HA-BY-121-FL		Lab ID: 70333473001		Collected: 01/15/25 06:11		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 14:19	7439-92-1	
Sample: 06-01-HA-BY-121-FR		Lab ID: 70333473002		Collected: 01/15/25 06:11		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 14:35	7439-92-1	
Sample: 06-01-HA-BY-121-BF		Lab ID: 70333473003		Collected: 01/15/25 06:12		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 14:38	7439-92-1	
Sample: 06-01-CR-IN-128-B		Lab ID: 70333473004		Collected: 01/15/25 06:16		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 14:41	7439-92-1	
Sample: 06-01-CR-IN-128-T		Lab ID: 70333473005		Collected: 01/15/25 06:17		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 14:43	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD - School No.22

Pace Project No.: 70333473

Sample: 06-01-CR-IN-130-B		Lab ID: 70333473006		Collected: 01/15/25 06:20		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 14:46	7439-92-1	
Sample: 06-01-CR-IN-130-T		Lab ID: 70333473007		Collected: 01/15/25 06:21		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 14:49	7439-92-1	
Sample: 06-01-CR-IN-131-B		Lab ID: 70333473008		Collected: 01/15/25 06:22		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 14:51	7439-92-1	
Sample: 06-01-CR-IN-131-T		Lab ID: 70333473009		Collected: 01/15/25 06:22		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 14:54	7439-92-1	
Sample: 06-01-CR-IN-132-B		Lab ID: 70333473010		Collected: 01/15/25 06:24		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 14:57	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD - School No.22

Pace Project No.: 70333473

Sample: 06-01-CR-IN-132-T		Lab ID: 70333473011		Collected: 01/15/25 06:24		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 15:05	7439-92-1	
Sample: 06-01-CR-IN-133-B		Lab ID: 70333473012		Collected: 01/15/25 06:27		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 15:10	7439-92-1	
Sample: 06-01-CR-IN-133-T		Lab ID: 70333473013		Collected: 01/15/25 06:27		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 15:13	7439-92-1	
Sample: 06-01-CR-IN-134-B		Lab ID: 70333473014		Collected: 01/15/25 06:28		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 15:16	7439-92-1	
Sample: 06-01-CR-IN-134-T		Lab ID: 70333473015		Collected: 01/15/25 06:28		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 15:19	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD - School No.22

Pace Project No.: 70333473

Sample: 06-01-CR-IN-135-B		Lab ID: 70333473016		Collected: 01/15/25 06:30		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 15:21	7439-92-1	
Sample: 06-01-CR-IN-135-T		Lab ID: 70333473017		Collected: 01/15/25 06:30		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 15:24	7439-92-1	
Sample: 06-01-CR-IN-138-B		Lab ID: 70333473018		Collected: 01/15/25 06:33		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 15:27	7439-92-1	
Sample: 06-01-CR-IN-138-T		Lab ID: 70333473019		Collected: 01/15/25 06:33		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 15:29	7439-92-1	
Sample: 06-01-CR-IN-139-B		Lab ID: 70333473020		Collected: 01/15/25 06:35		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 15:38	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD - School No.22

Pace Project No.: 70333473

Sample: 06-01-CR-IN-139-T Lab ID: 70333473021 Collected: 01/15/25 06:35 Received: 01/17/25 12:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		01/28/25 17:27	7439-92-1	

Sample: 06-01-CR-IN-140-B Lab ID: 70333473022 Collected: 01/15/25 06:37 Received: 01/17/25 12:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		01/28/25 17:37	7439-92-1	

Sample: 06-01-CR-IN-140-T Lab ID: 70333473023 Collected: 01/15/25 06:37 Received: 01/17/25 12:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		01/28/25 17:40	7439-92-1	

Sample: 06-01-CR-IN-141-B Lab ID: 70333473024 Collected: 01/15/25 06:40 Received: 01/17/25 12:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		01/28/25 17:42	7439-92-1	

Sample: 06-01-CR-IN-141-T Lab ID: 70333473025 Collected: 01/15/25 06:40 Received: 01/17/25 12:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		01/28/25 17:45	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD - School No.22

Pace Project No.: 70333473

Sample: 06-01-CR-IN-142-B		Lab ID: 70333473026		Collected: 01/15/25 06:44		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	1.3	ug/L	1.0	15	1		01/28/25 17:48	7439-92-1	

Sample: 06-01-CR-IN-142-T		Lab ID: 70333473027		Collected: 01/15/25 06:44		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 17:50	7439-92-1	

Sample: 06-01-CR-IN-143-B		Lab ID: 70333473028		Collected: 01/15/25 06:49		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 17:58	7439-92-1	

Sample: 06-01-CR-IN-143-T		Lab ID: 70333473029		Collected: 01/15/25 06:50		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 18:01	7439-92-1	

Sample: 06-01-CR-IN-137-B		Lab ID: 70333473030		Collected: 01/15/25 06:51		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 18:03	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD - School No.22

Pace Project No.: 70333473

Sample: 06-01-CR-IN-137-T		Lab ID: 70333473031		Collected: 01/15/25 06:52		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 18:06	7439-92-1	
Sample: 06-01-HA-BY-82E-FL		Lab ID: 70333473032		Collected: 01/15/25 06:55		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 18:11	7439-92-1	
Sample: 06-01-HA-BY-82E-FR		Lab ID: 70333473033		Collected: 01/15/25 06:56		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 18:14	7439-92-1	
Sample: 06-01-HA-BY-82E-BF		Lab ID: 70333473034		Collected: 01/15/25 06:56		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 18:16	7439-92-1	
Sample: 06-01-KI-IN-82-T1		Lab ID: 70333473035		Collected: 01/15/25 06:59		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	1.2	ug/L	1.0	15	1		01/28/25 18:19	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD - School No.22

Pace Project No.: 70333473

Sample: 06-01-KI-IN-82-T2 **Lab ID:** 70333473036 Collected: 01/15/25 06:59 Received: 01/17/25 12:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		01/28/25 18:22	7439-92-1	

Sample: 06-01-KI-IN-82-T3 **Lab ID:** 70333473037 Collected: 01/15/25 07:00 Received: 01/17/25 12:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		01/28/25 18:29	7439-92-1	

Sample: 06-01-KI-IN-82-T4 **Lab ID:** 70333473038 Collected: 01/15/25 07:02 Received: 01/17/25 12:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		01/28/25 18:32	7439-92-1	

Sample: 06-01-KI-IN-82F-T5 **Lab ID:** 70333473039 Collected: 01/15/25 07:04 Received: 01/17/25 12:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		01/28/25 18:35	7439-92-1	

Sample: 06-01-KI-IN-82F-T6 **Lab ID:** 70333473040 Collected: 01/15/25 07:04 Received: 01/17/25 12:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		01/28/25 18:37	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD - School No.22

Pace Project No.: 70333473

Sample: 06-01-KI-IN-82F-T7 Lab ID: 70333473041 Collected: 01/15/25 07:05 Received: 01/17/25 12:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		01/28/25 18:45	7439-92-1	

Sample: 06-01-KI-IN-82F-T8 Lab ID: 70333473042 Collected: 01/15/25 07:05 Received: 01/17/25 12:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		01/28/25 19:01	7439-92-1	

Sample: 06-01-OF-IN-83-T Lab ID: 70333473043 Collected: 01/15/25 07:07 Received: 01/17/25 12:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		01/28/25 19:03	7439-92-1	

Sample: 06-01-CR-IN-86-B Lab ID: 70333473044 Collected: 01/15/25 07:10 Received: 01/17/25 12:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		01/28/25 19:06	7439-92-1	

Sample: 06-01-CR-IN-86-T Lab ID: 70333473045 Collected: 01/15/25 07:10 Received: 01/17/25 12:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		01/28/25 19:09	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD - School No.22

Pace Project No.: 70333473

Sample: 06-01-CR-IN-102-B		Lab ID: 70333473046		Collected: 01/15/25 07:13		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 19:11	7439-92-1	
Sample: 06-01-CR-IN-102-T		Lab ID: 70333473047		Collected: 01/15/25 07:13		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 19:14	7439-92-1	
Sample: 06-01-CR-IN-101-B		Lab ID: 70333473048		Collected: 01/15/25 07:14		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 19:16	7439-92-1	
Sample: 06-01-CR-IN-101-T		Lab ID: 70333473049		Collected: 01/15/25 07:22		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 19:19	7439-92-1	
Sample: 06-01-CR-IN-104-B		Lab ID: 70333473050		Collected: 01/15/25 07:26		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 19:22	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD - School No.22

Pace Project No.: 70333473

Sample: 06-01-CR-IN-104-T		Lab ID: 70333473051		Collected: 01/15/25 07:27		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 19:24	7439-92-1	
Sample: 06-01-CR-IN-103-B		Lab ID: 70333473052		Collected: 01/15/25 07:29		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 19:35	7439-92-1	
Sample: 06-01-CR-IN-103-T		Lab ID: 70333473053		Collected: 01/15/25 07:29		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 19:37	7439-92-1	
Sample: 06-01-CR-IN-106-B		Lab ID: 70333473054		Collected: 01/15/25 07:31		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 19:40	7439-92-1	
Sample: 06-01-CR-IN-106-T		Lab ID: 70333473055		Collected: 01/15/25 07:31		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 19:43	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD - School No.22

Pace Project No.: 70333473

Sample: 06-01-CR-IN-105-B		Lab ID: 70333473056		Collected: 01/15/25 07:32		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 19:45	7439-92-1	
Sample: 06-01-CR-IN-105-T		Lab ID: 70333473057		Collected: 01/15/25 07:33		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 19:48	7439-92-1	
Sample: 06-01-CR-IN-144-B		Lab ID: 70333473058		Collected: 01/15/25 07:36		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 19:50	7439-92-1	
Sample: 06-01-CR-IN-144-T		Lab ID: 70333473059		Collected: 01/15/25 07:36		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 19:53	7439-92-1	
Sample: 06-01-CR-IN-145-B		Lab ID: 70333473060		Collected: 01/15/25 07:42		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 19:56	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD - School No.22

Pace Project No.: 70333473

Sample: 06-01-CR-IN-145-T		Lab ID: 70333473061		Collected: 01/15/25 07:42		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 20:09	7439-92-1	
Sample: 06-01-CR-IN-147-B		Lab ID: 70333473062		Collected: 01/15/25 07:46		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 20:19	7439-92-1	
Sample: 06-01-CR-IN-147-T		Lab ID: 70333473063		Collected: 01/15/25 07:46		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	1.0	ug/L	1.0	15	1		01/28/25 20:22	7439-92-1	
Sample: 06-01-CR-IN-148-B		Lab ID: 70333473064		Collected: 01/15/25 07:48		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 20:24	7439-92-1	
Sample: 06-01-CR-IN-148-T		Lab ID: 70333473065		Collected: 01/15/25 07:48		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 20:27	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD - School No.22

Pace Project No.: 70333473

Sample: 06-01-CR-IN-146-B **Lab ID: 70333473066** Collected: 01/15/25 07:50 Received: 01/17/25 12:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		01/28/25 20:35	7439-92-1	

Sample: 06-01-CR-IN-146-T **Lab ID: 70333473067** Collected: 01/15/25 07:50 Received: 01/17/25 12:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		01/28/25 20:38	7439-92-1	

Sample: 06-01-CR-IN-122-B **Lab ID: 70333473068** Collected: 01/15/25 07:53 Received: 01/17/25 12:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		01/28/25 20:40	7439-92-1	

Sample: 06-01-CR-IN-122-T **Lab ID: 70333473069** Collected: 01/15/25 07:53 Received: 01/17/25 12:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		01/28/25 20:43	7439-92-1	

Sample: 06-02-HA-BY-216-FL **Lab ID: 70333473070** Collected: 01/15/25 08:00 Received: 01/17/25 12:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		01/28/25 20:45	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD - School No.22

Pace Project No.: 70333473

Sample: 06-02-HA-BY-216-FR Lab ID: 70333473071 Collected: 01/15/25 08:00 Received: 01/17/25 12:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		01/28/25 20:48	7439-92-1	

Sample: 06-02-HA-BY-216-BF Lab ID: 70333473072 Collected: 01/15/25 08:00 Received: 01/17/25 12:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		01/28/25 20:53	7439-92-1	

Sample: 06-02-TC-IN-216-B Lab ID: 70333473073 Collected: 01/15/25 08:01 Received: 01/17/25 12:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		01/28/25 20:56	7439-92-1	

Sample: 06-02-TC-IN-216-T Lab ID: 70333473074 Collected: 01/15/25 08:01 Received: 01/17/25 12:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	1.0	ug/L	1.0	15	1		01/28/25 20:58	7439-92-1	

Sample: 06-02-TC-IN-214-B Lab ID: 70333473075 Collected: 01/15/25 08:05 Received: 01/17/25 12:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		01/28/25 21:06	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD - School No.22

Pace Project No.: 70333473

Sample: 06-02-TC-IN-214-T		Lab ID: 70333473076		Collected: 01/15/25 08:05		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 21:09	7439-92-1	
Sample: 06-02-TC-IN-213-B		Lab ID: 70333473077		Collected: 01/15/25 08:07		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 21:12	7439-92-1	
Sample: 06-02-TC-IN-213-T		Lab ID: 70333473078		Collected: 01/15/25 08:07		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 21:14	7439-92-1	
Sample: 06-02-TC-IN-212-B		Lab ID: 70333473079		Collected: 01/15/25 08:09		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 21:17	7439-92-1	
Sample: 06-02-TC-IN-212-T		Lab ID: 70333473080		Collected: 01/15/25 08:09		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 21:19	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD - School No.22

Pace Project No.: 70333473

Sample: 06-02-TC-IN-210-B		Lab ID: 70333473081		Collected: 01/15/25 08:11		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 21:27	7439-92-1	
Sample: 06-02-TC-IN-210-T		Lab ID: 70333473082		Collected: 01/15/25 08:11		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	1.1	ug/L	1.0	15	1		01/28/25 21:43	7439-92-1	
Sample: 06-02-TC-IN-206-B		Lab ID: 70333473083		Collected: 01/15/25 08:14		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 21:46	7439-92-1	
Sample: 06-02-TC-IN-206-T		Lab ID: 70333473084		Collected: 01/15/25 08:14		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 21:48	7439-92-1	
Sample: 06-02-TC-IN-204-B		Lab ID: 70333473085		Collected: 01/15/25 08:18		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 21:51	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD - School No.22

Pace Project No.: 70333473

Sample: 06-02-TC-IN-204-T		Lab ID: 70333473086		Collected: 01/15/25 08:18		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 21:53	7439-92-1	
Sample: 06-02-TC-IN-203-B		Lab ID: 70333473087		Collected: 01/15/25 08:20		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 21:56	7439-92-1	
Sample: 06-02-TC-IN-203-T		Lab ID: 70333473088		Collected: 01/15/25 08:20		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 21:59	7439-92-1	
Sample: 06-02-TC-IN-201-B		Lab ID: 70333473089		Collected: 01/15/25 08:23		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 22:01	7439-92-1	
Sample: 06-02-TC-IN-201-T		Lab ID: 70333473090		Collected: 01/15/25 08:23		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 22:09	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD - School No.22

Pace Project No.: 70333473

Sample: 06-01-NO-IN-107-T		Lab ID: 70333473091		Collected: 01/15/25 08:27		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 22:12	7439-92-1	

Sample: 06-01-OF-IN-112E-T		Lab ID: 70333473092		Collected: 01/15/25 08:29		Received: 01/17/25 12:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		01/28/25 22:17	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: RCSD - School No.22
Pace Project No.: 70333473

QC Batch:	381791	Analysis Method:	EPA 200.8, Rev. 5.4
QC Batch Method:	EPA 200.8, Rev. 5.4	Analysis Description:	NB 200.8 ICPMS DW No Prep
		Laboratory:	Pace Analytical Services - Newburgh
Associated Lab Samples:	70333473001, 70333473002, 70333473003, 70333473004, 70333473005, 70333473006, 70333473007, 70333473008, 70333473009, 70333473010, 70333473011, 70333473012, 70333473013, 70333473014, 70333473015, 70333473016, 70333473017, 70333473018, 70333473019, 70333473020		

METHOD BLANK:	2004036	Matrix:	Water
Associated Lab Samples:	70333473001, 70333473002, 70333473003, 70333473004, 70333473005, 70333473006, 70333473007, 70333473008, 70333473009, 70333473010, 70333473011, 70333473012, 70333473013, 70333473014, 70333473015, 70333473016, 70333473017, 70333473018, 70333473019, 70333473020		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	01/28/25 14:14	

LABORATORY CONTROL SAMPLE:	2004037					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	49.2	98	85-115	

MATRIX SPIKE SAMPLE:		2004039					
		70333473001	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	51.0	102	70-130	

MATRIX SPIKE SAMPLE:	2004041						
		70333473011	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	51.2	102	70-130	

SAMPLE DUPLICATE:	2004038					
Parameter	Units	70333473001 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: RCSD - School No.22
Pace Project No.: 70333473

QC Batch:	381792	Analysis Method:	EPA 200.8, Rev. 5.4
QC Batch Method:	EPA 200.8, Rev. 5.4	Analysis Description:	NB 200.8 ICPMS DW No Prep
		Laboratory:	Pace Analytical Services - Newburgh
Associated Lab Samples:	70333473021, 70333473022, 70333473023, 70333473024, 70333473025, 70333473026, 70333473027, 70333473028, 70333473029, 70333473030, 70333473031, 70333473032, 70333473033, 70333473034, 70333473035, 70333473036, 70333473037, 70333473038, 70333473039, 70333473040		

METHOD BLANK:	2004045	Matrix:	Water
Associated Lab Samples:	70333473021, 70333473022, 70333473023, 70333473024, 70333473025, 70333473026, 70333473027, 70333473028, 70333473029, 70333473030, 70333473031, 70333473032, 70333473033, 70333473034, 70333473035, 70333473036, 70333473037, 70333473038, 70333473039, 70333473040		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	01/28/25 15:43	

LABORATORY CONTROL SAMPLE:	2004046					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	49.4	99	85-115	

MATRIX SPIKE SAMPLE:		2004048					
		70333473021	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	52.0	103	70-130	

MATRIX SPIKE SAMPLE:		2004050					
		70333473031	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	52.7	105	70-130	

SAMPLE DUPLICATE:	2004047					
Parameter	Units	70333473021 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: RCSD - School No.22
Pace Project No.: 70333473

QC Batch:	381794	Analysis Method:	EPA 200.8, Rev. 5.4
QC Batch Method:	EPA 200.8, Rev. 5.4	Analysis Description:	NB 200.8 ICPMS DW No Prep
		Laboratory:	Pace Analytical Services - Newburgh
Associated Lab Samples:	70333473041, 70333473042, 70333473043, 70333473044, 70333473045, 70333473046, 70333473047, 70333473048, 70333473049, 70333473050, 70333473051, 70333473052, 70333473053, 70333473054, 70333473055, 70333473056, 70333473057, 70333473058, 70333473059, 70333473060		

METHOD BLANK:	2004054	Matrix:	Water
Associated Lab Samples:	70333473041, 70333473042, 70333473043, 70333473044, 70333473045, 70333473046, 70333473047, 70333473048, 70333473049, 70333473050, 70333473051, 70333473052, 70333473053, 70333473054, 70333473055, 70333473056, 70333473057, 70333473058, 70333473059, 70333473060		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	01/28/25 18:40	

LABORATORY CONTROL SAMPLE:	2004055					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	49.2	98	85-115	

MATRIX SPIKE SAMPLE:		2004057					
		70333473041	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	52.3	104	70-130	

MATRIX SPIKE SAMPLE:	2004059						
		70333473051	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	51.6	102	70-130	

SAMPLE DUPLICATE:	2004056					
Parameter	Units	70333473041 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: RCSD - School No.22
Pace Project No.: 70333473

QC Batch:	381796	Analysis Method:	EPA 200.8, Rev. 5.4
QC Batch Method:	EPA 200.8, Rev. 5.4	Analysis Description:	NB 200.8 ICPMS DW No Prep
		Laboratory:	Pace Analytical Services - Newburgh
Associated Lab Samples:	70333473061, 70333473062, 70333473063, 70333473064, 70333473065, 70333473066, 70333473067, 70333473068, 70333473069, 70333473070, 70333473071, 70333473072, 70333473073, 70333473074, 70333473075, 70333473076, 70333473077, 70333473078, 70333473079, 70333473080		

METHOD BLANK:	2004063	Matrix:	Water
Associated Lab Samples:	70333473061, 70333473062, 70333473063, 70333473064, 70333473065, 70333473066, 70333473067, 70333473068, 70333473069, 70333473070, 70333473071, 70333473072, 70333473073, 70333473074, 70333473075, 70333473076, 70333473077, 70333473078, 70333473079, 70333473080		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	01/28/25 20:04	

LABORATORY CONTROL SAMPLE:	2004064					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	49.6	99	85-115	

MATRIX SPIKE SAMPLE:		2004066					
		70333473061	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	51.2	102	70-130	

MATRIX SPIKE SAMPLE:		2004068					
		70333473071	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	51.4	103	70-130	

SAMPLE DUPLICATE:	2004065					
Parameter	Units	70333473061 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: RCSD - School No.22

Pace Project No.: 70333473

QC Batch:	382010	Analysis Method:	EPA 200.8, Rev. 5.4
QC Batch Method:	EPA 200.8, Rev. 5.4	Analysis Description:	NB 200.8 ICPMS DW No Prep
		Laboratory:	Pace Analytical Services - Newburgh
Associated Lab Samples:	70333473081, 70333473082, 70333473083, 70333473084, 70333473085, 70333473086, 70333473087, 70333473088, 70333473089, 70333473090, 70333473091, 70333473092		

METHOD BLANK:	2004907	Matrix:	Water
Associated Lab Samples:	70333473081, 70333473082, 70333473083, 70333473084, 70333473085, 70333473086, 70333473087, 70333473088, 70333473089, 70333473090, 70333473091, 70333473092		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	01/28/25 21:22	

LABORATORY CONTROL SAMPLE:	2004908					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	48.4	97	85-115	

MATRIX SPIKE SAMPLE:	2004910						
		70333473081	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	51.0	101	70-130	

MATRIX SPIKE SAMPLE:	2004912						
		70333473091	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	51.7	102	70-130	

SAMPLE DUPLICATE:	2004909					
Parameter	Units	70333473081 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALIFIERS

Project: RCSD - School No.22
Pace Project No.: 70333473

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: RCSD - School No.22

Pace Project No.: 70333473

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70333473001	06-01-HA-BY-121-FL	EPA 200.8, Rev. 5.4	381791		
70333473002	06-01-HA-BY-121-FR	EPA 200.8, Rev. 5.4	381791		
70333473003	06-01-HA-BY-121-BF	EPA 200.8, Rev. 5.4	381791		
70333473004	06-01-CR-IN-128-B	EPA 200.8, Rev. 5.4	381791		
70333473005	06-01-CR-IN-128-T	EPA 200.8, Rev. 5.4	381791		
70333473006	06-01-CR-IN-130-B	EPA 200.8, Rev. 5.4	381791		
70333473007	06-01-CR-IN-130-T	EPA 200.8, Rev. 5.4	381791		
70333473008	06-01-CR-IN-131-B	EPA 200.8, Rev. 5.4	381791		
70333473009	06-01-CR-IN-131-T	EPA 200.8, Rev. 5.4	381791		
70333473010	06-01-CR-IN-132-B	EPA 200.8, Rev. 5.4	381791		
70333473011	06-01-CR-IN-132-T	EPA 200.8, Rev. 5.4	381791		
70333473012	06-01-CR-IN-133-B	EPA 200.8, Rev. 5.4	381791		
70333473013	06-01-CR-IN-133-T	EPA 200.8, Rev. 5.4	381791		
70333473014	06-01-CR-IN-134-B	EPA 200.8, Rev. 5.4	381791		
70333473015	06-01-CR-IN-134-T	EPA 200.8, Rev. 5.4	381791		
70333473016	06-01-CR-IN-135-B	EPA 200.8, Rev. 5.4	381791		
70333473017	06-01-CR-IN-135-T	EPA 200.8, Rev. 5.4	381791		
70333473018	06-01-CR-IN-138-B	EPA 200.8, Rev. 5.4	381791		
70333473019	06-01-CR-IN-138-T	EPA 200.8, Rev. 5.4	381791		
70333473020	06-01-CR-IN-139-B	EPA 200.8, Rev. 5.4	381791		
70333473021	06-01-CR-IN-139-T	EPA 200.8, Rev. 5.4	381792		
70333473022	06-01-CR-IN-140-B	EPA 200.8, Rev. 5.4	381792		
70333473023	06-01-CR-IN-140-T	EPA 200.8, Rev. 5.4	381792		
70333473024	06-01-CR-IN-141-B	EPA 200.8, Rev. 5.4	381792		
70333473025	06-01-CR-IN-141-T	EPA 200.8, Rev. 5.4	381792		
70333473026	06-01-CR-IN-142-B	EPA 200.8, Rev. 5.4	381792		
70333473027	06-01-CR-IN-142-T	EPA 200.8, Rev. 5.4	381792		
70333473028	06-01-CR-IN-143-B	EPA 200.8, Rev. 5.4	381792		
70333473029	06-01-CR-IN-143-T	EPA 200.8, Rev. 5.4	381792		
70333473030	06-01-CR-IN-137-B	EPA 200.8, Rev. 5.4	381792		
70333473031	06-01-CR-IN-137-T	EPA 200.8, Rev. 5.4	381792		
70333473032	06-01-HA-BY-82E-FL	EPA 200.8, Rev. 5.4	381792		
70333473033	06-01-HA-BY-82E-FR	EPA 200.8, Rev. 5.4	381792		
70333473034	06-01-HA-BY-82E-BF	EPA 200.8, Rev. 5.4	381792		
70333473035	06-01-KI-IN-82-T1	EPA 200.8, Rev. 5.4	381792		
70333473036	06-01-KI-IN-82-T2	EPA 200.8, Rev. 5.4	381792		
70333473037	06-01-KI-IN-82-T3	EPA 200.8, Rev. 5.4	381792		
70333473038	06-01-KI-IN-82-T4	EPA 200.8, Rev. 5.4	381792		
70333473039	06-01-KI-IN-82F-T5	EPA 200.8, Rev. 5.4	381792		
70333473040	06-01-KI-IN-82F-T6	EPA 200.8, Rev. 5.4	381792		
70333473041	06-01-KI-IN-82F-T7	EPA 200.8, Rev. 5.4	381794		
70333473042	06-01-KI-IN-82F-T8	EPA 200.8, Rev. 5.4	381794		
70333473043	06-01-OF-IN-83-T	EPA 200.8, Rev. 5.4	381794		
70333473044	06-01-CR-IN-86-B	EPA 200.8, Rev. 5.4	381794		
70333473045	06-01-CR-IN-86-T	EPA 200.8, Rev. 5.4	381794		
70333473046	06-01-CR-IN-102-B	EPA 200.8, Rev. 5.4	381794		
70333473047	06-01-CR-IN-102-T	EPA 200.8, Rev. 5.4	381794		
70333473048	06-01-CR-IN-101-B	EPA 200.8, Rev. 5.4	381794		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: RCSD - School No.22

Pace Project No.: 70333473

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70333473049	06-01-CR-IN-101-T	EPA 200.8, Rev. 5.4	381794		
70333473050	06-01-CR-IN-104-B	EPA 200.8, Rev. 5.4	381794		
70333473051	06-01-CR-IN-104-T	EPA 200.8, Rev. 5.4	381794		
70333473052	06-01-CR-IN-103-B	EPA 200.8, Rev. 5.4	381794		
70333473053	06-01-CR-IN-103-T	EPA 200.8, Rev. 5.4	381794		
70333473054	06-01-CR-IN-106-B	EPA 200.8, Rev. 5.4	381794		
70333473055	06-01-CR-IN-106-T	EPA 200.8, Rev. 5.4	381794		
70333473056	06-01-CR-IN-105-B	EPA 200.8, Rev. 5.4	381794		
70333473057	06-01-CR-IN-105-T	EPA 200.8, Rev. 5.4	381794		
70333473058	06-01-CR-IN-144-B	EPA 200.8, Rev. 5.4	381794		
70333473059	06-01-CR-IN-144-T	EPA 200.8, Rev. 5.4	381794		
70333473060	06-01-CR-IN-145-B	EPA 200.8, Rev. 5.4	381794		
70333473061	06-01-CR-IN-145-T	EPA 200.8, Rev. 5.4	381796		
70333473062	06-01-CR-IN-147-B	EPA 200.8, Rev. 5.4	381796		
70333473063	06-01-CR-IN-147-T	EPA 200.8, Rev. 5.4	381796		
70333473064	06-01-CR-IN-148-B	EPA 200.8, Rev. 5.4	381796		
70333473065	06-01-CR-IN-148-T	EPA 200.8, Rev. 5.4	381796		
70333473066	06-01-CR-IN-146-B	EPA 200.8, Rev. 5.4	381796		
70333473067	06-01-CR-IN-146-T	EPA 200.8, Rev. 5.4	381796		
70333473068	06-01-CR-IN-122-B	EPA 200.8, Rev. 5.4	381796		
70333473069	06-01-CR-IN-122-T	EPA 200.8, Rev. 5.4	381796		
70333473070	06-02-HA-BY-216-FL	EPA 200.8, Rev. 5.4	381796		
70333473071	06-02-HA-BY-216-FR	EPA 200.8, Rev. 5.4	381796		
70333473072	06-02-HA-BY-216-BF	EPA 200.8, Rev. 5.4	381796		
70333473073	06-02-TC-IN-216-B	EPA 200.8, Rev. 5.4	381796		
70333473074	06-02-TC-IN-216-T	EPA 200.8, Rev. 5.4	381796		
70333473075	06-02-TC-IN-214-B	EPA 200.8, Rev. 5.4	381796		
70333473076	06-02-TC-IN-214-T	EPA 200.8, Rev. 5.4	381796		
70333473077	06-02-TC-IN-213-B	EPA 200.8, Rev. 5.4	381796		
70333473078	06-02-TC-IN-213-T	EPA 200.8, Rev. 5.4	381796		
70333473079	06-02-TC-IN-212-B	EPA 200.8, Rev. 5.4	381796		
70333473080	06-02-TC-IN-212-T	EPA 200.8, Rev. 5.4	381796		
70333473081	06-02-TC-IN-210-B	EPA 200.8, Rev. 5.4	382010		
70333473082	06-02-TC-IN-210-T	EPA 200.8, Rev. 5.4	382010		
70333473083	06-02-TC-IN-206-B	EPA 200.8, Rev. 5.4	382010		
70333473084	06-02-TC-IN-206-T	EPA 200.8, Rev. 5.4	382010		
70333473085	06-02-TC-IN-204-B	EPA 200.8, Rev. 5.4	382010		
70333473086	06-02-TC-IN-204-T	EPA 200.8, Rev. 5.4	382010		
70333473087	06-02-TC-IN-203-B	EPA 200.8, Rev. 5.4	382010		
70333473088	06-02-TC-IN-203-T	EPA 200.8, Rev. 5.4	382010		
70333473089	06-02-TC-IN-201-B	EPA 200.8, Rev. 5.4	382010		
70333473090	06-02-TC-IN-201-T	EPA 200.8, Rev. 5.4	382010		
70333473091	06-01-NO-IN-107-T	EPA 200.8, Rev. 5.4	382010		
70333473092	06-01-OF-IN-112E-T	EPA 200.8, Rev. 5.4	382010		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 1 of 10

Page 37 of 47

LAB ID: M37025		REPORT TO:		INVOICE TO:	
PROJECT NAME: RCSD - School No. 22		Company: Lozier Environmental Consulting, Inc.		Company: (SAME)	
TURNAROUND TIME: Standard Rush		Address: 2011 East Main Street		Address:	
Other:		City/State Zip: Rochester NY 14609		City/State Zip:	
		Phone: 585-654-9080		Phone:	
		Fax: 585-654-9662		Fax:	
		E-Mail: vkaptein@lozierenv.com		Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS			
1	06-01-HA-BY-121-FL	1/15/2025	6:11		DW				Lead			
2	06-01-HA-BY-121-FR	1/15/2025	6:11		DW							
3	06-01-HA-BY-121-BF	1/15/2025	6:12		DW							
4	06-01-CR-IN-128-B	1/15/2025	6:16		DW							
5	06-01-CR-IN-128-T	1/15/2025	6:17		DW							
6	06-01-CR-IN-130-B	1/15/2025	6:20		DW							
7	06-01-CR-IN-130-T	1/15/2025	6:21		DW							
8	06-01-CR-IN-131-B	1/15/2025	6:22		DW							
9	06-01-CR-IN-131-T	1/15/2025	6:22		DW							
10	06-01-CR-IN-132-B	1/15/2025	6:24		DW							

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # 771456504290)

SAMPLED BY*: Joe Savioe

RELINQUISHED BY*: Joe Savioe

RECEIVED BY*: John Doe DATE: 1/15/25 TIME: 1200

RELINQUISHED BY*: _____ DATE: _____ TIME: _____

RECEIVED BY*: _____ DATE: _____ TIME: _____

RELINQUISHED BY*: _____ DATE: _____ TIME: _____

RECEIVED BY*: _____ DATE: _____ TIME: _____

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FOR LAB USE ONLY		FOR POTABLE WATER ONLY:	
PRESERVATIVE/BIOCIDES: HNO3-		COLIFORM BACTERIA:	
TOTAL NUMBER OF CONTAINERS: 92		Present Absent	
CUSTODY SEAL INTACT? YES		If Present, Date Client is contacted with result:	
SAMPLE ON ICE? NO		Date: _____	
TEMPERATURE: <u>7.9</u> C		Contacted By: _____	
SAMPLE IN COMPLIANCE: YES			





Lozier
Environmental Consulting, Inc.

2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 2 of 10
70333473

Page 38 of 47

LAB ID: M37025		Company: Lozier Environmental Consulting, Inc.		REPORT TO:	
PROJECT NAME: RCSD - School No. 22		Address: 2011 East Main Street		Company: (SAME)	
TURNAROUND TIME: Standard Rush		City/State Zip: Rochester NY 14609		Address:	
Other:		Phone: 585-654-9080 Fax: 585-654-9662		City/State Zip:	
		E-Mail: vkaplen@lozierenv.com		Phone: Fax:	
		Purchase Order #			

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS			
11	06-01-CR-IN-132-T	1/15/2025	6:24		DW				X			
12	06-01-CR-IN-133-B	1/15/2025	6:27		DW				X			
13	06-01-CR-IN-133-T	1/15/2025	6:27		DW				X			
14	06-01-CR-IN-134-B	1/15/2025	6:28		DW				X			
15	06-01-CR-IN-134-T	1/15/2025	6:28		DW				X			
16	06-01-CR-IN-135-B	1/15/2025	6:30		DW				X			
17	06-01-CR-IN-135-T	1/15/2025	6:30		DW				X			
18	06-01-CR-IN-138-B	1/15/2025	6:33		DW				X			
19	06-01-CR-IN-138-T	1/15/2025	6:33		DW				X			
20	06-01-CR-IN-139-B	1/15/2025	6:35		DW				X			

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # 771456504290)

SAMPLED BY*: Joe Savio

RELINQUISHED BY*: Joe Savio DATE: 1/15/2025 TIME: _____

RECEIVED BY: Alan Hu DATE: 1/17/25 TIME: 1200

RELINQUISHED BY*: _____ DATE: _____ TIME: _____

RECEIVED BY: _____ DATE: _____ TIME: _____

RELINQUISHED BY*: _____ DATE: _____ TIME: _____

RECEIVED BY: _____ DATE: _____ TIME: _____

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDE: HNO3-	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINERS: 92	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES	Present Absent
SAMPLE ON ICE? NO	If Present, Date Client is
TEMPERATURE: <u>7-9</u> C	contacted with result:
SAMPLE IN COMPLIANCE: YES	Date: _____
	Contacted By: _____



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 3 of 10
70333473

LAB ID: M37025		Company: Lozier Environmental Consulting, Inc.		REPORT TO:		INVOICE TO:	
PROJECT NAME: RCSD - School No. 22		Address: 2011 East Main Street		City, State Zip: Rochester NY 14609		Company: (SAME)	
TURNAROUND TIME: Standard Rush		Phone: 585-654-9080		Fax: 585-654-9662		City, State Zip:	
Other:		E-Mail: vkaptein@lozierenv.com		Purchase Order #:		Phone: Fax:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS			
21	06-01-CR-IN-139-T	1/15/2025	6:35		DW				X			
22	06-01-CR-IN-140-B	1/15/2025	6:37		DW				X			
23	06-01-CR-IN-140-T	1/15/2025	6:37		DW				X			
24	06-01-CR-IN-141-B	1/15/2025	6:40		DW				X			
25	06-01-CR-IN-141-T	1/15/2025	6:40		DW				X			
26	06-01-CR-IN-142-B	1/15/2025	6:44		DW				X			
27	06-01-CR-IN-142-T	1/15/2025	6:44		DW				X			
28	06-01-CR-IN-143-B	1/15/2025	6:49		DW				X			
29	06-01-CR-IN-143-T	1/15/2025	6:50		DW				X			
30	06-01-CR-IN-137-B	1/15/2025	6:51		DW				X			

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # 7714 5650 4200)

SAMPLED BY*: Joe Savioe

RELINQUISHED BY*: Joe Savioe DATE: 1/15/2025 TIME: _____

RECEIVED BY: [Signature] DATE: 1/15/25 TIME: 1200

RELINQUISHED BY*: [Signature] DATE: _____ TIME: _____

RECEIVED BY: _____ DATE: _____ TIME: _____

RELINQUISHED BY*: _____ DATE: _____ TIME: _____

RECEIVED BY: _____ DATE: _____ TIME: _____

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FOR LAB USE ONLY		FOR POTABLE WATER ONLY:	
PRESERVATIVE/BIOCIDE: HNO3-		COLIFORM BACTERIA:	
TOTAL NUMBER OF CONTAINERS: 92		Present	Absent
CUSTODY SEAL INTACT? YES		If Present, Date Client is contacted with result:	
SAMPLE ON ICE? NO		Date: _____	
TEMPERATURE: 29 C		Contacted By: _____	
SAMPLE IN COMPLIANCE: YES			



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 4 of 10
70333473

LAB ID: M37025		Company: Lozier Environmental Consulting, Inc.		REPORT TO:		INVOICE TO:	
PROJECT NAME: RCSD - School No. 22		Address: 2011 East Main Street		Address: (SAME)			
TURNAROUND TIME: Standard Rush		City, State Zip: Rochester NY 14609		City, State Zip:			
Other:		Phone: 585-654-9080 Fax: 585-654-9662		Phone: Fax:		Purchase Order #:	
E-Mail: vkaptein@lozierenv.com							

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS			
31	06-01-CR-IN-137-T	1/15/2025	6:52		DW				per			
32	06-01-HA-BY-82E-FL	1/15/2025	6:55		DW				x			
33	06-01-HA-BY-82E-FR	1/15/2025	6:56		DW				x			
34	06-01-HA-BY-82E-BF	1/15/2025	6:56		DW				x			
35	06-01-KI-IN-82-T1	1/15/2025	6:59		DW			dish	x			
36	06-01-KI-IN-82-T2	1/15/2025	6:59		DW			dish	x			
37	06-01-KI-IN-82-T3	1/15/2025	7:00		DW			island prep	x			
38	06-01-KI-IN-82-T4	1/15/2025	7:02		DW			hand wash	x			
39	06-01-KI-IN-82F-T5	1/15/2025	7:04		DW			hand wash	x			
40	06-01-KI-IN-82F-T6	1/15/2025	7:04		DW			prep	x			

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # 77456504800)

SAMPLED BY: Joe Savioe

RELINQUISHED BY: Joe Savioe DATE: 1/15/2025 TIME: _____

RECEIVED BY: Mike Ivan DATE: 1/17/25 TIME: 7:00

RELINQUISHED BY: _____ DATE: _____ TIME: _____

RECEIVED BY: _____ DATE: _____ TIME: _____

RELINQUISHED BY: _____ DATE: _____ TIME: _____

RECEIVED BY: _____ DATE: _____ TIME: _____

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FOR LAB USE ONLY		FOR POTABLE WATER ONLY:	
PRESERVATIVE/BIOCIDE: HNO3-		COLIFORM BACTERIA:	
TOTAL NUMBER OF CONTAINERS: 92		Present	Absent
CUSTODY SEAL INTACT? YES		If Present, Date Client is contacted with result:	
SAMPLE ON ICE? NO		Date: _____	
TEMPERATURE: 7.9 C		Contacted By: _____	
SAMPLE IN COMPLIANCE: YES			



2011 East Main Street, Rochester, NY 14609 Phone (585) 654-9080 Fax (585) 654-9662
Web: LozierEnv.com E-Mail: support@lozierenv.com

Page 5 of 10
70333413

LAB ID: M37025		Company: Lozier Environmental Consulting, Inc.		REPORT TO:		Company: (SAME)		INVOICE TO:	
PROJECT NAME: RCSD - School No. 22		Address: 2011 East Main Street				Address:			
TURNAROUND TIME: Standard Rush		City, State Zip: Rochester NY 14609				City, State Zip:			
Other:		Phone: 585-654-9080		Fax: 585-654-9662		Phone:		Fax:	
		E-Mail: vkaptein@lozierenv.com				Purchase Order #:			

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS				
41	06-01-KI-IN-82F-T7	1/15/2025	7:05		DW			prep	x				
42	06-01-KI-IN-82F-T8	1/15/2025	7:05		DW			hand wash	x				
43	06-01-OF-IN-83-T	1/15/2025	7:07		DW				x				
44	06-01-CR-IN-86-B	1/15/2025	7:10		DW				x				
45	06-01-CR-IN-86-T	1/15/2025	7:10		DW				x				
46	06-01-CR-IN-102-B	1/15/2025	7:13		DW				x				
47	06-01-CR-IN-102-T	1/15/2025	7:13		DW				x				
48	06-01-CR-IN-101-B	1/15/2025	7:14		DW				x				
49	06-01-CR-IN-101-T	1/15/2025	7:22		DW				x				
50	06-01-CR-IN-104-B	1/15/2025	7:26		DW				x				

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # 771456505735)

SAMPLED BY* Joe Savioe

RELINQUISHED BY*: Joe Savioe DATE: 1/15/2025 TIME: _____

RECEIVED BY: Adrian DATE: 1/17/25 TIME: 1200

RELINQUISHED BY*: _____ DATE: _____ TIME: _____

RECEIVED BY: _____ DATE: _____ TIME: _____

RELINQUISHED BY*: _____ DATE: _____ TIME: _____

RECEIVED BY: _____ DATE: _____ TIME: _____

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FOR LAB USE ONLY		FOR POTABLE WATER ONLY:	
PRESERVATIVE/BIOCIDE: HNO3-		COLIFORM BACTERIA:	
TOTAL NUMBER OF CONTAINERS: 92		Present	Absent
CUSTODY SEAL INTACT? YES		If Present, Date Client is contacted with result:	
SAMPLE ON ICE? NO		Date: _____	
TEMPERATURE: 7-9 C		Contacted By: _____	
SAMPLE IN COMPLIANCE: YES			



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 6 of 10
703334173

LAB ID: M37025		Company: Lozier Environmental Consulting, Inc.		REPORT TO:		INVOICE TO:	
PROJECT NAME: RCSD - School No. 22		Address: 2011 East Main Street		City, State Zip: Rochester NY 14609		Company: (SAME)	
TURNAROUND TIME: Standard Rush		Phone: 585-654-9080		Fax: 585-654-9662		City, State Zip:	
Other:		E-Mail: vkaptein@lozierenv.com		Purchase Order #:		Fax:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS			
51	06-01-CR-IN-104-T	1/15/2025	7:27		DW				X			
52	06-01-CR-IN-103-B	1/15/2025	7:29		DW				X			
53	06-01-CR-IN-103-T	1/15/2025	7:29		DW				X			
54	06-01-CR-IN-106-B	1/15/2025	7:31		DW				X			
55	06-01-CR-IN-106-T	1/15/2025	7:31		DW				X			
56	06-01-CR-IN-105-B	1/15/2025	7:32		DW				X			
57	06-01-CR-IN-105-T	1/15/2025	7:33		DW				X			
58	06-01-CR-IN-144-B	1/15/2025	7:36		DW				X			
59	06-01-CR-IN-144-T	1/15/2025	7:36		DW				X			
60	06-01-CR-IN-145-B	1/15/2025	7:42		DW				X			

Container Type (Circle One): Plastic Glass Sterile Other

Delivery (Circle One): Client Drop-Off / Courier (Tracking #

77456505735

SAMPLED BY: Joe Savioe

RELINQUISHED BY: Joe Savioe DATE: 1/15/2025 TIME:

RECEIVED BY: Alvin DATE: 1/15/2025 TIME: 1200

RELINQUISHED BY: DATE: TIME:

RECEIVED BY: DATE: TIME:

RELINQUISHED BY: DATE: TIME:

RECEIVED BY: DATE: TIME:

The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FOR LAB USE ONLY		FOR POTABLE WATER ONLY:	
PRESERVATIVE/BIOCIDE: HNO3-		COLIFORM BACTERIA:	
TOTAL NUMBER OF CONTAINERS: 92		Present	Absent
CUSTODY SEAL INTACT? YES		If Present, Date Client is contacted with result:	
SAMPLE ON ICE? NO		Date: _____	
TEMPERATURE: 7.9 C		Contacted By: _____	
SAMPLE IN COMPLIANCE: YES			



2011 East Main Street, Rochester, NY 14609 Phone (585) 654-9080 Fax (585) 654-9662
Web: LozierEnv.com E-Mail: support@lozierenv.com

Page 1 of 10
70333473

LAB ID: M37025		Company: Lozier Environmental Consulting, Inc.		REPORT TO:		INVOICE TO:	
PROJECT NAME: RCSD - School No. 22		Address: 2011 East Main Street		City/State Zip: Rochester NY 14609		Company: (SAME)	
TURNAROUND TIME: Standard Rush		Phone: 585-654-9080		Fax: 585-654-9662		Address:	
Other:		E-Mail: vkaptein@lozierenv.com		Purchase Order #:		City/State Zip:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS				
61	06-01-CR-IN-145-T	1/15/2025	7:42		DW			Lead					
62	06-01-CR-IN-147-B	1/15/2025	7:46		DW			X					
63	06-01-CR-IN-147-T	1/15/2025	7:46		DW			X					
64	06-01-CR-IN-148-B	1/15/2025	7:48		DW			X					
65	06-01-CR-IN-148-T	1/15/2025	7:48		DW			X					
66	06-01-CR-IN-146-B	1/15/2025	7:50		DW			X					
67	06-01-CR-IN-146-T	1/15/2025	7:50		DW			X					
68	06-01-CR-IN-122-B	1/15/2025	7:53		DW			X					
69	06-01-CR-IN-122-T	1/15/2025	7:53		DW			X					
70	06-02-HA-BY-216-FL	1/15/2025	8:00		DW			X					

Container Type (Circle One): Plastic Glass Sterile Other _____
Delivery (Circle One): Client Drop-Off / Courier (Tracking # 77145650 5735)

SAMPLED BY* Joe Savioe

RELINQUISHED BY* Joe Savioe DATE: 1/15/2025 TIME: _____

RECEIVED BY: *John Han* DATE: 1/17/25 TIME: 12:00

RELINQUISHED BY* DATE: _____ TIME: _____

RECEIVED BY: DATE: _____ TIME: _____

RELINQUISHED BY* DATE: _____ TIME: _____

RECEIVED BY: DATE: _____ TIME: _____

FOR LAB USE ONLY		FOR POTABLE WATER ONLY:	
PRESERVATIVE/BIOCIDES: HNO3-		COLIFORM BACTERIA:	
TOTAL NUMBER OF CONTAINERS: 92		Present	Absent
CUSTODY SEAL INTACT? YES		If Present, Date Client is contacted with result:	
SAMPLE ON ICE? NO		Date: _____	Contacted By: _____
TEMPERATURE: 7.9 C			
SAMPLE IN COMPLIANCE: YES			

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 8 of 10
70333473

LAB ID: M37025
PROJECT NAME: RCSD - School No. 22
TURNAROUND TIME: Standard Rush

Company: Lozier Environmental Consulting, Inc.
Address: 2011 East Main Street
City/State Zip: Rochester NY 14609
Phone: 585-654-9080 Fax: 585-654-9662
E-Mail: vkaptein@lozierenv.com

Company: (SAME)
Address:
City/State Zip:
Phone: Fax:
Purchase Order #:

REPORT TO:

INVOICE TO:

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS			
									Lead			
71	06-02-HA-BY-216-FR	1/15/2025	8:00		DW				x			
72	06-02-HA-BY-216-BF	1/15/2025	8:00		DW				x			
73	06-02-TC-IN-216-B	1/15/2025	8:01		DW				x			
74	06-02-TC-IN-216-T	1/15/2025	8:01		DW				x			
75	06-02-CR-IN-214-B	1/15/2025	8:05		DW				x			
76	06-02-CR-IN-214-T	1/15/2025	8:05		DW				x			
77	06-02-CR-IN-213-B	1/15/2025	8:07		DW				x			
78	06-02-CR-IN-213-T	1/15/2025	8:07		DW				x			
79	06-02-CR-IN-212-B	1/15/2025	8:09		DW				x			
80	06-02-CR-IN-212-T	1/15/2025	8:09		DW				x			


Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # 77145650 5735)

SAMPLED BY*: Joe Savioe
RELINQUISHED BY*: Joe Savioe
RECEIVED BY*: John Hu
RELINQUISHED BY*:
RECEIVED BY: 1/15/2025 DATE: 1/15/2025 TIME: 1200
RELINQUISHED BY*:
RECEIVED BY: DATE: TIME:
RELINQUISHED BY*:
RECEIVED BY: DATE: TIME:

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDE: HNO3-	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINERS: 92	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES	Present Absent
SAMPLE ON ICE? NO	If Present, Date Client is
TEMPERATURE: <u>7.4</u> C	contacted with result:
SAMPLE IN COMPLIANCE: YES	Date: _____
	Contacted By: _____

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 9 of 10
70333473

LAB ID: M37025		Company: Lozier Environmental Consulting, Inc.		REPORT TO:	
PROJECT NAME: RCSD - School No. 22		Address: 2011 East Main Street		Company: (SAME)	
TURNAROUND TIME: Standard Rush		City/State Zip: Rochester NY 14609		Address:	
Other:		Phone: 585-654-9080		City/State Zip:	
		Fax: 585-654-9662		Phone:	
		E-Mail: vkaptein@lozierenv.com		Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS				
81	06-02-CR-IN-210-B	1/15/2025	8:11		DW				x				
82	06-02-CR-IN-210-T	1/15/2025	8:11		DW				x				
83	06-02-CR-IN-206-B	1/15/2025	8:14		DW				x				
84	06-02-CR-IN-206-T	1/15/2025	8:14		DW				x				
85	06-02-CR-IN-204-B	1/15/2025	8:18		DW				x				
86	06-02-CR-IN-204-T	1/15/2025	8:18		DW				x				
87	06-02-CR-IN-203-B	1/15/2025	8:20		DW				x				
88	06-02-CR-IN-203-T	1/15/2025	8:20		DW				x				
89	06-02-CR-IN-201-B	1/15/2025	8:23		DW				x				
90	06-02-CR-IN-201-T	1/15/2025	8:23		DW				x				

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # 7714 5650 5658)

SAMPLED BY: Joe Savioe

RELINQUISHED BY: Joe Savioe DATE: 1/15/2025 TIME: _____

RECEIVED BY: [Signature] DATE: 1/15/25 TIME: 1200

RELINQUISHED BY: _____ DATE: _____ TIME: _____

RECEIVED BY: _____ DATE: _____ TIME: _____

RELINQUISHED BY: _____ DATE: _____ TIME: _____

RECEIVED BY: _____ DATE: _____ TIME: _____

FOR LAB USE ONLY		FOR POTABLE WATER ONLY:	
PRESERVATIVE/BIOCIDE: HNO3-		COLIFORM BACTERIA:	
TOTAL NUMBER OF CONTAINERS: 92		Present	Absent
CUSTODY SEAL INTACT? YES		If Present, Date Client is contacted with result:	
SAMPLE ON ICE? NO		Date: _____	
TEMPERATURE: 7.9 C		Contacted By: _____	
SAMPLE IN COMPLIANCE: YES			

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

2014 Post-Mortem Report Bookmarker NY 14600

[illegible]

Page 10 of 10

Page 46 of 47

		REPORT TO:		INVOICE TO:	
LAB ID: M37025		Company: Lozier Environmental Consulting, Inc.		Company: (SAME)	
PROJECT NAME: RCSD - School No. 22		Address: 2014 East Main Street		Address:	
TURNAROUND TIME: Standard Rush		City, State Zip: Rochester NY 14609		City, State Zip:	
Other:		Phone: 585-654-9080 Fax: 585-654-9662		Phone: Fax:	
		E-Mail: vkaptein@lozierenv.com		Purchase Order #:	

Page 46

[illegible]

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # 11150002070)

SAMPLED BY* Joe Savioe			
RELINQUISHED BY*: Joe SayJoe	DATE: 1/15/2025	TIME:	
RECEIVED BY:	DATE: 1/17/25	TIME: 1200	
RELINQUISHED BY*:	DATE:	TIME:	
RECEIVED BY:	DATE:	TIME:	
RELINQUISHED BY*:	DATE:	TIME:	
RECEIVED BY:	DATE:	TIME:	

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDES: HNO ₃	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINERS: 92	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES	Present Absent
SAMPLE ON ICE? NO	If Present, Date Client is
TEMPERATURE: 7-9°C	contacted with result:
SAMPLE IN COMPLIANCE: YES	Date: _____
	Contacted By: _____

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

WO#: 70333473

Project #

PM: RC1

Due Date: 01/31/25

Client:

CLIENT: NB-LOZIER

Date and Initials of person:

Examining contents:

Label:

Deliver to location:

pH:

Thermometer Used: IRG4

Date: 1/17

Time: 1200

Initials:

State of Origin: NY

Cooler #1 Temp. °C 7.9 (Visual) 0.2 @ 0.0°C -0.5 @ 20.0°C (Correction Factor) (Actual) ☒ Samples on ice, cooling process has begun

Courier: ☒ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☐ Pace ☐ Other

Shipping Method: ☐ First Overnight ☐ Priority Overnight ☐ Standard Overnight ☐ Ground

☐ Other

Tracking #

Custody Seal on Cooler/Box Present: ☐ Yes ☐ No

Seals intact: ☐ Yes ☐ No

Ice: ☒ Wet ☐ Blue ☐ Melted ☐ None

Packing Material: ☐ Bubble Wrap ☐ Bubble Bags ☐ None ☐ Other

Samples were collected by Pace employee ☐ Yes ☐ No ☐ N/A

Comments:

Chain of Custody Present	☒ Yes ☐ No ☐ N/A	
Chain of Custody Filled Out	☒ Yes ☐ No ☐ N/A	
Relinquished Signature on COC	☒ Yes ☐ No ☐ N/A	
Sampler Name and Signature on COC	☒ Yes ☐ No ☐ N/A	
Samples Arrived within Hold Time	☒ Yes ☐ No ☐ N/A	
Rush TAT requested on COC	☐ Yes ☐ No ☐ N/A	
Sufficient Volume	☒ Yes ☐ No ☐ N/A	
Correct Containers Used	☒ Yes ☐ No ☐ N/A	
Containers Intact	☒ Yes ☐ No ☐ N/A	
Sample Labels match COC (sample IDs & date/time of collection)	☒ Yes ☐ No ☐ N/A	
All containers needing acid/base preservation have been checked.	☐ Yes ☐ No ☐ N/A	Preservation Information:
All Containers needing preservation are found to be in compliance with EPA recommendation:	☐ Yes ☐ No ☐ N/A	Preservative: _____
Exceptions: Vials, Microbiology, O&G, Metals		Lot #/Trace #: _____
		Date: _____ Time: _____
		Initials: _____
Headspace in VOA Vials? (>6mm):	☐ Yes ☐ No ☐ N/A	
Trip Blank Present:	☐ Yes ☐ No ☐ N/A	

Additional Login Comments:

Client notification/ Resolution

Person Contacted:

Date/Time:

Comments/Resolution: