



November 21, 2024

Amy Kaptein
Lozier Environmental Consulting, Inc
2011 E. Main St.
Rochester, NY 14609

RE: Project: RCSD- School No.33
Pace Project No.: 70320171

Dear Amy Kaptein:

Enclosed are the analytical results for sample(s) received by the laboratory on November 04, 2024. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Newburgh

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in cursive script that reads "Renee Cusack".

Renee Cusack
renee.cusack@pacelabs.com
(845)562-0890
Project Manager

Enclosures

cc: Amy Pusateri, Lozier Environmental Consulting Inc.



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



CERTIFICATIONS

Project: RCSD- School No.33

Pace Project No.: 70320171

Pace Analytical Services, LLC- Newburgh, NY

315 Fullerton Avenue, Newburgh, NY 12550

New York Certification #: 10142 Primary Accrediting Body

New Jersey Certification #: NY015

Connecticut Certification #: PH-0823

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE SUMMARY

Project: RCSD- School No.33
Pace Project No.: 70320171

Lab ID	Sample ID	Matrix	Date Collected	Date Received
70320171001	33-01-HA-BY-A120-F	Drinking Water	10/24/24 06:15	11/04/24 18:19
70320171002	33-01-HA-BY-A120-BF	Drinking Water	10/24/24 06:15	11/04/24 18:19
70320171003	33-01-CR-IN-A110-B	Drinking Water	10/24/24 06:21	11/04/24 18:19
70320171004	33-01-CR-IN-A110-T	Drinking Water	10/24/24 06:21	11/04/24 18:19
70320171005	33-01-CR-IN-A111-B	Drinking Water	10/24/24 06:24	11/04/24 18:19
70320171006	33-01-CR-IN-A111-T	Drinking Water	10/24/24 06:24	11/04/24 18:19
70320171007	33-01-CR-IN-A112-B	Drinking Water	10/24/24 06:26	11/04/24 18:19
70320171008	33-01-CR-IN-A112-T	Drinking Water	10/24/24 06:26	11/04/24 18:19
70320171009	33-01-CR-IN-A117-T	Drinking Water	10/24/24 06:30	11/04/24 18:19
70320171010	33-01-CR-IN-A118-T	Drinking Water	10/24/24 07:04	11/04/24 18:19
70320171011	33-01-CR-IN-A103-B	Drinking Water	10/24/24 06:35	11/04/24 18:19
70320171012	33-01-CR-IN-A103-T	Drinking Water	10/24/24 06:35	11/04/24 18:19
70320171013	33-01-CR-IN-A104-B	Drinking Water	10/24/24 06:38	11/04/24 18:19
70320171014	33-01-CR-IN-A104-T	Drinking Water	10/24/24 06:38	11/04/24 18:19
70320171015	33-01-CR-IN-A105-T	Drinking Water	10/24/24 06:49	11/04/24 18:19
70320171016	33-01-CR-IN-B104-T	Drinking Water	10/24/24 06:49	11/04/24 18:19
70320171017	33-01-CR-IN-B105-B	Drinking Water	10/24/24 06:52	11/04/24 18:19
70320171018	33-01-CR-IN-B105-T	Drinking Water	10/24/24 06:52	11/04/24 18:19
70320171019	33-01-CR-IN-B102-T	Drinking Water	10/24/24 06:54	11/04/24 18:19
70320171020	33-01-CR-IN-B100-T	Drinking Water	10/24/24 06:55	11/04/24 18:19
70320171021	33-01-HA-BY-B114-F	Drinking Water	10/24/24 06:56	11/04/24 18:19
70320171022	33-01-HA-BY-B114-BF	Drinking Water	10/24/24 06:56	11/04/24 18:19
70320171023	33-01-BT-IN-D114-TL	Drinking Water	10/24/24 07:00	11/04/24 18:19
70320171024	33-01-BT-IN-D114-TR	Drinking Water	10/24/24 07:00	11/04/24 18:19
70320171025	33-01-CR-IN-B116-T	Drinking Water	10/24/24 07:03	11/04/24 18:19
70320171026	33-01-CR-IN-B118-T	Drinking Water	10/24/24 07:04	11/04/24 18:19
70320171027	33-01-CR-IN-B120-T	Drinking Water	10/24/24 07:05	11/04/24 18:19
70320171028	33-01-CR-IN-B121-T	Drinking Water	10/24/24 07:08	11/04/24 18:19
70320171029	33-01-CR-IN-B121-B	Drinking Water	10/24/24 07:10	11/04/24 18:19
70320171030	33-01-NO-IN-H100Q-T	Drinking Water	10/25/24 06:08	11/04/24 18:19
70320171031	33-01-NO-IN-H100P-T	Drinking Water	10/25/24 06:08	11/04/24 18:19
70320171032	33-01-NO-IN-H100K-TL	Drinking Water	10/25/24 06:09	11/04/24 18:19
70320171033	33-01-NO-IN-H100K-TR	Drinking Water	10/25/24 06:11	11/04/24 18:19
70320171034	33-01-NO-IN-H100E-TL	Drinking Water	10/25/24 06:12	11/04/24 18:19
70320171035	33-01-NO-IN-H100E-TR	Drinking Water	10/25/24 06:14	11/04/24 18:19
70320171036	33-01-NO-IN-H100H-T	Drinking Water	10/25/24 06:14	11/04/24 18:19
70320171037	33-01-NO-IN-H100F-T	Drinking Water	10/25/24 06:16	11/04/24 18:19

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE SUMMARY

Project: RCSD- School No.33
Pace Project No.: 70320171

Lab ID	Sample ID	Matrix	Date Collected	Date Received
70320171038	33-01-NO-IN-H100I-T	Drinking Water	10/25/24 06:17	11/04/24 18:19
70320171039	33-01-NO-IN-H100T-T	Drinking Water	10/25/24 06:17	11/04/24 18:19
70320171040	33-01-NO-IN-H100-T	Drinking Water	10/25/24 06:19	11/04/24 18:19
70320171041	33-01-NO-IN-H100U-T	Drinking Water	10/25/24 06:22	11/04/24 18:19
70320171042	33-01-KI-IN-A122-T	Drinking Water	10/25/24 06:32	11/04/24 18:19
70320171043	33-01-HA-BY-D115-F	Drinking Water	10/25/24 06:55	11/04/24 18:19
70320171044	33-01-HA-BY-D115-BF	Drinking Water	10/25/24 06:58	11/04/24 18:19
70320171045	33-02-CR-IN-B207-B	Drinking Water	10/25/24 07:05	11/04/24 18:19
70320171046	33-02-CR-IN-B207-T	Drinking Water	10/25/24 07:06	11/04/24 18:19
70320171047	33-02-CR-IN-B205-B	Drinking Water	10/25/24 07:10	11/04/24 18:19
70320171048	33-02-CR-IN-B205-T	Drinking Water	10/25/24 07:11	11/04/24 18:19
70320171049	33-02-CR-IN-B204-B	Drinking Water	10/29/24 06:10	11/04/24 18:19
70320171050	33-02-CR-IN-B204-T	Drinking Water	10/29/24 06:11	11/04/24 18:19
70320171051	33-02-CR-IN-B202-B	Drinking Water	10/29/24 06:14	11/04/24 18:19
70320171052	33-02-CR-IN-B202-T	Drinking Water	10/29/24 06:15	11/04/24 18:19
70320171053	33-02-CR-IN-B203-B	Drinking Water	10/29/24 06:26	11/04/24 18:19
70320171054	33-02-CR-IN-B203-T	Drinking Water	10/29/24 06:26	11/04/24 18:19
70320171055	33-02-CR-IN-B201-T	Drinking Water	10/29/24 06:28	11/04/24 18:19
70320171056	33-02-CR-IN-B217-B	Drinking Water	10/29/24 06:30	11/04/24 18:19
70320171057	33-02-CR-IN-B217-T	Drinking Water	10/29/24 06:31	11/04/24 18:19
70320171058	33-02-CR-IN-B215-B	Drinking Water	10/29/24 06:34	11/04/24 18:19
70320171059	33-02-CR-IN-B215-T	Drinking Water	10/29/24 06:35	11/04/24 18:19
70320171060	33-02-CR-IN-B218-B	Drinking Water	10/29/24 06:36	11/04/24 18:19
70320171061	33-02-CR-IN-B218-T	Drinking Water	10/29/24 06:36	11/04/24 18:19
70320171062	33-02-CR-IN-B216-B	Drinking Water	10/29/24 06:38	11/04/24 18:19
70320171063	33-02-CR-IN-B216-T	Drinking Water	10/29/24 06:40	11/04/24 18:19
70320171064	33-02-CR-IN-B213-B	Drinking Water	10/29/24 06:42	11/04/24 18:19
70320171065	33-02-CR-IN-B213-T	Drinking Water	10/29/24 06:43	11/04/24 18:19
70320171066	33-02-CR-IN-B211-B	Drinking Water	10/29/24 06:45	11/04/24 18:19
70320171067	33-02-CR-IN-B211-T	Drinking Water	10/29/24 06:46	11/04/24 18:19
70320171068	33-02-KI-IN-B219A-1	Drinking Water	10/29/24 06:49	11/04/24 18:19
70320171069	33-02-KI-IN-B219A-2	Drinking Water	10/29/24 06:49	11/04/24 18:19
70320171070	33-02-KI-IN-B219A-3	Drinking Water	10/29/24 06:50	11/04/24 18:19
70320171071	33-02-KI-IN-B219A-4	Drinking Water	10/29/24 06:50	11/04/24 18:19
70320171072	33-02-KI-IN-B219A-5	Drinking Water	10/29/24 06:51	11/04/24 18:19
70320171073	33-02-KI-IN-B219A-6	Drinking Water	10/29/24 06:52	11/04/24 18:19
70320171074	33-02-KI-IN-B219A-7	Drinking Water	10/29/24 06:53	11/04/24 18:19

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE SUMMARY

Project: RCSD- School No.33

Pace Project No.: 70320171

Lab ID	Sample ID	Matrix	Date Collected	Date Received
70320171075	33-02-KI-IN-B219A-8	Drinking Water	10/29/24 06:54	11/04/24 18:19
70320171076	33-02-CR-IN-A218-T	Drinking Water	10/29/24 06:57	11/04/24 18:19
70320171077	33-02-CR-IN-A215-B	Drinking Water	10/29/24 06:59	11/04/24 18:19
70320171078	33-02-CR-IN-A215-T	Drinking Water	10/29/24 07:00	11/04/24 18:19
70320171079	33-02-CR-IN-A213-B	Drinking Water	10/29/24 07:03	11/04/24 18:19
70320171080	33-02-CR-IN-A213-T	Drinking Water	10/29/24 07:04	11/04/24 18:19
70320171081	33-02-CR-IN-A212-B	Drinking Water	10/29/24 07:06	11/04/24 18:19
70320171082	33-02-CR-IN-A212-T	Drinking Water	10/29/24 07:06	11/04/24 18:19
70320171083	33-02-CR-IN-A211-T	Drinking Water	10/29/24 07:08	11/04/24 18:19
70320171084	33-02-CR-IN-A210-B	Drinking Water	10/29/24 07:10	11/04/24 18:19
70320171085	33-02-CR-IN-A210-T	Drinking Water	10/29/24 07:11	11/04/24 18:19
70320171086	33-02-CR-IN-A200-B	Drinking Water	10/30/24 06:11	11/04/24 18:19
70320171087	33-02-CR-IN-A200-T	Drinking Water	10/30/24 06:11	11/04/24 18:19
70320171088	33-02-CR-IN-A203-B	Drinking Water	10/30/24 06:15	11/04/24 18:19
70320171089	33-02-CR-IN-A203-T	Drinking Water	10/30/24 06:15	11/04/24 18:19
70320171090	33-02-CR-IN-A205-B	Drinking Water	10/30/24 06:18	11/04/24 18:19
70320171091	33-02-CR-IN-A205-T	Drinking Water	10/30/24 06:18	11/04/24 18:19
70320171092	33-02-CR-IN-A206-B	Drinking Water	10/30/24 06:20	11/04/24 18:19
70320171093	33-02-CR-IN-A206-T	Drinking Water	10/30/24 06:20	11/04/24 18:19
70320171094	33-02-CR-IN-A207-B	Drinking Water	10/30/24 06:23	11/04/24 18:19
70320171095	33-02-CR-IN-A207-T	Drinking Water	10/30/24 06:23	11/04/24 18:19
70320171096	33-02-CR-IN-A208-B	Drinking Water	10/30/24 06:26	11/04/24 18:19
70320171097	33-02-CR-IN-A208-T	Drinking Water	10/30/24 06:26	11/04/24 18:19
70320171098	33-03-CR-IN-B323-B	Drinking Water	10/30/24 06:30	11/04/24 18:19
70320171099	33-03-CR-IN-B323-T	Drinking Water	10/30/24 06:30	11/04/24 18:19
70320171100	33-03-CR-IN-B321-B	Drinking Water	10/30/24 06:34	11/04/24 18:19
70320171101	33-03-CR-IN-B321-T	Drinking Water	10/30/24 06:34	11/04/24 18:19
70320171102	33-03-CR-IN-B322-B	Drinking Water	10/30/24 06:38	11/04/24 18:19
70320171103	33-03-CR-IN-B322-T	Drinking Water	10/30/24 06:38	11/04/24 18:19
70320171104	33-03-CR-IN-B320-B	Drinking Water	10/30/24 06:41	11/04/24 18:19
70320171105	33-03-CR-IN-B320-T	Drinking Water	10/30/24 06:41	11/04/24 18:19
70320171106	33-03-CR-IN-B319-B	Drinking Water	10/30/24 06:44	11/04/24 18:19
70320171107	33-03-CR-IN-B319-T	Drinking Water	10/30/24 06:47	11/04/24 18:19
70320171108	33-03-CR-IN-B317-B	Drinking Water	10/30/24 06:50	11/04/24 18:19
70320171109	33-03-CR-IN-B317-T	Drinking Water	10/30/24 06:50	11/04/24 18:19
70320171110	33-03-HA-BY-B315-F	Drinking Water	10/30/24 06:55	11/04/24 18:19
70320171111	33-03-HA-BY-B315-BF	Drinking Water	10/30/24 06:55	11/04/24 18:19

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE SUMMARY

Project: RCSD- School No.33

Pace Project No.: 70320171

Lab ID	Sample ID	Matrix	Date Collected	Date Received
70320171112	33-03-HA-BY-B312-B	Drinking Water	10/30/24 06:58	11/04/24 18:19
70320171113	33-03-CR-IN-B312-T	Drinking Water	10/30/24 06:58	11/04/24 18:19
70320171114	33-03-CR-IN-B310-B	Drinking Water	10/30/24 07:00	11/04/24 18:19
70320171115	33-03-CR-IN-B310-T	Drinking Water	10/30/24 07:00	11/04/24 18:19
70320171116	33-03-CR-IN-B307-B	Drinking Water	10/30/24 07:03	11/04/24 18:19
70320171117	33-03-CR-IN-B307-T	Drinking Water	10/30/24 07:03	11/04/24 18:19
70320171118	33-03-CR-IN-B305-B	Drinking Water	10/30/24 07:06	11/04/24 18:19
70320171119	33-03-CR-IN-B305-T	Drinking Water	10/30/24 07:06	11/04/24 18:19
70320171120	33-03-CR-IN-B304-B	Drinking Water	10/30/24 07:09	11/04/24 18:19
70320171121	33-03-CR-IN-B304-T	Drinking Water	10/30/24 07:09	11/04/24 18:19
70320171122	33-03-CR-IN-B302-B	Drinking Water	10/30/24 07:11	11/04/24 18:19
70320171123	33-03-CR-IN-B302-T	Drinking Water	10/30/24 07:11	11/04/24 18:19
70320171124	33-03-CR-IN-B303-B	Drinking Water	10/30/24 07:13	11/04/24 18:19
70320171125	33-03-CR-IN-B303-T	Drinking Water	10/30/24 07:13	11/04/24 18:19
70320171126	33-03-CR-IN-B301-B	Drinking Water	10/30/24 07:15	11/04/24 18:19
70320171127	33-03-CR-IN-B301-T	Drinking Water	10/30/24 07:15	11/04/24 18:19
70320171128	33-03-CR-IN-A302-T	Drinking Water	10/31/24 06:09	11/04/24 18:19
70320171129	33-03-CR-IN-A306-B	Drinking Water	10/31/24 06:12	11/04/24 18:19
70320171130	33-03-CR-IN-A306-T	Drinking Water	10/31/24 06:12	11/04/24 18:19
70320171131	33-03-CR-IN-A307-B	Drinking Water	10/31/24 06:14	11/04/24 18:19
70320171132	33-03-CR-IN-A307-T	Drinking Water	10/31/24 06:14	11/04/24 18:19
70320171133	33-03-CR-IN-A308-B	Drinking Water	10/31/24 06:17	11/04/24 18:19
70320171134	33-03-CR-IN-A308-T	Drinking Water	10/31/24 06:17	11/04/24 18:19
70320171135	33-03-CR-IN-A309-B	Drinking Water	10/31/24 06:20	11/04/24 18:19
70320171136	33-03-CR-IN-A309-T	Drinking Water	10/31/24 06:20	11/04/24 18:19
70320171137	33-03-CR-IN-A310-B	Drinking Water	10/31/24 06:22	11/04/24 18:19
70320171138	33-03-CR-IN-A310-T	Drinking Water	10/31/24 06:23	11/04/24 18:19
70320171139	33-03-CR-IN-A311-B	Drinking Water	10/31/24 06:23	11/04/24 18:19
70320171140	33-03-CR-IN-A311-T	Drinking Water	10/31/24 06:26	11/04/24 18:19
70320171141	33-03-CR-IN-A312-B	Drinking Water	10/31/24 06:26	11/04/24 18:19
70320171142	33-03-CR-IN-A312-T	Drinking Water	10/31/24 06:26	11/04/24 18:19
70320171143	33-03-CR-IN-A313-B	Drinking Water	10/31/24 06:29	11/04/24 18:19
70320171144	33-03-CR-IN-A313-T	Drinking Water	10/31/24 06:29	11/04/24 18:19
70320171145	33-03-CR-IN-A314-B	Drinking Water	10/31/24 06:32	11/04/24 18:19
70320171146	33-03-CR-IN-A314-T	Drinking Water	10/31/24 06:32	11/04/24 18:19
70320171147	33-03-CR-IN-A319-B	Drinking Water	10/31/24 06:35	11/04/24 18:19
70320171148	33-03-CR-IN-A319-T	Drinking Water	10/31/24 06:35	11/04/24 18:19

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE SUMMARY

Project: RCSD- School No.33

Pace Project No.: 70320171

Lab ID	Sample ID	Matrix	Date Collected	Date Received
70320171149	33-03-CR-IN-A320-B	Drinking Water	10/31/24 06:38	11/04/24 18:19
70320171150	33-03-CR-IN-A320-T	Drinking Water	10/31/24 06:38	11/04/24 18:19

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE ANALYTE COUNT

Project: RCSD- School No.33
Pace Project No.: 70320171

Lab ID	Sample ID	Method	Analysts	Analytes Reported
70320171001	33-01-HA-BY-A120-F	EPA 200.8, Rev. 5.4	JC1	1
70320171002	33-01-HA-BY-A120-BF	EPA 200.8, Rev. 5.4	JC1	1
70320171003	33-01-CR-IN-A110-B	EPA 200.8, Rev. 5.4	JC1	1
70320171004	33-01-CR-IN-A110-T	EPA 200.8, Rev. 5.4	JC1	1
70320171005	33-01-CR-IN-A111-B	EPA 200.8, Rev. 5.4	JC1	1
70320171006	33-01-CR-IN-A111-T	EPA 200.8, Rev. 5.4	JC1	1
70320171007	33-01-CR-IN-A112-B	EPA 200.8, Rev. 5.4	JC1	1
70320171008	33-01-CR-IN-A112-T	EPA 200.8, Rev. 5.4	JC1	1
70320171009	33-01-CR-IN-A117-T	EPA 200.8, Rev. 5.4	JC1	1
70320171010	33-01-CR-IN-A118-T	EPA 200.8, Rev. 5.4	JC1	1
70320171011	33-01-CR-IN-A103-B	EPA 200.8, Rev. 5.4	JC1	1
70320171012	33-01-CR-IN-A103-T	EPA 200.8, Rev. 5.4	JC1	1
70320171013	33-01-CR-IN-A104-B	EPA 200.8, Rev. 5.4	JC1	1
70320171014	33-01-CR-IN-A104-T	EPA 200.8, Rev. 5.4	JC1	1
70320171015	33-01-CR-IN-A105-T	EPA 200.8, Rev. 5.4	JC1	1
70320171016	33-01-CR-IN-B104-T	EPA 200.8, Rev. 5.4	JC1	1
70320171017	33-01-CR-IN-B105-B	EPA 200.8, Rev. 5.4	JC1	1
70320171018	33-01-CR-IN-B105-T	EPA 200.8, Rev. 5.4	JC1	1
70320171019	33-01-CR-IN-B102-T	EPA 200.8, Rev. 5.4	JC1	1
70320171020	33-01-CR-IN-B100-T	EPA 200.8, Rev. 5.4	JC1	1
70320171021	33-01-HA-BY-B114-F	EPA 200.8, Rev. 5.4	JC1	1
70320171022	33-01-HA-BY-B114-BF	EPA 200.8, Rev. 5.4	JC1	1
70320171023	33-01-BT-IN-D114-TL	EPA 200.8, Rev. 5.4	JC1	1
70320171024	33-01-BT-IN-D114-TR	EPA 200.8, Rev. 5.4	JC1	1
70320171025	33-01-CR-IN-B116-T	EPA 200.8, Rev. 5.4	JC1	1
70320171026	33-01-CR-IN-B118-T	EPA 200.8, Rev. 5.4	JC1	1
70320171027	33-01-CR-IN-B120-T	EPA 200.8, Rev. 5.4	JC1	1
70320171028	33-01-CR-IN-B121-T	EPA 200.8, Rev. 5.4	JC1	1
70320171029	33-01-CR-IN-B121-B	EPA 200.8, Rev. 5.4	JC1	1
70320171030	33-01-NO-IN-H100Q-T	EPA 200.8, Rev. 5.4	JC1	1
70320171031	33-01-NO-IN-H100P-T	EPA 200.8, Rev. 5.4	JC1	1
70320171032	33-01-NO-IN-H100K-TL	EPA 200.8, Rev. 5.4	JC1	1
70320171033	33-01-NO-IN-H100K-TR	EPA 200.8, Rev. 5.4	JC1	1
70320171034	33-01-NO-IN-H100E-TL	EPA 200.8, Rev. 5.4	JC1	1
70320171035	33-01-NO-IN-H100E-TR	EPA 200.8, Rev. 5.4	JC1	1
70320171036	33-01-NO-IN-H100H-T	EPA 200.8, Rev. 5.4	JC1	1
70320171037	33-01-NO-IN-H100F-T	EPA 200.8, Rev. 5.4	JC1	1

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE ANALYTE COUNT

Project: RCSD- School No.33
Pace Project No.: 70320171

Lab ID	Sample ID	Method	Analysts	Analytes Reported
70320171038	33-01-NO-IN-H100I-T	EPA 200.8, Rev. 5.4	JC1	1
70320171039	33-01-NO-IN-H100T-T	EPA 200.8, Rev. 5.4	JC1	1
70320171040	33-01-NO-IN-H100-T	EPA 200.8, Rev. 5.4	JC1	1
70320171041	33-01-NO-IN-H100U-T	EPA 200.8, Rev. 5.4	JC1	1
70320171042	33-01-KI-IN-A122-T	EPA 200.8, Rev. 5.4	JC1	1
70320171043	33-01-HA-BY-D115-F	EPA 200.8, Rev. 5.4	JC1	1
70320171044	33-01-HA-BY-D115-BF	EPA 200.8, Rev. 5.4	JC1	1
70320171045	33-02-CR-IN-B207-B	EPA 200.8, Rev. 5.4	JC1	1
70320171046	33-02-CR-IN-B207-T	EPA 200.8, Rev. 5.4	JC1	1
70320171047	33-02-CR-IN-B205-B	EPA 200.8, Rev. 5.4	JC1	1
70320171048	33-02-CR-IN-B205-T	EPA 200.8, Rev. 5.4	JC1	1
70320171049	33-02-CR-IN-B204-B	EPA 200.8, Rev. 5.4	JC1	1
70320171050	33-02-CR-IN-B204-T	EPA 200.8, Rev. 5.4	JC1	1
70320171051	33-02-CR-IN-B202-B	EPA 200.8, Rev. 5.4	JC1	1
70320171052	33-02-CR-IN-B202-T	EPA 200.8, Rev. 5.4	JC1	1
70320171053	33-02-CR-IN-B203-B	EPA 200.8, Rev. 5.4	JC1	1
70320171054	33-02-CR-IN-B203-T	EPA 200.8, Rev. 5.4	JC1	1
70320171055	33-02-CR-IN-B201-T	EPA 200.8, Rev. 5.4	JC1	1
70320171056	33-02-CR-IN-B217-B	EPA 200.8, Rev. 5.4	JC1	1
70320171057	33-02-CR-IN-B217-T	EPA 200.8, Rev. 5.4	JC1	1
70320171058	33-02-CR-IN-B215-B	EPA 200.8, Rev. 5.4	JC1	1
70320171059	33-02-CR-IN-B215-T	EPA 200.8, Rev. 5.4	JC1	1
70320171060	33-02-CR-IN-B218-B	EPA 200.8, Rev. 5.4	JC1	1
70320171061	33-02-CR-IN-B218-T	EPA 200.8, Rev. 5.4	JC1	1
70320171062	33-02-CR-IN-B216-B	EPA 200.8, Rev. 5.4	JC1	1
70320171063	33-02-CR-IN-B216-T	EPA 200.8, Rev. 5.4	JC1	1
70320171064	33-02-CR-IN-B213-B	EPA 200.8, Rev. 5.4	JC1	1
70320171065	33-02-CR-IN-B213-T	EPA 200.8, Rev. 5.4	JC1	1
70320171066	33-02-CR-IN-B211-B	EPA 200.8, Rev. 5.4	JC1	1
70320171067	33-02-CR-IN-B211-T	EPA 200.8, Rev. 5.4	JC1	1
70320171068	33-02-KI-IN-B219A-1	EPA 200.8, Rev. 5.4	JC1	1
70320171069	33-02-KI-IN-B219A-2	EPA 200.8, Rev. 5.4	JC1	1
70320171070	33-02-KI-IN-B219A-3	EPA 200.8, Rev. 5.4	JC1	1
70320171071	33-02-KI-IN-B219A-4	EPA 200.8, Rev. 5.4	JC1	1
70320171072	33-02-KI-IN-B219A-5	EPA 200.8, Rev. 5.4	JC1	1
70320171073	33-02-KI-IN-B219A-6	EPA 200.8, Rev. 5.4	JC1	1
70320171074	33-02-KI-IN-B219A-7	EPA 200.8, Rev. 5.4	JC1	1

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE ANALYTE COUNT

Project: RCSD- School No.33

Pace Project No.: 70320171

Lab ID	Sample ID	Method	Analysts	Analytes Reported
70320171075	33-02-KI-IN-B219A-8	EPA 200.8, Rev. 5.4	JC1	1
70320171076	33-02-CR-IN-A218-T	EPA 200.8, Rev. 5.4	JC1	1
70320171077	33-02-CR-IN-A215-B	EPA 200.8, Rev. 5.4	JC1	1
70320171078	33-02-CR-IN-A215-T	EPA 200.8, Rev. 5.4	JC1	1
70320171079	33-02-CR-IN-A213-B	EPA 200.8, Rev. 5.4	JC1	1
70320171080	33-02-CR-IN-A213-T	EPA 200.8, Rev. 5.4	JC1	1
70320171081	33-02-CR-IN-A212-B	EPA 200.8, Rev. 5.4	JC1	1
70320171082	33-02-CR-IN-A212-T	EPA 200.8, Rev. 5.4	JC1	1
70320171083	33-02-CR-IN-A211-T	EPA 200.8, Rev. 5.4	JC1	1
70320171084	33-02-CR-IN-A210-B	EPA 200.8, Rev. 5.4	JC1	1
70320171085	33-02-CR-IN-A210-T	EPA 200.8, Rev. 5.4	JC1	1
70320171086	33-02-CR-IN-A200-B	EPA 200.8, Rev. 5.4	JC1	1
70320171087	33-02-CR-IN-A200-T	EPA 200.8, Rev. 5.4	JC1	1
70320171088	33-02-CR-IN-A203-B	EPA 200.8, Rev. 5.4	JC1	1
70320171089	33-02-CR-IN-A203-T	EPA 200.8, Rev. 5.4	JC1	1
70320171090	33-02-CR-IN-A205-B	EPA 200.8, Rev. 5.4	JC1	1
70320171091	33-02-CR-IN-A205-T	EPA 200.8, Rev. 5.4	JC1	1
70320171092	33-02-CR-IN-A206-B	EPA 200.8, Rev. 5.4	JC1	1
70320171093	33-02-CR-IN-A206-T	EPA 200.8, Rev. 5.4	JC1	1
70320171094	33-02-CR-IN-A207-B	EPA 200.8, Rev. 5.4	JC1	1
70320171095	33-02-CR-IN-A207-T	EPA 200.8, Rev. 5.4	JC1	1
70320171096	33-02-CR-IN-A208-B	EPA 200.8, Rev. 5.4	JC1	1
70320171097	33-02-CR-IN-A208-T	EPA 200.8, Rev. 5.4	JC1	1
70320171098	33-03-CR-IN-B323-B	EPA 200.8, Rev. 5.4	JC1	1
70320171099	33-03-CR-IN-B323-T	EPA 200.8, Rev. 5.4	JC1	1
70320171100	33-03-CR-IN-B321-B	EPA 200.8, Rev. 5.4	JC1	1
70320171101	33-03-CR-IN-B321-T	EPA 200.8, Rev. 5.4	JC1	1
70320171102	33-03-CR-IN-B322-B	EPA 200.8, Rev. 5.4	JC1	1
70320171103	33-03-CR-IN-B322-T	EPA 200.8, Rev. 5.4	JC1	1
70320171104	33-03-CR-IN-B320-B	EPA 200.8, Rev. 5.4	JC1	1
70320171105	33-03-CR-IN-B320-T	EPA 200.8, Rev. 5.4	JC1	1
70320171106	33-03-CR-IN-B319-B	EPA 200.8, Rev. 5.4	JC1	1
70320171107	33-03-CR-IN-B319-T	EPA 200.8, Rev. 5.4	JC1	1
70320171108	33-03-CR-IN-B317-B	EPA 200.8, Rev. 5.4	JC1	1
70320171109	33-03-CR-IN-B317-T	EPA 200.8, Rev. 5.4	JC1	1
70320171110	33-03-HA-BY-B315-F	EPA 200.8, Rev. 5.4	JC1	1
70320171111	33-03-HA-BY-B315-BF	EPA 200.8, Rev. 5.4	JC1	1

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE ANALYTE COUNT

Project: RCSD- School No.33
Pace Project No.: 70320171

Lab ID	Sample ID	Method	Analysts	Analytes Reported
70320171112	33-03-HA-BY-B312-B	EPA 200.8, Rev. 5.4	JC1	1
70320171113	33-03-CR-IN-B312-T	EPA 200.8, Rev. 5.4	JC1	1
70320171114	33-03-CR-IN-B310-B	EPA 200.8, Rev. 5.4	JC1	1
70320171115	33-03-CR-IN-B310-T	EPA 200.8, Rev. 5.4	JC1	1
70320171116	33-03-CR-IN-B307-B	EPA 200.8, Rev. 5.4	JC1	1
70320171117	33-03-CR-IN-B307-T	EPA 200.8, Rev. 5.4	JC1	1
70320171118	33-03-CR-IN-B305-B	EPA 200.8, Rev. 5.4	JC1	1
70320171119	33-03-CR-IN-B305-T	EPA 200.8, Rev. 5.4	JC1	1
70320171120	33-03-CR-IN-B304-B	EPA 200.8, Rev. 5.4	JC1	1
70320171121	33-03-CR-IN-B304-T	EPA 200.8, Rev. 5.4	JC1	1
70320171122	33-03-CR-IN-B302-B	EPA 200.8, Rev. 5.4	JC1	1
70320171123	33-03-CR-IN-B302-T	EPA 200.8, Rev. 5.4	JC1	1
70320171124	33-03-CR-IN-B303-B	EPA 200.8, Rev. 5.4	JC1	1
70320171125	33-03-CR-IN-B303-T	EPA 200.8, Rev. 5.4	JC1	1
70320171126	33-03-CR-IN-B301-B	EPA 200.8, Rev. 5.4	JC1	1
70320171127	33-03-CR-IN-B301-T	EPA 200.8, Rev. 5.4	JC1	1
70320171128	33-03-CR-IN-A302-T	EPA 200.8, Rev. 5.4	JC1	1
70320171129	33-03-CR-IN-A306-B	EPA 200.8, Rev. 5.4	JC1	1
70320171130	33-03-CR-IN-A306-T	EPA 200.8, Rev. 5.4	JC1	1
70320171131	33-03-CR-IN-A307-B	EPA 200.8, Rev. 5.4	JC1	1
70320171132	33-03-CR-IN-A307-T	EPA 200.8, Rev. 5.4	JC1	1
70320171133	33-03-CR-IN-A308-B	EPA 200.8, Rev. 5.4	JC1	1
70320171134	33-03-CR-IN-A308-T	EPA 200.8, Rev. 5.4	JC1	1
70320171135	33-03-CR-IN-A309-B	EPA 200.8, Rev. 5.4	JC1	1
70320171136	33-03-CR-IN-A309-T	EPA 200.8, Rev. 5.4	JC1	1
70320171137	33-03-CR-IN-A310-B	EPA 200.8, Rev. 5.4	JC1	1
70320171138	33-03-CR-IN-A310-T	EPA 200.8, Rev. 5.4	JC1	1
70320171139	33-03-CR-IN-A311-B	EPA 200.8, Rev. 5.4	JC1	1
70320171140	33-03-CR-IN-A311-T	EPA 200.8, Rev. 5.4	JC1	1
70320171141	33-03-CR-IN-A312-B	EPA 200.8, Rev. 5.4	JC1	1
70320171142	33-03-CR-IN-A312-T	EPA 200.8, Rev. 5.4	JC1	1
70320171143	33-03-CR-IN-A313-B	EPA 200.8, Rev. 5.4	JC1	1
70320171144	33-03-CR-IN-A313-T	EPA 200.8, Rev. 5.4	JC1	1
70320171145	33-03-CR-IN-A314-B	EPA 200.8, Rev. 5.4	JC1	1
70320171146	33-03-CR-IN-A314-T	EPA 200.8, Rev. 5.4	JC1	1
70320171147	33-03-CR-IN-A319-B	EPA 200.8, Rev. 5.4	JC1	1
70320171148	33-03-CR-IN-A319-T	EPA 200.8, Rev. 5.4	JC1	1

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE ANALYTE COUNT

Project: RCSD- School No.33

Pace Project No.: 70320171

Lab ID	Sample ID	Method	Analysts	Analytes Reported
70320171149	33-03-CR-IN-A320-B	EPA 200.8, Rev. 5.4	JC1	1
70320171150	33-03-CR-IN-A320-T	EPA 200.8, Rev. 5.4	JC1	1

PASI-NB = Pace Analytical Services - Newburgh

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



PROJECT NARRATIVE

Project: RCSD- School No.33
Pace Project No.: 70320171

Method: EPA 200.8, Rev. 5.4
Description: NB 200.8 ICPMS DW No Prep
Client: Lozier Environmental Consulting, Inc.
Date: November 21, 2024

General Information:

150 samples were analyzed for EPA 200.8, Rev. 5.4 by Pace Analytical Services Newburgh. All samples were received in acceptable condition with any exceptions noted below or on the chain-of custody and/or the sample condition upon receipt form (SCUR) attached at the end of this report.

Hold Time:

The samples were analyzed within the method required hold times with any exceptions noted below.

Initial Calibrations (including MS Tune as applicable):

All criteria were within method requirements with any exceptions noted below.

Continuing Calibration:

All criteria were within method requirements with any exceptions noted below.

Internal Standards:

All internal standards were within QC limits with any exceptions noted below.

Surrogates:

All surrogates were within QC limits with any exceptions noted below.

Method Blank:

All analytes were below the report limit in the method blank, where applicable, with any exceptions noted below.

Laboratory Control Spike:

All laboratory control spike compounds were within QC limits with any exceptions noted below.

Matrix Spikes:

All percent recoveries and relative percent differences (RPDs) were within acceptance criteria with any exceptions noted below.

Duplicate Sample:

All duplicate sample results were within method acceptance criteria with any exceptions noted below.

Additional Comments:

This data package has been reviewed for quality and completeness and is approved for release.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD- School No.33

Pace Project No.: 70320171

Sample: 33-01-HA-BY-A120-F Lab ID: 70320171001 Collected: 10/24/24 06:15 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		11/11/24 13:22	7439-92-1	

Sample: 33-01-HA-BY-A120-BF Lab ID: 70320171002 Collected: 10/24/24 06:15 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		11/11/24 13:27	7439-92-1	

Sample: 33-01-CR-IN-A110-B Lab ID: 70320171003 Collected: 10/24/24 06:21 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	1.6	ug/L	1.0	15	1		11/11/24 13:29	7439-92-1	

Sample: 33-01-CR-IN-A110-T Lab ID: 70320171004 Collected: 10/24/24 06:21 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	9.0	ug/L	1.0	15	1		11/11/24 13:30	7439-92-1	

Sample: 33-01-CR-IN-A111-B Lab ID: 70320171005 Collected: 10/24/24 06:24 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	2.4	ug/L	1.0	15	1		11/11/24 13:34	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD- School No.33

Pace Project No.: 70320171

Sample: 33-01-CR-IN-A111-T		Lab ID: 70320171006		Collected: 10/24/24 06:24		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		11/11/24 13:36	7439-92-1	
Sample: 33-01-CR-IN-A112-B		Lab ID: 70320171007		Collected: 10/24/24 06:26		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	1.1	ug/L	1.0	15	1		11/11/24 13:37	7439-92-1	
Sample: 33-01-CR-IN-A112-T		Lab ID: 70320171008		Collected: 10/24/24 06:26		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	1.4	ug/L	1.0	15	1		11/11/24 13:39	7439-92-1	
Sample: 33-01-CR-IN-A117-T		Lab ID: 70320171009		Collected: 10/24/24 06:30		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	16.4	ug/L	1.0	15	1		11/11/24 13:40	7439-92-1	
Sample: 33-01-CR-IN-A118-T		Lab ID: 70320171010		Collected: 10/24/24 07:04		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	4.8	ug/L	1.0	15	1		11/11/24 13:41	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD- School No.33

Pace Project No.: 70320171

Sample: 33-01-CR-IN-A103-B		Lab ID: 70320171011		Collected: 10/24/24 06:35		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	2.4	ug/L	1.0	15	1		11/11/24 13:43	7439-92-1	
Sample: 33-01-CR-IN-A103-T		Lab ID: 70320171012		Collected: 10/24/24 06:35		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	6.3	ug/L	1.0	15	1		11/11/24 13:46	7439-92-1	
Sample: 33-01-CR-IN-A104-B		Lab ID: 70320171013		Collected: 10/24/24 06:38		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		11/11/24 13:47	7439-92-1	
Sample: 33-01-CR-IN-A104-T		Lab ID: 70320171014		Collected: 10/24/24 06:38		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	2.2	ug/L	1.0	15	1		11/11/24 13:51	7439-92-1	
Sample: 33-01-CR-IN-A105-T		Lab ID: 70320171015		Collected: 10/24/24 06:49		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	4.5	ug/L	1.0	15	1		11/11/24 13:53	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD- School No.33

Pace Project No.: 70320171

Sample: 33-01-CR-IN-B104-T		Lab ID: 70320171016		Collected: 10/24/24 06:49		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		11/11/24 13:54	7439-92-1	
Sample: 33-01-CR-IN-B105-B		Lab ID: 70320171017		Collected: 10/24/24 06:52		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	1.3	ug/L	1.0	15	1		11/11/24 13:56	7439-92-1	
Sample: 33-01-CR-IN-B105-T		Lab ID: 70320171018		Collected: 10/24/24 06:52		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	2.6	ug/L	1.0	15	1		11/11/24 13:57	7439-92-1	
Sample: 33-01-CR-IN-B102-T		Lab ID: 70320171019		Collected: 10/24/24 06:54		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	3.1	ug/L	1.0	15	1		11/11/24 13:58	7439-92-1	
Sample: 33-01-CR-IN-B100-T		Lab ID: 70320171020		Collected: 10/24/24 06:55		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		11/11/24 14:00	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD- School No.33

Pace Project No.: 70320171

Sample: 33-01-HA-BY-B114-F Lab ID: 70320171021 Collected: 10/24/24 06:56 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		11/11/24 14:01	7439-92-1	

Sample: 33-01-HA-BY-B114-BF Lab ID: 70320171022 Collected: 10/24/24 06:56 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		11/11/24 14:10	7439-92-1	

Sample: 33-01-BT-IN-D114-TL Lab ID: 70320171023 Collected: 10/24/24 07:00 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	4.6	ug/L	1.0	15	1		11/11/24 14:11	7439-92-1	

Sample: 33-01-BT-IN-D114-TR Lab ID: 70320171024 Collected: 10/24/24 07:00 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	1.7	ug/L	1.0	15	1		11/11/24 14:13	7439-92-1	

Sample: 33-01-CR-IN-B116-T Lab ID: 70320171025 Collected: 10/24/24 07:03 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	3.2	ug/L	1.0	15	1		11/11/24 14:14	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD- School No.33

Pace Project No.: 70320171

Sample: 33-01-CR-IN-B118-T		Lab ID: 70320171026		Collected: 10/24/24 07:04		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	7.2	ug/L	1.0	15	1		11/11/24 14:15	7439-92-1	
Sample: 33-01-CR-IN-B120-T		Lab ID: 70320171027		Collected: 10/24/24 07:05		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	5.5	ug/L	1.0	15	1		11/11/24 14:17	7439-92-1	
Sample: 33-01-CR-IN-B121-T		Lab ID: 70320171028		Collected: 10/24/24 07:08		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	2.3	ug/L	1.0	15	1		11/11/24 14:18	7439-92-1	
Sample: 33-01-CR-IN-B121-B		Lab ID: 70320171029		Collected: 10/24/24 07:10		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	4.0	ug/L	1.0	15	1		11/11/24 14:20	7439-92-1	
Sample: 33-01-NO-IN-H100Q-T		Lab ID: 70320171030		Collected: 10/25/24 06:08		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	1.1	ug/L	1.0	15	1		11/11/24 14:21	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD- School No.33

Pace Project No.: 70320171

Sample: 33-01-NO-IN-H100P-T		Lab ID: 70320171031		Collected: 10/25/24 06:08		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	6.6	ug/L	1.0	15	1		11/11/24 14:25	7439-92-1	
Sample: 33-01-NO-IN-H100K-TL		Lab ID: 70320171032		Collected: 10/25/24 06:09		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	1.1	ug/L	1.0	15	1		11/11/24 14:28	7439-92-1	
Sample: 33-01-NO-IN-H100K-TR		Lab ID: 70320171033		Collected: 10/25/24 06:11		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	2.1	ug/L	1.0	15	1		11/11/24 14:30	7439-92-1	
Sample: 33-01-NO-IN-H100E-TL		Lab ID: 70320171034		Collected: 10/25/24 06:12		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	2.6	ug/L	1.0	15	1		11/11/24 14:31	7439-92-1	
Sample: 33-01-NO-IN-H100E-TR		Lab ID: 70320171035		Collected: 10/25/24 06:14		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	4.9	ug/L	1.0	15	1		11/11/24 14:32	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD- School No.33

Pace Project No.: 70320171

Sample: 33-01-NO-IN-H100H-T		Lab ID: 70320171036		Collected: 10/25/24 06:14		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	3.2	ug/L	1.0	15	1		11/11/24 14:34	7439-92-1	
Sample: 33-01-NO-IN-H100F-T		Lab ID: 70320171037		Collected: 10/25/24 06:16		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	4.0	ug/L	1.0	15	1		11/11/24 14:35	7439-92-1	
Sample: 33-01-NO-IN-H100I-T		Lab ID: 70320171038		Collected: 10/25/24 06:17		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	10.2	ug/L	1.0	15	1		11/11/24 14:37	7439-92-1	
Sample: 33-01-NO-IN-H100T-T		Lab ID: 70320171039		Collected: 10/25/24 06:17		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	2.1	ug/L	1.0	15	1		11/11/24 14:38	7439-92-1	
Sample: 33-01-NO-IN-H100-T		Lab ID: 70320171040		Collected: 10/25/24 06:19		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	1.5	ug/L	1.0	15	1		11/11/24 14:42	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD- School No.33

Pace Project No.: 70320171

Sample: 33-01-NO-IN-H100U-T		Lab ID: 70320171041		Collected: 10/25/24 06:22		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	3.5	ug/L	1.0	15	1		11/11/24 14:44	7439-92-1	
Sample: 33-01-KI-IN-A122-T		Lab ID: 70320171042		Collected: 10/25/24 06:32		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	46.3	ug/L	1.0	15	1		11/11/24 14:49	7439-92-1	
Sample: 33-01-HA-BY-D115-F		Lab ID: 70320171043		Collected: 10/25/24 06:55		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		11/11/24 14:51	7439-92-1	
Sample: 33-01-HA-BY-D115-BF		Lab ID: 70320171044		Collected: 10/25/24 06:58		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		11/11/24 14:52	7439-92-1	
Sample: 33-02-CR-IN-B207-B		Lab ID: 70320171045		Collected: 10/25/24 07:05		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		11/11/24 14:53	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD- School No.33

Pace Project No.: 70320171

Sample: 33-02-CR-IN-B207-T		Lab ID: 70320171046		Collected: 10/25/24 07:06		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	1.8	ug/L	1.0	15	1		11/11/24 14:55	7439-92-1	
Sample: 33-02-CR-IN-B205-B		Lab ID: 70320171047		Collected: 10/25/24 07:10		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		11/11/24 14:59	7439-92-1	
Sample: 33-02-CR-IN-B205-T		Lab ID: 70320171048		Collected: 10/25/24 07:11		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	1.3	ug/L	1.0	15	1		11/11/24 15:01	7439-92-1	
Sample: 33-02-CR-IN-B204-B		Lab ID: 70320171049		Collected: 10/29/24 06:10		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		11/11/24 15:02	7439-92-1	
Sample: 33-02-CR-IN-B204-T		Lab ID: 70320171050		Collected: 10/29/24 06:11		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	2.8	ug/L	1.0	15	1		11/11/24 15:03	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD- School No.33

Pace Project No.: 70320171

Sample: 33-02-CR-IN-B202-B Lab ID: 70320171051 Collected: 10/29/24 06:14 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		11/11/24 15:05	7439-92-1	

Sample: 33-02-CR-IN-B202-T Lab ID: 70320171052 Collected: 10/29/24 06:15 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	1.1	ug/L	1.0	15	1		11/11/24 15:07	7439-92-1	

Sample: 33-02-CR-IN-B203-B Lab ID: 70320171053 Collected: 10/29/24 06:26 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		11/11/24 15:09	7439-92-1	

Sample: 33-02-CR-IN-B203-T Lab ID: 70320171054 Collected: 10/29/24 06:26 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	1.4	ug/L	1.0	15	1		11/11/24 15:10	7439-92-1	

Sample: 33-02-CR-IN-B201-T Lab ID: 70320171055 Collected: 10/29/24 06:28 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	3.0	ug/L	1.0	15	1		11/11/24 15:12	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD- School No.33

Pace Project No.: 70320171

Sample: 33-02-CR-IN-B217-B		Lab ID: 70320171056		Collected: 10/29/24 06:30		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	3.0	ug/L	1.0	15	1		11/11/24 15:16	7439-92-1	
Sample: 33-02-CR-IN-B217-T		Lab ID: 70320171057		Collected: 10/29/24 06:31		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	6.7	ug/L	1.0	15	1		11/11/24 15:17	7439-92-1	
Sample: 33-02-CR-IN-B215-B		Lab ID: 70320171058		Collected: 10/29/24 06:34		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	1.2	ug/L	1.0	15	1		11/11/24 15:19	7439-92-1	
Sample: 33-02-CR-IN-B215-T		Lab ID: 70320171059		Collected: 10/29/24 06:35		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	1.1	ug/L	1.0	15	1		11/11/24 15:20	7439-92-1	
Sample: 33-02-CR-IN-B218-B		Lab ID: 70320171060		Collected: 10/29/24 06:36		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	1.2	ug/L	1.0	15	1		11/11/24 15:21	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD- School No.33

Pace Project No.: 70320171

Sample: 33-02-CR-IN-B218-T Lab ID: 70320171061 Collected: 10/29/24 06:36 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	2.0	ug/L	1.0	15	1		11/11/24 15:23	7439-92-1	

Sample: 33-02-CR-IN-B216-B Lab ID: 70320171062 Collected: 10/29/24 06:38 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		11/11/24 15:28	7439-92-1	

Sample: 33-02-CR-IN-B216-T Lab ID: 70320171063 Collected: 10/29/24 06:40 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	3.9	ug/L	1.0	15	1		11/11/24 15:33	7439-92-1	

Sample: 33-02-CR-IN-B213-B Lab ID: 70320171064 Collected: 10/29/24 06:42 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	1.5	ug/L	1.0	15	1		11/11/24 15:34	7439-92-1	

Sample: 33-02-CR-IN-B213-T Lab ID: 70320171065 Collected: 10/29/24 06:43 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	3.1	ug/L	1.0	15	1		11/11/24 15:36	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD- School No.33

Pace Project No.: 70320171

Sample: 33-02-CR-IN-B211-B **Lab ID:** 70320171066 **Collected:** 10/29/24 06:45 **Received:** 11/04/24 18:19 **Matrix:** Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		11/11/24 15:37	7439-92-1	

Sample: 33-02-CR-IN-B211-T **Lab ID:** 70320171067 **Collected:** 10/29/24 06:46 **Received:** 11/04/24 18:19 **Matrix:** Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh									
Lead	2.1	ug/L	1.0	15	1		11/11/24 15:38	7439-92-1	

Sample: 33-02-KI-IN-B219A-1 **Lab ID:** 70320171068 **Collected:** 10/29/24 06:49 **Received:** 11/04/24 18:19 **Matrix:** Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh									
Lead	1.0	ug/L	1.0	15	1		11/11/24 15:40	7439-92-1	

Sample: 33-02-KI-IN-B219A-2 **Lab ID:** 70320171069 **Collected:** 10/29/24 06:49 **Received:** 11/04/24 18:19 **Matrix:** Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh									
Lead	10.5	ug/L	1.0	15	1		11/11/24 15:41	7439-92-1	

Sample: 33-02-KI-IN-B219A-3 **Lab ID:** 70320171070 **Collected:** 10/29/24 06:50 **Received:** 11/04/24 18:19 **Matrix:** Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		11/11/24 15:43	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD- School No.33

Pace Project No.: 70320171

Sample: 33-02-KI-IN-B219A-4 Lab ID: 70320171071 Collected: 10/29/24 06:50 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		11/11/24 15:44	7439-92-1	

Sample: 33-02-KI-IN-B219A-5 Lab ID: 70320171072 Collected: 10/29/24 06:51 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	1.9	ug/L	1.0	15	1		11/11/24 15:50	7439-92-1	

Sample: 33-02-KI-IN-B219A-6 Lab ID: 70320171073 Collected: 10/29/24 06:52 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	4.4	ug/L	1.0	15	1		11/11/24 15:51	7439-92-1	

Sample: 33-02-KI-IN-B219A-7 Lab ID: 70320171074 Collected: 10/29/24 06:53 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		11/11/24 15:52	7439-92-1	

Sample: 33-02-KI-IN-B219A-8 Lab ID: 70320171075 Collected: 10/29/24 06:54 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		11/11/24 15:54	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD- School No.33

Pace Project No.: 70320171

Sample: 33-02-CR-IN-A218-T		Lab ID: 70320171076		Collected: 10/29/24 06:57		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	1.9	ug/L	1.0	15	1		11/11/24 15:55	7439-92-1	
Sample: 33-02-CR-IN-A215-B		Lab ID: 70320171077		Collected: 10/29/24 06:59		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		11/11/24 15:57	7439-92-1	
Sample: 33-02-CR-IN-A215-T		Lab ID: 70320171078		Collected: 10/29/24 07:00		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	2.7	ug/L	1.0	15	1		11/11/24 15:58	7439-92-1	
Sample: 33-02-CR-IN-A213-B		Lab ID: 70320171079		Collected: 10/29/24 07:03		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		11/11/24 15:59	7439-92-1	
Sample: 33-02-CR-IN-A213-T		Lab ID: 70320171080		Collected: 10/29/24 07:04		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	3.0	ug/L	1.0	15	1		11/11/24 16:01	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD- School No.33

Pace Project No.: 70320171

Sample: 33-02-CR-IN-A212-B Lab ID: 70320171081 Collected: 10/29/24 07:06 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		11/11/24 16:02	7439-92-1	

Sample: 33-02-CR-IN-A212-T Lab ID: 70320171082 Collected: 10/29/24 07:06 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	1.2	ug/L	1.0	15	1		11/11/24 16:11	7439-92-1	

Sample: 33-02-CR-IN-A211-T Lab ID: 70320171083 Collected: 10/29/24 07:08 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	4.3	ug/L	1.0	15	1		11/11/24 16:12	7439-92-1	

Sample: 33-02-CR-IN-A210-B Lab ID: 70320171084 Collected: 10/29/24 07:10 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	4.5	ug/L	1.0	15	1		11/11/24 16:13	7439-92-1	

Sample: 33-02-CR-IN-A210-T Lab ID: 70320171085 Collected: 10/29/24 07:11 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	23.7	ug/L	1.0	15	1		11/11/24 16:15	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD- School No.33

Pace Project No.: 70320171

Sample: 33-02-CR-IN-A200-B		Lab ID: 70320171086		Collected: 10/30/24 06:11		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	4.2	ug/L	1.0	15	1		11/11/24 16:16	7439-92-1	
Sample: 33-02-CR-IN-A200-T		Lab ID: 70320171087		Collected: 10/30/24 06:11		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	10	ug/L	1.0	15	1		11/11/24 16:18	7439-92-1	
Sample: 33-02-CR-IN-A203-B		Lab ID: 70320171088		Collected: 10/30/24 06:15		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	1.2	ug/L	1.0	15	1		11/11/24 16:19	7439-92-1	
Sample: 33-02-CR-IN-A203-T		Lab ID: 70320171089		Collected: 10/30/24 06:15		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	2.4	ug/L	1.0	15	1		11/11/24 16:23	7439-92-1	
Sample: 33-02-CR-IN-A205-B		Lab ID: 70320171090		Collected: 10/30/24 06:18		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	2.2	ug/L	1.0	15	1		11/11/24 16:25	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD- School No.33

Pace Project No.: 70320171

Sample: 33-02-CR-IN-A205-T		Lab ID: 70320171091		Collected: 10/30/24 06:18		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	9.3	ug/L	1.0	15	1		11/11/24 16:26	7439-92-1	
Sample: 33-02-CR-IN-A206-B		Lab ID: 70320171092		Collected: 10/30/24 06:20		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	1.2	ug/L	1.0	15	1		11/11/24 16:29	7439-92-1	
Sample: 33-02-CR-IN-A206-T		Lab ID: 70320171093		Collected: 10/30/24 06:20		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	2.3	ug/L	1.0	15	1		11/11/24 16:30	7439-92-1	
Sample: 33-02-CR-IN-A207-B		Lab ID: 70320171094		Collected: 10/30/24 06:23		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	1.3	ug/L	1.0	15	1		11/11/24 16:32	7439-92-1	
Sample: 33-02-CR-IN-A207-T		Lab ID: 70320171095		Collected: 10/30/24 06:23		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	2.5	ug/L	1.0	15	1		11/11/24 16:33	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD- School No.33

Pace Project No.: 70320171

Sample: 33-02-CR-IN-A208-B		Lab ID: 70320171096		Collected: 10/30/24 06:26		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	3.5	ug/L	1.0	15	1		11/11/24 16:34	7439-92-1	
Sample: 33-02-CR-IN-A208-T		Lab ID: 70320171097		Collected: 10/30/24 06:26		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	4.2	ug/L	1.0	15	1		11/11/24 16:36	7439-92-1	
Sample: 33-03-CR-IN-B323-B		Lab ID: 70320171098		Collected: 10/30/24 06:30		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	2.8	ug/L	1.0	15	1		11/11/24 16:40	7439-92-1	
Sample: 33-03-CR-IN-B323-T		Lab ID: 70320171099		Collected: 10/30/24 06:30		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	3.5	ug/L	1.0	15	1		11/11/24 16:42	7439-92-1	
Sample: 33-03-CR-IN-B321-B		Lab ID: 70320171100		Collected: 10/30/24 06:34		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	2.0	ug/L	1.0	15	1		11/11/24 16:43	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD- School No.33

Pace Project No.: 70320171

Sample: 33-03-CR-IN-B321-T		Lab ID: 70320171101		Collected: 10/30/24 06:34		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	1.2	ug/L	1.0	15	1		11/11/24 16:45	7439-92-1	
Sample: 33-03-CR-IN-B322-B		Lab ID: 70320171102		Collected: 10/30/24 06:38		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	1.7	ug/L	1.0	15	1		11/11/24 16:50	7439-92-1	
Sample: 33-03-CR-IN-B322-T		Lab ID: 70320171103		Collected: 10/30/24 06:38		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	2.0	ug/L	1.0	15	1		11/11/24 16:52	7439-92-1	
Sample: 33-03-CR-IN-B320-B		Lab ID: 70320171104		Collected: 10/30/24 06:41		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		11/11/24 16:53	7439-92-1	
Sample: 33-03-CR-IN-B320-T		Lab ID: 70320171105		Collected: 10/30/24 06:41		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	1.3	ug/L	1.0	15	1		11/11/24 16:57	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD- School No.33

Pace Project No.: 70320171

Sample: 33-03-CR-IN-B319-B Lab ID: 70320171106 Collected: 10/30/24 06:44 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	1.1	ug/L	1.0	15	1		11/11/24 16:59	7439-92-1	

Sample: 33-03-CR-IN-B319-T Lab ID: 70320171107 Collected: 10/30/24 06:47 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	1.9	ug/L	1.0	15	1		11/11/24 17:00	7439-92-1	

Sample: 33-03-CR-IN-B317-B Lab ID: 70320171108 Collected: 10/30/24 06:50 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		11/11/24 17:01	7439-92-1	

Sample: 33-03-CR-IN-B317-T Lab ID: 70320171109 Collected: 10/30/24 06:50 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	2.0	ug/L	1.0	15	1		11/11/24 17:03	7439-92-1	

Sample: 33-03-HA-BY-B315-F Lab ID: 70320171110 Collected: 10/30/24 06:55 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		11/11/24 17:04	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD- School No.33

Pace Project No.: 70320171

Sample: 33-03-HA-BY-B315-BF Lab ID: 70320171111 Collected: 10/30/24 06:55 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		11/11/24 17:06	7439-92-1	

Sample: 33-03-HA-BY-B312-B Lab ID: 70320171112 Collected: 10/30/24 06:58 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	2.9	ug/L	1.0	15	1		11/11/24 17:09	7439-92-1	

Sample: 33-03-CR-IN-B312-T Lab ID: 70320171113 Collected: 10/30/24 06:58 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	3.5	ug/L	1.0	15	1		11/11/24 17:10	7439-92-1	

Sample: 33-03-CR-IN-B310-B Lab ID: 70320171114 Collected: 10/30/24 07:00 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	3.1	ug/L	1.0	15	1		11/11/24 17:14	7439-92-1	

Sample: 33-03-CR-IN-B310-T Lab ID: 70320171115 Collected: 10/30/24 07:00 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	3.7	ug/L	1.0	15	1		11/11/24 17:16	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD- School No.33

Pace Project No.: 70320171

Sample: 33-03-CR-IN-B307-B Lab ID: 70320171116 Collected: 10/30/24 07:03 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		11/11/24 17:17	7439-92-1	

Sample: 33-03-CR-IN-B307-T Lab ID: 70320171117 Collected: 10/30/24 07:03 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		11/11/24 17:18	7439-92-1	

Sample: 33-03-CR-IN-B305-B Lab ID: 70320171118 Collected: 10/30/24 07:06 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		11/11/24 17:20	7439-92-1	

Sample: 33-03-CR-IN-B305-T Lab ID: 70320171119 Collected: 10/30/24 07:06 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	1.4	ug/L	1.0	15	1		11/11/24 17:21	7439-92-1	

Sample: 33-03-CR-IN-B304-B Lab ID: 70320171120 Collected: 10/30/24 07:09 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		11/11/24 17:23	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD- School No.33

Pace Project No.: 70320171

Sample: 33-03-CR-IN-B304-T		Lab ID: 70320171121		Collected: 10/30/24 07:09		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		11/11/24 17:24	7439-92-1	
Sample: 33-03-CR-IN-B302-B		Lab ID: 70320171122		Collected: 10/30/24 07:11		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	1.2	ug/L	1.0	15	1		11/11/24 17:33	7439-92-1	
Sample: 33-03-CR-IN-B302-T		Lab ID: 70320171123		Collected: 10/30/24 07:11		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	1.5	ug/L	1.0	15	1		11/11/24 17:34	7439-92-1	
Sample: 33-03-CR-IN-B303-B		Lab ID: 70320171124		Collected: 10/30/24 07:13		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		11/11/24 17:35	7439-92-1	
Sample: 33-03-CR-IN-B303-T		Lab ID: 70320171125		Collected: 10/30/24 07:13		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	1.0	ug/L	1.0	15	1		11/11/24 17:37	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD- School No.33

Pace Project No.: 70320171

Sample: 33-03-CR-IN-B301-B		Lab ID: 70320171126		Collected: 10/30/24 07:15		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	1.0	ug/L	1.0	15	1		11/11/24 17:38	7439-92-1	
Sample: 33-03-CR-IN-B301-T		Lab ID: 70320171127		Collected: 10/30/24 07:15		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	1.3	ug/L	1.0	15	1		11/11/24 17:40	7439-92-1	
Sample: 33-03-CR-IN-A302-T		Lab ID: 70320171128		Collected: 10/31/24 06:09		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	4.9	ug/L	1.0	15	1		11/11/24 17:41	7439-92-1	
Sample: 33-03-CR-IN-A306-B		Lab ID: 70320171129		Collected: 10/31/24 06:12		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	6.9	ug/L	1.0	15	1		11/11/24 17:42	7439-92-1	
Sample: 33-03-CR-IN-A306-T		Lab ID: 70320171130		Collected: 10/31/24 06:12		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	8.5	ug/L	1.0	15	1		11/11/24 17:44	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD- School No.33

Pace Project No.: 70320171

Sample: 33-03-CR-IN-A307-B		Lab ID: 70320171131		Collected: 10/31/24 06:14		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	1.2	ug/L	1.0	15	1		11/11/24 17:48	7439-92-1	
Sample: 33-03-CR-IN-A307-T		Lab ID: 70320171132		Collected: 10/31/24 06:14		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	2.6	ug/L	1.0	15	1		11/11/24 17:51	7439-92-1	
Sample: 33-03-CR-IN-A308-B		Lab ID: 70320171133		Collected: 10/31/24 06:17		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	3.5	ug/L	1.0	15	1		11/11/24 17:52	7439-92-1	
Sample: 33-03-CR-IN-A308-T		Lab ID: 70320171134		Collected: 10/31/24 06:17		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	4.5	ug/L	1.0	15	1		11/11/24 17:54	7439-92-1	
Sample: 33-03-CR-IN-A309-B		Lab ID: 70320171135		Collected: 10/31/24 06:20		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	5.1	ug/L	1.0	15	1		11/11/24 17:55	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD- School No.33

Pace Project No.: 70320171

Sample: 33-03-CR-IN-A309-T		Lab ID: 70320171136		Collected: 10/31/24 06:20		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	5.7	ug/L	1.0	15	1		11/11/24 17:57	7439-92-1	
Sample: 33-03-CR-IN-A310-B		Lab ID: 70320171137		Collected: 10/31/24 06:22		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	2.7	ug/L	1.0	15	1		11/11/24 17:58	7439-92-1	
Sample: 33-03-CR-IN-A310-T		Lab ID: 70320171138		Collected: 10/31/24 06:23		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	7.1	ug/L	1.0	15	1		11/11/24 17:59	7439-92-1	
Sample: 33-03-CR-IN-A311-B		Lab ID: 70320171139		Collected: 10/31/24 06:23		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	1.0	ug/L	1.0	15	1		11/11/24 18:01	7439-92-1	
Sample: 33-03-CR-IN-A311-T		Lab ID: 70320171140		Collected: 10/31/24 06:26		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	3.6	ug/L	1.0	15	1		11/11/24 18:05	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD- School No.33

Pace Project No.: 70320171

Sample: 33-03-CR-IN-A312-B		Lab ID: 70320171141		Collected: 10/31/24 06:26		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	1.6	ug/L	1.0	15	1		11/11/24 18:07	7439-92-1	
Sample: 33-03-CR-IN-A312-T		Lab ID: 70320171142		Collected: 10/31/24 06:26		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	2.2	ug/L	1.0	15	1		11/11/24 18:12	7439-92-1	
Sample: 33-03-CR-IN-A313-B		Lab ID: 70320171143		Collected: 10/31/24 06:29		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	1.4	ug/L	1.0	15	1		11/11/24 18:14	7439-92-1	
Sample: 33-03-CR-IN-A313-T		Lab ID: 70320171144		Collected: 10/31/24 06:29		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	2.5	ug/L	1.0	15	1		11/11/24 18:15	7439-92-1	
Sample: 33-03-CR-IN-A314-B		Lab ID: 70320171145		Collected: 10/31/24 06:32		Received: 11/04/24 18:19		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		11/11/24 18:17	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD- School No.33

Pace Project No.: 70320171

Sample: 33-03-CR-IN-A314-T Lab ID: 70320171146 Collected: 10/31/24 06:32 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		11/11/24 18:18	7439-92-1	

Sample: 33-03-CR-IN-A319-B Lab ID: 70320171147 Collected: 10/31/24 06:35 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	1.8	ug/L	1.0	15	1		11/11/24 18:22	7439-92-1	

Sample: 33-03-CR-IN-A319-T Lab ID: 70320171148 Collected: 10/31/24 06:35 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	2.4	ug/L	1.0	15	1		11/11/24 18:24	7439-92-1	

Sample: 33-03-CR-IN-A320-B Lab ID: 70320171149 Collected: 10/31/24 06:38 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	1.8	ug/L	1.0	15	1		11/11/24 18:25	7439-92-1	

Sample: 33-03-CR-IN-A320-T Lab ID: 70320171150 Collected: 10/31/24 06:38 Received: 11/04/24 18:19 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	3.7	ug/L	1.0	15	1		11/11/24 18:27	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: RCSD- School No.33
Pace Project No.: 70320171

QC Batch:	369656	Analysis Method:	EPA 200.8, Rev. 5.4
QC Batch Method:	EPA 200.8, Rev. 5.4	Analysis Description:	NB 200.8 ICPMS DW No Prep
		Laboratory:	Pace Analytical Services - Newburgh
Associated Lab Samples:	70320171001, 70320171002, 70320171003, 70320171004, 70320171005, 70320171006, 70320171007, 70320171008, 70320171009, 70320171010, 70320171011, 70320171012, 70320171013, 70320171014, 70320171015, 70320171016, 70320171017, 70320171018, 70320171019, 70320171020		

METHOD BLANK:	1932131	Matrix:	Water
Associated Lab Samples:	70320171001, 70320171002, 70320171003, 70320171004, 70320171005, 70320171006, 70320171007, 70320171008, 70320171009, 70320171010, 70320171011, 70320171012, 70320171013, 70320171014, 70320171015, 70320171016, 70320171017, 70320171018, 70320171019, 70320171020		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	11/11/24 13:19	

LABORATORY CONTROL SAMPLE:	1932132					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	54.7	109	85-115	

MATRIX SPIKE SAMPLE:		1932134					
		70320171001	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	59.2	118	70-130	

MATRIX SPIKE SAMPLE:	1932136						
		70320171011	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	2.4	50	61.6	118	70-130	

SAMPLE DUPLICATE:	1932133					
Parameter	Units	70320171001 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: RCSD- School No.33
Pace Project No.: 70320171

QC Batch:	369657	Analysis Method:	EPA 200.8, Rev. 5.4
QC Batch Method:	EPA 200.8, Rev. 5.4	Analysis Description:	NB 200.8 ICPMS DW No Prep
		Laboratory:	Pace Analytical Services - Newburgh
Associated Lab Samples:	70320171021, 70320171022, 70320171023, 70320171024, 70320171025, 70320171026, 70320171027, 70320171028, 70320171029, 70320171030, 70320171031, 70320171032, 70320171033, 70320171034, 70320171035, 70320171036, 70320171037, 70320171038, 70320171039, 70320171040		

METHOD BLANK:	1932137	Matrix:	Water
Associated Lab Samples:	70320171021, 70320171022, 70320171023, 70320171024, 70320171025, 70320171026, 70320171027, 70320171028, 70320171029, 70320171030, 70320171031, 70320171032, 70320171033, 70320171034, 70320171035, 70320171036, 70320171037, 70320171038, 70320171039, 70320171040		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	11/11/24 13:19	

LABORATORY CONTROL SAMPLE:	1932138					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	54.7	109	85-115	

MATRIX SPIKE SAMPLE:		1932140					
		70320171021	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	55.9	112	70-130	

MATRIX SPIKE SAMPLE:		1932142					
		70320171031	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	6.6	50	61.9	110	70-130	

SAMPLE DUPLICATE:	1932139					
Parameter	Units	70320171021 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: RCSD- School No.33
Pace Project No.: 70320171

QC Batch:	369658	Analysis Method:	EPA 200.8, Rev. 5.4
QC Batch Method:	EPA 200.8, Rev. 5.4	Analysis Description:	NB 200.8 ICPMS DW No Prep
		Laboratory:	Pace Analytical Services - Newburgh
Associated Lab Samples:	70320171041, 70320171042, 70320171043, 70320171044, 70320171045, 70320171046, 70320171047, 70320171048, 70320171049, 70320171050, 70320171051, 70320171052, 70320171053, 70320171054, 70320171055, 70320171056, 70320171057, 70320171058, 70320171059, 70320171060		

METHOD BLANK:	1932143	Matrix:	Water
Associated Lab Samples:	70320171041, 70320171042, 70320171043, 70320171044, 70320171045, 70320171046, 70320171047, 70320171048, 70320171049, 70320171050, 70320171051, 70320171052, 70320171053, 70320171054, 70320171055, 70320171056, 70320171057, 70320171058, 70320171059, 70320171060		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	11/11/24 13:19	

LABORATORY CONTROL SAMPLE:	1932144					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	54.7	109	85-115	

MATRIX SPIKE SAMPLE:		1932146					
		70320171041	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	3.5	50	58.0	109	70-130	

MATRIX SPIKE SAMPLE:	1932148						
		70320171051	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	57.0	112	70-130	

SAMPLE DUPLICATE:	1932145					
Parameter	Units	70320171041 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	3.5	3.5	1	20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: RCSD- School No.33
Pace Project No.: 70320171

QC Batch:	369842	Analysis Method:	EPA 200.8, Rev. 5.4
QC Batch Method:	EPA 200.8, Rev. 5.4	Analysis Description:	NB 200.8 ICPMS DW No Prep
		Laboratory:	Pace Analytical Services - Newburgh
Associated Lab Samples:	70320171061, 70320171062, 70320171063, 70320171064, 70320171065, 70320171066, 70320171067, 70320171068, 70320171069, 70320171070, 70320171071, 70320171072, 70320171073, 70320171074, 70320171075, 70320171076, 70320171077, 70320171078, 70320171079, 70320171080		

METHOD BLANK:	1932986	Matrix:	Water
Associated Lab Samples:	70320171061, 70320171062, 70320171063, 70320171064, 70320171065, 70320171066, 70320171067, 70320171068, 70320171069, 70320171070, 70320171071, 70320171072, 70320171073, 70320171074, 70320171075, 70320171076, 70320171077, 70320171078, 70320171079, 70320171080		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	11/11/24 13:19	

LABORATORY CONTROL SAMPLE:	1932987					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	54.7	109	85-115	

MATRIX SPIKE SAMPLE:		1932989					
		70320171061	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	2.0	50	57.8	111	70-130	

MATRIX SPIKE SAMPLE:		1932991					
		70320171071	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	53.1	106	70-130	

SAMPLE DUPLICATE:	1932988					
Parameter	Units	70320171061 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	2.0	2.0	1	20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: RCSD- School No.33
Pace Project No.: 70320171

QC Batch:	369843	Analysis Method:	EPA 200.8, Rev. 5.4
QC Batch Method:	EPA 200.8, Rev. 5.4	Analysis Description:	NB 200.8 ICPMS DW No Prep
		Laboratory:	Pace Analytical Services - Newburgh
Associated Lab Samples:	70320171081, 70320171082, 70320171083, 70320171084, 70320171085, 70320171086, 70320171087, 70320171088, 70320171089, 70320171090, 70320171091, 70320171092, 70320171093, 70320171094, 70320171095, 70320171096, 70320171097, 70320171098, 70320171099, 70320171100		

METHOD BLANK:	1932992	Matrix:	Water
Associated Lab Samples:	70320171081, 70320171082, 70320171083, 70320171084, 70320171085, 70320171086, 70320171087, 70320171088, 70320171089, 70320171090, 70320171091, 70320171092, 70320171093, 70320171094, 70320171095, 70320171096, 70320171097, 70320171098, 70320171099, 70320171100		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	11/11/24 13:19	

LABORATORY CONTROL SAMPLE:	1932993					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	54.7	109	85-115	

MATRIX SPIKE SAMPLE:		1932995					
		70320171081	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	55.4	110	70-130	

MATRIX SPIKE SAMPLE:		1932998					
		70320171091	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	9.3	50	63.7	109	70-130	

SAMPLE DUPLICATE:	1932994					
Parameter	Units	70320171081 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: RCSD- School No.33
Pace Project No.: 70320171

QC Batch:	369846	Analysis Method:	EPA 200.8, Rev. 5.4
QC Batch Method:	EPA 200.8, Rev. 5.4	Analysis Description:	NB 200.8 ICPMS DW No Prep
		Laboratory:	Pace Analytical Services - Newburgh
Associated Lab Samples:	70320171101, 70320171102, 70320171103, 70320171104, 70320171105, 70320171106, 70320171107, 70320171108, 70320171109, 70320171110, 70320171111, 70320171112, 70320171113, 70320171114, 70320171115, 70320171116, 70320171117, 70320171118, 70320171119, 70320171120		

METHOD BLANK:	1933008	Matrix:	Water
Associated Lab Samples:	70320171101, 70320171102, 70320171103, 70320171104, 70320171105, 70320171106, 70320171107, 70320171108, 70320171109, 70320171110, 70320171111, 70320171112, 70320171113, 70320171114, 70320171115, 70320171116, 70320171117, 70320171118, 70320171119, 70320171120		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	11/11/24 13:19	

LABORATORY CONTROL SAMPLE:	1933009					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	54.7	109	85-115	

MATRIX SPIKE SAMPLE:		1933011					
		70320171101	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	1.2	50	55.3	108	70-130	

MATRIX SPIKE SAMPLE:		1933013					
		70320171111	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	54.3	108	70-130	

SAMPLE DUPLICATE:	1933010					
Parameter	Units	70320171101 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	1.2	1.3	4	20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: RCSD- School No.33
Pace Project No.: 70320171

QC Batch:	369879	Analysis Method:	EPA 200.8, Rev. 5.4
QC Batch Method:	EPA 200.8, Rev. 5.4	Analysis Description:	NB 200.8 ICPMS DW No Prep
		Laboratory:	Pace Analytical Services - Newburgh
Associated Lab Samples:	70320171121, 70320171122, 70320171123, 70320171124, 70320171125, 70320171126, 70320171127, 70320171128, 70320171129, 70320171130, 70320171131, 70320171132, 70320171133, 70320171134, 70320171135, 70320171136, 70320171137, 70320171138, 70320171139, 70320171140		

METHOD BLANK:	1933152	Matrix:	Water
Associated Lab Samples:	70320171121, 70320171122, 70320171123, 70320171124, 70320171125, 70320171126, 70320171127, 70320171128, 70320171129, 70320171130, 70320171131, 70320171132, 70320171133, 70320171134, 70320171135, 70320171136, 70320171137, 70320171138, 70320171139, 70320171140		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	11/11/24 13:19	

LABORATORY CONTROL SAMPLE:	1933153					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	54.7	109	85-115	

MATRIX SPIKE SAMPLE:		1933155					
		70320171121	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	55.7	110	70-130	

MATRIX SPIKE SAMPLE:	1933157						
		70320171131	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	1.2	50	56.0	110	70-130	

SAMPLE DUPLICATE:	1933154					
Parameter	Units	70320171121 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: RCSD- School No.33

Pace Project No.: 70320171

QC Batch:	369880	Analysis Method:	EPA 200.8, Rev. 5.4
QC Batch Method:	EPA 200.8, Rev. 5.4	Analysis Description:	NB 200.8 ICPMS DW No Prep
		Laboratory:	Pace Analytical Services - Newburgh
Associated Lab Samples:	70320171141, 70320171142, 70320171143, 70320171144, 70320171145, 70320171146, 70320171147, 70320171148, 70320171149, 70320171150		

METHOD BLANK:	1933172	Matrix:	Water
Associated Lab Samples:	70320171141, 70320171142, 70320171143, 70320171144, 70320171145, 70320171146, 70320171147, 70320171148, 70320171149, 70320171150		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	11/11/24 13:19	

LABORATORY CONTROL SAMPLE:	1933173					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	54.7	109	85-115	

MATRIX SPIKE SAMPLE:	1933175						
Parameter	Units	70320171141 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.6	50	55.2	107	70-130	

SAMPLE DUPLICATE: 1933174						
		70320171141	Dup		Max	
Parameter	Units	Result	Result	RPD	RPD	Qualifiers
Lead	ug/L	1.6	1.6	1	20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALIFIERS

Project: RCSD- School No.33
Pace Project No.: 70320171

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: RCSD- School No.33

Pace Project No.: 70320171

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70320171001	33-01-HA-BY-A120-F	EPA 200.8, Rev. 5.4	369656		
70320171002	33-01-HA-BY-A120-BF	EPA 200.8, Rev. 5.4	369656		
70320171003	33-01-CR-IN-A110-B	EPA 200.8, Rev. 5.4	369656		
70320171004	33-01-CR-IN-A110-T	EPA 200.8, Rev. 5.4	369656		
70320171005	33-01-CR-IN-A111-B	EPA 200.8, Rev. 5.4	369656		
70320171006	33-01-CR-IN-A111-T	EPA 200.8, Rev. 5.4	369656		
70320171007	33-01-CR-IN-A112-B	EPA 200.8, Rev. 5.4	369656		
70320171008	33-01-CR-IN-A112-T	EPA 200.8, Rev. 5.4	369656		
70320171009	33-01-CR-IN-A117-T	EPA 200.8, Rev. 5.4	369656		
70320171010	33-01-CR-IN-A118-T	EPA 200.8, Rev. 5.4	369656		
70320171011	33-01-CR-IN-A103-B	EPA 200.8, Rev. 5.4	369656		
70320171012	33-01-CR-IN-A103-T	EPA 200.8, Rev. 5.4	369656		
70320171013	33-01-CR-IN-A104-B	EPA 200.8, Rev. 5.4	369656		
70320171014	33-01-CR-IN-A104-T	EPA 200.8, Rev. 5.4	369656		
70320171015	33-01-CR-IN-A105-T	EPA 200.8, Rev. 5.4	369656		
70320171016	33-01-CR-IN-B104-T	EPA 200.8, Rev. 5.4	369656		
70320171017	33-01-CR-IN-B105-B	EPA 200.8, Rev. 5.4	369656		
70320171018	33-01-CR-IN-B105-T	EPA 200.8, Rev. 5.4	369656		
70320171019	33-01-CR-IN-B102-T	EPA 200.8, Rev. 5.4	369656		
70320171020	33-01-CR-IN-B100-T	EPA 200.8, Rev. 5.4	369656		
70320171021	33-01-HA-BY-B114-F	EPA 200.8, Rev. 5.4	369657		
70320171022	33-01-HA-BY-B114-BF	EPA 200.8, Rev. 5.4	369657		
70320171023	33-01-BT-IN-D114-TL	EPA 200.8, Rev. 5.4	369657		
70320171024	33-01-BT-IN-D114-TR	EPA 200.8, Rev. 5.4	369657		
70320171025	33-01-CR-IN-B116-T	EPA 200.8, Rev. 5.4	369657		
70320171026	33-01-CR-IN-B118-T	EPA 200.8, Rev. 5.4	369657		
70320171027	33-01-CR-IN-B120-T	EPA 200.8, Rev. 5.4	369657		
70320171028	33-01-CR-IN-B121-T	EPA 200.8, Rev. 5.4	369657		
70320171029	33-01-CR-IN-B121-B	EPA 200.8, Rev. 5.4	369657		
70320171030	33-01-NO-IN-H100Q-T	EPA 200.8, Rev. 5.4	369657		
70320171031	33-01-NO-IN-H100P-T	EPA 200.8, Rev. 5.4	369657		
70320171032	33-01-NO-IN-H100K-TL	EPA 200.8, Rev. 5.4	369657		
70320171033	33-01-NO-IN-H100K-TR	EPA 200.8, Rev. 5.4	369657		
70320171034	33-01-NO-IN-H100E-TL	EPA 200.8, Rev. 5.4	369657		
70320171035	33-01-NO-IN-H100E-TR	EPA 200.8, Rev. 5.4	369657		
70320171036	33-01-NO-IN-H100H-T	EPA 200.8, Rev. 5.4	369657		
70320171037	33-01-NO-IN-H100F-T	EPA 200.8, Rev. 5.4	369657		
70320171038	33-01-NO-IN-H100I-T	EPA 200.8, Rev. 5.4	369657		
70320171039	33-01-NO-IN-H100T-T	EPA 200.8, Rev. 5.4	369657		
70320171040	33-01-NO-IN-H100-T	EPA 200.8, Rev. 5.4	369657		
70320171041	33-01-NO-IN-H100U-T	EPA 200.8, Rev. 5.4	369658		
70320171042	33-01-KI-IN-A122-T	EPA 200.8, Rev. 5.4	369658		
70320171043	33-01-HA-BY-D115-F	EPA 200.8, Rev. 5.4	369658		
70320171044	33-01-HA-BY-D115-BF	EPA 200.8, Rev. 5.4	369658		
70320171045	33-02-CR-IN-B207-B	EPA 200.8, Rev. 5.4	369658		
70320171046	33-02-CR-IN-B207-T	EPA 200.8, Rev. 5.4	369658		
70320171047	33-02-CR-IN-B205-B	EPA 200.8, Rev. 5.4	369658		
70320171048	33-02-CR-IN-B205-T	EPA 200.8, Rev. 5.4	369658		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: RCSD- School No.33

Pace Project No.: 70320171

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70320171049	33-02-CR-IN-B204-B	EPA 200.8, Rev. 5.4	369658		
70320171050	33-02-CR-IN-B204-T	EPA 200.8, Rev. 5.4	369658		
70320171051	33-02-CR-IN-B202-B	EPA 200.8, Rev. 5.4	369658		
70320171052	33-02-CR-IN-B202-T	EPA 200.8, Rev. 5.4	369658		
70320171053	33-02-CR-IN-B203-B	EPA 200.8, Rev. 5.4	369658		
70320171054	33-02-CR-IN-B203-T	EPA 200.8, Rev. 5.4	369658		
70320171055	33-02-CR-IN-B201-T	EPA 200.8, Rev. 5.4	369658		
70320171056	33-02-CR-IN-B217-B	EPA 200.8, Rev. 5.4	369658		
70320171057	33-02-CR-IN-B217-T	EPA 200.8, Rev. 5.4	369658		
70320171058	33-02-CR-IN-B215-B	EPA 200.8, Rev. 5.4	369658		
70320171059	33-02-CR-IN-B215-T	EPA 200.8, Rev. 5.4	369658		
70320171060	33-02-CR-IN-B218-B	EPA 200.8, Rev. 5.4	369658		
70320171061	33-02-CR-IN-B218-T	EPA 200.8, Rev. 5.4	369842		
70320171062	33-02-CR-IN-B216-B	EPA 200.8, Rev. 5.4	369842		
70320171063	33-02-CR-IN-B216-T	EPA 200.8, Rev. 5.4	369842		
70320171064	33-02-CR-IN-B213-B	EPA 200.8, Rev. 5.4	369842		
70320171065	33-02-CR-IN-B213-T	EPA 200.8, Rev. 5.4	369842		
70320171066	33-02-CR-IN-B211-B	EPA 200.8, Rev. 5.4	369842		
70320171067	33-02-CR-IN-B211-T	EPA 200.8, Rev. 5.4	369842		
70320171068	33-02-KI-IN-B219A-1	EPA 200.8, Rev. 5.4	369842		
70320171069	33-02-KI-IN-B219A-2	EPA 200.8, Rev. 5.4	369842		
70320171070	33-02-KI-IN-B219A-3	EPA 200.8, Rev. 5.4	369842		
70320171071	33-02-KI-IN-B219A-4	EPA 200.8, Rev. 5.4	369842		
70320171072	33-02-KI-IN-B219A-5	EPA 200.8, Rev. 5.4	369842		
70320171073	33-02-KI-IN-B219A-6	EPA 200.8, Rev. 5.4	369842		
70320171074	33-02-KI-IN-B219A-7	EPA 200.8, Rev. 5.4	369842		
70320171075	33-02-KI-IN-B219A-8	EPA 200.8, Rev. 5.4	369842		
70320171076	33-02-CR-IN-A218-T	EPA 200.8, Rev. 5.4	369842		
70320171077	33-02-CR-IN-A215-B	EPA 200.8, Rev. 5.4	369842		
70320171078	33-02-CR-IN-A215-T	EPA 200.8, Rev. 5.4	369842		
70320171079	33-02-CR-IN-A213-B	EPA 200.8, Rev. 5.4	369842		
70320171080	33-02-CR-IN-A213-T	EPA 200.8, Rev. 5.4	369842		
70320171081	33-02-CR-IN-A212-B	EPA 200.8, Rev. 5.4	369843		
70320171082	33-02-CR-IN-A212-T	EPA 200.8, Rev. 5.4	369843		
70320171083	33-02-CR-IN-A211-T	EPA 200.8, Rev. 5.4	369843		
70320171084	33-02-CR-IN-A210-B	EPA 200.8, Rev. 5.4	369843		
70320171085	33-02-CR-IN-A210-T	EPA 200.8, Rev. 5.4	369843		
70320171086	33-02-CR-IN-A200-B	EPA 200.8, Rev. 5.4	369843		
70320171087	33-02-CR-IN-A200-T	EPA 200.8, Rev. 5.4	369843		
70320171088	33-02-CR-IN-A203-B	EPA 200.8, Rev. 5.4	369843		
70320171089	33-02-CR-IN-A203-T	EPA 200.8, Rev. 5.4	369843		
70320171090	33-02-CR-IN-A205-B	EPA 200.8, Rev. 5.4	369843		
70320171091	33-02-CR-IN-A205-T	EPA 200.8, Rev. 5.4	369843		
70320171092	33-02-CR-IN-A206-B	EPA 200.8, Rev. 5.4	369843		
70320171093	33-02-CR-IN-A206-T	EPA 200.8, Rev. 5.4	369843		
70320171094	33-02-CR-IN-A207-B	EPA 200.8, Rev. 5.4	369843		
70320171095	33-02-CR-IN-A207-T	EPA 200.8, Rev. 5.4	369843		
70320171096	33-02-CR-IN-A208-B	EPA 200.8, Rev. 5.4	369843		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: RCSD- School No.33

Pace Project No.: 70320171

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70320171097	33-02-CR-IN-A208-T	EPA 200.8, Rev. 5.4	369843		
70320171098	33-03-CR-IN-B323-B	EPA 200.8, Rev. 5.4	369843		
70320171099	33-03-CR-IN-B323-T	EPA 200.8, Rev. 5.4	369843		
70320171100	33-03-CR-IN-B321-B	EPA 200.8, Rev. 5.4	369843		
70320171101	33-03-CR-IN-B321-T	EPA 200.8, Rev. 5.4	369846		
70320171102	33-03-CR-IN-B322-B	EPA 200.8, Rev. 5.4	369846		
70320171103	33-03-CR-IN-B322-T	EPA 200.8, Rev. 5.4	369846		
70320171104	33-03-CR-IN-B320-B	EPA 200.8, Rev. 5.4	369846		
70320171105	33-03-CR-IN-B320-T	EPA 200.8, Rev. 5.4	369846		
70320171106	33-03-CR-IN-B319-B	EPA 200.8, Rev. 5.4	369846		
70320171107	33-03-CR-IN-B319-T	EPA 200.8, Rev. 5.4	369846		
70320171108	33-03-CR-IN-B317-B	EPA 200.8, Rev. 5.4	369846		
70320171109	33-03-CR-IN-B317-T	EPA 200.8, Rev. 5.4	369846		
70320171110	33-03-HA-BY-B315-F	EPA 200.8, Rev. 5.4	369846		
70320171111	33-03-HA-BY-B315-BF	EPA 200.8, Rev. 5.4	369846		
70320171112	33-03-HA-BY-B312-B	EPA 200.8, Rev. 5.4	369846		
70320171113	33-03-CR-IN-B312-T	EPA 200.8, Rev. 5.4	369846		
70320171114	33-03-CR-IN-B310-B	EPA 200.8, Rev. 5.4	369846		
70320171115	33-03-CR-IN-B310-T	EPA 200.8, Rev. 5.4	369846		
70320171116	33-03-CR-IN-B307-B	EPA 200.8, Rev. 5.4	369846		
70320171117	33-03-CR-IN-B307-T	EPA 200.8, Rev. 5.4	369846		
70320171118	33-03-CR-IN-B305-B	EPA 200.8, Rev. 5.4	369846		
70320171119	33-03-CR-IN-B305-T	EPA 200.8, Rev. 5.4	369846		
70320171120	33-03-CR-IN-B304-B	EPA 200.8, Rev. 5.4	369846		
70320171121	33-03-CR-IN-B304-T	EPA 200.8, Rev. 5.4	369879		
70320171122	33-03-CR-IN-B302-B	EPA 200.8, Rev. 5.4	369879		
70320171123	33-03-CR-IN-B302-T	EPA 200.8, Rev. 5.4	369879		
70320171124	33-03-CR-IN-B303-B	EPA 200.8, Rev. 5.4	369879		
70320171125	33-03-CR-IN-B303-T	EPA 200.8, Rev. 5.4	369879		
70320171126	33-03-CR-IN-B301-B	EPA 200.8, Rev. 5.4	369879		
70320171127	33-03-CR-IN-B301-T	EPA 200.8, Rev. 5.4	369879		
70320171128	33-03-CR-IN-A302-T	EPA 200.8, Rev. 5.4	369879		
70320171129	33-03-CR-IN-A306-B	EPA 200.8, Rev. 5.4	369879		
70320171130	33-03-CR-IN-A306-T	EPA 200.8, Rev. 5.4	369879		
70320171131	33-03-CR-IN-A307-B	EPA 200.8, Rev. 5.4	369879		
70320171132	33-03-CR-IN-A307-T	EPA 200.8, Rev. 5.4	369879		
70320171133	33-03-CR-IN-A308-B	EPA 200.8, Rev. 5.4	369879		
70320171134	33-03-CR-IN-A308-T	EPA 200.8, Rev. 5.4	369879		
70320171135	33-03-CR-IN-A309-B	EPA 200.8, Rev. 5.4	369879		
70320171136	33-03-CR-IN-A309-T	EPA 200.8, Rev. 5.4	369879		
70320171137	33-03-CR-IN-A310-B	EPA 200.8, Rev. 5.4	369879		
70320171138	33-03-CR-IN-A310-T	EPA 200.8, Rev. 5.4	369879		
70320171139	33-03-CR-IN-A311-B	EPA 200.8, Rev. 5.4	369879		
70320171140	33-03-CR-IN-A311-T	EPA 200.8, Rev. 5.4	369879		
70320171141	33-03-CR-IN-A312-B	EPA 200.8, Rev. 5.4	369880		
70320171142	33-03-CR-IN-A312-T	EPA 200.8, Rev. 5.4	369880		
70320171143	33-03-CR-IN-A313-B	EPA 200.8, Rev. 5.4	369880		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: RCSD- School No.33
Pace Project No.: 70320171

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70320171144	33-03-CR-IN-A313-T	EPA 200.8, Rev. 5.4	369880		
70320171145	33-03-CR-IN-A314-B	EPA 200.8, Rev. 5.4	369880		
70320171146	33-03-CR-IN-A314-T	EPA 200.8, Rev. 5.4	369880		
70320171147	33-03-CR-IN-A319-B	EPA 200.8, Rev. 5.4	369880		
70320171148	33-03-CR-IN-A319-T	EPA 200.8, Rev. 5.4	369880		
70320171149	33-03-CR-IN-A320-B	EPA 200.8, Rev. 5.4	369880		
70320171150	33-03-CR-IN-A320-T	EPA 200.8, Rev. 5.4	369880		

REPORT OF LABORATORY ANALYSIS



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

70320171
Page 1 of 15

REPORT TO:		INVOICE TO:	
Company:	Lozier Environmental Consulting, Inc.	Company:	(SAME)
Address:	2011 East Main Street	Address:	
City, State Zip:	Rochester NY 14609	City, State Zip:	
Phone:	585-654-9080	Phone:	
Fax:	585-654-9662	Fax:	
E-Mail:	support@lozierenv.com	Purchase Order #:	

LAB ID: M36626	Address:
PROJECT NAME: RCSD - School No. 33	City, State Zip:
TURNAROUND TIME: Standard Rush	Phone:
Other:	E-Mail:

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	Lead	TEST ANALYSIS				
										WO#: 70320171				
1	33-01-HA-BY-A120-F	10/24/2024	6:15		DW				x					
2	33-01-HA-BY-A120-BF	10/24/2024	6:15		DW				x					
3	33-01-CR-IN-A110-B	10/24/2024	6:21		DW				x					
4	33-01-CR-IN-A110-T	10/24/2024	6:21		DW				x					
5	33-01-CR-IN-A111-B	10/24/2024	6:24		DW				x					
6	33-01-CR-IN-A111-T	10/24/2024	6:24		DW				x					
7	33-01-CR-IN-A112-B	10/24/2024	6:26		DW				x					
8	33-01-CR-IN-A112-T	10/24/2024	6:26		DW				x					
9	33-01-CR-IN-A117-T	10/24/2024	6:30		DW				x					
10	33-01-CR-IN-A118-T	10/24/2024	7:04		DW				x					

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # 7796 8448 0446)

SAMPLED BY* Joe Savioe

RELINQUISHED BY*: Joe Savioe	DATE: 11/1/24	TIME: 15:45
RECEIVED BY:	DATE: 11/4/24	TIME: 1030
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDE: HNO3-	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINERS: 150	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES	Present Absent
SAMPLE ON ICE? NO	If Present, Date Client is
TEMPERATURE: 16.5 C	contacted with result:
SAMPLE IN COMPLIANCE: YES	Date: _____
	Contacted By: _____



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 2 of 15

REPORT TO:		INVOICE TO:	
Company:	Lozier Environmental Consulting, Inc.	Company:	(SAME)
Address:	2011 East Main Street	Address:	
City, State Zip:	Rochester NY 14609	City, State Zip:	
Phone:	585-654-9080	Phone:	
Fax:	585-654-9662	Fax:	
E-Mail:	support@lozierenv.com	Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS					
									Lead					
11	33-01-CR-IN-A103-B	10/24/2024	6:35		DW				x					
12	33-01-CR-IN-A103-T	10/24/2024	6:35		DW				x					
13	33-01-CR-IN-A104-B	10/24/2024	6:38		DW				x					
14	33-01-CR-IN-A104-T	10/24/2024	6:38		DW				x					
15	33-01-CR-IN-A105-T	10/24/2024	6:49		DW				x					
16	33-01-CR-IN-B104-T	10/24/2024	6:49		DW				x					
17	33-01-CR-IN-B105-B	10/24/2024	6:52		DW				x					
18	33-01-CR-IN-B105-T	10/24/2024	6:52		DW				x					
19	33-01-CR-IN-B102-T	10/24/2024	6:54		DW				x					
20	33-01-CR-IN-B100-T	10/24/2024	6:55		DW				x					

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # 7968449 0486
FED EX GROUND)

SAMPLED BY* Joe Savioe

RELINQUISHED BY* Joe Savioe	DATE: 11/1/24	TIME: 15:45
RECEIVED BY: <u>[Signature]</u>	DATE: 11/4/24	TIME: 1030
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDE: HNO3-	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINERS: 150	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES	Present Absent
SAMPLE ON ICE? <u>NO</u>	If Present, Date Client is
TEMPERATURE: <u>16.5</u> C	contacted with result:
SAMPLE IN COMPLIANCE: YES	Date: _____
	Contacted By: _____



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 3 of 15

REPORT TO:		INVOICE TO:	
Company:	Lozier Environmental Consulting, Inc.	Company:	(SAME)
LAB ID: M36626	Address: 2011 East Main Street	Address:	
PROJECT NAME: RCSD - School No. 33	City, State Zip: Rochester NY 14609	City, State Zip:	
TURNAROUND TIME: Standard Rush	Phone: 585-654-9080 Fax: 585-654-9662	Phone:	Fax:
Other:	E-Mail: support@lozierenv.com	Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS					
									Lead					
21	33-01-HA-BY-B114-F	10/24/2024	6:56		DW				x					
22	33-01-HA-BY-B114-BF	10/24/2024	6:56		DW				x					
23	33-01-BT-IN-D114-TL	10/24/2024	7:00		DW				x					
24	33-01-BT-IN-D114-TR	10/24/2024	7:00		DW				x					
25	33-01-CR-IN-B116-T	10/24/2024	7:03		DW				x					
26	33-01-CR-IN-B118-T	10/24/2024	7:04		DW				x					
27	33-01-CR-IN-B120-T	10/24/2024	7:05		DW				x					
28	33-01-CR-IN-B121-T	10/24/2024	7:08		DW				x					
29	33-01-CR-IN-B121-B	10/24/2024	7:10		DW				x					
30	33-01-NO-IN-H100Q-T	10/25/2024	6:08		DW				x					

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # 77968448 0446)

SAMPLED BY* Joe Savioe

RELINQUISHED BY*: Joe Savioe	DATE: 11/1/24	TIME: 15:45
RECEIVED BY: <u>[Signature]</u>	DATE: 11/1/24	TIME: 1030
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDE: HNO3-	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINERS: 150	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES	Present Absent
SAMPLE ON ICE? <u>(NO)</u>	If Present, Date Client is
TEMPERATURE: <u>16.5</u> C	contacted with result:
SAMPLE IN COMPLIANCE: YES	Date: _____
	Contacted By: _____



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 4 of 15

REPORT TO:		INVOICE TO:	
Company:	Lozier Environmental Consulting, Inc.	Company:	(SAME)
Address:	2011 East Main Street	Address:	
City, State Zip:	Rochester NY 14609	City, State Zip:	
TURNAROUND TIME: Standard Rush	Phone: 585-654-9080 Fax: 585-654-9662	Phone:	Fax:
Other:	E-Mail: support@lozierenv.com	Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS					
									Lead					
31	33-01-NO-IN-H100P-T	10/25/2024	6:08		DW				x					
32	33-01-NO-IN-H100K-TL	10/25/2024	6:09		DW				x					
33	33-01-NO-IN-H100K-TR	10/25/2024	6:11		DW				x					
34	33-01-NO-IN-H100E-TL	10/25/2024	6:12		DW				x					
35	33-01-NO-IN-H100E-TR	10/25/2024	6:14		DW				x					
36	33-01-NO-IN-H100H-T	10/25/2024	6:14		DW				x					
37	33-01-NO-IN-H100F-T	10/25/2024	6:16		DW				x					
38	33-01-NO-IN-H100I-T	10/25/2024	6:17		DW				x					
39	33-01-NO-IN-H100T-T	10/25/2024	6:17		DW				x					
40	33-01-NO-IN-H100-T	10/25/2024	6:19		DW				x					

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # 7796 8448 0446
FED EX GLD)

SAMPLED BY* Joe Savioe

RELINQUISHED BY*: Joe Savioe	DATE: 11/1/24	TIME: 15:45
RECEIVED BY: <u>[Signature]</u>	DATE: <u>11/4/24</u>	TIME: <u>1030</u>
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDE: HNO3-	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINERS: 150	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES	Present Absent
SAMPLE ON ICE? <u>(NO)</u>	If Present, Date Client is
TEMPERATURE: <u>62.5</u> C	contacted with result:
SAMPLE IN COMPLIANCE: YES	Date: _____
	Contacted By: _____



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 5 of 15

REPORT TO:		INVOICE TO:	
Company:	Lozier Environmental Consulting, Inc.	Company:	(SAME)
Address:	2011 East Main Street	Address:	
City, State Zip:	Rochester NY 14609	City, State Zip:	
Phone:	585-654-9080	Phone:	
Fax:	585-654-9662	Fax:	
E-Mail:	support@lozierenv.com	Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS					
									Lead					
41	33-01-NO-IN-H100U-T	10/25/2024	6:22		DW				x					
42	33-01-KI-IN-A122-T	10/25/2024	6:32		DW				x					
43	33-01-HA-BY-D115-F	10/25/2024	6:55		DW				x					
44	33-01-HA-BY-D115-BF	10/25/2024	6:58		DW				x					
45	33-02-CR-IN-B207-B	10/25/2024	7:05		DW				x					
46	33-02-CR-IN-B207-T	10/25/2024	7:06		DW				x					
47	33-02-CR-IN-B205-B	10/25/2024	7:10		DW				x					
48	33-02-CR-IN-B205-T	10/25/2024	7:11		DW				x					
49	33-02-CR-IN-B204-B	10/29/2024	6:10		DW				x					
50	33-02-CR-IN-B204-T	10/29/2024	6:11		DW				x					

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # 7796 8448 0170
FED EX GPO)

SAMPLED BY* Joe Savioe

RELINQUISHED BY*: Joe Savioe	DATE: 11/1/24	TIME: 15:45
RECEIVED BY: <i>[Signature]</i>	DATE: 11/4/24	TIME: 1030
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDES: HNO3-	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINERS: 150	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES	Present Absent
SAMPLE ON ICE? NO	If Present, Date Client is
TEMPERATURE: 16.5 C	contacted with result:
SAMPLE IN COMPLIANCE: YES	Date: _____
	Contacted By: _____



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 6 of 15

REPORT TO:		INVOICE TO:	
Company:	Lozier Environmental Consulting, Inc.	Company:	(SAME)
Address:	2011 East Main Street	Address:	
City, State Zip:	Rochester NY 14609	City, State Zip:	
Phone:	585-654-9080	Phone:	
Fax:	585-654-9662	Fax:	
E-Mail:	support@lozierenv.com	Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS					
									Lead					
51	33-02-CR-IN-B202-B	10/29/2024	6:14		DW				x					
52	33-02-CR-IN-B202-T	10/29/2024	6:15		DW				x					
53	33-02-CR-IN-B203-B	10/29/2024	6:26		DW				x					
54	33-02-CR-IN-B203-T	10/29/2024	6:26		DW				x					
55	33-02-CR-IN-B201-T	10/29/2024	6:28		DW				x					
56	33-02-CR-IN-B217-B	10/29/2024	6:30		DW				x					
57	33-02-CR-IN-B217-T	10/29/2024	6:31		DW				x					
58	33-02-CR-IN-B215-B	10/29/2024	6:34		DW				x					
59	33-02-CR-IN-B215-T	10/29/2024	6:35		DW				x					
60	33-02-CR-IN-B218-B	10/29/2024	6:36		DW				x					

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # 7796 048070)

FED 58025

SAMPLED BY* Joe Savioe

RELINQUISHED BY*: Joe Savioe	DATE: 11/1/24	TIME: 15:45
RECEIVED BY:	DATE: 11/4/24	TIME: 1030
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDE: HNO3-	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINERS: 150	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES	Present Absent
SAMPLE ON ICE? NO	If Present, Date Client is
TEMPERATURE: 65 C	contacted with result:
SAMPLE IN COMPLIANCE: YES	Date: _____
	Contacted By: _____



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 7 of 15

REPORT TO:		INVOICE TO:	
Company:	Lozier Environmental Consulting, Inc.	Company:	(SAME)
LAB ID: M36626	Address: 2011 East Main Street	Address:	
PROJECT NAME: RCSD - School No. 33	City, State Zip: Rochester NY 14609	City, State Zip:	
TURNAROUND TIME: Standard Rush	Phone: 585-654-9080 Fax: 585-654-9662	Phone:	Fax:
Other:	E-Mail: support@lozierenv.com	Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS					
									Lead					
61	33-02-CR-IN-B218-T	10/29/2024	6:36		DW				x					
62	33-02-CR-IN-B216-B	10/29/2024	6:38		DW				x					
63	33-02-CR-IN-B216-T	10/29/2024	6:40		DW				x					
64	33-02-CR-IN-B213-B	10/29/2024	6:42		DW				x					
65	33-02-CR-IN-B213-T	10/29/2024	6:43		DW				x					
66	33-02-CR-IN-B211-B	10/29/2024	6:45		DW				x					
67	33-02-CR-IN-B211-T	10/29/2024	6:46		DW				x					
68	33-02-KI-IN-B219A-1	10/29/2024	6:49		DW				x					
69	33-02-KI-IN-B219A-2	10/29/2024	6:49		DW				x					
70	33-02-KI-IN-B219A-3	10/29/2024	6:50		DW				x					

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # 77968480170
FED EX 620)

SAMPLED BY* Joe Savioe

RELINQUISHED BY*: Joe Savioe	DATE: 11/1/24	TIME: 15:45
RECEIVED BY: <i>[Signature]</i>	DATE: 11/1/24	TIME: 1630
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDE: HNO3-	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINERS: 150	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES	Present Absent
SAMPLE ON ICE? <i>NO</i>	If Present, Date Client is
TEMPERATURE: 65 C	contacted with result:
SAMPLE IN COMPLIANCE: YES	Date: _____
	Contacted By: _____



REPORT TO:		INVOICE TO:	
Company:	Lozier Environmental Consulting, Inc.	Company:	(SAME)
LAB ID:	M36626	Address:	
PROJECT NAME:	RCSD - School No. 33	City, State Zip:	
TURNAROUND TIME:	Standard Rush	Phone:	
Other:		Fax:	
	E-Mail: support@lozierenv.com	Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS					
									Lead					
71	33-02-KI-IN-B219A-4	10/29/2024	6:50		DW				x					
72	33-02-KI-IN-B219A-5	10/29/2024	6:51		DW				x					
73	33-02-KI-IN-B219A-6	10/29/2024	6:52		DW				x					
74	33-02-KI-IN-B219A-7	10/29/2024	6:53		DW				x					
75	33-02-KI-IN-B219A-8	10/29/2024	6:54		DW				x					
76	33-02-CR-IN-A218-T	10/29/2024	6:57		DW				x					
77	33-02-CR-IN-A215-B	10/29/2024	6:59		DW				x					
78	33-02-CR-IN-A215-T	10/29/2024	7:00		DW				x					
79	33-02-CR-IN-A213-B	10/29/2024	7:03		DW				x					
80	33-02-CR-IN-A213-T	10/29/2024	7:04		DW				x					

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # 7796 8448 0170)
FEB 6X670

SAMPLED BY* Joe Savioe

RELINQUISHED BY*: Joe Savioe	DATE: 11/1/24	TIME: 15:45
RECEIVED BY: <u>[Signature]</u>	DATE: <u>11/4/24</u>	TIME: <u>1030</u>
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDE: HNO3-	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINERS: 150	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES	Present Absent
SAMPLE ON ICE? <u>NO</u>	If Present, Date Client is
TEMPERATURE: <u>16.5</u> C	contacted with result:
SAMPLE IN COMPLIANCE: YES	Date: _____
	Contacted By: _____



REPORT TO:		INVOICE TO:	
Company:	Lozier Environmental Consulting, Inc.	Company:	(SAME)
Address:	2011 East Main Street	Address:	
City, State Zip:	Rochester NY 14609	City, State Zip:	
Phone:	585-654-9080	Phone:	
Fax:	585-654-9662	Fax:	
E-Mail:	support@lozierenv.com	Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS					
									Lead					
81	33-02-CR-IN-A212-B	10/29/2024	7:06		DW				x					
82	33-02-CR-IN-A212-T	10/29/2024	7:06		DW				x					
83	33-02-CR-IN-A211-T	10/29/2024	7:08		DW				x					
84	33-02-CR-IN-A210-B	10/29/2024	7:10		DW				x					
85	33-02-CR-IN-A210-T	10/29/2024	7:11		DW				x					
86	33-02-CR-IN-A200-B	10/30/2024	6:11		DW				x					
87	33-02-CR-IN-A200-T	10/30/2024	6:11		DW				x					
88	33-02-CR-IN-A203-B	10/30/2024	6:15		DW				x					
89	33-02-CR-IN-A203-T	10/30/2024	6:15		DW				x					
90	33-02-CR-IN-A205-B	10/30/2024	6:18		DW				x					

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # 7796 8448 8940)

SAMPLED BY* Joe Savioe

RELINQUISHED BY*: Joe Savioe	DATE: 11/1/24	TIME: 15:45
RECEIVED BY: <u>[Signature]</u>	DATE: 11/4/24	TIME: 1030
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDE: HNO3-	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINERS: 150	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES	Present Absent
SAMPLE ON ICE? <u>NO</u>	If Present, Date Client is
TEMPERATURE: <u>6.5</u> C	contacted with result:
SAMPLE IN COMPLIANCE: YES	Date: _____
	Contacted By: _____



REPORT TO:		INVOICE TO:	
Company:	Lozier Environmental Consulting, Inc.	Company:	(SAME)
Address:	2011 East Main Street	Address:	
City, State Zip:	Rochester NY 14609	City, State Zip:	
Phone:	585-654-9080	Phone:	
Fax:	585-654-9662	Fax:	
E-Mail:	support@lozierenv.com	Purchase Order #:	

LAB ID: M36626	Address:
PROJECT NAME: RCSD - School No. 33	City, State Zip:
TURNAROUND TIME: Standard Rush	Phone:
Other:	Fax:

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS					
									Lead					
91	33-02-CR-IN-A205-T	10/30/2024	6:18		DW				x					
92	33-02-CR-IN-A206-B	10/30/2024	6:20		DW				x					
93	33-02-CR-IN-A206-T	10/30/2024	6:20		DW				x					
94	33-02-CR-IN-A207-B	10/30/2024	6:23		DW				x					
95	33-02-CR-IN-A207-T	10/30/2024	6:23		DW				x					
96	33-02-CR-IN-A208-B	10/30/2024	6:26		DW				x					
97	33-02-CR-IN-A208-T	10/30/2024	6:26		DW				x					
98	33-03-CR-IN-B323-B	10/30/2024	6:30		DW				x					
99	33-03-CR-IN-B323-T	10/30/2024	6:30		DW				x					
100	33-03-CR-IN-B321-B	10/30/2024	6:34		DW				x					

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # 7796 8443 8940)
FEDEX

SAMPLED BY* Joe Savioe

RELINQUISHED BY*: Joe Savioe	DATE: 11/1/24	TIME: 15:45
RECEIVED BY: [Signature]	DATE: 11/1/24	TIME: 10:30
RELINQUISHED BY*: [Signature]	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDE: HNO3-	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINERS: 150	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES	Present Absent
SAMPLE ON ICE? NO	If Present, Date Client is
TEMPERATURE: 16.5 C	contacted with result:
SAMPLE IN COMPLIANCE: YES	Date: _____
	Contacted By: _____

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 12 of 15

REPORT TO:		INVOICE TO:	
Company:	Lozier Environmental Consulting, Inc.	Company:	(SAME)
Address:	2011 East Main Street	Address:	
City, State Zip:	Rochester NY 14609	City, State Zip:	
Phone:	585-654-9080	Fax:	585-654-9662
E-Mail:	support@lozierenv.com	Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS					
									Lead					
111	33-03-HA-BY-B315-BF	10/30/2024	6:55		DW				x					
112	33-03-HA-BY-B312-B	10/30/2024	6:58		DW				x					
113	33-03-CR-IN-B312-T	10/30/2024	6:58		DW				x					
114	33-03-CR-IN-B310-B	10/30/2024	7:00		DW				x					
115	33-03-CR-IN-B310-T	10/30/2024	7:00		DW				x					
116	33-03-CR-IN-B307-B	10/30/2024	7:03		DW				x					
117	33-03-CR-IN-B307-T	10/30/2024	7:03		DW				x					
118	33-03-CR-IN-B305-B	10/30/2024	7:06		DW				x					
119	33-03-CR-IN-B305-T	10/30/2024	7:06		DW				x					
120	33-03-CR-IN-B304-B	10/30/2024	7:09		DW				x					

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # 7796 8440 8940)
FSD 5x6TD

SAMPLED BY* Joe Savioe

RELINQUISHED BY*: Joe Savioe	DATE: 11/1/24	TIME: 15:45
RECEIVED BY: <i>[Signature]</i>	DATE: 11/4/24	TIME: 10:30
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDE: HNO3-	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINERS: 150	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES	Present Absent
SAMPLE ON ICE? NO	If Present, Date Client is
TEMPERATURE: 16.5 C	contacted with result:
SAMPLE IN COMPLIANCE: YES	Date: _____
	Contacted By: _____



REPORT TO:				INVOICE TO:			
Company: Lozier Environmental Consulting, Inc.				Company: (SAME)			
Address: 2011 East Main Street				Address:			
City, State Zip: Rochester NY 14609				City, State Zip:			
Phone: 585-654-9080 Fax: 585-654-9662				Phone: Fax:			
E-Mail: support@lozierenv.com				Purchase Order #:			

LAB ID: M36626	PROJECT NAME: RCSD - School No. 33	TURNAROUND TIME: Standard Rush	Other:
----------------	------------------------------------	--------------------------------	--------

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS					
									Lead					
121	33-03-CR-IN-B304-T	10/30/2024	7:09		DW				x					
122	33-03-CR-IN-B302-B	10/30/2024	7:11		DW				x					
123	33-03-CR-IN-B302-T	10/30/2024	7:11		DW				x					
124	33-03-CR-IN-B303-B	10/30/2024	7:13		DW				x					
125	33-03-CR-IN-B303-T	10/30/2024	7:13		DW				x					
126	33-03-CR-IN-B301-B	10/30/2024	7:15		DW				x					
127	33-03-CR-IN-B301-T	10/30/2024	7:15		DW				x					
128	33-03-CR-IN-A302-T	10/31/2024	6:09		DW				x					
129	33-03-CR-IN-A306-B	10/31/2024	6:12		DW				x					
130	33-03-CR-IN-A306-T	10/31/2024	6:12		DW				x					

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # 1776 8448 9144)

SAMPLED BY* Joe Savioe

RELINQUISHED BY*: Joe Savioe	DATE: 11/1/24	TIME: 15:45
RECEIVED BY: <i>[Signature]</i>	DATE: 11/4/24	TIME: 1030
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDE: HNO3-	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINERS: 150	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES	Present Absent
SAMPLE ON ICE? NO	If Present, Date Client is
TEMPERATURE: <u>16.5</u> C	contacted with result:
SAMPLE IN COMPLIANCE: YES	Date: _____
	Contacted By: _____



REPORT TO:		INVOICE TO:	
Company:	Lozier Environmental Consulting, Inc.	Company:	(SAME)
Address:	2011 East Main Street	Address:	
City, State Zip:	Rochester NY 14609	City, State Zip:	
Phone:	585-654-9080	Phone:	
Fax:	585-654-9662	Fax:	
E-Mail:	support@lozierenv.com	Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS					
									Lead					
141	33-03-CR-IN-A312-B	10/31/2024	6:26		DW				x					
142	33-03-CR-IN-A312-T	10/31/2024	6:26		DW				x					
143	33-03-CR-IN-A313-B	10/31/2024	6:29		DW				x					
144	33-03-CR-IN-A313-T	10/31/2024	6:29		DW				x					
145	33-03-CR-IN-A314-B	10/31/2024	6:32		DW				x					
146	33-03-CR-IN-A314-T	10/31/2024	6:32		DW				x					
147	33-03-CR-IN-A319-B	10/31/2024	6:35		DW				x					
148	33-03-CR-IN-A319-T	10/31/2024	6:35		DW				x					
149	33-03-CR-IN-A320-B	10/31/2024	6:38		DW				x					
150	33-03-CR-IN-A320-T	10/31/2024	6:38		DW				x					

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # 7968448 9144)

SAMPLED BY* Joe Savioe

RELINQUISHED BY*: Joe Savioe	DATE: 11/1/24	TIME: 15:45
RECEIVED BY: <u>[Signature]</u>	DATE: <u>11/4/24</u>	TIME: <u>1030</u>
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDE: HNO3-	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINERS: 150	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES NO	Present Absent
SAMPLE ON ICE? YES NO	If Present, Date Client is
TEMPERATURE: <u>16.5</u> C	contacted with result:
SAMPLE IN COMPLIANCE: YES NO	Date: _____
	Contacted By: _____

Sample Condition Upon Receipt Form (SCUR)

Project # 70320171

Client: Lozier

Date and Initials of person:

Examining contents: _____

Label: _____

Deliver to location: _____

pH: _____

Thermometer Used: _____ IRG4 _____ Date: 11/4 Time: 1630 Initials: _____

State of Origin: NY

Cooler #1 Temp. °C 16.5 (Visual) 0.2 @ 0.0°C, -0.5 @ 20.0°C (Correction Factor) _____ (Actual) ☒ Samples on ice, cooling process has begun

Courier: ☒ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☐ Pace ☐ Other _____

Shipping Method: ☐ First Overnight ☐ Priority Overnight ☐ Standard Overnight ☒ Ground

☐ Other _____

Tracking # 7796 8448 9144

Custody Seal on Cooler/Box Present: ☐ Yes ☐ No Seals intact: ☐ Yes ☐ No Ice: ☒ Wet ☐ Blue ☐ Melted ☐ None

Packing Material: ☐ Bubble Wrap ☐ Bubble Bags ☐ None ☐ Other _____

Samples were collected by Pace employee ☐ Yes ☐ No ☐ N/A

Comments:	
Chain of Custody Present	☒ Yes ☐ No ☐ N/A
Chain of Custody Filled Out	☒ Yes ☐ No ☐ N/A
Relinquished Signature on COC	☒ Yes ☐ No ☐ N/A
Sampler Name and Signature on COC	☒ Yes ☐ No ☐ N/A
Samples Arrived within Hold Time	☒ Yes ☐ No ☐ N/A
Rush TAT requested on COC	☐ Yes ☐ No ☐ N/A
Sufficient Volume	☒ Yes ☐ No ☐ N/A
Correct Containers Used	☒ Yes ☐ No ☐ N/A
Containers Intact	☒ Yes ☐ No ☐ N/A
Sample Labels match COC (sample IDs & date/time of collection)	☒ Yes ☐ No ☐ N/A
All containers needing acid/base preservation have been checked.	☐ Yes ☐ No ☐ N/A
All Containers needing preservation are found to be in compliance with EPA recommendation:	☐ Yes ☐ No ☐ N/A
Exceptions: Vials, Microbiology, O&G, Metals	Date: _____ Time: _____ Initials: _____
Headspace in VOA Vials? (>6mm):	☐ Yes ☐ No ☐ N/A
Trip Blank Present:	☐ Yes ☐ No ☐ N/A
Additional Login Comments:	

WO#: 70320171

PM: RC1

Due Date: 11/19/24

CLIENT: NB-LOZIER

Client notification/ Resolution

Person Contacted:

Comments/Resolution: