


October 21, 2024

V Kaptein
NB-Lozier Environmental Consulting, Inc
2011 E Main Street
Rochester, NY 14609

Project Location:
Project Number: RCSD-School No.25
Laboratory Work Order Number: 24J1546

Enclosed are results of analyses for samples received by the laboratory on October 10, 2024. If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Project Manager



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

NB-Lozier Environmental Consulting, Inc
2011 E Main Street
Rochester, NY 14609
ATTN: V Kaptein

REPORT DATE: 10/21/2024

PURCHASE ORDER NUMBER:

PROJECT NUMBER: RCSD-School No.25

ANALYTICAL SUMMARY

WORK ORDER NUMBER: 24J1546

The results of analyses performed on the following samples submitted to Pace Analytical Services, LLC - Newburgh are found in this report.

PROJECT LOCATION:

FIELD SAMPLE #	LAB ID:	MATRIX	SAMPLE DESCRIPTION	TEST	SUB LAB
(1) 02-01-KI-IN-124A-T	24J1546-01	Drinking Water		EPA 200.8 Rev 5.4	
(2) 02-01-KI-IN-124-T2	24J1546-02	Drinking Water		EPA 200.8 Rev 5.4	
(3) 02-01-KI-IN-124-T3	24J1546-03	Drinking Water		EPA 200.8 Rev 5.4	
(4) 02-01-KI-IN-124-T4	24J1546-04	Drinking Water		EPA 200.8 Rev 5.4	
(5) 02-01-KI-IN-124-T5	24J1546-05	Drinking Water		EPA 200.8 Rev 5.4	
(6) 02-01-KI-IN-124-T6	24J1546-06	Drinking Water		EPA 200.8 Rev 5.4	
(7) 02-01-KI-IN-124-T7	24J1546-07	Drinking Water		EPA 200.8 Rev 5.4	
(8) 02-01-CF-IN-124-FL	24J1546-08	Drinking Water		EPA 200.8 Rev 5.4	
(9) 02-01-CR-IN-124-FR	24J1546-09	Drinking Water		EPA 200.8 Rev 5.4	
(10) 02-01-CR-IN-124-BF	24J1546-10	Drinking Water		EPA 200.8 Rev 5.4	
(11) 02-01-HA-BY-125A-B	24J1546-11	Drinking Water		EPA 200.8 Rev 5.4	
(12) 02-01-HA-BY-125A-BF	24J1546-12	Drinking Water		EPA 200.8 Rev 5.4	
(13) 02-01-LI-IN-111-T	24J1546-13	Drinking Water		EPA 200.8 Rev 5.4	
(14) 02-01-HA-BY-133-B	24J1546-14	Drinking Water		EPA 200.8 Rev 5.4	
(15) 02-01-HA-BY-133-BF	24J1546-15	Drinking Water		EPA 200.8 Rev 5.4	
(16) 02-01-CR-IN-112-TL	24J1546-16	Drinking Water		EPA 200.8 Rev 5.4	
(17) 02-01-CR-IN-112-TR	24J1546-17	Drinking Water		EPA 200.8 Rev 5.4	
(18) 02-01-CR-IN-115-B	24J1546-18	Drinking Water		EPA 200.8 Rev 5.4	
(19) 02-01-CR-IN-115-T	24J1546-19	Drinking Water		EPA 200.8 Rev 5.4	
(20) 02-01-CR-IN-116-B	24J1546-20	Drinking Water		EPA 200.8 Rev 5.4	
(21) 02-01-CR-IN-116-T	24J1546-21	Drinking Water		EPA 200.8 Rev 5.4	
(22) 02-01-CR-IN-117-B	24J1546-22	Drinking Water		EPA 200.8 Rev 5.4	
(23) 02-01-CR-IN-117-T	24J1546-23	Drinking Water		EPA 200.8 Rev 5.4	
(24) 02-01-CR-IN-119-B	24J1546-24	Drinking Water		EPA 200.8 Rev 5.4	
(25) 02-01-CR-IN-119-T	24J1546-25	Drinking Water		EPA 200.8 Rev 5.4	
(26) 02-01-CR-IN-118-B	24J1546-26	Drinking Water		EPA 200.8 Rev 5.4	
(27) 02-01-CR-IN-118-T	24J1546-27	Drinking Water		EPA 200.8 Rev 5.4	
(28) 02-01-CR-IN-121-B	24J1546-28	Drinking Water		EPA 200.8 Rev 5.4	
(29) 02-01-NO-IN-121-T	24J1546-29	Drinking Water		EPA 200.8 Rev 5.4	
(30) 02-01-CR-IN-120-B	24J1546-30	Drinking Water		EPA 200.8 Rev 5.4	
(31) 02-01-CR-IN-120-T	24J1546-31	Drinking Water		EPA 200.8 Rev 5.4	
(32) 02-01-CR-IN-152-B	24J1546-32	Drinking Water		EPA 200.8 Rev 5.4	
(33) 02-01-CR-IN-152-T	24J1546-33	Drinking Water		EPA 200.8 Rev 5.4	
(34) 02-01-CR-IN-154-B	24J1546-34	Drinking Water		EPA 200.8 Rev 5.4	
(35) 02-01-CR-IN-154-T	24J1546-35	Drinking Water		EPA 200.8 Rev 5.4	
(36) 02-01-HA-BY-155-FL	24J1546-36	Drinking Water		EPA 200.8 Rev 5.4	
(37) 02-01-HA-BY-155-FR	24J1546-37	Drinking Water		EPA 200.8 Rev 5.4	
(38) 02-01-HA-BY-155-BF	24J1546-38	Drinking Water		EPA 200.8 Rev 5.4	
(39) 02-01-CR-IN-102-B	24J1546-39	Drinking Water		EPA 200.8 Rev 5.4	
(40) 02-01-CR-IN-102-T	24J1546-40	Drinking Water		EPA 200.8 Rev 5.4	



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

NB-Lozier Environmental Consulting, Inc
2011 E Main Street
Rochester, NY 14609
ATTN: V Kaptein

REPORT DATE: 10/21/2024

PURCHASE ORDER NUMBER:

PROJECT NUMBER: RCSD-School No.25

ANALYTICAL SUMMARY

WORK ORDER NUMBER: 24J1546

The results of analyses performed on the following samples submitted to Pace Analytical Services, LLC - Newburgh are found in this report.

PROJECT LOCATION:

FIELD SAMPLE #	LAB ID:	MATRIX	SAMPLE DESCRIPTION	TEST	SUB LAB
(81) 02-02-CR-IN-205-B	24J1546-41	Drinking Water		EPA 200.8 Rev 5.4	
(82) 02-02-CR-IN-205-T	24J1546-42	Drinking Water		EPA 200.8 Rev 5.4	
(83) 02-02-CR-IN-206-B	24J1546-43	Drinking Water		EPA 200.8 Rev 5.4	
(84) 02-02-CR-IN-206-T	24J1546-44	Drinking Water		EPA 200.8 Rev 5.4	
(85) 02-02-CR-IN-203-B	24J1546-45	Drinking Water		EPA 200.8 Rev 5.4	
(86) 02-02-CR-IN-203-T	24J1546-46	Drinking Water		EPA 200.8 Rev 5.4	
(87) 02-02-CR-IN-204-B	24J1546-47	Drinking Water		EPA 200.8 Rev 5.4	
(88) 02-02-CR-IN-204-T	24J1546-48	Drinking Water		EPA 200.8 Rev 5.4	
(89) 02-02-CR-IN-258-B	24J1546-49	Drinking Water		EPA 200.8 Rev 5.4	
(90) 02-02-CR-IN-258-T	24J1546-50	Drinking Water		EPA 200.8 Rev 5.4	
(91) 02-02-CR-IN-256-T	24J1546-51	Drinking Water		EPA 200.8 Rev 5.4	
(92) 02-02-HA-BY-254-FL	24J1546-52	Drinking Water		EPA 200.8 Rev 5.4	
(93) 02-02-HA-BY-254-FR	24J1546-53	Drinking Water		EPA 200.8 Rev 5.4	
(94) 02-02-HA-BY-254-BF	24J1546-54	Drinking Water		EPA 200.8 Rev 5.4	
(95) 02-02-CR-IN-221-B	24J1546-55	Drinking Water		EPA 200.8 Rev 5.4	
(96) 02-02-CR-IN-221-T	24J1546-56	Drinking Water		EPA 200.8 Rev 5.4	
(97) 02-02-CR-IN-222-B	24J1546-57	Drinking Water		EPA 200.8 Rev 5.4	
(98) 02-02-CR-IN-222-T	24J1546-58	Drinking Water		EPA 200.8 Rev 5.4	
(99) 02-02-CR-IN-220-B	24J1546-59	Drinking Water		EPA 200.8 Rev 5.4	
(100) 02-02-CR-IN-220-T	24J1546-60	Drinking Water		EPA 200.8 Rev 5.4	
(101) 02-02-CR-IN-219-B	24J1546-61	Drinking Water		EPA 200.8 Rev 5.4	
(102) 02-02-CR-IN-219-T	24J1546-62	Drinking Water		EPA 200.8 Rev 5.4	
(103) 02-02-OF-IN-131-T	24J1546-63	Drinking Water		EPA 200.8 Rev 5.4	
(104) 02-02-OF-IN-123-T	24J1546-64	Drinking Water		EPA 200.8 Rev 5.4	
(105) 02-01-TC-IN-102/101-T	24J1546-65	Drinking Water		EPA 200.8 Rev 5.4	

CASE NARRATIVE SUMMARY

All reported results are within defined laboratory quality control objectives unless listed below or otherwise qualified in this report.

EPA 200.8 Rev 5.4

Qualifications:

Z-01

#


Analyte & Samples(s) Qualified:

Lead

24J1546-02[(2) 02-01-KI-IN-124-T2], 24J1546-21[(21) 02-01-CR-IN-116-T], 24J1546-26[(26) 02-01-CR-IN-118-B], 24J1546-28[(28) 02-01-CR-IN-121-B], 24J1546-29[(29) 02-01-NO-IN-121-T], 24J1546-41[(81) 02-02-CR-IN-205-B], 24J1546-45[(85) 02-02-CR-IN-203-B], 24J1546-63[(103) 02-02-OF-IN-131-T], 24J1546-64[(104) 02-02-OF-IN-123-T]

The results of analyses reported only relate to samples submitted to the Pace Analytical Services, LLC - Newburgh for testing.

I certify that the analyses listed above, unless specifically listed as subcontracted, if any, were performed under my direction according to the approved methodologies listed in this document, and that based upon my inquiry of those individuals immediately responsible for obtaining the information, the material contained in this report is, to the best of my knowledge and belief, accurate and complete.



Renee Cusack
PM



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (1) 02-01-KI-IN-124A-T

Sample ID: 24J1546-01

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/24/2024 05:25

Work Order: 24J1546

Metals Analyses (Total)											
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL							Prepared	Analyzed	
Lead	8.0	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 11:32	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (2) 02-01-KI-IN-124-T2

Sample ID: 24J1546-02

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/24/2024 05:25

Work Order: 24J1546

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL			Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
		RL		Units						
Lead	21	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	10/17/24	10/20/24 11:41	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (3) 02-01-KI-IN-124-T3

Sample ID: 24J1546-03

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/24/2024 05:26

Work Order: 24J1546

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL			Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
		RL		Units						
Lead	3.2	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 11:43	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (4) 02-01-KI-IN-124-T4

Sample ID: 24J1546-04

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/24/2024 05:28

Work Order: 24J1546

Metals Analyses (Total)											
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL							Prepared	Analyzed	
Lead	1.5	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 11:45	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (5) 02-01-KI-IN-124-T5

Sample ID: 24J1546-05

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/24/2024 05:28

Work Order: 24J1546

Metals Analyses (Total)											
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL							Prepared	Analyzed	
Lead	1.4	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 11:52	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (6) 02-01-KI-IN-124-T6

Sample ID: 24J1546-06

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/24/2024 05:30

Work Order: 24J1546

Metals Analyses (Total)											
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL							Prepared	Analyzed	
Lead	2.4	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 11:54	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (7) 02-01-KI-IN-124-T7

Sample ID: 24J1546-07

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/24/2024 05:31

Work Order: 24J1546

Metals Analyses (Total)											
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL							Prepared	Analyzed	
Lead	2.0	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 11:56	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (8) 02-01-CF-IN-124-FL

Sample ID: 24J1546-08

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/24/2024 05:34

Work Order: 24J1546

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 11:58	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (9) 02-01-CR-IN-124-FR

Sample ID: 24J1546-09

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/24/2024 05:35

Work Order: 24J1546

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
		RL								
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 12:00	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (10) 02-01-CR-IN-124-BF

Sample ID: 24J1546-10

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/24/2024 05:35

Work Order: 24J1546

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
		RL								
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 12:03	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (11) 02-01-HA-BY-125A-B

Sample ID: 24J1546-11

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/24/2024 05:38

Work Order: 24J1546

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 12:05	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (12) 02-01-HA-BY-125A-BF

Sample ID: 24J1546-12

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/24/2024 05:39

Work Order: 24J1546

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 12:09	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (13) 02-01-LI-IN-111-T

Sample ID: 24J1546-13

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/24/2024 05:43

Work Order: 24J1546

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 12:11	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (14) 02-01-HA-BY-133-B

Sample ID: 24J1546-14

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/24/2024 05:45

Work Order: 24J1546

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 12:18	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (15) 02-01-HA-BY-133-BF

Sample ID: 24J1546-15

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/24/2024 05:46

Work Order: 24J1546

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 12:20	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (16) 02-01-CR-IN-112-TL

Sample ID: 24J1546-16

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/24/2024 05:50

Work Order: 24J1546

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 12:22	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (17) 02-01-CR-IN-112-TR

Sample ID: 24J1546-17

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/24/2024 05:50

Work Order: 24J1546

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
		RL								
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 12:25	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (18) 02-01-CR-IN-115-B

Sample ID: 24J1546-18

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/24/2024 05:56

Work Order: 24J1546

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL			Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL		Units				Prepared	Analyzed	
Lead	10	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 12:27	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (19) 02-01-CR-IN-115-T

Sample ID: 24J1546-19

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/24/2024 05:58

Work Order: 24J1546

Metals Analyses (Total)											
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL							Prepared	Analyzed	
Lead	2.5	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 12:29	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (20) 02-01-CR-IN-116-B

Sample ID: 24J1546-20

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/24/2024 06:01

Work Order: 24J1546

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time
		RL							Prepared	Analyzed
Lead	13	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 12:31 AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (21) 02-01-CR-IN-116-T

Sample ID: 24J1546-21

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/24/2024 06:01

Work Order: 24J1546

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	51	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	10/17/24	10/20/24 12:33	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (22) 02-01-CR-IN-117-B

Sample ID: 24J1546-22

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/24/2024 06:03

Work Order: 24J1546

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time
		RL							Prepared	Analyzed
Lead	2.2	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 12:47 AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (23) 02-01-CR-IN-117-T

Sample ID: 24J1546-23

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/24/2024 06:04

Work Order: 24J1546

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time
		RL							Prepared	Analyzed
Lead	1.5	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 12:49 AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (24) 02-01-CR-IN-119-B

Sample ID: 24J1546-24

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/24/2024 06:07

Work Order: 24J1546

Metals Analyses (Total)											
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL							Prepared	Analyzed	
Lead	9.7	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 12:51	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (25) 02-01-CR-IN-119-T

Sample ID: 24J1546-25

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/24/2024 06:07

Work Order: 24J1546

Metals Analyses (Total)											
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL							Prepared	Analyzed	
Lead	7.1	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 12:53	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (26) 02-01-CR-IN-118-B

Sample ID: 24J1546-26

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/24/2024 06:09

Work Order: 24J1546

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL			Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL		Units				Prepared	Analyzed	
Lead	15	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	10/17/24	10/20/24 12:55	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (27) 02-01-CR-IN-118-T

Sample ID: 24J1546-27

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/24/2024 06:10

Work Order: 24J1546

Metals Analyses (Total)											
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL							Prepared	Analyzed	
Lead	6.8	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 12:57	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (28) 02-01-CR-IN-121-B

Sample ID: 24J1546-28

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/24/2024 06:13

Work Order: 24J1546

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL			Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
		RL		Units						
Lead	39	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	10/17/24	10/20/24 13:00	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (29) 02-01-NO-IN-121-T

Sample ID: 24J1546-29

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/24/2024 06:13

Work Order: 24J1546

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL			Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
		RL		Units						
Lead	29	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	10/17/24	10/20/24 13:02	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (30) 02-01-CR-IN-120-B

Sample ID: 24J1546-30

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/24/2024 06:17

Work Order: 24J1546

Metals Analyses (Total)											
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time	
		RL							Prepared	Analyzed	Analyst
Lead	3.9	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 13:04	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (31) 02-01-CR-IN-120-T

Sample ID: 24J1546-31

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/24/2024 06:18

Work Order: 24J1546

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time
		RL							Prepared	Analyzed
Lead	3.3	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 13:11 AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (32) 02-01-CR-IN-152-B

Sample ID: 24J1546-32

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/24/2024 06:20

Work Order: 24J1546

Metals Analyses (Total)											
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time	
		RL							Prepared	Analyzed	Analyst
Lead	1.1	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 13:15	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (33) 02-01-CR-IN-152-T

Sample ID: 24J1546-33

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/24/2024 06:21

Work Order: 24J1546

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 13:17	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (34) 02-01-CR-IN-154-B

Sample ID: 24J1546-34

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/24/2024 06:25

Work Order: 24J1546

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 13:19	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (35) 02-01-CR-IN-154-T

Sample ID: 24J1546-35

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/24/2024 06:25

Work Order: 24J1546

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 13:22	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (36) 02-01-HA-BY-155-FL

Sample ID: 24J1546-36

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/24/2024 06:26

Work Order: 24J1546

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 13:24	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (37) 02-01-HA-BY-155-FR

Sample ID: 24J1546-37

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/24/2024 06:26

Work Order: 24J1546

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 13:26	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (38) 02-01-HA-BY-155-BF

Sample ID: 24J1546-38

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/24/2024 06:27

Work Order: 24J1546

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 13:28	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (39) 02-01-CR-IN-102-B

Sample ID: 24J1546-39

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/24/2024 06:30

Work Order: 24J1546

Metals Analyses (Total)											
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time	
		RL							Prepared	Analyzed	Analyst
Lead	10	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 13:30	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (40) 02-01-CR-IN-102-T

Sample ID: 24J1546-40

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/24/2024 06:31

Work Order: 24J1546

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time
		RL							Prepared	Analyzed
Lead	3.8	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 13:37 AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (81) 02-02-CR-IN-205-B

Sample ID: 24J1546-41

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/25/2024 05:50

Work Order: 24J1546

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL			Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
		RL		Units						
Lead	15	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	10/17/24	10/20/24 13:39	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (82) 02-02-CR-IN-205-T

Sample ID: 24J1546-42

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/25/2024 05:51

Work Order: 24J1546

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time
		RL							Prepared	Analyzed
Lead	9.4	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 13:47 AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (83) 02-02-CR-IN-206-B

Sample ID: 24J1546-43

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/25/2024 05:54

Work Order: 24J1546

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time
		RL							Prepared	Analyzed
Lead	1.1	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 13:49 AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (84) 02-02-CR-IN-206-T

Sample ID: 24J1546-44

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/25/2024 05:55

Work Order: 24J1546

Metals Analyses (Total)											
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL							Prepared	Analyzed	
Lead	1.5	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 13:52	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (85) 02-02-CR-IN-203-B

Sample ID: 24J1546-45

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/25/2024 05:58

Work Order: 24J1546

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL			Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
		RL		Units						
Lead	15	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	10/17/24	10/20/24 13:54	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (86) 02-02-CR-IN-203-T

Sample ID: 24J1546-46

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/25/2024 05:58

Work Order: 24J1546

Metals Analyses (Total)											
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL							Prepared	Analyzed	
Lead	8.6	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 13:56	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (87) 02-02-CR-IN-204-B

Sample ID: 24J1546-47

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/25/2024 05:59

Work Order: 24J1546

Metals Analyses (Total)											
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL							Prepared	Analyzed	
Lead	2.8	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 14:03	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (88) 02-02-CR-IN-204-T

Sample ID: 24J1546-48

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/25/2024 06:00

Work Order: 24J1546

Metals Analyses (Total)											
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time	
		RL							Prepared	Analyzed	Analyst
Lead	1.6	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 14:05	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (89) 02-02-CR-IN-258-B

Sample ID: 24J1546-49

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/25/2024 06:03

Work Order: 24J1546

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 14:07	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (90) 02-02-CR-IN-258-T

Sample ID: 24J1546-50

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/25/2024 06:04

Work Order: 24J1546

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 14:09	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (91) 02-02-CR-IN-256-T

Sample ID: 24J1546-51

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/25/2024 06:07

Work Order: 24J1546

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 14:11	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (92) 02-02-HA-BY-254-FL

Sample ID: 24J1546-52

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/25/2024 06:09

Work Order: 24J1546

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 14:16	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (93) 02-02-HA-BY-254-FR

Sample ID: 24J1546-53

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/25/2024 06:09

Work Order: 24J1546

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 14:18	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (94) 02-02-HA-BY-254-BF

Sample ID: 24J1546-54

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/25/2024 06:10

Work Order: 24J1546

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 14:20	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (95) 02-02-CR-IN-221-B

Sample ID: 24J1546-55

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/25/2024 06:14

Work Order: 24J1546

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 14:22	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (96) 02-02-CR-IN-221-T

Sample ID: 24J1546-56

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/25/2024 06:15

Work Order: 24J1546

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 14:29	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (97) 02-02-CR-IN-222-B

Sample ID: 24J1546-57

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/25/2024 06:19

Work Order: 24J1546

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 14:31	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (98) 02-02-CR-IN-222-T

Sample ID: 24J1546-58

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/25/2024 06:19

Work Order: 24J1546

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 14:33	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (99) 02-02-CR-IN-220-B

Sample ID: 24J1546-59

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/25/2024 06:20

Work Order: 24J1546

Metals Analyses (Total)											
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time	
		RL							Prepared	Analyzed	Analyst
Lead	ND	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 14:35	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (100) 02-02-CR-IN-220-T

Sample ID: 24J1546-60

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/25/2024 06:21

Work Order: 24J1546

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 14:37	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (101) 02-02-CR-IN-219-B

Sample ID: 24J1546-61

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/25/2024 06:24

Work Order: 24J1546

Metals Analyses (Total)											
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL							Prepared	Analyzed	
Lead	4.3	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 14:39	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (102) 02-02-CR-IN-219-T

Sample ID: 24J1546-62

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/25/2024 06:25

Work Order: 24J1546

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time
		RL							Prepared	Analyzed
Lead	12	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 14:48 AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (103) 02-02-OF-IN-131-T

Sample ID: 24J1546-63

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/25/2024 06:37

Work Order: 24J1546

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	39	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	10/17/24	10/20/24 14:55	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (104) 02-02-OF-IN-123-T

Sample ID: 24J1546-64

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/25/2024 06:39

Work Order: 24J1546

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	22	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	10/17/24	10/20/24 14:57	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location:

Date Received: 10/10/2024

Field Sample #: (105) 02-01-TC-IN-102/101-T

Sample ID: 24J1546-65

Sample Matrix: Drinking Water

Sample Description:

Sampled: 9/25/2024 06:43

Work Order: 24J1546

Metals Analyses (Total)											
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time	
		RL							Prepared	Analyzed	Analyst
Lead	2.7	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/17/24	10/20/24 14:59	AR3

FLAG/QUALIFIER SUMMARY

*	QC result is outside of established limits.
†	Wide recovery limits established for difficult compound.
‡	Wide RPD limits established for difficult compound.
#	Data exceeded client recommended or regulatory level
ND	Not Detected
RL	Reporting Limit is at the level of quantitation (LOQ)
DL	Detection Limit is the lower limit of detection determined by the MDL study
MCL	Maximum Contaminant Level
	Percent recoveries and relative percent differences (RPDs) are determined by the software using values in the calculation which have not been rounded.
	No results have been blank subtracted unless specified in the case narrative section.
Z-01	#

CERTIFICATIONS

Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 200.8 Rev 5.4 in Drinking Water</i>	
Lead	NB-CT,NB-NJ,NB-NY

Pace Analytical Services, LCC operates under the following certifications and accreditations:

Code	Description	Number	Expires
NB-CT	Connecticut Department of Public Health	PH-0823	09/30/2024
NB-NJ	New Jersey DEP	NY015 NELAP	06/30/2024
NB-NY	New York State Department of Health	10142 NELAP	03/31/2025



2011 East Main Street, Rochester, NY 14609 Phone (585) 654-9080 Fax (585) 654-9662
Web: LozierEnv.com E-Mail: support@lozierenv.com



LAB ID: M36200		Company: Lozier Environmental Consulting, Inc.		REPORT TO:	
PROJECT NAME: RCSD - School No. 25		Address: 2011 East Main Street		City/State Zip: Rochester NY 14609	
TURNAROUND TIME: Standard Rush		Phone: 585-654-9080		Fax: 585-654-9662	
Other:		E-Mail: support@lozierenv.com		Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	Lead	REQUESTED ANALYSIS			
1	02-01-KI-IN-124A-T	9/24/2024	5:25		DW			kitchen hand wash sink	x				
2	02-01-KI-IN-124-T2	9/24/2024	5:25		DW			dish sink	x				
3	02-01-KI-IN-124-T3	9/24/2024	5:26		DW			dish sprayer	x				
4	02-01-KI-IN-124-T4	9/24/2024	5:28		DW			right prep sink	x				
5	02-01-KI-IN-124-T5	9/24/2024	5:28		DW			left prep sink	x				
6	02-01-KI-IN-124-T6	9/24/2024	5:30		DW			left serving hand sink	x				
7	02-01-KI-IN-124-T7	9/24/2024	5:31		DW			right serving hand sink	x				
8	02-01-CF-IN-124-FL	9/24/2024	5:34		DW				x				
9	02-01-CR-IN-124-FR	9/24/2024	5:35		DW				x				
10	02-01-CR-IN-124-BF	9/24/2024	5:35		DW				x				

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # 7790 92363485)

SAMPLED BY* Joe Savioe

RELINQUISHED BY*: Joe Savioe DATE: 10/8/24 TIME: 10:45

RECEIVED BY*: [Signature] DATE: 10/10/24 TIME: 10:40

RELINQUISHED BY*: DATE: TIME:

RECEIVED BY*: DATE: TIME:

RELINQUISHED BY*: DATE: TIME:

RECEIVED BY*: DATE: TIME:

FOR LAB USE ONLY

PRESERVATIVE/BIOCIDE: HNO3- TOTAL NUMBER OF CONTAINERS: _____

CUSTODY SEAL INTACT? YES NO

SAMPLE ON ICE? YES NO

TEMPERATURE: 9.7C

SAMPLE IN COMPLIANCE: YES NO

FOR POTABLE WATER ONLY:

COLIFORM BACTERIA:

Present Absent

If Present, Date Client is contacted with result:

Date: _____

Contacted By: _____

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis



REPORT TO:		INVOICE TO:	
Company:	Lozier Environmental Consulting, Inc.	Company: (SAME)	
Address:	2011 East Main Street	Address:	
City/State/Zip:	Rochester NY 14609	City/State/Zip:	
Phone:	585-654-9080	Phone:	
Fax:	585-654-9662	Fax:	
E-Mail:	support@lozierenv.com	Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS				
11	02-01-HA-BY-125A-B	9/24/2024	5:38		DW			fountain not bubbler	Lead				
12	02-01-HA-BY-125A-BF	9/24/2024	5:39		DW				1				
13	02-01-LI-IN-111-T	9/24/2024	5:43		DW				1				
14	02-01-HA-BY-133-B	9/24/2024	5:45		DW			fountain not bubbler	1				
15	02-01-HA-BY-133-BF	9/24/2024	5:46		DW				1				
16	02-01-CR-IN-112-TL	9/24/2024	5:50		DW				1				
17	02-01-CR-IN-112-TR	9/24/2024	5:50		DW				1				
18	02-01-CR-IN-115-B	9/24/2024	5:56		DW				1				
19	02-01-CR-IN-115-T	9/24/2024	5:58		DW				1				
20	02-01-CR-IN-116-B	9/24/2024	6:01		DW				1				

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # 778092563485) 740 BE 6RD

SAMPLED BY*: Joe Savioe

RELINQUISHED BY*: Joe Savioe DATE: 10/8/24 TIME: 10:45

RECEIVED BY: Alan Hsu DATE: 10/10/24 TIME: 10:40

RELINQUISHED BY: DATE: TIME:

RECEIVED BY: DATE: TIME:

RELINQUISHED BY*: DATE: TIME:

RECEIVED BY: DATE: TIME:

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDES: HNO3- TOTAL NUMBER OF CONTAINERS: _____ CUSTODY SEAL INTACT? YES <u>NO</u> SAMPLE ON ICE? YES <u>NO</u> TEMPERATURE: <u>19.7</u> C SAMPLE IN COMPLIANCE: YES NO	FOR POTABLE WATER ONLY: COLIFORM BACTERIA: Present Absent If Present, Date Client is contacted with result: Date: _____ Contacted By: _____



REPORT TO:		INVOICE TO:	
Company:	Lozier Environmental Consulting, Inc.	Company: (SAME)	
Address:	2011 East Main Street	Address:	
City/State Zip:	Rochester NY 14609	City/State Zip:	
Phone:	585-654-9080	Phone:	
Fax:	585-654-9662	Fax:	
E-Mail:	support@lozierenv.com	Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS				
21	02-01-CR-IN-116-T	9/24/2024	6:01		DW				Lead	1			
22	02-01-CR-IN-117-B	9/24/2024	6:03		DW					1			
23	02-01-CR-IN-117-T	9/24/2024	6:04		DW					1			
24	02-01-CR-IN-119-B	9/24/2024	6:07		DW					1			
25	02-01-CR-IN-119-T	9/24/2024	6:07		DW					1			
26	02-01-CR-IN-118-B	9/24/2024	6:09		DW					1			
27	02-01-CR-IN-118-T	9/24/2024	6:10		DW					1			
28	02-01-CR-IN-121-B	9/24/2024	6:13		DW					1			
29	02-01-NO-IN-121-T	9/24/2024	6:13		DW			CR not NO		1			
30	02-01-CR-IN-120-B	9/24/2024	6:17		DW					1			

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # 77909236 3485)

FED EX 6024

SAMPLED BY*: Joe Savioe

RELINQUISHED BY*: Joe Savioe DATE: 10/8/24 TIME: 10:45

RECEIVED BY: John Hsu DATE: 10/10/24 TIME: 10:50

RELINQUISHED BY*: DATE: TIME:

RECEIVED BY: DATE: TIME:

RELINQUISHED BY*: DATE: TIME:

RECEIVED BY: DATE: TIME:

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDES: HNO3- TOTAL NUMBER OF CONTAINERS: _____ CUSTODY SEAL INTACT? YES NO SAMPLE ON ICE? YES <u>NO</u> TEMPERATURE: <u>18.7</u> C SAMPLE IN COMPLIANCE: YES NO	FOR POTABLE WATER ONLY: COLIFORM BACTERIA: Present Absent If Present, Date Client is contacted with result: Date: _____ Contacted By: _____



REPORT TO:		INVOICE TO:	
Company:	Lozier Environmental Consulting, Inc.	Company: (SAME)	
Address:	2011 East Main Street	Address:	
City/State/Zip:	Rochester NY 14609	City/State/Zip:	
Phone:	585-654-9080	Phone:	
Fax:	585-654-9662	Fax:	
E-Mail:	support@lozierenv.com	Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS				
31	02-01-CR-IN-120-T	9/24/2024	6:18		DW			Lead	1				
32	02-01-CR-IN-152-B	9/24/2024	6:20		DW				1				
33	02-01-CR-IN-152-T	9/24/2024	6:21		DW				1				
34	02-01-CR-IN-154-B	9/24/2024	6:25		DW				1				
35	02-01-CR-IN-154-T	9/24/2024	6:25		DW				1				
36	02-01-HA-BY-155-FL	9/24/2024	6:26		DW				1				
37	02-01-HA-BY-155-FR	9/24/2024	6:26		DW				1				
38	02-01-HA-BY-155-BF	9/24/2024	6:27		DW				1				
39	02-01-CR-IN-102-B	9/24/2024	6:30		DW				1				
40	02-01-CR-IN-102-T	9/24/2024	6:31		DW				1				

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # 77A092363485) FEDEX GROUND

SAMPLED BY* Joe Savioe

RELINQUISHED BY*: Joe Savioe DATE: 10/8/24 TIME: 10:45

RECEIVED BY: [Signature] DATE: 10/10/24 TIME: 10:40

RELINQUISHED BY*: DATE: TIME:

RECEIVED BY: DATE: TIME:

RELINQUISHED BY*: DATE: TIME:

RECEIVED BY: DATE: TIME:

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDES: HNO3- TOTAL NUMBER OF CONTAINERS: _____ CUSTODY SEAL INTACT? YES NO SAMPLE ON ICE? YES <u>NO</u> TEMPERATURE: <u>14.7</u> C SAMPLE IN COMPLIANCE: YES NO	FOR POTABLE WATER ONLY: COLIFORM BACTERIA: Present Absent If Present, Date Client is contacted with result: Date: _____ Contacted By: _____

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page ____ of ____

LAB ID: M36200		Company: Lozier Environmental Consulting, Inc.		REPORT TO:		INVOICE TO:	
PROJECT NAME: RCSD - School No. 25		Address: 2011 East Main Street		City/State Zip: Rochester NY 14609		Company: (SAME)	
TURNAROUND TIME: Standard Rush		Phone: 585-654-9080		Fax: 585-654-9662		Address:	
Other:		E-Mail: support@lozierenv.com		Phone:		Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS				
81	02-02-CR-IN-205-B	9/25/2024	5:50		DW			1	Lead				
82	02-02-CR-IN-205-T	9/25/2024	5:51		DW			1					
83	02-02-CR-IN-206-B	9/25/2024	5:54		DW			1					
84	02-02-CR-IN-206-T	9/25/2024	5:55		DW			1					
85	02-02-CR-IN-203-B	9/25/2024	5:58		DW			1					
86	02-02-CR-IN-203-T	9/25/2024	5:58		DW			1					
87	02-02-CR-IN-204-B	9/25/2024	5:59		DW			1					
88	02-02-CR-IN-204-T	9/25/2024	6:00		DW			1					
89	02-02-CR-IN-258-B	9/25/2024	6:03		DW			1					
90	02-02-CR-IN-258-T	9/25/2024	6:04		DW			1					

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # 779092362560)

Fed Ex GRD

SAMPLED BY* Joe Savioe

RELINQUISHED BY* Joe Savioe

RECEIVED BY: JS

RELINQUISHED BY*:

RECEIVED BY:

RELINQUISHED BY*:

RECEIVED BY:

FOR LAB USE ONLY		FOR POTABLE WATER ONLY:	
PRESERVATIVE/BIOCIDES: HNO3-	TOTAL NUMBER OF CONTAINERS:	COLIFORM BACTERIA:	Present Absent
CUSTODY SEAL INTACT? YES NO	TEMPERATURE: <u>19.7</u> C	DATE: _____	contacted with result:
SAMPLE IN COMPLIANCE: YES NO		contacted By: _____	

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page ____ of ____

LAB ID: M36200		Company: Lozier Environmental Consulting, Inc.		REPORT TO:		INVOICE TO:	
PROJECT NAME: RCSD - School No. 25		Address: 2011 East Main Street		City, State Zip: Rochester NY 14609		Company: (SAME)	
TURNAROUND TIME: Standard Rush		Phone: 585-654-9080		Fax: 585-654-9662		Address:	
Other:		E-Mail: support@lozierenv.com		Purchase Order #:		City, State Zip:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS				
91	02-02-CR-IN-256-T	9/25/2024	6:07		DW			Lead	1				
92	02-02-HA-BY-254-FL	9/25/2024	6:09		DW				1				
93	02-02-HA-BY-254-FR	9/25/2024	6:09		DW				1				
94	02-02-HA-BY-254-BF	9/25/2024	6:10		DW				1				
95	02-02-CR-IN-221-B	9/25/2024	6:14		DW				1				
96	02-02-CR-IN-221-T	9/25/2024	6:15		DW				1				
97	02-02-CR-IN-222-B	9/25/2024	6:19		DW				1				
98	02-02-CR-IN-222-T	9/25/2024	6:19		DW				1				
99	02-02-CR-IN-220-B	9/25/2024	6:20		DW				1				
100	02-02-CR-IN-220-T	9/25/2024	6:21		DW				1				

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # 779092362560) *ESD Ex 6815*

SAMPLED BY* Joe Savioe

RELINQUISHED BY*: Joe Savioe DATE: 10/8/24 TIME: 10:45

RECEIVED BY: *Joe Savioe* DATE: 10/10/24 TIME: 10:40

RELINQUISHED BY*: DATE: TIME:

RECEIVED BY: DATE: TIME:

RELINQUISHED BY*: DATE: TIME:

RECEIVED BY: DATE: TIME:

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDES: HNO3- TOTAL NUMBER OF CONTAINERS: _____ CUSTODY SEAL INTACT? YES NO SAMPLE ON ICE? YES (NO) TEMPERATURE: 18.7 C SAMPLE IN COMPLIANCE: YES NO	FOR POTABLE WATER ONLY: COLIFORM BACTERIA: Present Absent If Present, Date Client is contacted with result: Date: _____ Contacted By: _____

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis



Web: /ozierFny.com

E-Mail: support@lone.com

Page of

Page 78 of 79

Environmental Consulting, Inc.	
REPORT TO:	
Company:	Lozier Environmental Consulting, Inc.
Address:	2011 East Main Street
City/State Zip:	Rochester NY 14609
Phone:	585-654-9080
Fax:	585-654-9662
E-Mail:	support@lozierenv.com
INVOICE TO:	
Company: (SAME)	
Address:	
City/State Zip:	
Phone:	
Fax:	
Purchase Order #:	

[illegible]

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # 7790 9236 2560)

SAMPLED BY* Joe Savioe

RELINQUISHED BY: ~~Joe~~ Joe Savioe DATE: 10/8/24 TIME: 10:45

RECEIVED BY: *CR* DATE: *10/10/24* TIME: *1040*

RELINQUISHED BY*: _____ DATE: _____ TIME: _____

RECEIVED BY:	DATE:	TIME:
--------------	-------	-------

RELINQUISHED BY*: DATE: TIME:

RECEIVED BY: _____ DATE: _____ TIME: _____

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDES: HNO3- TOTAL NUMBER OF CONTAINERS: _____ CUSTODY SEAL INTACT? YES NO SAMPLE ON ICE? YES NO TEMPERATURE: <u>19.7</u> C SAMPLE IN COMPLIANCE: YES NO	FOR POTABLE WATER ONLY COLIFORM BACTERIA: Present Absent If Present, Date Client is contacted with result: Date: _____ Contacted By: _____

Sample Condition Upon Receipt Form (SCUR)

Project # 24J1546
Client: Lozier

Date and Initials of person:
Examining contents: _____
Label: _____
Deliver to location: _____
pH: _____

Thermometer Used: IRG4 Date: 10/10 Time: 1040 Initials: _____

State of Origin: NY

Cooler #1 Temp. °C 4.7 (Visual) 0.2 @ 0.0°C, -0.5 @ 20.0°C (Correction Factor) _____ (Actual) ☒ Samples on ice, cooling process has begun

Courier: ☒ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☐ Pace ☐ Other _____

Shipping Method: ☐ First Overnight ☐ Priority Overnight ☐ Standard Overnight ☐ Ground

☐ Other _____

Tracking # 7790 9236 3485

Custody Seal on Cooler/Box Present: ☐ Yes ☐ No Seals intact: ☐ Yes ☐ No Ice: ☒ Wet ☐ Blue ☐ Melted ☐ None

Packing Material: ☐ Bubble Wrap ☐ Bubble Bags ☐ None ☐ Other _____

Samples were collected by Pace employee ☐ Yes ☐ No ☐ N/A

Comments:

Chain of Custody Present	☒ Yes ☐ No ☐ N/A	
Chain of Custody Filled Out	☒ Yes ☐ No ☐ N/A	
Relinquished Signature on COC	☒ Yes ☐ No ☐ N/A	
Sampler Name and Signature on COC	☒ Yes ☐ No ☐ N/A	
Samples Arrived within Hold Time	☒ Yes ☐ No ☐ N/A	
Rush TAT requested on COC	☐ Yes ☐ No ☐ N/A	
Sufficient Volume	☒ Yes ☐ No ☐ N/A	
Correct Containers Used	☒ Yes ☐ No ☐ N/A	
Containers Intact	☒ Yes ☐ No ☐ N/A	
Sample Labels match COC (sample IDs & date/time of collection)	☒ Yes ☐ No ☐ N/A	
All containers needing acid/base preservation have been checked.	☐ Yes ☐ No ☐ N/A	Preservation Information: Preservative: _____ Lot #/Trace #: _____ Date: _____ Time: _____ Initials: _____
All Containers needing preservation are found to be in compliance with EPA recommendation:	☐ Yes ☐ No ☐ N/A	
Exceptions: Vials, Microbiology, O&G, Metals		
Headspace in VOA Vials? (>6mm):	☐ Yes ☐ No ☐ N/A	
Trip Blank Present:	☐ Yes ☐ No ☐ N/A	

Additional Login Comments:

Client notification/ Resolution

Person Contacted: _____ Date/Time: _____
Comments/Resolution: _____