


November 20, 2023

V Kaptein
NB-Lozier Environmental Consulting, Inc
2011 E Main Street
Rochester, NY 14609

Project Location:
Project Number: Lozier Environmental Consulting
Laboratory Work Order Number: 23K1996

Enclosed are results of analyses for samples received by the laboratory on November 15, 2023. If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Project Manager

NB-Lozier Environmental Consulting, Inc
2011 E Main Street
Rochester, NY 14609
ATTN: V Kaptein

REPORT DATE: 11/20/2023

ANALYTICAL SUMMARY

The results of analyses performed on the following samples submitted to Pace Analytical Services, LLC - Newburgh are found in this report.

FIELD SAMPLE #	LAB ID:	MATRIX	SAMPLE DESCRIPTION	TEST	SUB LAB
09-01-CR-IN-135A-T (13)	23K1996-01	Drinking Water		EPA 200.8 Rev 5.4	
09-01-CR-IN-135-T (14)	23K1996-02	Drinking Water		EPA 200.8 Rev 5.4	
09-01-CR-IN-136-B (15)	23K1996-03	Drinking Water		EPA 200.8 Rev 5.4	
09-01-CR-IN-136-T (16)	23K1996-04	Drinking Water		EPA 200.8 Rev 5.4	
09-02-CR-IN-203-TR (27)	23K1996-05	Drinking Water		EPA 200.8 Rev 5.4	
09-02-CR-IN-204-T (28)	23K1996-06	Drinking Water		EPA 200.8 Rev 5.4	
09-02-CR-IN-205-B (29)	23K1996-07	Drinking Water		EPA 200.8 Rev 5.4	
09-02-CR-IN-205-T (30)	23K1996-08	Drinking Water		EPA 200.8 Rev 5.4	
09-02-CR-IN-207-B (32)	23K1996-09	Drinking Water		EPA 200.8 Rev 5.4	
09-02-CR-IN-207-T (33)	23K1996-10	Drinking Water		EPA 200.8 Rev 5.4	
09-02-CR-IN-221-T (34)	23K1996-11	Drinking Water		EPA 200.8 Rev 5.4	
09-02-CR-IN-222-T (35)	23K1996-12	Drinking Water		EPA 200.8 Rev 5.4	
09-02-CR-IN-228-T (36)	23K1996-13	Drinking Water		EPA 200.8 Rev 5.4	
09-02-TR-224-TR (38)	23K1996-14	Drinking Water		EPA 200.8 Rev 5.4	
09-03-CR-IN-303-TL (41)	23K1996-15	Drinking Water		EPA 200.8 Rev 5.4	
09-03-CR-IN-306-T (42)	23K1996-16	Drinking Water		EPA 200.8 Rev 5.4	
09-03-CR-IN-318-B (43)	23K1996-17	Drinking Water		EPA 200.8 Rev 5.4	
09-03-CR-IN-318-T (44)	23K1996-18	Drinking Water		EPA 200.8 Rev 5.4	
09-03-CR-IN-321-T (46)	23K1996-19	Drinking Water		EPA 200.8 Rev 5.4	
09-03-CR-IN-323-T (47)	23K1996-20	Drinking Water		EPA 200.8 Rev 5.4	
09-03-CR-IN-324-T (48)	23K1996-21	Drinking Water		EPA 200.8 Rev 5.4	
09-03-CR-327-B (TR-BY) (49)	23K1996-22	Drinking Water		EPA 200.8 Rev 5.4	
09-03-CR-328-T (TR-BY) (50)	23K1996-23	Drinking Water		EPA 200.8 Rev 5.4	
09-03-TR-BY-307-TR (51)	23K1996-24	Drinking Water		EPA 200.8 Rev 5.4	
09-01-CR-BY-134-F (62)	23K1996-25	Drinking Water		EPA 200.8 Rev 5.4	
09-01-CR-BY-134-BF (63)	23K1996-26	Drinking Water		EPA 200.8 Rev 5.4	
09-01-NO-IN-141-T (64)	23K1996-27	Drinking Water		EPA 200.8 Rev 5.4	
09-01-HA-BY-CCG1-FL (65)	23K1996-28	Drinking Water		EPA 200.8 Rev 5.4	
09-01-HA-BY-CCG1-FR (66)	23K1996-29	Drinking Water		EPA 200.8 Rev 5.4	
09-01-HA-BY-CCG1-BF (67)	23K1996-30	Drinking Water		EPA 200.8 Rev 5.4	
09-01-HA-BY-CC104-FL (68)	23K1996-31	Drinking Water		EPA 200.8 Rev 5.4	
09-01-HA-BY-CC104-FR (69)	23K1996-32	Drinking Water		EPA 200.8 Rev 5.4	
09-01-HA-BY-CC104-BF (70)	23K1996-33	Drinking Water		EPA 200.8 Rev 5.4	
09-01-CR-IN-CC104-T1 (71)	23K1996-34	Drinking Water		EPA 200.8 Rev 5.4	
09-01-CR-IN-CC104-T2 (72)	23K1996-35	Drinking Water		EPA 200.8 Rev 5.4	
09-01-CR-IN-CC104-T3 (73)	23K1996-36	Drinking Water		EPA 200.8 Rev 5.4	
09-01-CR-IN-CC104-T4 (74)	23K1996-37	Drinking Water		EPA 200.8 Rev 5.4	
09-01-HA-BY-2317-FL (75)	23K1996-38	Drinking Water		EPA 200.8 Rev 5.4	
09-01-HA-BY-2317-FR (76)	23K1996-39	Drinking Water		EPA 200.8 Rev 5.4	
09-01-HA-BY-2317-BF (77)	23K1996-40	Drinking Water		EPA 200.8 Rev 5.4	

NB-Lozier Environmental Consulting, Inc
2011 E Main Street
Rochester, NY 14609
ATTN: V Kaptein

REPORT DATE: 11/20/2023

ANALYTICAL SUMMARY

The results of analyses performed on the following samples submitted to Pace Analytical Services, LLC - Newburgh are found in this report.

FIELD SAMPLE #	LAB ID:	MATRIX	SAMPLE DESCRIPTION	TEST	SUB LAB
09-02-CR-IN-CC216-T (78)	23K1996-41	Drinking Water		EPA 200.8 Rev 5.4	
09-02-KI-IN-CC203-T (79)	23K1996-42	Drinking Water		EPA 200.8 Rev 5.4	
09-02-KI-IN-CC203-S (80)	23K1996-43	Drinking Water		EPA 200.8 Rev 5.4	
09-02-KI-IN-CC203-T (81)	23K1996-44	Drinking Water		EPA 200.8 Rev 5.4	
09-02-HA-BY-CC203-FL (82)	23K1996-45	Drinking Water		EPA 200.8 Rev 5.4	
09-02-HA-BY-CC203-FR (83)	23K1996-46	Drinking Water		EPA 200.8 Rev 5.4	
09-02-HA-BY-CC203-BF (84)	23K1996-47	Drinking Water		EPA 200.8 Rev 5.4	
09-02-HA-BY-227-F (85)	23K1996-48	Drinking Water		EPA 200.8 Rev 5.4	
09-02-HA-BY-227-BF (86)	23K1996-49	Drinking Water		EPA 200.8 Rev 5.4	
09-02-CR-IN-227-T (87)	23K1996-50	Drinking Water		EPA 200.8 Rev 5.4	
09-02-CR-IN-226-T (88)	23K1996-51	Drinking Water		EPA 200.8 Rev 5.4	
09-02-CR-IN-224-B (89)	23K1996-52	Drinking Water		EPA 200.8 Rev 5.4	
09-02-HA-BY-224-F (90)	23K1996-53	Drinking Water		EPA 200.8 Rev 5.4	
09-02-HA-BY-224-BF (91)	23K1996-54	Drinking Water		EPA 200.8 Rev 5.4	
09-02-CR-IN-220-TL (92)	23K1996-55	Drinking Water		EPA 200.8 Rev 5.4	
09-02-CR-IN-223-T (94)	23K1996-56	Drinking Water		EPA 200.8 Rev 5.4	
09-02-CR-IN-203-TL (95)	23K1996-57	Drinking Water		EPA 200.8 Rev 5.4	
09-02-CR-IN-200A-T (96)	23K1996-58	Drinking Water		EPA 200.8 Rev 5.4	
09-03-HA-BY-327-F (97)	23K1996-59	Drinking Water		EPA 200.8 Rev 5.4	
09-03-HA-BY-327-BR (98)	23K1996-60	Drinking Water		EPA 200.8 Rev 5.4	
09-03-CR-IN-305-T (100)	23K1996-61	Drinking Water		EPA 200.8 Rev 5.4	
09-03-CR-IN-304-T (101)	23K1996-62	Drinking Water		EPA 200.8 Rev 5.4	
09-03-CR-IN-303-TR (102)	23K1996-63	Drinking Water		EPA 200.8 Rev 5.4	
09-03-CR-IN-301-T (103)	23K1996-64	Drinking Water		EPA 200.8 Rev 5.4	
09-03-CR-IN-317-T (104)	23K1996-65	Drinking Water		EPA 200.8 Rev 5.4	
09-03-HA-BY-324-F (105)	23K1996-66	Drinking Water		EPA 200.8 Rev 5.4	
09-03-HA-BY-324-BF (106)	23K1996-67	Drinking Water		EPA 200.8 Rev 5.4	
09-03-CR-IN-326-T (107)	23K1996-68	Drinking Water		EPA 200.8 Rev 5.4	
09-03-CR-IN-322-T (108)	23K1996-69	Drinking Water		EPA 200.8 Rev 5.4	
09-03-CR-IN-320-TR (109)	23K1996-70	Drinking Water		EPA 200.8 Rev 5.4	
09-01-CR-IN0130B-FRI (110)	23K1996-71	Drinking Water		EPA 200.8 Rev 5.4	
09-01-CR-IN-129A-T (111)	23K1996-72	Drinking Water		EPA 200.8 Rev 5.4	
09-01-CR-IN-126A-T (112)	23K1996-73	Drinking Water		EPA 200.8 Rev 5.4	

CASE NARRATIVE SUMMARY

All reported results are within defined laboratory quality control objectives unless listed below or otherwise qualified in this report.

EPA 200.8 Rev 5.4

Qualifications:

Z-01

#


Analyte & Samples(s) Qualified:

Lead

23K1996-06[09-02-CR-IN-204-T (28)], 23K1996-07[09-02-CR-IN-205-B (29)], 23K1996-09[09-02-CR-IN-207-B (32)], 23K1996-10[09-02-CR-IN-207-T (33)], 23K1996-11[09-02-CR-IN-221-T (34)], 23K1996-12[09-02-CR-IN-222-T (35)], 23K1996-13[09-02-CR-IN-228-T (36)], 23K1996-14[09-02-TR-224-TR (38)], 23K1996-15[09-03-CR-IN-303-TL (41)], 23K1996-16[09-03-CR-IN-306-T (42)], 23K1996-17[09-03-CR-IN-318-B (43)], 23K1996-18[09-03-CR-IN-318-T (44)], 23K1996-20[09-03-CR-IN-323-T (47)], 23K1996-22[09-03-CR-327-B (TR-BY) (49)], 23K1996-23[09-03-CR-328-T (TR-BY) (50)], 23K1996-24[09-03-TR-BY-307-TR (51)], 23K1996-36[09-01-CR-IN-CC104-T3 (73)], 23K1996-37[09-01-CR-IN-CC104-T4 (74)], 23K1996-46[09-02-HA-BY-CC203-FR (83)], 23K1996-51[09-02-CR-IN-226-T (88)], 23K1996-52[09-02-CR-IN-224-B (89)], 23K1996-55[09-02-CR-IN-220-TL (92)], 23K1996-56[09-02-CR-IN-223-T (94)], 23K1996-57[09-02-CR-IN-203-TL (95)], 23K1996-58[09-02-CR-IN-200A-T (96)], 23K1996-61[09-03-CR-IN-305-T (100)], 23K1996-62[09-03-CR-IN-304-T (101)], 23K1996-65[09-03-CR-IN-317-T (104)], 23K1996-68[09-03-CR-IN-326-T (107)], 23K1996-72[09-01-CR-IN-129A-T (111)], 23K1996-73[09-01-CR-IN-126A-T (112)]

The results of analyses reported only relate to samples submitted to the Pace Analytical Services, LLC - Newburgh for testing.

I certify that the analyses listed above, unless specifically listed as subcontracted, if any, were performed under my direction according to the approved methodologies listed in this document, and that based upon my inquiry of those individuals immediately responsible for obtaining the information, the material contained in this report is, to the best of my knowledge and belief, accurate and complete.



Renee Cusack
PM

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-01-CR-IN-135A-T (13)

Sampled: 11/7/2023 07:06

Sample ID: 23K1996-01

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	1.2	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	11/17/23	11/17/23 11:19	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-01-CR-IN-135-T (14)

Sampled: 11/7/2023 07:04

Sample ID: 23K1996-02

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	3.4	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	11/17/23	11/17/23 11:29	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-01-CR-IN-136-B (15)

Sampled: 11/7/2023 07:09

Sample ID: 23K1996-03

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	1.4	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	11/17/23	11/17/23 11:32	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-01-CR-IN-136-T (16)

Sampled: 11/7/2023 07:09

Sample ID: 23K1996-04

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	1.3	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	11/17/23	11/17/23 11:34	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-02-CR-IN-203-TR (27)

Sampled: 11/7/2023 08:00

Sample ID: 23K1996-05

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	14	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	11/17/23	11/17/23 11:36	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-02-CR-IN-204-T (28)

Sampled: 11/7/2023 08:10

Sample ID: 23K1996-06

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
# Lead	30	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	11/17/23	11/17/23 11:39	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-02-CR-IN-205-B (29)

Sampled: 11/7/2023 08:16

Sample ID: 23K1996-07

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
# Lead	21	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	11/17/23	11/17/23 11:46	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-02-CR-IN-205-T (30)

Sampled: 11/7/2023 08:17

Sample ID: 23K1996-08

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	12	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	11/17/23	11/17/23 11:48	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-02-CR-IN-207-B (32)

Sampled: 11/7/2023 08:13

Sample ID: 23K1996-09

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
# Lead	32	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	11/17/23	11/17/23 11:51	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-02-CR-IN-207-T (33)

Sampled: 11/7/2023 08:14

Sample ID: 23K1996-10

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
# Lead	23	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	11/17/23	11/17/23 11:53	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-02-CR-IN-221-T (34)

Sampled: 11/7/2023 08:08

Sample ID: 23K1996-11

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
# Lead	59	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	11/17/23	11/17/23 11:56	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-02-CR-IN-222-T (35)

Sampled: 11/7/2023 08:11

Sample ID: 23K1996-12

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
# Lead	39	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	11/17/23	11/17/23 12:01	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-02-CR-IN-228-T (36)

Sampled: 11/7/2023 07:51

Sample ID: 23K1996-13

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
# Lead	39	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	11/17/23	11/17/23 12:03	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-02-TR-224-TR (38)

Sampled: 11/7/2023 08:00

Sample ID: 23K1996-14

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
# Lead	440	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	11/17/23	11/17/23 12:05	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-03-CR-IN-303-TL (41)

Sampled: 11/7/2023 08:39

Sample ID: 23K1996-15

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
# Lead	22	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	11/17/23	11/17/23 12:08	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-03-CR-IN-306-T (42)

Sampled: 11/7/2023 08:36

Sample ID: 23K1996-16

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
# Lead	28	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	11/17/23	11/17/23 12:15	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-03-CR-IN-318-B (43)

Sampled: 11/9/2023 06:22

Sample ID: 23K1996-17

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
# Lead	40	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	11/17/23	11/17/23 12:18	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-03-CR-IN-318-T (44)

Sampled: 11/9/2023 06:22

Sample ID: 23K1996-18

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
# Lead	35	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	11/17/23	11/17/23 12:20	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-03-CR-IN-321-T (46)

Sampled: 11/9/2023 06:38

Sample ID: 23K1996-19

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	4.6	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	11/17/23	11/17/23 12:22	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-03-CR-IN-323-T (47)

Sampled: 11/9/2023 06:35

Sample ID: 23K1996-20

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
# Lead	17	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	11/17/23	11/17/23 12:25	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-03-CR-IN-324-T (48)

Sampled: 11/9/2023 06:34

Sample ID: 23K1996-21

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	10	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	11/17/23	11/17/23 12:27	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-03-CR-327-B (TR-BY) (49)

Sampled: 11/9/2023 06:29

Sample ID: 23K1996-22

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
# Lead	50	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	11/17/23	11/17/23 12:37	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-03-CR-328-T (TR-BY) (50)

Sampled: 11/7/2023 08:30

Sample ID: 23K1996-23

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
# Lead	31	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	11/17/23	11/17/23 12:44	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-03-TR-BY-307-TR (51)

Sampled: 11/7/2023 08:34

Sample ID: 23K1996-24

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
# Lead	140	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	11/17/23	11/17/23 12:47	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-01-CR-BY-134-F (62)

Sampled: 11/7/2023 07:03

Sample ID: 23K1996-25

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	11/17/23	11/17/23 12:49	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-01-CR-BY-134-BF (63)

Sampled: 11/7/2023 07:04

Sample ID: 23K1996-26

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	11/17/23	11/17/23 12:52	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-01-NO-IN-141-T (64)

Sampled: 11/7/2023 07:12

Sample ID: 23K1996-27

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	11/17/23	11/17/23 12:54	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-01-HA-BY-CCG1-FL (65)

Sampled: 11/7/2023 07:16

Sample ID: 23K1996-28

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	11/17/23	11/17/23 12:56	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-01-HA-BY-CCG1-FR (66)

Sampled: 11/7/2023 07:17

Sample ID: 23K1996-29

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	11/17/23	11/17/23 12:59	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-01-HA-BY-CCG1-BF (67)

Sampled: 11/7/2023 07:17

Sample ID: 23K1996-30

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	11/17/23	11/17/23 13:01	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-01-HA-BY-CC104-FL (68)

Sampled: 11/7/2023 06:19

Sample ID: 23K1996-31

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	11/17/23	11/17/23 13:04	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-01-HA-BY-CC104-FR (69)

Sampled: 11/7/2023 06:20

Sample ID: 23K1996-32

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	11/17/23	11/17/23 13:13	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-01-HA-BY-CC104-BF (70)

Sampled: 11/7/2023 06:20

Sample ID: 23K1996-33

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	11/17/23	11/17/23 13:16	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-01-CR-IN-CC104-T1 (71)

Sampled: 11/7/2023 07:22

Sample ID: 23K1996-34

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	3.5	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	11/17/23	11/17/23 13:18	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-01-CR-IN-CC104-T2 (72)

Sampled: 11/7/2023 07:24

Sample ID: 23K1996-35

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	2.0	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	11/17/23	11/17/23 13:21	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-01-CR-IN-CC104-T3 (73)

Sampled: 11/7/2023 07:26

Sample ID: 23K1996-36

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
# Lead	64	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	11/17/23	11/17/23 13:23	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-01-CR-IN-CC104-T4 (74)

Sampled: 11/7/2023 07:26

Sample ID: 23K1996-37

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
# Lead	78	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	11/17/23	11/17/23 13:26	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-01-HA-BY-2317-FL (75)

Sampled: 11/7/2023 07:29

Sample ID: 23K1996-38

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	11/17/23	11/17/23 13:33	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-01-HA-BY-2317-FR (76)

Sampled: 11/7/2023 07:30

Sample ID: 23K1996-39

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	11/17/23	11/17/23 13:51	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-01-HA-BY-2317-BF (77)

Sampled: 11/7/2023 07:30

Sample ID: 23K1996-40

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	11/17/23	11/17/23 13:53	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-02-CR-IN-CC216-T (78)

Sampled: 11/7/2023 07:34

Sample ID: 23K1996-41

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	4.5	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	11/17/23	11/17/23 13:56	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-02-KI-IN-CC203-T (79)

Sampled: 11/7/2023 07:36

Sample ID: 23K1996-42

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	2.4	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	11/17/23	11/17/23 13:58	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-02-KI-IN-CC203-S (80)

Sampled: 11/7/2023 07:37

Sample ID: 23K1996-43

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	2.8	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	11/17/23	11/17/23 14:01	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-02-KI-IN-CC203-T (81)

Sampled: 11/7/2023 07:37

Sample ID: 23K1996-44

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	6.0	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	11/17/23	11/17/23 14:03	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-02-HA-BY-CC203-FL (82)

Sampled: 11/7/2023 07:39

Sample ID: 23K1996-45

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	11/17/23	11/17/23 14:06	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-02-HA-BY-CC203-FR (83)

Sampled: 11/7/2023 07:40

Sample ID: 23K1996-46

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
# Lead	210	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	11/17/23	11/17/23 14:08	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-02-HA-BY-CC203-BF (84)

Sampled: 11/7/2023 07:41

Sample ID: 23K1996-47

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	11/17/23	11/17/23 14:15	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-02-HA-BY-227-F (85)

Sampled: 11/7/2023 07:54

Sample ID: 23K1996-48

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	11/17/23	11/17/23 14:18	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-02-HA-BY-227-BF (86)

Sampled: 11/7/2023 07:56

Sample ID: 23K1996-49

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	11/17/23	11/17/23 14:23	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-02-CR-IN-227-T (87)

Sampled: 11/7/2023 07:56

Sample ID: 23K1996-50

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	9.2	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	11/17/23	11/17/23 14:25	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-02-CR-IN-226-T (88)

Sampled: 11/7/2023 07:56

Sample ID: 23K1996-51

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
# Lead	40	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	11/17/23	11/17/23 14:27	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-02-CR-IN-224-B (89)

Sampled: 11/7/2023 08:00

Sample ID: 23K1996-52

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
# Lead	65	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	11/17/23	11/17/23 14:30	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-02-HA-BY-224-F (90)

Sampled: 11/7/2023 08:02

Sample ID: 23K1996-53

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	11/17/23	11/17/23 14:32	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-02-HA-BY-224-BF (91)

Sampled: 11/7/2023 08:04

Sample ID: 23K1996-54

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	11/17/23	11/17/23 14:35	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-02-CR-IN-220-TL (92)

Sampled: 11/7/2023 08:05

Sample ID: 23K1996-55

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
# Lead	61	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	11/17/23	11/17/23 14:37	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-02-CR-IN-223-T (94)

Sampled: 11/7/2023 08:09

Sample ID: 23K1996-56

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
# Lead	52	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	11/17/23	11/17/23 14:44	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-02-CR-IN-203-TL (95)

Sampled: 11/7/2023 08:21

Sample ID: 23K1996-57

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
# Lead	31	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	11/17/23	11/17/23 14:47	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-02-CR-IN-200A-T (96)

Sampled: 11/7/2023 08:26

Sample ID: 23K1996-58

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
# Lead	69	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	11/17/23	11/17/23 14:49	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-03-HA-BY-327-F (97)

Sampled: 11/7/2023 08:29

Sample ID: 23K1996-59

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	11/17/23	11/17/23 14:59	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-03-HA-BY-327-BR (98)

Sampled: 11/7/2023 08:29

Sample ID: 23K1996-60

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	11/17/23	11/17/23 15:01	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-03-CR-IN-305-T (100)

Sampled: 11/7/2023 08:37

Sample ID: 23K1996-61

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
# Lead	23	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	11/17/23	11/17/23 15:04	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-03-CR-IN-304-T (101)

Sampled: 11/7/2023 08:38

Sample ID: 23K1996-62

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
# Lead	27	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	11/17/23	11/17/23 15:06	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-03-CR-IN-303-TR (102)

Sampled: 11/7/2023 08:39

Sample ID: 23K1996-63

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	11	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	11/17/23	11/17/23 15:13	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-03-CR-IN-301-T (103)

Sampled: 11/7/2023 08:43

Sample ID: 23K1996-64

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	14	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	11/17/23	11/17/23 15:16	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-03-CR-IN-317-T (104)

Sampled: 11/9/2023 06:24

Sample ID: 23K1996-65

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
# Lead	58	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	11/17/23	11/17/23 15:18	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-03-HA-BY-324-F (105)

Sampled: 11/9/2023 06:27

Sample ID: 23K1996-66

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	11/17/23	11/17/23 15:21	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-03-HA-BY-324-BF (106)

Sampled: 11/9/2023 06:27

Sample ID: 23K1996-67

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	11/17/23	11/17/23 15:23	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-03-CR-IN-326-T (107)

Sampled: 11/9/2023 06:31

Sample ID: 23K1996-68

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
# Lead	47	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	11/17/23	11/17/23 15:26	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-03-CR-IN-322-T (108)

Sampled: 11/9/2023 06:37

Sample ID: 23K1996-69

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	9.6	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	11/17/23	11/17/23 15:30	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-03-CR-IN-320-TR (109)

Sampled: 11/9/2023 06:40

Sample ID: 23K1996-70

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
# Lead	85	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	11/17/23	11/17/23 15:33	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-01-CR-IN0130B-FRI (110)

Sampled: 11/9/2023 06:46

Sample ID: 23K1996-71

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	1.5	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	11/17/23	11/17/23 15:35	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-01-CR-IN-129A-T (111)

Sampled: 11/9/2023 06:50

Sample ID: 23K1996-72

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
# Lead	50	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	11/17/23	11/17/23 15:42	EMC

Project Location:

Sample Description:

Work Order: 23K1996

Date Received: 11/15/2023

Field Sample #: 09-01-CR-IN-126A-T (112)

Sampled: 11/9/2023 06:55

Sample ID: 23K1996-73

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
# Lead	43	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	11/17/23	11/17/23 15:45	EMC

Sample Extraction Data

Prep Method: NB EPA 200.8 Analytical Method: EPA 200.8 Rev 5.4

Lab Number [Field ID]	Batch	Initial [mL]	Final [mL]	Date
23K1996-01 [09-01-CR-IN-135A-T (13)]	B358447	50.0	50.0	11/17/23
23K1996-02 [09-01-CR-IN-135-T (14)]	B358447	50.0	50.0	11/17/23
23K1996-03 [09-01-CR-IN-136-B (15)]	B358447	50.0	50.0	11/17/23
23K1996-04 [09-01-CR-IN-136-T (16)]	B358447	50.0	50.0	11/17/23
23K1996-05 [09-02-CR-IN-203-TR (27)]	B358447	50.0	50.0	11/17/23
23K1996-06 [09-02-CR-IN-204-T (28)]	B358447	50.0	50.0	11/17/23
23K1996-07 [09-02-CR-IN-205-B (29)]	B358447	50.0	50.0	11/17/23
23K1996-08 [09-02-CR-IN-205-T (30)]	B358447	50.0	50.0	11/17/23
23K1996-09 [09-02-CR-IN-207-B (32)]	B358447	50.0	50.0	11/17/23
23K1996-10 [09-02-CR-IN-207-T (33)]	B358447	50.0	50.0	11/17/23
23K1996-11 [09-02-CR-IN-221-T (34)]	B358447	50.0	50.0	11/17/23
23K1996-12 [09-02-CR-IN-222-T (35)]	B358447	50.0	50.0	11/17/23
23K1996-13 [09-02-CR-IN-228-T (36)]	B358447	50.0	50.0	11/17/23
23K1996-14 [09-02-TR-224-TR (38)]	B358447	50.0	50.0	11/17/23
23K1996-15 [09-03-CR-IN-303-TL (41)]	B358447	50.0	50.0	11/17/23
23K1996-16 [09-03-CR-IN-306-T (42)]	B358447	50.0	50.0	11/17/23
23K1996-17 [09-03-CR-IN-318-B (43)]	B358447	50.0	50.0	11/17/23
23K1996-18 [09-03-CR-IN-318-T (44)]	B358447	50.0	50.0	11/17/23
23K1996-19 [09-03-CR-IN-321-T (46)]	B358447	50.0	50.0	11/17/23
23K1996-20 [09-03-CR-IN-323-T (47)]	B358447	50.0	50.0	11/17/23
23K1996-21 [09-03-CR-IN-324-T (48)]	B358447	50.0	50.0	11/17/23
23K1996-22 [09-03-CR-327-B (TR-BY) (49)]	B358447	50.0	50.0	11/17/23
23K1996-23 [09-03-CR-328-T (TR-BY) (50)]	B358447	50.0	50.0	11/17/23
23K1996-24 [09-03-TR-BY-307-TR (51)]	B358447	50.0	50.0	11/17/23
23K1996-25 [09-01-CR-BY-134-F (62)]	B358447	50.0	50.0	11/17/23
23K1996-26 [09-01-CR-BY-134-BF (63)]	B358447	50.0	50.0	11/17/23
23K1996-27 [09-01-NO-IN-141-T (64)]	B358447	50.0	50.0	11/17/23
23K1996-28 [09-01-HA-BY-CCG1-FL (65)]	B358447	50.0	50.0	11/17/23
23K1996-29 [09-01-HA-BY-CCG1-FR (66)]	B358447	50.0	50.0	11/17/23
23K1996-30 [09-01-HA-BY-CCG1-BF (67)]	B358447	50.0	50.0	11/17/23
23K1996-31 [09-01-HA-BY-CC104-FL (68)]	B358447	50.0	50.0	11/17/23
23K1996-32 [09-01-HA-BY-CC104-FR (69)]	B358447	50.0	50.0	11/17/23
23K1996-33 [09-01-HA-BY-CC104-BF (70)]	B358447	50.0	50.0	11/17/23
23K1996-34 [09-01-CR-IN-CC104-T1 (71)]	B358447	50.0	50.0	11/17/23
23K1996-35 [09-01-CR-IN-CC104-T2 (72)]	B358447	50.0	50.0	11/17/23
23K1996-36 [09-01-CR-IN-CC104-T3 (73)]	B358447	50.0	50.0	11/17/23
23K1996-37 [09-01-CR-IN-CC104-T4 (74)]	B358447	50.0	50.0	11/17/23

Prep Method: NB EPA 200.8 Analytical Method: EPA 200.8 Rev 5.4

Lab Number [Field ID]	Batch	Initial [mL]	Final [mL]	Date
23K1996-38 [09-01-HA-BY-2317-FL (75)]	B358471	50.0	50.0	11/17/23
23K1996-39 [09-01-HA-BY-2317-FR (76)]	B358471	50.0	50.0	11/17/23
23K1996-40 [09-01-HA-BY-2317-BF (77)]	B358471	50.0	50.0	11/17/23
23K1996-41 [09-02-CR-IN-CC216-T (78)]	B358471	50.0	50.0	11/17/23
23K1996-42 [09-02-KI-IN-CC203-T (79)]	B358471	50.0	50.0	11/17/23
23K1996-43 [09-02-KI-IN-CC203-S (80)]	B358471	50.0	50.0	11/17/23
23K1996-44 [09-02-KI-IN-CC203-T (81)]	B358471	50.0	50.0	11/17/23
23K1996-45 [09-02-HA-BY-CC203-FL (82)]	B358471	50.0	50.0	11/17/23
23K1996-46 [09-02-HA-BY-CC203-FR (83)]	B358471	50.0	50.0	11/17/23
23K1996-47 [09-02-HA-BY-CC203-BF (84)]	B358471	50.0	50.0	11/17/23
23K1996-48 [09-02-HA-BY-227-F (85)]	B358471	50.0	50.0	11/17/23
23K1996-49 [09-02-HA-BY-227-BF (86)]	B358471	50.0	50.0	11/17/23

Sample Extraction Data

Prep Method: NB EPA 200.8 Analytical Method: EPA 200.8 Rev 5.4

Lab Number [Field ID]	Batch	Initial [mL]	Final [mL]	Date
23K1996-50 [09-02-CR-IN-227-T (87)]	B358471	50.0	50.0	11/17/23
23K1996-51 [09-02-CR-IN-226-T (88)]	B358471	50.0	50.0	11/17/23
23K1996-52 [09-02-CR-IN-224-B (89)]	B358471	50.0	50.0	11/17/23
23K1996-53 [09-02-HA-BY-224-F (90)]	B358471	50.0	50.0	11/17/23
23K1996-54 [09-02-HA-BY-224-BF (91)]	B358471	50.0	50.0	11/17/23
23K1996-55 [09-02-CR-IN-220-TL (92)]	B358471	50.0	50.0	11/17/23
23K1996-56 [09-02-CR-IN-223-T (94)]	B358471	50.0	50.0	11/17/23
23K1996-57 [09-02-CR-IN-203-TL (95)]	B358471	50.0	50.0	11/17/23
23K1996-58 [09-02-CR-IN-200A-T (96)]	B358471	50.0	50.0	11/17/23
23K1996-59 [09-03-HA-BY-327-F (97)]	B358471	50.0	50.0	11/17/23
23K1996-60 [09-03-HA-BY-327-BR (98)]	B358471	50.0	50.0	11/17/23
23K1996-61 [09-03-CR-IN-305-T (100)]	B358471	50.0	50.0	11/17/23
23K1996-62 [09-03-CR-IN-304-T (101)]	B358471	50.0	50.0	11/17/23
23K1996-63 [09-03-CR-IN-303-TR (102)]	B358471	50.0	50.0	11/17/23
23K1996-64 [09-03-CR-IN-301-T (103)]	B358471	50.0	50.0	11/17/23
23K1996-65 [09-03-CR-IN-317-T (104)]	B358471	50.0	50.0	11/17/23
23K1996-66 [09-03-HA-BY-324-F (105)]	B358471	50.0	50.0	11/17/23
23K1996-67 [09-03-HA-BY-324-BF (106)]	B358471	50.0	50.0	11/17/23
23K1996-68 [09-03-CR-IN-326-T (107)]	B358471	50.0	50.0	11/17/23
23K1996-69 [09-03-CR-IN-322-T (108)]	B358471	50.0	50.0	11/17/23
23K1996-70 [09-03-CR-IN-320-TR (109)]	B358471	50.0	50.0	11/17/23
23K1996-71 [09-01-CR-IN0130B-FRI (110)]	B358471	50.0	50.0	11/17/23
23K1996-72 [09-01-CR-IN-129A-T (111)]	B358471	50.0	50.0	11/17/23
23K1996-73 [09-01-CR-IN-126A-T (112)]	B358471	50.0	50.0	11/17/23

QUALITY CONTROL

Metals Analyses (Total) - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
Batch B358447 - NB EPA 200.8										
Blank (B358447-BLK1)				Prepared & Analyzed: 11/17/23						
Lead	ND	1.0	µg/L							
LCS (B358447-BS1)				Prepared & Analyzed: 11/17/23						
Lead	51.9	1.0	µg/L	50.0		104	85-115			
Duplicate (B358447-DUP1)				Prepared & Analyzed: 11/17/23						
Lead	1.15	1.0	µg/L		1.17			2.12	20	
Duplicate (B358447-DUP2)				Prepared & Analyzed: 11/17/23						
Lead	10.5	1.0	µg/L		10.4			1.14	20	
Matrix Spike (B358447-MS1)				Prepared & Analyzed: 11/17/23						
Lead	55.0	1.0	µg/L	50.0	1.17	108	70-130			
Matrix Spike (B358447-MS2)				Prepared & Analyzed: 11/17/23						
Lead	113	1.0	µg/L	50.0	59.1	108	70-130			
Matrix Spike (B358447-MS3)				Prepared & Analyzed: 11/17/23						
Lead	65.4	1.0	µg/L	50.0	10.4	110	70-130			
Matrix Spike (B358447-MS4)				Prepared & Analyzed: 11/17/23						
Lead	55.9	1.0	µg/L	50.0	ND	112	70-130			
Batch B358471 - NB EPA 200.8										
Blank (B358471-BLK1)				Prepared & Analyzed: 11/17/23						
Lead	ND	1.0	µg/L							
LCS (B358471-BS1)				Prepared & Analyzed: 11/17/23						
Lead	47.0	1.0	µg/L	50.0		94.0	85-115			
Duplicate (B358471-DUP1)				Prepared & Analyzed: 11/17/23						
Lead	ND	1.0	µg/L		ND			NC	20	
Duplicate (B358471-DUP2)				Prepared & Analyzed: 11/17/23						
Lead	68.9	1.0	µg/L		69.3			0.499	20	
Matrix Spike (B358471-MS1)				Prepared & Analyzed: 11/17/23						
Lead	56.8	1.0	µg/L	50.0	ND	114	70-130			
Matrix Spike (B358471-MS2)				Prepared & Analyzed: 11/17/23						
Lead	57.4	1.0	µg/L	50.0	ND	115	70-130			

QUALITY CONTROL

Metals Analyses (Total) - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
---------	--------	--------------------	-------	----------------	------------------	------	----------------	-----	--------------	-------

Batch B358471 - NB EPA 200.8

Matrix Spike (B358471-MS3)		Source: 23K1996-58			Prepared & Analyzed: 11/17/23					
Lead	126	1.0	µg/L	50.0	69.3	114	70-130			
Matrix Spike (B358471-MS4)		Source: 23K1996-68			Prepared & Analyzed: 11/17/23					
Lead	106	1.0	µg/L	50.0	46.8	118	70-130			

FLAG/QUALIFIER SUMMARY

*	QC result is outside of established limits.
†	Wide recovery limits established for difficult compound.
‡	Wide RPD limits established for difficult compound.
#	Data exceeded client recommended or regulatory level
ND	Not Detected
RL	Reporting Limit is at the level of quantitation (LOQ)
DL	Detection Limit is the lower limit of detection determined by the MDL study
MCL	Maximum Contaminant Level
	Percent recoveries and relative percent differences (RPDs) are determined by the software using values in the calculation which have not been rounded.
	No results have been blank subtracted unless specified in the case narrative section.
Z-01	#

CERTIFICATIONS

Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 200.8 Rev 5.4 in Drinking Water</i>	
Lead	NB-CT,NB-NJ,NB-NY

Pace Analytical Services, LCC operates under the following certifications and accreditations:

Code	Description	Number	Expires
NB-CT	Connecticut Department of Public Health	PH-0823	09/30/2024
NB-NJ	New Jersey DEP	NY015 NELAP	06/30/2023
NB-NY	New York State Department of Health	10142 NELAP	04/1/2024



2011 East Main Street, Rochester, NY 14609 Phone (585) 654-9080 Fax (585) 654-9662
Web: LozierEnv.com E-Mail: support@lozierenv.com

REPORT TO:		INVOICE TO:	
Company:	Lozier Environmental Consulting, Inc.	Company:	SAME
Address:	2011 East Main Street	Address:	
City, State Zip:	Rochester, New York 14609	City, State Zip:	
Phone:		Phone:	
Fax:		Fax:	
E-Mail:	vkaptain@lozierenv.com	Purchase Order #:	

LAB ID: M33476	PROJECT NAME: RCD Dr. Martin Luther King Jr. School No. 9
TURNAROUND TIME: Standard Rush	Other:

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	LEAD	REQUESTED ANALYSIS			
1	09-01-CR-IN-103-TR	11/7/23	650		DW				X				
2	09-01-CR-IN-105-T		654										
3	09-01-CR-IN-106-T		655										
4	09-01-CR-IN-107-T		657										
5	09-01-CR-IN-120-BR		641										
6	09-01-CR-IN-120-TR		630										
7	09-01-CR-IN-121-T		637										
8	09-01-CR-IN-122-T		636										
9	09-01-CR-IN-123-T		635										
10	09-01-CR-IN-124-T		633										



Container Type (Circle One): Plastic Glass Sterile Other _____
Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)
BIOCIDES: _____

SAMPLED BY*: J. Savioe / F. Golioch

RELINQUISHED BY*: V. Kaptain	DATE: 11/10/23	TIME: 1000
RECEIVED BY:	DATE: 11/5	TIME: 1100
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:

FOR LAB USE ONLY	
PRESERVATIVE: HNO3-	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINERS: 73	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES NO	Present Absent
SAMPLE ON ICE? YES NO	If Present, Date Client is contacted with result:
TEMPERATURE: 11.6 C	Date: _____
SAMPLE IN COMPLIANCE: YES NO	Contacted By: _____

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis



2011 East Main Street, Rochester, NY 14609 Phone (585) 654-9080 Fax (585) 654-9662
Web: LozierEnv.com E-Mail: support@lozierenv.com

Page 2 of 10

REPORT TO:		INVOICE TO:	
Company:	Lozier Environmental Consulting, Inc.	Company:	SAME
Address:	2011 East Main Street	Address:	
City/State/Zip:	Rochester, New York 14609	City/State/Zip:	

City/State/Zip:	Rochester, New York 14609	City/State/Zip:	
Phone:		Phone:	
Fax:		Fax:	
E-Mail:	vkaptein@lozierenv.com	Purchase Order #:	

LAB ID: M33476
PROJECT NAME: RCSD Dr. Martin Luther King Jr. School No. 9
TURNAROUND TIME: Standard Rush
Other:

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS			
									LEAD			
11 *	09-01-CR-IN-134-T	11/7/23	702		DW				X			
13	09-01-CR-IN-135A-T		706									
14	09-01-CR-IN-135-T		704									
15	09-01-CR-IN-136-B		709									
16	09-01-CR-IN-136-T		709									
17 *	09-01-HA-BY-125A-F		620									
19 *	09-01-KI-IN-143-T		617									
24 *	09-01-RM-IN-100-T		646									
25 *	09-01-TL-IN-130B-T		623									
27	09-02-CR-IN-203-TR		0800									

Container Type (Circle One): Plastic Glass Sterile Other

Delivery (Circle One): Client Drop-Off / Courier (Tracking #)

BIOCIDE:

SAMPLED BY*: J. Savioe / F. Gololuch

RELINQUISHED BY*: X. Kaptein	DATE: 11/10/23	TIME: 1000
RECEIVED BY: <u>JP</u>	DATE: 11/15	TIME: 1100
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:

FOR LAB USE ONLY	
PRESERVATIVE: HNO3-	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINERS: 73	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES NO	Present Absent
SAMPLE ON ICE? YES NO	If Present, Date Client is contacted with result:
TEMPERATURE: 11.6 C	Date:
SAMPLE IN COMPLIANCE: YES NO	Contacted By:

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis



2011 East Main Street, Rochester, NY 14609 Phone (585) 654-9080 Fax (585) 654-9662
Web: LozierEnv.com E-Mail: support@lozierenv.com

Page 2 of 10

REPORT TO:		INVOICE TO:	
Company:	Lozier Environmental Consulting, Inc.	Company:	SAME
Address:	2011 East Main Street	Address:	
City/State Zip:	Rochester, New York 14609	City/State Zip:	
Phone:		Phone:	
Fax:		Fax:	
E-Mail:	vkaptain@lozierenv.com	Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	LEAD	REQUESTED ANALYSIS			
28	09-02-CR-IN-204-T	11/7/23	0810		DW				X				
29	09-02-CR-IN-205-B		0816										
30	09-02-CR-IN-205-T		0817										
32	09-02-CR-IN-207-B		0813										
33	09-02-CR-IN-207-T		0814										
34	09-02-CR-IN-221-T		0808										
35	09-02-CR-IN-222-T		0811										
36	09-02-CR-IN-228-T		751										
38	09-02-TR-BY-224-TR		0800										
41	09-03-CR-IN-303-TL		0839										

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

BIOCIDES:

SAMPLED BY*: J. Savioe / F. Goljuch

RELINQUISHED BY*: Y. Kaptain DATE: 11/10/23 TIME: 1000

RECEIVED BY*: AK DATE: 11/15 TIME: 1100

RELINQUISHED BY*: DATE: TIME:

RECEIVED BY*: DATE: TIME:

RELINQUISHED BY*: DATE: TIME:

RECEIVED BY*: DATE: TIME:

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FOR LAB USE ONLY	
PRESERVATIVE: HNO3-	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINERS: 73	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES NO	Present Absent
SAMPLE ON ICE? YES NO	If Present, Date Client is
TEMPERATURE: 11.6 C	contacted with result:
SAMPLE IN COMPLIANCE: YES NO	Date: _____
	Contacted By: _____



2011 East Main Street, Rochester, NY 14609 Phone (585) 654-9080 Fax (585) 654-9662
Web: LozierEnv.com E-Mail: support@lozierenv.com

Page 4 of 10

LAB ID: M33476

REPORT TO:		INVOICE TO:	
Company:	Lozier Environmental Consulting, Inc.	Company:	SAME
Address:	2011 East Main Street	Address:	
City/State/Zip:	Rochester, New York 14609	City/State/Zip:	
Phone:		Phone:	
Fax:		Fax:	
E-Mail:	vkaptain@lozierenv.com	Purchase Order #:	

PROJECT NAME:	RCSD Dr. Martin Luther King Jr. School No. 9
TURNAROUND TIME:	Standard Rush
Other:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS				
									LEAD				
42	09-03-CR-IN-306-T	11/7/23	836		DW				X				
43	09-03-CR-IN-318-B	11/9/23	622										
44	09-03-CR-IN-318-T		622										
46	09-03-CR-IN-321-T		638										
47	09-03-CR-IN-323-T		635										
48	09-03-CR-IN-324-T		634										
49	09-03-CR-IN-327-B (TR-BY)		629										
50	09-03-CR-IN-328-T (TR-BY)	11/7/23	830										
51	09-03-TR-BY-307-TR		834										
52	09-01-KI-IN-143-SL		618										

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

BIOCODE:

SAMPLED BY*: J. Savioe / F. Goljuch

RELINQUISHED BY*: X Kaptein	DATE: 11/10/23	TIME: 1000
RECEIVED BY: [Signature]	DATE: 11/15	TIME: 1100
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:

FOR LAB USE ONLY

PRESERVATIVE: HNO3-	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINERS: 73	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES NO	Present Absent
SAMPLE ON ICE? YES NO	If Present, Date Client is contacted with result:
TEMPERATURE: 11.6 C	Date: _____
SAMPLE IN COMPLIANCE: YES NO	Contacted By: _____

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis



2011 East Main Street, Rochester, NY 14609 Phone (585) 654-9080 Fax (585) 654-9662
Web: LozierEnv.com E-Mail: support@lozierenv.com

Page 5 of 10

LAB ID: M33476		REPORT TO:		INVOICE TO:	
PROJECT NAME: RCD Dr. Martin Luther King Jr. School No. 9		Company: Lozier Environmental Consulting, Inc.		Company: SAME	
TURNAROUND TIME: Standard Rush		Address: 2011 East Main Street		Address:	
Other:		City/State Zip: Rochester, New York 14609		City/State Zip:	
E-Mail: vkaptein@lozierenv.com		Phone:		Phone:	
		Fax:		Fax:	
		Purchase Order #:			

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	LEAD	REQUESTED ANALYSIS				
53 ✕	09-01-KI-IN-143-SR	11/7/23	619		DW				X					
54 ✕	09-01-HA-BY-125A-BF		620											
55 ✕	09-01-HA-BY-107-F		628											
56 ✕	09-01-HA-BY-107-BF		628											
58 ✕	09-01-CR-IN-122-B		637											
59 ✕	09-01-CR-IN-120-BL		642											
60 ✕	09-01-CR-IN-120-TL		642											
61 ✕	09-01-CR-IN-104-T		652											
62	09-01-CR-BY-134-F		703											
63	09-01-CR-BY-134-BF		704											

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

BIOCODE:

SAMPLED BY*: J. Savioe / F. Goloiuch

RELINQUISHED BY*: Y. Kaptein DATE: 11/10/23 TIME: 1000

RECEIVED BY*: DATE: 11/15 TIME: 1100

RELINQUISHED BY*: DATE: TIME:

RECEIVED BY*: DATE: TIME:

RELINQUISHED BY*: DATE: TIME:

RECEIVED BY*: DATE: TIME:

FOR LAB USE ONLY	
PRESERVATIVE: HNO3-	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINERS: 73	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES NO	Present Absent
SAMPLE ON ICE? YES NO	If Present, Date Client is contacted with result:
TEMPERATURE: 11.6 C	Date: _____
SAMPLE IN COMPLIANCE: YES NO	Contacted By: _____

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis



2011 East Main Street, Rochester, NY 14609 Phone (585) 654-9080 Fax (585) 654-9662
Web: LozierEnv.com E-Mail: support@lozierenv.com

Page 6 of 10

LAB ID: M33476		REPORT TO:		INVOICE TO:	
PROJECT NAME: RCSD Dr. Martin Luther King Jr. School No. 9		Company: Lozier Environmental Consulting, Inc.		Company: SAME	
TURNAROUND TIME: Standard Rush		Address: 2011 East Main Street		Address:	
Other:		City/State Zip: Rochester, New York 14609		City/State Zip:	
		Phone:		Phone:	
		E-Mail: vkaptein@lozierenv.com		Fax:	
				Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	LEAD	REQUESTED ANALYSIS				
64	09-01-NO-IN-141-T	11/7/23	712		DW				X					
65	09-01-HA-BY-CCG1-FL		716											
66	09-01-HA-BY-CCG1-FR		717											
67	09-01-HA-BY-CCG1-BF		717											
68	09-01-HA-BY-CC104-FL		619											
69	09-01-HA-BY-CC104-FR		620											
70	09-01-HA-BY-CC104-BF		620											
71	09-01-CR-IN-CC104-T1		722											
72	09-01-CR-IN-CC104-T2		724											
73	09-01-CR-IN-CC104-T3		726											

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

BIOCODE:

SAMPLED BY*: J. Savioe / F. Goljuch

RELINQUISHED BY*: V. Kaptein DATE: 11/10/23 TIME: 1000

RECEIVED BY*: *[Signature]* DATE: 11/15 TIME: 1100

RELINQUISHED BY*: DATE: TIME:

RECEIVED BY*: DATE: TIME:

RELINQUISHED BY*: DATE: TIME:

RECEIVED BY*: DATE: TIME:

FOR LAB USE ONLY		FOR POTABLE WATER ONLY:	
PRESERVATIVE: HNO3-	TOTAL NUMBER OF CONTAINERS: 73	COLIFORM BACTERIA:	
CUSTODY SEAL INTACT? YES NO	SAMPLE ON ICE? YES NO	Present	Absent
TEMPERATURE: 11.6 C	SAMPLE IN COMPLIANCE: YES NO	If Present, Date Client is contacted with result:	
		Date: _____	
		Contacted By: _____	

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis



2011 East Main Street, Rochester, NY 14609 Phone (585) 654-9080 Fax (585) 654-9662
Web: LozierEnv.com E-Mail: support@lozierenv.com

Page 7 of 10

REPORT TO:		INVOICE TO:	
Company:	Lozier Environmental Consulting, Inc.	Company:	SAME
Address:	2011 East Main Street	Address:	
City, State Zip:	Rochester, New York 14609	City, State Zip:	
Phone:		Phone:	
Fax:		Fax:	
E-Mail:	vkaptein@lozierenv.com	Purchase Order #:	

LAB ID: M33476	PROJECT NAME: RCD Dr. Martin Luther King Jr. School No. 9
TURNAROUND TIME: Standard Rush	Other:

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	LEAD	REQUESTED ANALYSIS				
74	09-01-CR-IN-CC104-T4	11/7/23	726		DW				X					
75	09-01-HA-BY-2317-FL		729											
76	09-01-HA-BY-2317-FR		730											
77	09-01-HA-BY-2317-BF		730											
78	09-02-CR-IN-CC216-T		734											
79	09-02-KI-IN-CC203-T		736											
80	09-02-KI-IN-CC203-S		737											
81	09-02-KI-IN-CC203-T		737											
82	09-02-HA-BY-CC203-FL		739											
83	09-02-HA-BY-CC203-FR		740											

Container Type (Circle One): Plastic Glass Sterile Other _____
Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)
BIOCODE: _____

SAMPLED BY*: J. Savioe / F. Gololuch

RELINQUISHED BY*: Y. Kaptein	DATE: 11/10/23	TIME: 1000
RECEIVED BY: <i>AB</i>	DATE: 11/15	TIME: 1100
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:

FOR LAB USE ONLY	
PRESERVATIVE: HNO3-	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINERS: 73	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES NO	Present Absent
SAMPLE ON ICE? YES NO	If Present, Date Client is contacted with result:
TEMPERATURE: 11.6 C	Date: _____
SAMPLE IN COMPLIANCE: YES NO	Contacted By: _____

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis



2011 East Main Street, Rochester, NY 14609 Phone (585) 654-9080 Fax (585) 654-9662
Web: LozierEnv.com E-Mail: support@lozierenv.com

Page 8 of 10

Lozier
Environmental Consulting, Inc.

LAB ID: M33476	Company: Lozier Environmental Consulting, Inc.	REPORT TO:	INVOICE TO:
PROJECT NAME: RCD Dr. Martin Luther King Jr. School No. 9	Address: 2011 East Main Street		SAME
TURNAROUND TIME: Standard Rush	City/State Zip: Rochester, New York 14609		
Other:	Phone:	Fax:	
	E-Mail: vkaptein@lozierenv.com		Purchase Order #:

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS			
									LEAD			
84	09-02-HA-BY-CC203-BF	11/7/23	741		DW				X			
85	09-02-HA-BY-227-F		754									
86	09-02-HA-BY-227-BF		756									
87	09-02-CR-IN-227-T		756									
88	09-02-CR-IN-226-T		756									
89	09-02-CR-IN-224-B		800									
90	09-02-HA-BY-224-F		802									
91	09-02-HA-BY-224-BF		804									
92	09-02-CR-IN-220-TL		805									
93	09-02-CR-IN-220-TR		806									

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

BIOCODE: _____

SAMPLED BY*: J. Savioe / F. Golojuch

RELINQUISHED BY*: Y. Kaptein DATE: 11/10/23 TIME: 1000

RECEIVED BY*: JP DATE: 11/15 TIME: 1100

RELINQUISHED BY*: _____ DATE: _____ TIME: _____

RECEIVED BY*: _____ DATE: _____ TIME: _____

RELINQUISHED BY*: _____ DATE: _____ TIME: _____

RECEIVED BY*: _____ DATE: _____ TIME: _____

FOR LAB USE ONLY	
PRESERVATIVE: HNO3-	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINERS: 73	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES NO	Present Absent
SAMPLE ON ICE? YES NO	If Present, Date Client is contacted with result:
TEMPERATURE: 11.6 C	Date: _____
SAMPLE IN COMPLIANCE: YES NO	Contacted By: _____

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis



2011 East Main Street, Rochester, NY 14609 Phone (585) 654-9080 Fax (585) 654-9662
Web: LozierEnv.com E-Mail: support@lozierenv.com

Page 9 of 10

REPORT TO:		INVOICE TO:	
Company:	Lozier Environmental Consulting, Inc.	Company:	SAME
Address:	2011 East Main Street	Address:	
City, State Zip:	Rochester, New York 14609	City, State Zip:	
Phone:		Phone:	
Fax:		Fax:	
E-Mail:	vkaptain@lozierenv.com	Purchase Order #:	

LAB ID: M33476	PROJECT NAME: RCD Dr. Martin Luther King Jr. School No. 9	TURNAROUND TIME: Standard Rush
Other:		

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS			
									LEAD			
94	09-02-CR-IN-223-T	11/7/23	809		DW				X			
95	09-02-CR-IN-203-TL		821									
96	09-02-CR-IN-200A-T		826									
97	09-03-HA-BY-327-F		829									
98	09-03-HA-BY-327-BR		829									
99	09-03-CR-IN-328-B		830									
100	09-03-CR-IN-305-T		837									
101	09-03-CR-IN-304-T		838									
102	09-03-CR-IN-303-TR		839									
103	09-03-CR-IN-301-T		843									

Container Type (Circle One): Plastic Glass Sterile Other _____
Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)
BIOCODE: _____

SAMPLED BY*: J. Savioe / F. Goljuch	DATE: 11/10/23	TIME: 1000
RELINQUISHED BY*: X Kaptein	DATE: 11/15	TIME: 1100
RECEIVED BY:	DATE:	TIME:
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:

FOR LAB USE ONLY	
PRESERVATIVE: HNO3-	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINERS: 73	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES NO	Present Absent
SAMPLE ON ICE? YES NO	If Present, Date Client is contacted with result:
TEMPERATURE: 11.6 C	Date: _____
SAMPLE IN COMPLIANCE: YES NO	Contacted By: _____

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis



2011 East Main Street, Rochester, NY 14609 Phone (585) 654-9080 Fax (585) 654-9662
Web: LozierEnv.com E-Mail: support@lozierenv.com

Page 10 of 10

LAB ID: M33476		Company: Lozier Environmental Consulting, Inc.		REPORT TO:		INVOICE TO:	
PROJECT NAME: RCD Dr. Martin Luther King Jr. School No. 9		Address: 2011 East Main Street		City, State Zip: Rochester, New York 14609		Address: SAME	
TURNAROUND TIME: Standard Rush		Phone:		Fax:		City, State Zip:	
Other:		E-Mail: vkaptein@lozierenv.com		Purchase Order #:		Fax:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	LEAD	REQUESTED ANALYSIS				
104	09-03-CR-IN-317-T	11/9/23	624		DW				X					
105	09-03-HA-BY-324-F		627											
106	09-03-HA-BY-324-BF		627											
107	09-03-CR-IN-326-T		631											
108	09-03-CR-IN-322-T		637											
109	09-03-CR-IN-320-TR		640											
110	09-01-CR-IN-130B-FRI		646											
111	09-01-CR-IN-129A-T		650											
112	09-01-CR-IN-126A-T		655											

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

BIOCODE: _____

SAMPLED BY*: J. Savioe / F. Goljuch	
REINQUISHED BY*: V. Kaptein	DATE: 11/10/23 TIME: 1000
RECEIVED BY: <u>VP</u>	DATE: 11/15 TIME: 1100
REINQUISHED BY*: <u>VP</u>	DATE: _____ TIME: _____
RECEIVED BY: _____	DATE: _____ TIME: _____
REINQUISHED BY*: _____	DATE: _____ TIME: _____
RECEIVED BY: _____	DATE: _____ TIME: _____

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FOR LAB USE ONLY	
PRESERVATIVE: HNO3- TOTAL NUMBER OF CONTAINERS: 73 CUSTODY SEAL INTACT? YES NO SAMPLE ON ICE? YES NO TEMPERATURE: 11.6 C SAMPLE IN COMPLIANCE: YES NO	FOR POTABLE WATER ONLY: COLIFORM BACTERIA: Present Absent If Present, Date Client is contacted with result: Date: _____ Contacted By: _____

Sample Condition Upon Receipt Form (SCUR)

Project # 23K1996
Client: Lozier

Date and Initials of person:
Examining contents: _____
Label: _____
Deliver to location: _____
pH: _____

Thermometer Used: IRG4

Date: 11/15

Time: 1100

Initials: PR

State of Origin: NY

Cooler #1 Temp. °C 11.0 (Visual) 0.2 @ 0.0°C, -0.5 @ 20.0°C (Correction Factor) (Actual) ☒ ~~Samples on ice, cooling process has begun~~

Courier: ☒ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☐ Pace ☐ Other _____

Shipping Method: ☐ First Overnight ☐ Priority Overnight ☐ Standard Overnight ☒ Ground 7740 6929 6738
☐ Other _____

Tracking # 7740 6933 0141, 7740 6932 2198, 7740 6931 1488

Custody Seal on Cooler/Box Present: ☐ Yes ☐ No Seals intact: ☐ Yes ☐ No Ice: ☒ Blue Melted None

Packing Material: ☐ Bubble Wrap ☐ Bubble Bags ☐ None ☐ Other _____

Samples were collected by Pace employee ☐ Yes ☐ No ☐ N/A

Comments:

Chain of Custody Present	☒ Yes ☐ No ☐ N/A	
Chain of Custody Filled Out	☒ Yes ☐ No ☐ N/A	
Relinquished Signature on COC	☒ Yes ☐ No ☐ N/A	
Sampler Name and Signature on COC	☒ Yes ☐ No ☐ N/A	
Samples Arrived within Hold Time	☒ Yes ☐ No ☐ N/A	
Rush TAT requested on COC	☐ Yes ☐ No ☐ N/A	
Sufficient Volume	☒ Yes ☐ No ☐ N/A	
Correct Containers Used	☒ Yes ☐ No ☐ N/A	
Containers Intact	☒ Yes ☐ No ☐ N/A	
Sample Labels match COC (sample IDs & date/time of collection)	☒ Yes ☐ No ☐ N/A	
All containers needing acid/base preservation have been checked.	☐ Yes ☐ No ☐ N/A	Preservation Information:
All Containers needing preservation are found to be in compliance with EPA recommendation:	☐ Yes ☐ No ☐ N/A	Preservative: _____
Exceptions: Vials, Microbiology, O&G, Metals		Lot #/Trace #: _____
		Date: _____ Time: _____
		Initials: _____
Headspace in VOA Vials? (>6mm):	☐ Yes ☐ No ☐ N/A	
Trip Blank Present:	☐ Yes ☐ No ☐ N/A	

Additional Login Comments:

Client notification/ Resolution

Person Contacted: _____ Date/Time: _____

Comments/Resolution: _____

** Signifies sample(s) that have not been received.*