


January 3, 2025

V Kaptein
NB-Lozier Environmental Consulting, Inc
2011 E Main Street
Rochester, NY 14609

Project Location: RCSD-School No. 17
Project Number: Lozier Environmental Consulting
Laboratory Work Order Number: 24J3921

Enclosed are results of analyses for samples received by the laboratory on October 28, 2024. If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Project Manager



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

NB-Lozier Environmental Consulting, Inc
2011 E Main Street
Rochester, NY 14609
ATTN: V Kaptein

REPORT DATE: 1/3/2025

PURCHASE ORDER NUMBER:

PROJECT NUMBER: Lozier Environmental Consulting

ANALYTICAL SUMMARY

WORK ORDER NUMBER: 24J3921

The results of analyses performed on the following samples submitted to Pace Analytical Services, LLC - Newburgh are found in this report.

PROJECT LOCATION: RCSD-School No. 17

FIELD SAMPLE #	LAB ID:	MATRIX	SAMPLE DESCRIPTION	TEST	SUB LAB
(1) 17-01-OF-IN-100A-T	24J3921-01	Drinking Water		EPA 200.8 Rev 5.4	
(2) 17-01-CR-IN-K100-B	24J3921-02	Drinking Water		EPA 200.8 Rev 5.4	
(3) 17-01-CR-IN-K100-T	24J3921-03	Drinking Water		EPA 200.8 Rev 5.4	
(4) 17-01-CR-IN-K101-B	24J3921-04	Drinking Water		EPA 200.8 Rev 5.4	
(5) 17-01-CR-IN-K101-T	24J3921-05	Drinking Water		EPA 200.8 Rev 5.4	
(6) 17-01-CR-IN-K103-B	24J3921-06	Drinking Water		EPA 200.8 Rev 5.4	
(7) 17-01-CR-IN-K103-T	24J3921-07	Drinking Water		EPA 200.8 Rev 5.4	
(8) 17-01-CR-IN-K102-B	24J3921-08	Drinking Water		EPA 200.8 Rev 5.4	
(9) 17-01-CR-IN-K102-T	24J3921-09	Drinking Water		EPA 200.8 Rev 5.4	
(10) 17-01-CR-IN-146-B	24J3921-10	Drinking Water		EPA 200.8 Rev 5.4	
(11) 17-01-CR-IN-146-T	24J3921-11	Drinking Water		EPA 200.8 Rev 5.4	
(12) 17-01-CR-IN-144-B	24J3921-12	Drinking Water		EPA 200.8 Rev 5.4	
(13) 17-01-CR-IN-144-T	24J3921-13	Drinking Water		EPA 200.8 Rev 5.4	
(14) 17-01-CR-IN-140-T	24J3921-14	Drinking Water		EPA 200.8 Rev 5.4	
(15) 17-01-CR-IN-118-B	24J3921-15	Drinking Water		EPA 200.8 Rev 5.4	
(16) 17-01-CR-IN-118-T	24J3921-16	Drinking Water		EPA 200.8 Rev 5.4	
(17) 17-01-CR-IN-116-B	24J3921-17	Drinking Water		EPA 200.8 Rev 5.4	
(18) 17-01-CR-IN-116-T	24J3921-18	Drinking Water		EPA 200.8 Rev 5.4	
(19) 17-01-CR-IN-114-B	24J3921-19	Drinking Water		EPA 200.8 Rev 5.4	
(20) 17-01-CR-IN-114-T	24J3921-20	Drinking Water		EPA 200.8 Rev 5.4	
(21) 17-01-CR-IN-112-B	24J3921-21	Drinking Water		EPA 200.8 Rev 5.4	
(22) 17-01-CR-IN-112-T	24J3921-22	Drinking Water		EPA 200.8 Rev 5.4	
(23) 17-01-NO-IN-107-T	24J3921-23	Drinking Water		EPA 200.8 Rev 5.4	
(24) 17-01-NO-IN-107A-T	24J3921-24	Drinking Water		EPA 200.8 Rev 5.4	
(25) 17-01-CR-IN-150-T	24J3921-25	Drinking Water		EPA 200.8 Rev 5.4	
(26) 17-01-CR-IN-152-T	24J3921-26	Drinking Water		EPA 200.8 Rev 5.4	
(27) 17-01-HA-BY-151-FL	24J3921-27	Drinking Water		EPA 200.8 Rev 5.4	
(28) 17-01-HA-BY-151-FR	24J3921-28	Drinking Water		EPA 200.8 Rev 5.4	
(29) 17-01-HA-BY-151-BF	24J3921-29	Drinking Water		EPA 200.8 Rev 5.4	
(30) 17-01-CR-IN-G105-B	24J3921-30	Drinking Water		EPA 200.8 Rev 5.4	
(31) 17-01-CR-IN-G105-T	24J3921-31	Drinking Water		EPA 200.8 Rev 5.4	
(32) 17-01-CR-IN-G100-B	24J3921-32	Drinking Water		EPA 200.8 Rev 5.4	
(33) 17-01-CR-IN-G100-T	24J3921-33	Drinking Water		EPA 200.8 Rev 5.4	
(34) 17-01-CF-IN-G102-FL	24J3921-34	Drinking Water		EPA 200.8 Rev 5.4	
(35) 17-01-CF-IN-G102-FR	24J3921-35	Drinking Water		EPA 200.8 Rev 5.4	
(36) 17-01-CF-IN-G102-BF	24J3921-36	Drinking Water		EPA 200.8 Rev 5.4	
(37) 17-01-KL-IN-G102A-T1	24J3921-37	Drinking Water		EPA 200.8 Rev 5.4	
(38) 17-01-KL-IN-G102A-T2	24J3921-38	Drinking Water		EPA 200.8 Rev 5.4	
(39) 17-01-KL-IN-G102A-T3	24J3921-39	Drinking Water		EPA 200.8 Rev 5.4	
(40) 17-01-KL-IN-G102A-T4	24J3921-40	Drinking Water		EPA 200.8 Rev 5.4	



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

NB-Lozier Environmental Consulting, Inc
2011 E Main Street
Rochester, NY 14609
ATTN: V Kaptein

REPORT DATE: 1/3/2025

PURCHASE ORDER NUMBER:

PROJECT NUMBER: Lozier Environmental Consulting

ANALYTICAL SUMMARY

WORK ORDER NUMBER: 24J3921

The results of analyses performed on the following samples submitted to Pace Analytical Services, LLC - Newburgh are found in this report.

PROJECT LOCATION: RCSD-School No. 17

FIELD SAMPLE #	LAB ID:	MATRIX	SAMPLE DESCRIPTION	TEST	SUB LAB
(41) 17-01-KL-IN-G102A-T5	24J3921-41	Drinking Water		EPA 200.8 Rev 5.4	
(42) 17-01-KL-IN-G102A-T6	24J3921-42	Drinking Water		EPA 200.8 Rev 5.4	
(43) 17-01-KL-IN-G102A-T7	24J3921-43	Drinking Water		EPA 200.8 Rev 5.4	
(44) 17-01-KL-IN-G102A-T8	24J3921-44	Drinking Water		EPA 200.8 Rev 5.4	
(45) 17-01-KL-IN-G102A-T9	24J3921-45	Drinking Water		EPA 200.8 Rev 5.4	
(46) 17-01-HA-BY-G112-FL	24J3921-46	Drinking Water		EPA 200.8 Rev 5.4	
(47) 17-01-HA-BY-G112-FR	24J3921-47	Drinking Water		EPA 200.8 Rev 5.4	
(48) 17-01-HA-BY-G112-BF	24J3921-48	Drinking Water		EPA 200.8 Rev 5.4	
(49) 17-01-HA-BY-G110-F	24J3921-49	Drinking Water		EPA 200.8 Rev 5.4	
(50) 17-01-HA-BY-G110-BF	24J3921-50	Drinking Water		EPA 200.8 Rev 5.4	
(51) 17-02-CR-IN-200-B	24J3921-51	Drinking Water		EPA 200.8 Rev 5.4	
(52) 17-02-CR-IN-200-T	24J3921-52	Drinking Water		EPA 200.8 Rev 5.4	
(53) 17-02-CR-IN-201-B	24J3921-53	Drinking Water		EPA 200.8 Rev 5.4	
(54) 17-02-CR-IN-201-T	24J3921-54	Drinking Water		EPA 200.8 Rev 5.4	
(55) 17-02-CR-IN-202-B	24J3921-55	Drinking Water		EPA 200.8 Rev 5.4	
(56) 17-02-CR-IN-202-T	24J3921-56	Drinking Water		EPA 200.8 Rev 5.4	
(57) 17-02-CR-IN-208-B	24J3921-57	Drinking Water		EPA 200.8 Rev 5.4	
(58) 17-02-CR-IN-208-T	24J3921-58	Drinking Water		EPA 200.8 Rev 5.4	
(59) 17-02-CR-IN-210-B	24J3921-59	Drinking Water		EPA 200.8 Rev 5.4	
(60) 17-02-CR-IN-210-T	24J3921-60	Drinking Water		EPA 200.8 Rev 5.4	
(61) 17-02-CR-IN-214-B	24J3921-61	Drinking Water		EPA 200.8 Rev 5.4	
(62) 17-02-CR-IN-214-T	24J3921-62	Drinking Water		EPA 200.8 Rev 5.4	
(63) 17-02-RM-IN-209-T	24J3921-63	Drinking Water		EPA 200.8 Rev 5.4	
(64) 17-02-CR-IN-210-TL	24J3921-64	Drinking Water		EPA 200.8 Rev 5.4	
(65) 17-02-CR-IN-210-TR	24J3921-65	Drinking Water		EPA 200.8 Rev 5.4	
(66) 17-02-HA-BY-213-FL	24J3921-66	Drinking Water		EPA 200.8 Rev 5.4	
(67) 17-02-HA-BY-213-FR	24J3921-67	Drinking Water		EPA 200.8 Rev 5.4	
(68) 17-02-CR-IN-223-B	24J3921-68	Drinking Water		EPA 200.8 Rev 5.4	
(69) 17-02-CR-IN-223-T	24J3921-69	Drinking Water		EPA 200.8 Rev 5.4	
(70) 17-02-CR-IN-224-B	24J3921-70	Drinking Water		EPA 200.8 Rev 5.4	
(71) 17-02-CR-IN-224-T	24J3921-71	Drinking Water		EPA 200.8 Rev 5.4	
(72) 17-02-CR-IN-226-T	24J3921-72	Drinking Water		EPA 200.8 Rev 5.4	
(73) 17-02-CR-IN-228-T	24J3921-73	Drinking Water		EPA 200.8 Rev 5.4	
(74) 17-02-CR-IN-230-B	24J3921-74	Drinking Water		EPA 200.8 Rev 5.4	
(75) 17-02-CR-IN-230-T	24J3921-75	Drinking Water		EPA 200.8 Rev 5.4	
(76) 17-02-CR-IN-232-B	24J3921-76	Drinking Water		EPA 200.8 Rev 5.4	
(77) 17-02-CR-IN-232-T	24J3921-77	Drinking Water		EPA 200.8 Rev 5.4	
(78) 17-02-CR-IN-234-B	24J3921-78	Drinking Water		EPA 200.8 Rev 5.4	
(79) 17-02-CR-IN-234-T	24J3921-79	Drinking Water		EPA 200.8 Rev 5.4	
(80) 17-02-CR-IN-236-B	24J3921-80	Drinking Water		EPA 200.8 Rev 5.4	



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

NB-Lozier Environmental Consulting, Inc
2011 E Main Street
Rochester, NY 14609
ATTN: V Kaptein

REPORT DATE: 1/3/2025

PURCHASE ORDER NUMBER:

PROJECT NUMBER: Lozier Environmental Consulting

ANALYTICAL SUMMARY

WORK ORDER NUMBER: 24J3921

The results of analyses performed on the following samples submitted to Pace Analytical Services, LLC - Newburgh are found in this report.

PROJECT LOCATION: RCSD-School No. 17

FIELD SAMPLE #	LAB ID:	MATRIX	SAMPLE DESCRIPTION	TEST	SUB LAB
(81) 17-02-CR-IN-236-T	24J3921-81	Drinking Water		EPA 200.8 Rev 5.4	
(82) 17-02-CR-IN-237-B	24J3921-82	Drinking Water		EPA 200.8 Rev 5.4	
(83) 17-02-CR-IN-237-T	24J3921-83	Drinking Water		EPA 200.8 Rev 5.4	
(84) 17-02-CR-IN-239-B	24J3921-84	Drinking Water		EPA 200.8 Rev 5.4	
(85) 17-02-CR-IN-239-T	24J3921-85	Drinking Water		EPA 200.8 Rev 5.4	
(86) 17-03-CR-IN-332-B	24J3921-86	Drinking Water		EPA 200.8 Rev 5.4	
(87) 17-03-CR-IN-332-T	24J3921-87	Drinking Water		EPA 200.8 Rev 5.4	
(88) 17-03-CR-IN-330-B	24J3921-88	Drinking Water		EPA 200.8 Rev 5.4	
(89) 17-03-CR-IN-330-T	24J3921-89	Drinking Water		EPA 200.8 Rev 5.4	
(90) 17-03-CR-IN-328-B	24J3921-90	Drinking Water		EPA 200.8 Rev 5.4	
(91) 17-03-CR-IN-328-T	24J3921-91	Drinking Water		EPA 200.8 Rev 5.4	
(92) 17-03-CR-IN-326-B	24J3921-92	Drinking Water		EPA 200.8 Rev 5.4	
(93) 17-03-CR-IN-326-T	24J3921-93	Drinking Water		EPA 200.8 Rev 5.4	
(94) 17-03-CR-IN-324-B	24J3921-94	Drinking Water		EPA 200.8 Rev 5.4	
(95) 17-03-CR-IN-324-T	24J3921-95	Drinking Water		EPA 200.8 Rev 5.4	
(96) 17-03-CR-IN-323-TL	24J3921-96	Drinking Water		EPA 200.8 Rev 5.4	
(97) 17-03-CR-IN-323-TR	24J3921-97	Drinking Water		EPA 200.8 Rev 5.4	
(98) 17-03-HA-BY-313-F	24J3921-98	Drinking Water		EPA 200.8 Rev 5.4	
(99) 17-03-HA-BY-313-BF	24J3921-99	Drinking Water		EPA 200.8 Rev 5.4	
(100) 17-03-CR-IN-313-TL	24J3921-AA	Drinking Water		EPA 200.8 Rev 5.4	
(101) 17-03-CR-IN-313-TR	24J3921-AB	Drinking Water		EPA 200.8 Rev 5.4	
(102) 17-03-CR-IN-301-B	24J3921-AC	Drinking Water		EPA 200.8 Rev 5.4	
(103) 17-03-CR-IN-301-T	24J3921-AD	Drinking Water		EPA 200.8 Rev 5.4	
(104) 17-03-CR-IN-302-B	24J3921-AE	Drinking Water		EPA 200.8 Rev 5.4	
(105) 17-03-CR-IN-302-T	24J3921-AF	Drinking Water		EPA 200.8 Rev 5.4	
(106) 17-03-CR-IN-308-B	24J3921-AG	Drinking Water		EPA 200.8 Rev 5.4	
(107) 17-03-CR-IN-308-T	24J3921-AH	Drinking Water		EPA 200.8 Rev 5.4	
(108) 17-03-CR-IN-312-B	24J3921-AI	Drinking Water		EPA 200.8 Rev 5.4	
(109) 17-03-CR-IN-312-T	24J3921-AJ	Drinking Water		EPA 200.8 Rev 5.4	
(110) 17-01-RM-IN-BRK RM HLTH CTR-T	24J3921-AK	Drinking Water		EPA 200.8 Rev 5.4	
(111) 17-01-RM-IN-WAIT RM HLTH CTR-F	24J3921-AL	Drinking Water		EPA 200.8 Rev 5.4	
(112) 17-01-RM-IN-WAIT RM HLTH CTR-BF	24J3921-AM	Drinking Water		EPA 200.8 Rev 5.4	
(113) 17-01-RM-IN-EXAM1-T1	24J3921-AN	Drinking Water		EPA 200.8 Rev 5.4	
(114) 17-01-RM-IN-EXAM1-T2	24J3921-AO	Drinking Water		EPA 200.8 Rev 5.4	
(115) 17-01-RM-IN-EXAM2-T	24J3921-AP	Drinking Water		EPA 200.8 Rev 5.4	
(116) 17-01-RM-IN-EXAM3-T	24J3921-AQ	Drinking Water		EPA 200.8 Rev 5.4	
(117) 17-01-RM-IN-EXAM4-T	24J3921-AR	Drinking Water		EPA 200.8 Rev 5.4	
(118) 17-01-RM-IN-EXAM5-T	24J3921-AS	Drinking Water		EPA 200.8 Rev 5.4	
(119) 17-01-RM-IN-EXAM6-T	24J3921-AT	Drinking Water		EPA 200.8 Rev 5.4	
(120) 17-01-RM-IN-U118-T	24J3921-AU	Drinking Water		EPA 200.8 Rev 5.4	



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

NB-Lozier Environmental Consulting, Inc
2011 E Main Street
Rochester, NY 14609
ATTN: V Kaptein

REPORT DATE: 1/3/2025

PURCHASE ORDER NUMBER:

PROJECT NUMBER: Lozier Environmental Consulting

ANALYTICAL SUMMARY

WORK ORDER NUMBER: 24J3921

The results of analyses performed on the following samples submitted to Pace Analytical Services, LLC - Newburgh are found in this report.

PROJECT LOCATION: RCSD-School No. 17


FIELD SAMPLE #	LAB ID:	MATRIX	SAMPLE DESCRIPTION	TEST	SUB LAB
(121) 17-01-RM-IN-EXAM7-T	24J3921-AV	Drinking Water		EPA 200.8 Rev 5.4	
(122) 17-01-RM-IN-HYGIENE-T	24J3921-AW	Drinking Water		EPA 200.8 Rev 5.4	
(123) 17-01-RM-IN-EXAM8-T	24J3921-AX	Drinking Water		EPA 200.8 Rev 5.4	
(124) 17-01-RM-IN-U142-T1	24J3921-AY	Drinking Water		EPA 200.8 Rev 5.4	
(125) 17-01-RM-IN-U142-T2	24J3921-AZ	Drinking Water		EPA 200.8 Rev 5.4	
(126) 17-01-RM-IN-U142-T3	24J3921-BA	Drinking Water		EPA 200.8 Rev 5.4	
(127) 17-01-RM-IN-U142-T4	24J3921-BB	Drinking Water		EPA 200.8 Rev 5.4	
(128) 17-01-RM-IN-U138-T	24J3921-BC	Drinking Water		EPA 200.8 Rev 5.4	
(129) 17-01-KL-IN-U102-T	24J3921-BD	Drinking Water		EPA 200.8 Rev 5.4	
(130) 17-01-HA-BY-U111A	24J3921-BE	Drinking Water		EPA 200.8 Rev 5.4	

CASE NARRATIVE SUMMARY

All reported results are within defined laboratory quality control objectives unless listed below or otherwise qualified in this report.

The results of analyses reported only relate to samples submitted to the Pace Analytical Services, LLC - Newburgh for testing.

I certify that the analyses listed above, unless specifically listed as subcontracted, if any, were performed under my direction according to the approved methodologies listed in this document, and that based upon my inquiry of those individuals immediately responsible for obtaining the information, the material contained in this report is, to the best of my knowledge and belief, accurate and complete.



Renee Cusack
PM



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Sampled: 10/15/2024 06:09

Field Sample #: (1) 17-01-OF-IN-100A-T

Sample ID: 24J3921-01

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 17:37	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (2) 17-01-CR-IN-K100-B

Sampled: 10/15/2024 06:15

Sample ID: 24J3921-02

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 17:46	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (3) 17-01-CR-IN-K100-T

Sampled: 10/15/2024 06:16

Sample ID: 24J3921-03

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 17:49	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Sampled: 10/15/2024 06:18

Field Sample #: (4) 17-01-CR-IN-K101-B

Sample ID: 24J3921-04

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 17:51	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (5) 17-01-CR-IN-K101-T

Sampled: 10/15/2024 06:18

Sample ID: 24J3921-05

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 17:58	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Sampled: 10/15/2024 06:20

Field Sample #: (6) 17-01-CR-IN-K103-B

Sample ID: 24J3921-06

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 18:01	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (7) 17-01-CR-IN-K103-T

Sampled: 10/15/2024 06:20

Sample ID: 24J3921-07

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 18:03	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Sampled: 10/15/2024 06:22

Field Sample #: (8) 17-01-CR-IN-K102-B

Sample ID: 24J3921-08

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 18:05	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (9) 17-01-CR-IN-K102-T

Sampled: 10/15/2024 06:22

Sample ID: 24J3921-09

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 18:08	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (10) 17-01-CR-IN-146-B

Sampled: 10/15/2024 06:26

Sample ID: 24J3921-10

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 18:10	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (11) 17-01-CR-IN-146-T

Sampled: 10/15/2024 06:27

Sample ID: 24J3921-11

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 18:12	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (12) 17-01-CR-IN-144-B

Sampled: 10/15/2024 06:30

Sample ID: 24J3921-12

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 18:17	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (13) 17-01-CR-IN-144-T

Sampled: 10/15/2024 06:30

Sample ID: 24J3921-13

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 18:19	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (14) 17-01-CR-IN-140-T

Sampled: 10/15/2024 06:33

Sample ID: 24J3921-14

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 18:27	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (15) 17-01-CR-IN-118-B

Sampled: 10/15/2024 06:38

Sample ID: 24J3921-15

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 18:29	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (16) 17-01-CR-IN-118-T

Sampled: 10/15/2024 06:38

Sample ID: 24J3921-16

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 18:31	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (17) 17-01-CR-IN-116-B

Sampled: 10/15/2024 06:41

Sample ID: 24J3921-17

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 18:34	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (18) 17-01-CR-IN-116-T

Sampled: 10/15/2024 06:41

Sample ID: 24J3921-18

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	2.0	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 18:36	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (19) 17-01-CR-IN-114-B

Sampled: 10/15/2024 06:44

Sample ID: 24J3921-19

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	1.3	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 18:38	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (20) 17-01-CR-IN-114-T

Sampled: 10/15/2024 06:44

Sample ID: 24J3921-20

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 18:41	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (21) 17-01-CR-IN-112-B

Sampled: 10/15/2024 06:47

Sample ID: 24J3921-21

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 18:43	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (22) 17-01-CR-IN-112-T

Sampled: 10/15/2024 06:47

Sample ID: 24J3921-22

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 18:57	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (23) 17-01-NO-IN-107-T

Sampled: 10/15/2024 06:51

Sample ID: 24J3921-23

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 19:00	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (24) 17-01-NO-IN-107A-T

Sampled: 10/15/2024 06:51

Sample ID: 24J3921-24

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 19:02	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (25) 17-01-CR-IN-150-T

Sampled: 10/15/2024 06:53

Sample ID: 24J3921-25

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 19:04	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (26) 17-01-CR-IN-152-T

Sampled: 10/15/2024 06:56

Sample ID: 24J3921-26

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 19:07	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (27) 17-01-HA-BY-151-FL

Sampled: 10/15/2024 06:58

Sample ID: 24J3921-27

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 19:09	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (28) 17-01-HA-BY-151-FR

Sampled: 10/15/2024 06:59

Sample ID: 24J3921-28

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 19:11	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (29) 17-01-HA-BY-151-BF

Sampled: 10/15/2024 06:59

Sample ID: 24J3921-29

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 19:14	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (30) 17-01-CR-IN-G105-B

Sampled: 10/15/2024 07:05

Sample ID: 24J3921-30

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 19:16	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (31) 17-01-CR-IN-G105-T

Sampled: 10/15/2024 07:05

Sample ID: 24J3921-31

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 19:23	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (32) 17-01-CR-IN-G100-B

Sampled: 10/15/2024 07:08

Sample ID: 24J3921-32

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 19:28	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (33) 17-01-CR-IN-G100-T

Sampled: 10/15/2024 07:08

Sample ID: 24J3921-33

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 19:30	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (34) 17-01-CF-IN-G102-FL

Sampled: 10/16/2024 06:04

Sample ID: 24J3921-34

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 19:33	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (35) 17-01-CF-IN-G102-FR

Sampled: 10/16/2024 06:05

Sample ID: 24J3921-35

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 19:35	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Sampled: 10/16/2024 06:05

Field Sample #: (36) 17-01-CF-IN-G102-BF

Sample ID: 24J3921-36

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 19:37	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Sampled: 10/16/2024 06:09

Field Sample #: (37) 17-01-KL-IN-G102A-T1

Sample ID: 24J3921-37

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	1.2	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 19:40	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (38) 17-01-KL-IN-G102A-T2

Sampled: 10/16/2024 06:10

Sample ID: 24J3921-38

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 19:42	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Sampled: 10/16/2024 06:11

Field Sample #: (39) 17-01-KL-IN-G102A-T3

Sample ID: 24J3921-39

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	1.1	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 19:44	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (40) 17-01-KL-IN-G102A-T4

Sampled: 10/16/2024 06:12

Sample ID: 24J3921-40

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	1.4	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 19:51	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (41) 17-01-KL-IN-G102A-T5

Sampled: 10/16/2024 06:12

Sample ID: 24J3921-41

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	1.3	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 19:54	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Sampled: 10/16/2024 06:13

Field Sample #: (42) 17-01-KL-IN-G102A-T6

Sample ID: 24J3921-42

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 20:03	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (43) 17-01-KL-IN-G102A-T7

Sampled: 10/16/2024 06:13

Sample ID: 24J3921-43

Sample Matrix: Drinking Water

Metals Analyses (Total)											
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL							Prepared	Analyzed	
Lead	1.1	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 20:05	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (44) 17-01-KL-IN-G102A-T8

Sampled: 10/16/2024 06:14

Sample ID: 24J3921-44

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	4.8	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 20:08	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (45) 17-01-KL-IN-G102A-T9

Sampled: 10/16/2024 06:15

Sample ID: 24J3921-45

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 20:10	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (46) 17-01-HA-BY-G112-FL

Sampled: 10/16/2024 06:17

Sample ID: 24J3921-46

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 20:12	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Sampled: 10/16/2024 06:17

Field Sample #: (47) 17-01-HA-BY-G112-FR

Sample ID: 24J3921-47

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 20:20	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (48) 17-01-HA-BY-G112-BF

Sampled: 10/16/2024 06:18

Sample ID: 24J3921-48

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 20:22	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (49) 17-01-HA-BY-G110-F

Sampled: 10/16/2024 06:20

Sample ID: 24J3921-49

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 20:24	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (50) 17-01-HA-BY-G110-BF

Sampled: 10/16/2024 06:20

Sample ID: 24J3921-50

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 20:27	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (51) 17-02-CR-IN-200-B

Sampled: 10/16/2024 06:30

Sample ID: 24J3921-51

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	11	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 20:29	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Sampled: 10/16/2024 06:31

Field Sample #: (52) 17-02-CR-IN-200-T

Sample ID: 24J3921-52

Sample Matrix: Drinking Water

Metals Analyses (Total)											
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time	
		RL							Prepared	Analyzed	Analyst
Lead	4.2	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 20:34	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Sampled: 10/16/2024 06:34

Field Sample #: (53) 17-02-CR-IN-201-B

Sample ID: 24J3921-53

Sample Matrix: Drinking Water

Metals Analyses (Total)											
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time	
		RL							Prepared	Analyzed	Analyst
Lead	5.5	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 20:36	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Sampled: 10/16/2024 06:35

Field Sample #: (54) 17-02-CR-IN-201-T

Sample ID: 24J3921-54

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL			Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
		RL		Units						
Lead	3.9	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 20:38	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (55) 17-02-CR-IN-202-B

Sampled: 10/16/2024 06:37

Sample ID: 24J3921-55

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 20:41	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Sampled: 10/16/2024 06:38

Field Sample #: (56) 17-02-CR-IN-202-T

Sample ID: 24J3921-56

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 20:48	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Sampled: 10/16/2024 06:41

Field Sample #: (57) 17-02-CR-IN-208-B

Sample ID: 24J3921-57

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 20:50	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (58) 17-02-CR-IN-208-T

Sampled: 10/16/2024 06:41

Sample ID: 24J3921-58

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 20:52	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Sampled: 10/16/2024 06:43

Field Sample #: (59) 17-02-CR-IN-210-B

Sample ID: 24J3921-59

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 20:55	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (60) 17-02-CR-IN-210-T

Sampled: 10/16/2024 06:44

Sample ID: 24J3921-60

Sample Matrix: Drinking Water

Metals Analyses (Total)											
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL							Prepared	Analyzed	
Lead	1.1	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 20:57	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (61) 17-02-CR-IN-214-B

Sampled: 10/16/2024 06:45

Sample ID: 24J3921-61

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 20:59	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Sampled: 10/16/2024 06:46

Field Sample #: (62) 17-02-CR-IN-214-T

Sample ID: 24J3921-62

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL			Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
		RL		Units						
Lead	1.1	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 21:09	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (63) 17-02-RM-IN-209-T

Sampled: 10/16/2024 06:48

Sample ID: 24J3921-63

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	5.3	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/31/24 13:21	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (64) 17-02-CR-IN-210-TL

Sampled: 10/16/2024 06:52

Sample ID: 24J3921-64

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	1.2	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/31/24 13:24	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (65) 17-02-CR-IN-210-TR

Sampled: 10/16/2024 06:53

Sample ID: 24J3921-65

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/31/24 13:26	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (66) 17-02-HA-BY-213-FL

Sampled: 10/16/2024 06:54

Sample ID: 24J3921-66

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/31/24 13:28	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (67) 17-02-HA-BY-213-FR

Sampled: 10/16/2024 06:55

Sample ID: 24J3921-67

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/31/24 13:31	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (68) 17-02-CR-IN-223-B

Sampled: 10/16/2024 06:57

Sample ID: 24J3921-68

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	3.6	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/31/24 13:33	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Sampled: 10/16/2024 06:58

Field Sample #: (69) 17-02-CR-IN-223-T

Sample ID: 24J3921-69

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	1.3	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/31/24 13:35	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (70) 17-02-CR-IN-224-B

Sampled: 10/16/2024 06:58

Sample ID: 24J3921-70

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL			Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
		RL		Units						
Lead	2.0	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/31/24 13:38	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (71) 17-02-CR-IN-224-T

Sampled: 10/16/2024 06:59

Sample ID: 24J3921-71

Sample Matrix: Drinking Water

Metals Analyses (Total)											
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time	
		RL							Prepared	Analyzed	Analyst
Lead	1.5	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/31/24 13:40	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Sampled: 10/16/2024 07:00

Field Sample #: (72) 17-02-CR-IN-226-T

Sample ID: 24J3921-72

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time
		RL							Prepared	Analyzed
Lead	2.2	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/31/24 13:50 JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Sampled: 10/16/2024 07:04

Field Sample #: (73) 17-02-CR-IN-228-T

Sample ID: 24J3921-73

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time
		RL							Prepared	Analyzed
Lead	2.3	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/31/24 13:52 JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (74) 17-02-CR-IN-230-B

Sampled: 10/16/2024 07:05

Sample ID: 24J3921-74

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	2.4	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/31/24 13:54	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Sampled: 10/16/2024 07:05

Field Sample #: (75) 17-02-CR-IN-230-T

Sample ID: 24J3921-75

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	1.6	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/31/24 13:57	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (76) 17-02-CR-IN-232-B

Sampled: 10/16/2024 07:07

Sample ID: 24J3921-76

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/31/24 13:59	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Sampled: 10/16/2024 07:08

Field Sample #: (77) 17-02-CR-IN-232-T

Sample ID: 24J3921-77

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/31/24 14:01	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Sampled: 10/17/2024 06:10

Field Sample #: (78) 17-02-CR-IN-234-B

Sample ID: 24J3921-78

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/31/24 14:04	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Sampled: 10/17/2024 06:10

Field Sample #: (79) 17-02-CR-IN-234-T

Sample ID: 24J3921-79

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/31/24 14:06	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (80) 17-02-CR-IN-236-B

Sampled: 10/17/2024 06:12

Sample ID: 24J3921-80

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/31/24 14:09	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (81) 17-02-CR-IN-236-T

Sampled: 10/17/2024 06:12

Sample ID: 24J3921-81

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/31/24 14:16	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (82) 17-02-CR-IN-237-B

Sampled: 10/17/2024 06:17

Sample ID: 24J3921-82

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 22:19	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (83) 17-02-CR-IN-237-T

Sampled: 10/17/2024 06:17

Sample ID: 24J3921-83

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 22:21	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (84) 17-02-CR-IN-239-B

Sampled: 10/17/2024 06:20

Sample ID: 24J3921-84

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 22:23	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (85) 17-02-CR-IN-239-T

Sampled: 10/17/2024 06:21

Sample ID: 24J3921-85

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 22:26	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (86) 17-03-CR-IN-332-B

Sampled: 10/17/2024 06:25

Sample ID: 24J3921-86

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 22:28	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (87) 17-03-CR-IN-332-T

Sampled: 10/17/2024 06:25

Sample ID: 24J3921-87

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	1.2	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 22:30	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (88) 17-03-CR-IN-330-B

Sampled: 10/17/2024 06:29

Sample ID: 24J3921-88

Sample Matrix: Drinking Water

Metals Analyses (Total)											
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL							Prepared	Analyzed	
Lead	8.1	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 22:33	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (89) 17-03-CR-IN-330-T

Sampled: 10/17/2024 06:29

Sample ID: 24J3921-89

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	7.7	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 22:40	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (90) 17-03-CR-IN-328-B

Sampled: 10/17/2024 06:32

Sample ID: 24J3921-90

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	5.4	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 22:42	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (91) 17-03-CR-IN-328-T

Sampled: 10/17/2024 06:32

Sample ID: 24J3921-91

Sample Matrix: Drinking Water

Metals Analyses (Total)											
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL							Prepared	Analyzed	
Lead	2.1	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 22:44	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (92) 17-03-CR-IN-326-B

Sampled: 10/17/2024 06:36

Sample ID: 24J3921-92

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	4.2	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 22:49	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (93) 17-03-CR-IN-326-T

Sampled: 10/17/2024 06:37

Sample ID: 24J3921-93

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	1.6	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 22:51	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (94) 17-03-CR-IN-324-B

Sampled: 10/17/2024 06:39

Sample ID: 24J3921-94

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	3.4	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 22:54	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (95) 17-03-CR-IN-324-T

Sampled: 10/17/2024 06:39

Sample ID: 24J3921-95

Sample Matrix: Drinking Water

Metals Analyses (Total)											
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL							Prepared	Analyzed	
Lead	2.0	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 22:56	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (96) 17-03-CR-IN-323-TL

Sampled: 10/17/2024 06:41

Sample ID: 24J3921-96

Sample Matrix: Drinking Water

Metals Analyses (Total)											
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL							Prepared	Analyzed	
Lead	2.6	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 22:58	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (97) 17-03-CR-IN-323-TR

Sampled: 10/17/2024 06:41

Sample ID: 24J3921-97

Sample Matrix: Drinking Water

Metals Analyses (Total)											
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time	
		RL							Prepared	Analyzed	Analyst
Lead	2.1	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 23:01	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (98) 17-03-HA-BY-313-F

Sampled: 10/17/2024 06:42

Sample ID: 24J3921-98

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 23:08	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (99) 17-03-HA-BY-313-BF

Sampled: 10/17/2024 06:43

Sample ID: 24J3921-99

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 23:10	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (100) 17-03-CR-IN-313-TL

Sampled: 10/17/2024 06:44

Sample ID: 24J3921-AA

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	1.4	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 23:13	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (101) 17-03-CR-IN-313-TR

Sampled: 10/17/2024 06:44

Sample ID: 24J3921-AB

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	3.0	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 23:15	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (102) 17-03-CR-IN-301-B

Sampled: 10/17/2024 06:49

Sample ID: 24J3921-AC

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	1.9	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 23:24	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (103) 17-03-CR-IN-301-T

Sampled: 10/17/2024 06:49

Sample ID: 24J3921-AD

Sample Matrix: Drinking Water

Metals Analyses (Total)											
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL							Prepared	Analyzed	
Lead	2.0	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 23:27	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (104) 17-03-CR-IN-302-B

Sampled: 10/17/2024 06:52

Sample ID: 24J3921-AE

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 23:29	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (105) 17-03-CR-IN-302-T

Sampled: 10/17/2024 06:53

Sample ID: 24J3921-AF

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 23:36	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (106) 17-03-CR-IN-308-B

Sampled: 10/17/2024 06:59

Sample ID: 24J3921-AG

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	12	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 23:38	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (107) 17-03-CR-IN-308-T

Sampled: 10/17/2024 07:00

Sample ID: 24J3921-AH

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	8.4	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 23:41	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Sampled: 10/17/2024 07:02

Field Sample #: (108) 17-03-CR-IN-312-B

Sample ID: 24J3921-AI

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 23:43	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (109) 17-03-CR-IN-312-T

Sampled: 10/17/2024 07:03

Sample ID: 24J3921-AJ

Sample Matrix: Drinking Water

Metals Analyses (Total)											
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL							Prepared	Analyzed	
Lead	1.5	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 23:46	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (110) 17-01-RM-IN-BRK RM HLTH CTR-

Sampled: 10/17/2024 07:12

Sample ID: 24J3921-AK

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 23:48	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (111) 17-01-RM-IN-WAIT RM HLTH CTR

Sampled: 10/17/2024 07:17

Sample ID: 24J3921-AL

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 23:50	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (112) 17-01-RM-IN-WAIT RM HLTH CTR

Sampled: 10/17/2024 07:17

Sample ID: 24J3921-AM

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 23:55	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (113) 17-01-RM-IN-EXAM1-T1

Sampled: 10/17/2024 07:33

Sample ID: 24J3921-AN

Sample Matrix: Drinking Water

Metals Analyses (Total)											
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL							Prepared	Analyzed	
Lead	3.2	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/30/24 23:57	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (114) 17-01-RM-IN-EXAM1-T2

Sampled: 10/17/2024 07:35

Sample ID: 24J3921-AO

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	4.2	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/31/24 0:04	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (115) 17-01-RM-IN-EXAM2-T

Sampled: 10/17/2024 07:36

Sample ID: 24J3921-AP

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	1.9	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/31/24 0:07	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (116) 17-01-RM-IN-EXAM3-T

Sampled: 10/17/2024 07:37

Sample ID: 24J3921-AO

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	3.0	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/31/24 0:09	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (117) 17-01-RM-IN-EXAM4-T

Sampled: 10/17/2024 07:38

Sample ID: 24J3921-AR

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	5.3	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/31/24 0:11	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (118) 17-01-RM-IN-EXAM5-T

Sampled: 10/17/2024 07:39

Sample ID: 24J3921-AS

Sample Matrix: Drinking Water

Metals Analyses (Total)											
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL							Prepared	Analyzed	
Lead	3.1	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/31/24 0:14	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (119) 17-01-RM-IN-EXAM6-T

Sampled: 10/17/2024 07:40

Sample ID: 24J3921-AT

Sample Matrix: Drinking Water

Metals Analyses (Total)											
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL							Prepared	Analyzed	
Lead	2.1	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/31/24 0:16	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (120) 17-01-RM-IN-U118-T

Sampled: 10/17/2024 07:40

Sample ID: 24J3921-AU

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	6.4	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/31/24 0:18	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (121) 17-01-RM-IN-EXAM7-T

Sampled: 10/17/2024 07:43

Sample ID: 24J3921-AV

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	2.2	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/31/24 0:21	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (122) 17-01-RM-IN-HYGIENE-T

Sampled: 10/17/2024 07:44

Sample ID: 24J3921-AW

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/31/24 0:35	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (123) 17-01-RM-IN-EXAM8-T

Sampled: 10/17/2024 08:02

Sample ID: 24J3921-AX

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	1.7	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/31/24 0:37	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (124) 17-01-RM-IN-U142-T1

Sampled: 10/17/2024 08:03

Sample ID: 24J3921-AY

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	1.6	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/31/24 0:40	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Sampled: 10/17/2024 08:07

Field Sample #: (125) 17-01-RM-IN-U142-T2

Sample ID: 24J3921-AZ

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/31/24 0:42	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Sampled: 10/17/2024 08:07

Field Sample #: (126) 17-01-RM-IN-U142-T3

Sample ID: 24J3921-BA

Sample Matrix: Drinking Water

Metals Analyses (Total)											
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL							Prepared	Analyzed	
Lead	1.5	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/31/24 0:44	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Sampled: 10/17/2024 08:08

Field Sample #: (127) 17-01-RM-IN-U142-T4

Sample ID: 24J3921-BB

Sample Matrix: Drinking Water

Metals Analyses (Total)											
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL							Prepared	Analyzed	
Lead	2.4	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/31/24 0:47	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (128) 17-01-RM-IN-U138-T

Sampled: 10/17/2024 08:09

Sample ID: 24J3921-BC

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	3.0	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/31/24 0:49	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (129) 17-01-KL-IN-U102-T

Sampled: 10/17/2024 08:01

Sample ID: 24J3921-BD

Sample Matrix: Drinking Water

Metals Analyses (Total)											
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL							Prepared	Analyzed	
Lead	4.0	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/31/24 0:52	JC



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD-School No. 17

Sample Description:

Work Order: 24J3921

Date Received: 10/28/2024

Field Sample #: (130) 17-01-HA-BY-U111A

Sampled: 10/17/2024 07:30

Sample ID: 24J3921-BE

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	3.6	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	10/29/24	10/31/24 0:54	JC

FLAG/QUALIFIER SUMMARY

*	QC result is outside of established limits.
†	Wide recovery limits established for difficult compound.
‡	Wide RPD limits established for difficult compound.
#	Data exceeded client recommended or regulatory level
ND	Not Detected
RL	Reporting Limit is at the level of quantitation (LOQ)
DL	Detection Limit is the lower limit of detection determined by the MDL study
MCL	Maximum Contaminant Level
	Percent recoveries and relative percent differences (RPDs) are determined by the software using values in the calculation which have not been rounded.
	No results have been blank subtracted unless specified in the case narrative section.

CERTIFICATIONS

Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 200.8 Rev 5.4 in Drinking Water</i>	

Lead NB-CT,NB-NJ,NB-NY

Pace Analytical Services, LCC operates under the following certifications and accreditations:

Code	Description	Number	Expires
NB-CT	Connecticut Department of Public Health	PH-0823	09/30/2024
NB-NJ	New Jersey DEP	NY015 NELAP	06/30/2024
NB-NY	New York State Department of Health	10142 NELAP	03/31/2025



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com
Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 1 of 1

Page 139 of 152

LAB ID: M36476		Company: Lozier Environmental Consulting, Inc.		REPORT TO:		INVOICE TO:	
PROJECT NAME: RCSD - School No. 17		Address: 2011 East Main Street		City, State Zip: Rochester NY 14609		Company: (SAME)	
TURNAROUND TIME: Standard Rush		Phone: 585-654-9080		Fax: 585-654-9662		City, State Zip:	
Other:		E-Mail: support@lozierenv.com		Purchase Order #:		Fax:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	Lead	REQUESTED ANALYSIS	
1	17-01-OE-IN-100A-T	10/15/2024	6:09		DW				x		
2	17-01-CR-IN-K100-B	10/15/2024	6:15		DW				x		
3	17-01-CR-IN-K100-T	10/15/2024	6:16		DW				x		
4	17-01-CR-IN-K101-B	10/15/2024	6:18		DW				x		
5	17-01-CR-IN-K101-T	10/15/2024	6:18		DW				x		
6	17-01-CR-IN-K103-B	10/15/2024	6:20		DW				x		
7	17-01-CR-IN-K103-T	10/15/2024	6:20		DW				x		
8	17-01-CR-IN-K102-B	10/15/2024	6:22		DW				x		
9	17-01-CR-IN-K102-T	10/15/2024	6:22		DW				x		
10	17-01-CR-IN-146-B	10/15/2024	6:26		DW				x		

Container Type (Circle One): Plastic Glass Sterile Other

Delivery (Circle One): Client Drop-Off / Courier (Tracking # 7794 9066 1065)

FOR LAB USE ONLY

SAMPLED BY*: Joe Savio	DATE: 10/17/24	TIME: 845
RELINQUISHED BY*: Joe Savio	DATE: 10/17/24	TIME: 845
RECEIVED BY*: <i>[Signature]</i>	DATE: 10/17/24	TIME: 1040
RELINQUISHED BY*: <i>[Signature]</i>	DATE: 10/17/24	TIME: 1040
RECEIVED BY:	DATE:	TIME:
RELINQUISHED BY:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDES: HNO3-	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINERS 10	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES	Present Absent
SAMPLE ON ICE? NO	If Present, Date Client is
TEMPERATURE: 20.6	contacted with result:
SAMPLE IN COMPLIANCE: YES	Date: 10/17/24
	Contacted By: <i>[Signature]</i>

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 2 of 13

Page 140 of 152

REPORT TO:		INVOICE TO:	
Company:	Lozier Environmental Consulting, Inc.	Company: (SAME)	
Address:	2011 East Main Street	Address:	
City/State Zip:	Rochester NY 14609	City/State Zip:	
Phone:	585-654-9080	Phone:	
Fax:	585-654-9662	Fax:	
E-Mail:	support@lozierenv.com	Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS			
11	17-01-CR-IN-146-T	10/15/2024	6:27		DW				Lead			
12	17-01-CR-IN-144-B	10/15/2024	6:30		DW							
13	17-01-CR-IN-144-T	10/15/2024	6:30		DW							
14	17-01-TC-IN-140-T	10/15/2024	6:33		DW							
15	17-01-CR-IN-118-B	10/15/2024	6:38		DW							
16	17-01-CR-IN-118-T	10/15/2024	6:38		DW							
17	17-01-CR-IN-116-B	10/15/2024	6:41		DW							
18	17-01-CR-IN-116-T	10/15/2024	6:41		DW							
19	17-01-CR-IN-114-B	10/15/2024	6:44		DW							
20	17-01-CR-IN-114-T	10/15/2024	6:44		DW							

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # 77949666 7065)

FCO Sealed

SAMPLED BY*: Joe Savioe

RELINQUISHED BY*: Joe Savioe DATE: 10/17/24 TIME: 845

RECEIVED BY*: *John* DATE: 10/18/24 TIME: 1040

RELINQUISHED BY*: DATE: TIME:

RECEIVED BY*: DATE: TIME:

RELINQUISHED BY*: DATE: TIME:

RECEIVED BY*: DATE: TIME:

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDE: HNOS-	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINERS: 10	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES	Present Absent
SAMPLE ON ICE? NO	If Present, Date Client is
TEMPERATURE: 200 15.1	contacted with result:
SAMPLE IN COMPLIANCE: YES	Date: _____
	Contacted By: _____



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

REPORT TO:				INVOICE TO:	
Company:	Lozier Environmental Consulting, Inc.	Company: (SAME)			
Address:	2011 East Main Street	Address:			
City/State/Zip:	Rochester NY 14609	City/State/Zip:			
Phone:	585-654-9080	Phone:			
Fax:	585-654-9662	Fax:			
E-Mail:	support@lozierenv.com	Purchase Order #:			

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS				
21	17-01-CR-IN-112-B	10/15/2024	6:47		DW				Lead				
22	17-01-CR-IN-112-T	10/15/2024	6:47		DW								
23	17-01-NO-IN-107-T	10/15/2024	6:51		DW								
24	17-01-NO-IN-107A-T	10/15/2024	6:51		DW								
25	17-01-CR-IN-150-T	10/15/2024	6:53		DW								
26	17-01-CR-IN-152-T	10/15/2024	6:56		DW								
27	17-01-HA-BY-151-FL	10/15/2024	6:58		DW								
28	17-01-HA-BY-151-FR	10/15/2024	6:59		DW								
29	17-01-HA-BY-151-BF	10/15/2024	6:59		DW								
30	17-01-CR-IN-G105-B	10/15/2024	7:05		DW								

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

77949066 (065)
FED EX GROUND

SAMPLED BY*: Joe Savioe	DATE: 10/17/24	TIME: 845
RECEIVED BY*: Joe Savioe	DATE: 10/17/24	TIME: 1040
RELINQUISHED BY*: [Signature]	DATE: 10/17/24	TIME: 1040
RECEIVED BY:	DATE:	TIME:
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDE: HNO3-	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINERS: 10	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES	Present Absent
SAMPLE ON ICE? NO	If Present, Date Client is
TEMPERATURE: 20.0 (5.0)	contacted with result:
SAMPLE IN COMPLIANCE: YES	Date: _____
	Contacted By: _____

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis



2011 East Main Street, Rochester, NY 14609 Phone (585) 654-9080 Fax (585) 654-9662
Web: LozierEnv.com E-Mail: support@lozierenv.com

Page 4 of 13

Page 142 of 152

REPORT TO:		INVOICE TO:	
Company:	Lozier Environmental Consulting, Inc.	Company:	(SAME)
Address:	2011 East Main Street	Address:	
City, State Zip:	Rochester NY 14609	City, State Zip:	
Phone:	585-654-9080	Phone:	
Fax:	585-654-9662	Fax:	
E-Mail:	support@lozierenv.com	Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS			
31	17-01-CR-IN-G105-T	10/15/2024	7:05		DW				Lead			
32	17-01-CR-IN-G100-B	10/15/2024	7:08		DW							
33	17-01-CR-IN-G100-T	10/15/2024	7:08		DW							
34	17-01-CF-IN-G102-FL	10/16/2024	6:04		DW							
35	17-01-CF-IN-G102-FR	10/16/2024	6:05		DW							
36	17-01-CF-IN-G102-BF	10/16/2024	6:05		DW							
37	17-01-KI-IN-G102A-T1	10/16/2024	6:09		DW			hand wash sink	x			
38	17-01-KI-IN-G102A-T2	10/16/2024	6:10		DW			hand wash sink	x			
39	17-01-KI-IN-G102A-T3	10/16/2024	6:11		DW			hand wash sink	x			
40	17-01-KI-IN-G102A-T4	10/16/2024	6:12		DW			dish sink left	x			

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # 7794 9066 4065)

SAMPLED BY*: Joe Savioe

RELINQUISHED BY*: Joe Savioe DATE: 10/17/24 TIME: 8:45

RECEIVED BY*: [Signature] DATE: 10/18/24 TIME: 10:40

RELINQUISHED BY*: _____ DATE: _____ TIME: _____

RECEIVED BY*: _____ DATE: _____ TIME: _____

RELINQUISHED BY*: _____ DATE: _____ TIME: _____

RECEIVED BY*: _____ DATE: _____ TIME: _____

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDES: HNO3-	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINERS: 10	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES	Present Absent
SAMPLE ON ICE? NO	If Present, Date Client is contacted with result:
TEMPERATURE: <u>20.0</u> <u>5.1</u>	Date: _____
SAMPLE IN COMPLIANCE: YES	Contacted By: _____



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com
Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 5 of 13

REPORT TO:		INVOICE TO:	
Company:	Lozier Environmental Consulting, Inc.	Company: (SAME)	
Address:	2011 East Main Street	Address:	
City/State Zip:	Rochester NY 14609	City/State Zip:	
Phone:	585-654-9080	Phone:	
Fax:	585-654-9662	Fax:	
E-Mail:	support@lozierenv.com	Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS			
41	17-01-KI-IN-G102A-T5	10/16/2024	6:12		DW			dish sink sprayer	x			
42	17-01-KI-IN-G102A-T6	10/16/2024	6:13		DW			dish sink right	x			
43	17-01-KI-IN-G102A-T7	10/16/2024	6:13		DW			island prep station	x			
44	17-01-KI-IN-G102A-T8	10/16/2024	6:14		DW			hand wash sink	x			
45	17-01-KI-IN-G102A-T9	10/16/2024	6:15		DW			wall prep station	x			
46	17-01-HA-BY-G112-FL	10/16/2024	6:17		DW				x			
47	17-01-HA-BY-G112-FR	10/16/2024	6:17		DW				x			
48	17-01-HA-BY-G112-BF	10/16/2024	6:18		DW				x			
49	17-01-HA-BY-G110-F	10/16/2024	6:20		DW				x			
50	17-01-HA-BY-G110-BF	10/16/2024	6:20		DW				x			

Container Type (Circle One): Plastic Glass Sterile Other

Delivery (Circle One): Client Drop-Off / Courier (Tracking # 779490665389)

SAMPLED BY*: Joe Savioe

RELINQUISHED BY*: Joe Savioe DATE: 10/17/24 TIME: 8:45

RECEIVED BY*: *Joe Savioe* DATE: 10/17/24 TIME: 10:00

RELINQUISHED BY*: DATE: TIME:

RECEIVED BY*: DATE: TIME:

RELINQUISHED BY*: DATE: TIME:

RECEIVED BY*: DATE: TIME:

FOR LAB USE ONLY

PRESERVATIVE/BIOCIDES: HNO3- FOR POTABLE WATER ONLY:

TOTAL NUMBER OF CONTAINERS: 10 COLIFORM BACTERIA:

CUSTODY SEAL INTACT? YES Present Absent

SAMPLE ON ICE? NO If Present, Date Client is

TEMPERATURE: 20.0 3.1 contacted with result:

SAMPLE IN COMPLIANCE: YES Date: Contacted By:



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 6 of 13

Page 144 of 152

REPORT TO:				INVOICE TO:			
Company:		Lozier Environmental Consulting, Inc.		Company: (SAME)			
Address:		2011 East Main Street		Address:			
City/State Zip:		Rochester NY 14609		City/State Zip:			
Phone:		585-654-9080		Phone:			
Fax:		585-654-9662		Fax:			
E-Mail: support@lozierenv.com				Purchase Order #:			

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS				
51	17-02-CR-IN-200-B	10/16/2024	6:30		DW				Lead				
52	17-02-CR-IN-200-T	10/16/2024	6:31		DW				X				
53	17-02-CR-IN-201-B	10/16/2024	6:34		DW				X				
54	17-02-CR-IN-201-T	10/16/2024	6:35		DW				X				
55	17-02-CR-IN-202-B	10/16/2024	6:37		DW				X				
56	17-02-CR-IN-202-T	10/16/2024	6:38		DW				X				
57	17-02-CR-IN-208-B	10/16/2024	6:41		DW				X				
58	17-02-CR-IN-208-T	10/16/2024	6:41		DW				X				
59	17-02-CR-IN-210-B	10/16/2024	6:43		DW				X				
60	17-02-CR-IN-210-T	10/16/2024	6:44		DW				X				

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # 7744 00663369)

SAMPLED BY*: Joe Savioe

RELINQUISHED BY*: Joe Savioe

DATE: 10/17/24 TIME: 845

RECEIVED BY*: Joe Savioe

DATE: 10/28/24 TIME: 1040

RELINQUISHED BY*:

DATE: TIME:

RECEIVED BY*:

DATE: TIME:

RELINQUISHED BY*:

DATE: TIME:

RECEIVED BY*:

DATE: TIME:

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FOR LAB USE ONLY		FOR POTABLE WATER ONLY:	
PRESERVATIVE/BIOCIDES: HNO3-		COLIFORM BACTERIA:	Present Absent
TOTAL NUMBER OF CONTAINERS: 10			
CUSTODY SEAL INTACT? YES			
SAMPLE ON ICE? NO			
TEMPERATURE: <u>20.6</u> <u>13.1</u>			
SAMPLE IN COMPLIANCE: YES			
		Date: _____	Contacted By: _____



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 7 of 13

Page 145 of 152

LAB ID: M36476	Company: Lozier Environmental Consulting, Inc.	REPORT TO:	INVOICE TO:
PROJECT NAME: RCSD - School No. 17	Address: 2011 East Main Street		
TURNAROUND TIME: Standard Rush	City/State Zip: Rochester NY 14609		
Other:	Phone: 585-654-9080 Fax: 585-654-9662		
	E-Mail: support@lozierenv.com		

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS				
61	17-02-CR-IN-214-B	10/16/2024	6:45	DW					x				
62	17-02-CR-IN-214-T	10/16/2024	6:46	DW					x				
63	17-02-RM-IN-209-T	10/16/2024	6:48	DW					x				
64	17-02-CR-IN-210-TL	10/16/2024	6:52	DW					x				
65	17-02-CR-IN-210-TR	10/16/2024	6:53	DW					x				
66	17-02-HA-BY-213-FL	10/16/2024	6:54	DW					x				
67	17-02-HA-BY-213-FR	10/16/2024	6:55	DW					x				
68	17-02-CR-IN-223-B	10/16/2024	6:57	DW					x				
69	17-02-CR-IN-223-T	10/16/2024	6:58	DW					x				
70	17-02-CR-IN-224-B	10/16/2024	6:58	DW					x				

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # 779496665389) FE0 6x 6x2

SAMPLED BY*: Joe Savioe

RELINQUISHED BY*: Joe Savioe

RECEIVED BY: [Signature] DATE: 10/17/24 TIME: 845

RELINQUISHED BY*: [Signature] DATE: 10/17/24 TIME: 1040

RECEIVED BY: DATE: TIME:

RELINQUISHED BY*: DATE: TIME:

RECEIVED BY: DATE: TIME:

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDES: HNO3-	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINERS: 10	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES	Present Absent
SAMPLE ON ICE? NO	If Present, Date Client is
TEMPERATURE: 20°C 13-1	contacted with result:
SAMPLE IN COMPLIANCE: YES	Date: _____
	Contacted By: _____

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 8 of 13

Page 146 of 152

LAB ID: M36476	Company: Lozier Environmental Consulting, Inc.	REPORT TO:	INVOICE TO:
PROJECT NAME: RCSD - School No. 17	Address: 2011 East Main Street		
TURNAROUND TIME: Standard Rush	City/State Zip: Rochester NY 14609		
Other:	Phone: 585-654-9080 Fax: 585-654-9662		
	E-Mail: support@lozierenv.com		
	Purchase Order #:		

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS				
									Lead				
71	17-02-CR-IN-224-T	10/16/2024	6:59		DW				x				
72	17-02-CR-IN-226-T	10/16/2024	7:00		DW			attached disabled bubbler	x				
73	17-02-CR-IN-228-T	10/16/2024	7:04		DW			attached disabled bubbler	x				
74	17-02-CR-IN-230-B	10/16/2024	7:05		DW				x				
75	17-02-CR-IN-230-T	10/16/2024	7:05		DW				x				
76	17-02-CR-IN-232-B	10/16/2024	7:07		DW				x				
77	17-02-CR-IN-232-T	10/16/2024	7:08		DW				x				
78	17-02-CR-IN-234-B	10/17/2024	6:10		DW				x				
79	17-02-CR-IN-234-T	10/17/2024	6:10		DW				x				
80	17-02-CR-IN-236-B	10/17/2024	6:12		DW				x				

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # 779490665389)

FSV 566AD

SAMPLED BY*: Joe Savioe

RELINQUISHED BY*: Joe Savioe DATE: 10/17/24 TIME: 8:45

RECEIVED BY*: John Doe DATE: 10/20/24 TIME: 10:40

RELINQUISHED BY*: DATE: TIME:

RECEIVED BY: DATE: TIME:

RELINQUISHED BY*: DATE: TIME:

RECEIVED BY: DATE: TIME:

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDES: HNO3-	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINERS: 10	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES	Present Absent
SAMPLE ON ICE? NO	If Present, Date Client is
TEMPERATURE: <u>20C</u> <u>13.0</u>	contacted with result:
SAMPLE IN COMPLIANCE: YES	Date: _____
	Contacted By: _____

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 9 of 13

Page 147 of 152

REPORT TO:		INVOICE TO:	
Company:	Lozier Environmental Consulting, Inc.	Company:	(SAME)
Address:	2011 East Main Street	Address:	
City/State Zip:	Rochester NY 14609	City/State Zip:	
Phone:	585-654-9080	Phone:	
Fax:	585-654-9662	Fax:	
E-Mail:	support@lozierenv.com	Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS			
81	17-02-CR-IN-236-T	10/17/2024	6:12		DW							
82	17-02-CR-IN-237-B	10/17/2024	6:17		DW							
83	17-02-CR-IN-237-T	10/17/2024	6:17		DW							
84	17-02-CR-IN-239-B	10/17/2024	6:20		DW							
85	17-02-CR-IN-239-T	10/17/2024	6:21		DW							
86	17-03-CR-IN-332-B	10/17/2024	6:25		DW							
87	17-03-CR-IN-332-T	10/17/2024	6:25		DW							
88	17-03-CR-IN-330-B	10/17/2024	6:29		DW							
89	17-03-CR-IN-330-T	10/17/2024	6:29		DW							
90	17-03-CR-IN-328-B	10/17/2024	6:32		DW							

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # 779490665231)

SAMPLED BY*: Joe Savio

RELINQUISHED BY*: Joe Savio DATE: 10/17/24 TIME: 845

RECEIVED BY*: *[Signature]* DATE: 10/28/24 TIME: 1040

RELINQUISHED BY*: DATE: TIME:

RECEIVED BY: DATE: TIME:

RELINQUISHED BY*: DATE: TIME:

RECEIVED BY: DATE: TIME:

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDES: HNO3-	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINERS: 10	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES	Present Absent
SAMPLE ON ICE? NO	If Present, Date Client is
TEMPERATURE: 20°C 15.1	contacted with result:
SAMPLE IN COMPLIANCE: YES	Date: _____
	Contacted By: _____



2011 East Main Street, Rochester, NY 14609 Phone (585) 654-9080 Fax (585) 654-9662
Web: LozierEnv.com E-Mail: support@lozierenv.com

Page 10 of 13

Page 148 of 152

REPORT TO:				INVOICE TO:			
Company: Lozier Environmental Consulting, Inc.		Address:		Company: (SAME)		Address:	
City/State Zip: 2011 East Main Street		City/State Zip:		City/State Zip:		City/State Zip:	
Phone: 585-654-9080		Fax: 585-654-9662		Phone:		Fax:	
E-Mail: support@lozierenv.com		Purchase Order #:					

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS			
91	17-03-CR-IN-328-T	10/17/2024	6:32		DW				X			
92	17-03-CR-IN-326-B	10/17/2024	6:36		DW				X			
93	17-03-CR-IN-326-T	10/17/2024	6:37		DW				X			
94	17-03-CR-IN-324-B	10/17/2024	6:39		DW				X			
95	17-03-CR-IN-324-T	10/17/2024	6:39		DW				X			
96	17-03-CR-IN-323-TL	10/17/2024	6:41		DW				X			
97	17-03-CR-IN-323-TR	10/17/2024	6:41		DW				X			
98	17-03-HA-BY-313-F	10/17/2024	6:42		DW				X			
99	17-03-HA-BY-313-BF	10/17/2024	6:43		DW				X			
100	17-03-CR-IN-313-TL	10/17/2024	6:44		DW				X			

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # 77949066 3231)

FED EX GROUND

SAMPLED BY*: Joe Savioe	DATE: 10/17/24	TIME: 8:45
RELINQUISHED BY*: Joe Savioe	DATE: 10/17/24	TIME: 10:00
RECEIVED BY*: Joe Savioe	DATE: 10/17/24	TIME: 10:00
RELINQUISHED BY*: Joe Savioe	DATE: 10/17/24	TIME: 10:00
RECEIVED BY*: Joe Savioe	DATE: 10/17/24	TIME: 10:00
RELINQUISHED BY*: Joe Savioe	DATE: 10/17/24	TIME: 10:00
RECEIVED BY*: Joe Savioe	DATE: 10/17/24	TIME: 10:00

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDES: HNO3-	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINERS: 5	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES	Present Absent
SAMPLE ON ICE? NO	If Present, Date Client is
TEMPERATURE: 20°C (50°F)	contacted with result:
SAMPLE IN COMPLIANCE: YES	Date: _____
	Contacted By: _____



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 11 of 15

Page 149 of 152

LAB ID: M36476		REPORT TO:		INVOICE TO:	
PROJECT NAME: RCSD - School No. 17		Company: Lozier Environmental Consulting, Inc.		Company: (SAME)	
TURNAROUND TIME: Standard Rush		Address: 2011 East Main Street		Address:	
Other:		City/State Zip: Rochester NY 14609		City/State Zip:	
		Phone: 585-654-9080		Phone:	
		Fax: 585-654-9662		Fax:	
		E-Mail: support@lozierenv.com		Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS				
101	17-03-CR-IN-313-TR	10/17/2024	6:44		DW				Lead				
102	17-03-CR-IN-301-B	10/17/2024	6:49		DW								
103	17-03-CR-IN-301-T	10/17/2024	6:49		DW								
104	17-03-CR-IN-302-B	10/17/2024	6:52		DW								
105	17-03-CR-IN-302-T	10/17/2024	6:53		DW								
106	17-03-CR-IN-308-B	10/17/2024	6:59		DW								
107	17-03-CR-IN-308-T	10/17/2024	7:00		DW								
108	17-03-CR-IN-312-B	10/17/2024	7:02		DW								
109	17-03-CR-IN-312-T	10/17/2024	7:03		DW								
110	17-01-RM-IN-BRK RM HLTH CTR-T	10/17/2024	7:12		DW								

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # 779496663251)

FEV SE 620

SAMPLED BY*: Joe Savioe

RELINQUISHED BY*: Joe Savioe

DATE: 10/17/24 TIME: 845

RECEIVED BY*: *[Signature]*

DATE: 10/18/24 TIME: 1040

RELINQUISHED BY*: *[Signature]*

DATE: _____ TIME: _____

RECEIVED BY: _____

DATE: _____ TIME: _____

RELINQUISHED BY*: _____

DATE: _____ TIME: _____

RECEIVED BY: _____

DATE: _____ TIME: _____

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FOR LAB USE ONLY		FOR POTABLE WATER ONLY:	
PRESERVATIVE/BIOCIDES: HNO3-		COLIFORM BACTERIA:	
TOTAL NUMBER OF CONTAINERS: 10		Present	Absent
CUSTODY SEAL INTACT? YES		If Present, Date Client is contacted with result:	
SAMPLE ON ICE? NO		Date: _____	Contacted By: _____
TEMPERATURE: 20.0 (5.0)			
SAMPLE IN COMPLIANCE: YES			



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 12 of 13

Page 150 of 152

LAB ID: M36476		REPORT TO:		INVOICE TO:	
PROJECT NAME: RCSD - School No. 17		Company: Lozier Environmental Consulting, Inc.		Company: (SAME)	
TURNAROUND TIME: Standard Rush		Address: 2011 East Main Street		Address:	
Other:		City, State Zip: Rochester NY 14609		City, State Zip:	
		Phone: 585-654-9080		Phone:	
		Fax: 585-654-9662		Fax:	
		E-Mail: support@lozierenv.com		Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS				
111	17-01-RM-IN-WAIT RM HLTH CTR-F	10/17/2024	7:17		DW				Lead				
112	17-01-RM-IN-WAIT RM HLTH CTR-BF	10/17/2024	7:17		DW				x				
113	17-01-RM-IN-EXAM1-T1	10/17/2024	7:33		DW				x				
114	17-01-RM-IN-EXAM1-T2	10/17/2024	7:35		DW				x				
115	17-01-RM-IN-EXAM2-T	10/17/2024	7:36		DW				x				
116	17-01-RM-IN-EXAM3-T	10/17/2024	7:37		DW				x				
117	17-01-RM-IN-EXAM4-T	10/17/2024	7:38		DW				x				
118	17-01-RM-IN-EXAM5-T	10/17/2024	7:39		DW				x				
119	17-01-RM-IN-EXAM6-T	10/17/2024	7:40		DW				x				
120	17-01-RM-IN-U118-T	10/17/2024	7:40		DW				x				

Container Type (Circle One): Plastic Glass Sterile Other _____ Delivery (Circle One): Client Drop-Off / Courier (Tracking # 72420665251)

SAMPLED BY*: Joe Savioe		DATE: 10/17/24		TIME: 8:45	
RELINQUISHED BY*: Joe Savioe		DATE: 10/28/24		TIME: 1:40	
RECEIVED BY*: <i>John Kim</i>		DATE: 10/28/24		TIME: 1:40	
RELINQUISHED BY*:		DATE:		TIME:	
RECEIVED BY:		DATE:		TIME:	
RELINQUISHED BY*:		DATE:		TIME:	
RECEIVED BY:		DATE:		TIME:	

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FOR LAB USE ONLY		FOR POTABLE WATER ONLY:	
PRESERVATIVE/BIOCIDE: HNO3-		COLIFORM BACTERIA:	
TOTAL NUMBER OF CONTAINERS: 10		Present Absent	
CUSTODY SEAL INTACT? YES		If Present, Date Client is contacted with result:	
SAMPLE ON ICE? NO		Date: _____	
TEMPERATURE: 20C 130C		Contacted By: _____	
SAMPLE IN COMPLIANCE: YES			



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 13 of 13

Page 151 of 152

REPORT TO:		INVOICE TO:	
Company:	Lozier Environmental Consulting, Inc.	Company: (SAME)	
Address:	2011 East Main Street	Address:	
City, State Zip:	Rochester NY 14609	City, State Zip:	
Phone:	585-654-9080	Phone:	
Fax:	585-654-9662	Fax:	
E-Mail:	support@lozierenv.com	Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS			
121	17-01-RM-IN-EXAM7-T	10/17/2024	7:43		DW				x			
122	17-01-RM-IN-HYGIENE-T	10/17/2024	7:44		DW				x			
123	17-01-RM-IN-EXAM8-T	10/17/2024	8:02		DW				x			
124	17-01-RM-IN-U142-T1	10/17/2024	8:03		DW				x			
125	17-01-RM-IN-U142-T2	10/17/2024	8:07		DW				x			
126	17-01-RM-IN-U142-T3	10/17/2024	8:07		DW				x			
127	17-01-RM-IN-U142-T4	10/17/2024	8:08		DW				x			
128	17-01-RM-IN-U138-T	10/17/2024	8:09		DW				x			
129	17-01-KI-IN-U102-T	10/17/2024	8:01		DW				x			
130	17-01-HA-BY-U111A	10/17/2024	7:30		DW				x			

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # 7754 9066 4561)

FEV 6x 620

SAMPLED BY*: Joe Savioe

RELINQUISHED BY*: Joe Savioe DATE: 10/17/24 TIME: 845

RECEIVED BY*: John Itin DATE: 10/18/24 TIME: 1040

RELINQUISHED BY*: DATE: TIME:

RECEIVED BY*: DATE: TIME:

RELINQUISHED BY*: DATE: TIME:

RECEIVED BY*: DATE: TIME:

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDES: HNO3-	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINERS: 10	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES	Present Absent
SAMPLE ON ICE? NO	If Present, Date Client is
TEMPERATURE: <u>20C</u> <u>13.1</u>	contacted with result:
SAMPLE IN COMPLIANCE: YES	Date: _____
	Contacted By: _____

Sample Condition Upon Receipt Form (SCUR)

Project # 24J3921
Client: Lozier Env. Consulting

Date and Initials of person:
Examining contents: _____
Label: _____
Deliver to location: _____
pH: _____

Thermometer Used: IRG4

Date: 10/28

Time: 1040

Initials: _____

State of Origin: NY

Cooler #1 Temp. °C 13.1 (Visual) 0.2 @ 0.0°C, -0.5 @ 20.0°C (Correction Factor) _____ (Actual) ☒ Samples on ice, cooling process has begun

Courier: ☒ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☐ Pace ☐ Other _____

Shipping Method: ☐ First Overnight ☐ Priority Overnight ☐ Standard Overnight ☒ Ground

☐ Other _____

Tracking # 7794 9066 4065

Custody Seal on Cooler/Box Present: ☐ Yes ☐ No

Seals intact: ☐ Yes ☐ No

Ice: ☒ Wet ☐ Blue ☐ Melted ☐ None

Packing Material: ☐ Bubble Wrap ☐ Bubble Bags ☐ None ☐ Other _____

Samples were collected by Pace employee ☐ Yes ☐ No ☐ N/A

Comments:

Chain of Custody Present	☒ Yes ☐ No ☐ N/A	
Chain of Custody Filled Out	☒ Yes ☐ No ☐ N/A	
Relinquished Signature on COC	☒ Yes ☐ No ☐ N/A	
Sampler Name and Signature on COC	☒ Yes ☐ No ☐ N/A	
Samples Arrived within Hold Time	☒ Yes ☐ No ☐ N/A	
Rush TAT requested on COC	☐ Yes ☐ No ☐ N/A	
Sufficient Volume	☒ Yes ☐ No ☐ N/A	
Correct Containers Used	☒ Yes ☐ No ☐ N/A	
Containers Intact	☒ Yes ☐ No ☐ N/A	
Sample Labels match COC (sample IDs & date/time of collection)	☒ Yes ☐ No ☐ N/A	
All containers needing acid/base preservation have been checked.	☐ Yes ☐ No ☐ N/A	Preservation Information: Preservative: _____ Lot #/Trace #: _____ Date: _____ Time: _____ Initials: _____
All Containers needing preservation are found to be in compliance with EPA recommendation: Exceptions: Vials, Microbiology, O&G, Metals	☐ Yes ☐ No ☐ N/A	
Headspace in VOA Vials? (>6mm):	☐ Yes ☐ No ☐ N/A	
Trip Blank Present:	☐ Yes ☐ No ☐ N/A	

Additional Login Comments:

Client notification/ Resolution

Person Contacted: _____ Date/Time: _____
Comments/Resolution: _____