


December 15, 2023

V Kaptein
NB-Lozier Environmental Consulting, Inc
2011 E Main Street
Rochester, NY 14609

Project Location: RCSD Dr. CTL School 19
Project Number: Lozier Environmental Consulting
Laboratory Work Order Number: 23L1416

Enclosed are results of analyses for samples received by the laboratory on December 11, 2023. If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Project Manager



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

NB-Lozier Environmental Consulting, Inc
2011 E Main Street
Rochester, NY 14609
ATTN: V Kaptein

REPORT DATE: 12/15/2023

PURCHASE ORDER NUMBER: M33568

PROJECT NUMBER: Lozier Environmental Consulting

ANALYTICAL SUMMARY

WORK ORDER NUMBER: 23L1416

The results of analyses performed on the following samples submitted to Pace Analytical Services, LLC - Newburgh are found in this report.

PROJECT LOCATION: RCSD Dr. CTL School 19

FIELD SAMPLE #	LAB ID:	MATRIX	SAMPLE DESCRIPTION	TEST	SUB LAB
19-01-CR-IN-106-B (1)	23L1416-01	Drinking Water		EPA 200.8 Rev 5.4	
19-01-CR-IN-107-T1 (2)	23L1416-02	Drinking Water		EPA 200.8 Rev 5.4	
19-01-CR-IN-107-T2 (3)	23L1416-03	Drinking Water		EPA 200.8 Rev 5.4	
19-01-CR-IN-108-T (5)	23L1416-04	Drinking Water		EPA 200.8 Rev 5.4	
19-01-CR-IN-116-B (6)	23L1416-05	Drinking Water		EPA 200.8 Rev 5.4	
19-01-CR-IN-116-T (7)	23L1416-06	Drinking Water		EPA 200.8 Rev 5.4	
19-01-CR-IN-117-B (8)	23L1416-07	Drinking Water		EPA 200.8 Rev 5.4	
19-01-CR-IN-118-T (9)	23L1416-08	Drinking Water		EPA 200.8 Rev 5.4	
19-01-CR-IN-118-T2 (10)	23L1416-09	Drinking Water		EPA 200.8 Rev 5.4	
19-01-CR-IN-118-T (11)	23L1416-10	Drinking Water		EPA 200.8 Rev 5.4	
19-01-CR-IN-122A-T (12)	23L1416-11	Drinking Water		EPA 200.8 Rev 5.4	
19-02-CR-IN-216-T (19)	23L1416-12	Drinking Water		EPA 200.8 Rev 5.4	
19-02-CR-IN-217-T (21)	23L1416-13	Drinking Water		EPA 200.8 Rev 5.4	
19-02-CR-IN-218-T (23)	23L1416-14	Drinking Water		EPA 200.8 Rev 5.4	
19-02-CR-IN-219-B (24)	23L1416-15	Drinking Water		EPA 200.8 Rev 5.4	
19-02-CR-IN-219-T (25)	23L1416-16	Drinking Water		EPA 200.8 Rev 5.4	
19-02-CR-IN-225-B (26)	23L1416-17	Drinking Water		EPA 200.8 Rev 5.4	
19-02-CR-IN-225-T (27)	23L1416-18	Drinking Water		EPA 200.8 Rev 5.4	
19-02-CR-IN-226-B (28)	23L1416-19	Drinking Water		EPA 200.8 Rev 5.4	
19-02-CR-IN-226-T (29)	23L1416-20	Drinking Water		EPA 200.8 Rev 5.4	
19-02-CR-IN-227-B (30)	23L1416-21	Drinking Water		EPA 200.8 Rev 5.4	
19-02-CR-IN-227-T (31)	23L1416-22	Drinking Water		EPA 200.8 Rev 5.4	
19-02-CR-IN-228-B (32)	23L1416-23	Drinking Water		EPA 200.8 Rev 5.4	
19-02-CR-IN-228-T (33)	23L1416-24	Drinking Water		EPA 200.8 Rev 5.4	
19-02-KL-IN-200A-T (35)	23L1416-25	Drinking Water		EPA 200.8 Rev 5.4	
19-02-KL-IN-200A-TL (36)	23L1416-26	Drinking Water		EPA 200.8 Rev 5.4	
19-02-KL-IN-200A-TM (37)	23L1416-27	Drinking Water		EPA 200.8 Rev 5.4	
19-02-KL-IN-200B-T (38)	23L1416-28	Drinking Water		EPA 200.8 Rev 5.4	
19-02-TC-IN-211-T (39)	23L1416-29	Drinking Water		EPA 200.8 Rev 5.4	
19-03-CR-IN-305B-T (41)	23L1416-30	Drinking Water		EPA 200.8 Rev 5.4	
19-03-CR-IN-316-B (49)	23L1416-31	Drinking Water		EPA 200.8 Rev 5.4	
19-03-CR-IN-316-T (50)	23L1416-32	Drinking Water		EPA 200.8 Rev 5.4	
19-03-CR-IN-317-B (51)	23L1416-33	Drinking Water		EPA 200.8 Rev 5.4	
19-03-CR-IN-317-T (52)	23L1416-34	Drinking Water		EPA 200.8 Rev 5.4	
19-03-CR-IN-318-T (54)	23L1416-36	Drinking Water		EPA 200.8 Rev 5.4	
19-03-CR-IN-319-B (55)	23L1416-37	Drinking Water		EPA 200.8 Rev 5.4	
19-03-CR-IN-319-T (56)	23L1416-38	Drinking Water		EPA 200.8 Rev 5.4	
19-03-CR-IN-325-B (57)	23L1416-39	Drinking Water		EPA 200.8 Rev 5.4	
19-03-CR-IN-325-T (58)	23L1416-40	Drinking Water		EPA 200.8 Rev 5.4	
19-03-CR-IN-326-B (59)	23L1416-41	Drinking Water		EPA 200.8 Rev 5.4	



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

NB-Lozier Environmental Consulting, Inc
2011 E Main Street
Rochester, NY 14609
ATTN: V Kaptein

REPORT DATE: 12/15/2023

PURCHASE ORDER NUMBER: M33568

PROJECT NUMBER: Lozier Environmental Consulting

ANALYTICAL SUMMARY

WORK ORDER NUMBER: 23L1416

The results of analyses performed on the following samples submitted to Pace Analytical Services, LLC - Newburgh are found in this report.

PROJECT LOCATION: RCSD Dr. CTL School 19

FIELD SAMPLE #	LAB ID:	MATRIX	SAMPLE DESCRIPTION	TEST	SUB LAB
19-03-CR-IN-326-T (60)	23L1416-42	Drinking Water		EPA 200.8 Rev 5.4	
19-03-CR-IN-327-B (61)	23L1416-43	Drinking Water		EPA 200.8 Rev 5.4	
19-03-CR-IN-327-T (62)	23L1416-44	Drinking Water		EPA 200.8 Rev 5.4	
19-03-CR-IN-328-B (63)	23L1416-45	Drinking Water		EPA 200.8 Rev 5.4	
19-03-CR-IN-328-T (64)	23L1416-46	Drinking Water		EPA 200.8 Rev 5.4	
19-03-HA-BY-302-F (65)	23L1416-47	Drinking Water		EPA 200.8 Rev 5.4	
19-03-HA-BY-322-F (66)	23L1416-48	Drinking Water		EPA 200.8 Rev 5.4	
19-03-NO-IN-329-BBACK (67)	23L1416-49	Drinking Water		EPA 200.8 Rev 5.4	
19-03-NO-IN-329-BFRONT (68)	23L1416-50	Drinking Water		EPA 200.8 Rev 5.4	
19-03-HA-BY-302-FL (70)	23L1416-51	Drinking Water		EPA 200.8 Rev 5.4	
19-03-HA-BY-302-BF (71)	23L1416-52	Drinking Water		EPA 200.8 Rev 5.4	
19-03-HA-BY-327-BF (72)	23L1416-53	Drinking Water		EPA 200.8 Rev 5.4	
19-03-NO-IN-329-B1 (73)	23L1416-54	Drinking Water		EPA 200.8 Rev 5.4	
19-03-NO-IN-329-B2 (74)	23L1416-55	Drinking Water		EPA 200.8 Rev 5.4	
19-03-CR-IN-321-B (75)	23L1416-56	Drinking Water		EPA 200.8 Rev 5.4	
19-03-CR-IN-321-T (76)	23L1416-57	Drinking Water		EPA 200.8 Rev 5.4	
19-02-HA-BY-200-F (77)	23L1416-58	Drinking Water		EPA 200.8 Rev 5.4	
19-02-HA-BY-300-BF (78)	23L1416-59	Drinking Water		EPA 200.8 Rev 5.4	
19-02-KI-200A-TM-S (79)	23L1416-60	Drinking Water		EPA 200.8 Rev 5.4	
19-02-CAFE-IN-205-F (80)	23L1416-61	Drinking Water		EPA 200.8 Rev 5.4	
19-02-CAFE-IN-205-BF (81)	23L1416-62	Drinking Water		EPA 200.8 Rev 5.4	
19-01-HA-BY-102-F (82)	23L1416-63	Drinking Water		EPA 200.8 Rev 5.4	
19-01-HA-BY-102-BF (83)	23L1416-64	Drinking Water		EPA 200.8 Rev 5.4	
19-01-CR-IN-116-T2 (84)	23L1416-65	Drinking Water		EPA 200.8 Rev 5.4	
19-01-CR-IN-108-T2 (84)	23L1416-66	Drinking Water		EPA 200.8 Rev 5.4	
19-01-CR-IN-107-B (86)	23L1416-67	Drinking Water		EPA 200.8 Rev 5.4	
19-01-CR-IN-106-T1 (87)	23L1416-68	Drinking Water		EPA 200.8 Rev 5.4	
19-01-CR-IN-106-T2 (88)	23L1416-69	Drinking Water		EPA 200.8 Rev 5.4	

CASE NARRATIVE SUMMARY

All reported results are within defined laboratory quality control objectives unless listed below or otherwise qualified in this report.

EPA 200.8 Rev 5.4

Qualifications:

Z-01

#


Analyte & Samples(s) Qualified:

Lead

23L1416-04[19-01-CR-IN-108-T (5)], 23L1416-05[19-01-CR-IN-116-B (6)], 23L1416-09[19-01-CR-IN-118-T2 (10)], 23L1416-13[19-02-CR-IN-217-T (21)], 23L1416-14[19-02-CR-IN-218-T (23)], 23L1416-15[19-02-CR-IN-219-B (24)], 23L1416-20[19-02-CR-IN-226-T (29)], 23L1416-23[19-02-CR-IN-228-B (32)], 23L1416-24[19-02-CR-IN-228-T (33)], 23L1416-30[19-03-CR-IN-305B-T (41)], 23L1416-31[19-03-CR-IN-316-B (49)], 23L1416-32[19-03-CR-IN-316-T (50)], 23L1416-33[19-03-CR-IN-317-B (51)], 23L1416-34[19-03-CR-IN-317-T (52)], 23L1416-36[19-03-CR-IN-318-T (54)], 23L1416-37[19-03-CR-IN-319-B (55)], 23L1416-38[19-03-CR-IN-319-T (56)], 23L1416-41[19-03-CR-IN-326-B (59)], 23L1416-45[19-03-CR-IN-328-B (63)], 23L1416-46[19-03-CR-IN-328-T (64)], 23L1416-49[19-03-NO-IN-329-BBACK (67)], 23L1416-50[19-03-NO-IN-329-BFRONT (68)], 23L1416-54[19-03-NO-IN-329-B1 (73)], 23L1416-56[19-03-CR-IN-321-B (75)], 23L1416-57[19-03-CR-IN-321-T (76)], 23L1416-66[19-01-CR-IN-108-T2 (84)]

The results of analyses reported only relate to samples submitted to the Pace Analytical Services, LLC - Newburgh for testing.

I certify that the analyses listed above, unless specifically listed as subcontracted, if any, were performed under my direction according to the approved methodologies listed in this document, and that based upon my inquiry of those individuals immediately responsible for obtaining the information, the material contained in this report is, to the best of my knowledge and belief, accurate and complete.



Renee Cusack
PM



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Sampled: 12/5/2023 07:38

Field Sample #: 19-01-CR-IN-106-B (1)

Sample ID: 23L1416-01

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time
		RL							Prepared	Analyzed
Lead	11	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	12/12/23	12/12/23 16:27 AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Sampled: 12/5/2023 07:35

Field Sample #: 19-01-CR-IN-107-T1 (2)

Sample ID: 23L1416-02

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	11	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	12/12/23	12/12/23 16:29	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Sampled: 12/5/2023 07:32

Field Sample #: 19-01-CR-IN-107-T2 (3)

Sample ID: 23L1416-03

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	6.4	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	12/12/23	12/12/23 16:37	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Sampled: 12/5/2023 07:28

Field Sample #: 19-01-CR-IN-108-T (5)

Sample ID: 23L1416-04

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	17	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	12/12/23	12/12/23 16:39	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-01-CR-IN-116-B (6)

Sampled: 12/5/2023 07:23

Sample ID: 23L1416-05

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	95	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	12/12/23	12/12/23 16:41	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-01-CR-IN-116-T (7)

Sampled: 12/5/2023 07:24

Sample ID: 23L1416-06

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	2.2	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	12/12/23	12/12/23 16:44	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-01-CR-IN-117-B (8)

Sampled: 12/5/2023 07:16

Sample ID: 23L1416-07

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	5.2	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	12/12/23	12/12/23 16:46	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-01-CR-IN-118-T (9)

Sampled: 12/5/2023 07:17

Sample ID: 23L1416-08

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	13	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	12/12/23	12/12/23 16:49	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Sampled: 12/5/2023 07:18

Field Sample #: 19-01-CR-IN-118-T2 (10)

Sample ID: 23L1416-09

Sample Matrix: Drinking Water

Metals Analyses (Total)											
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL							Prepared	Analyzed	
Lead	20	1.0	15		µg/L	1	Z-01	EPA 200.8 Rev 5.4	12/12/23	12/12/23 16:51	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-01-CR-IN-118-T (11)

Sampled: 12/5/2023 07:19

Sample ID: 23L1416-10

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL			Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
		RL		Units						
Lead	10	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	12/12/23	12/12/23 16:56	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-01-CR-IN-122A-T (12)

Sampled: 12/5/2023 07:19

Sample ID: 23L1416-11

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	7.2	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	12/12/23	12/12/23 16:58	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-02-CR-IN-216-T (19)

Sampled: 12/5/2023 06:47

Sample ID: 23L1416-12

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	6.9	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	12/12/23	12/12/23 17:06	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-02-CR-IN-217-T (21)

Sampled: 12/5/2023 06:48

Sample ID: 23L1416-13

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	17	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	12/12/23	12/12/23 17:08	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-02-CR-IN-218-T (23)

Sampled: 12/5/2023 06:51

Sample ID: 23L1416-14

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	15	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	12/12/23	12/12/23 17:11	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-02-CR-IN-219-B (24)

Sampled: 12/5/2023 06:49

Sample ID: 23L1416-15

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	20	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	12/12/23	12/12/23 17:13	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-02-CR-IN-219-T (25)

Sampled: 12/5/2023 06:19

Sample ID: 23L1416-16

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	5.9	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	12/12/23	12/12/23 17:15	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-02-CR-IN-225-B (26)

Sampled: 12/5/2023 07:04

Sample ID: 23L1416-17

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	7.7	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	12/12/23	12/12/23 17:18	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-02-CR-IN-225-T (27)

Sampled: 12/5/2023 07:05

Sample ID: 23L1416-18

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	2.7	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	12/12/23	12/12/23 17:20	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-02-CR-IN-226-B (28)

Sampled: 12/5/2023 07:05

Sample ID: 23L1416-19

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	10	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	12/12/23	12/12/23 17:23	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Sampled: 12/5/2023 07:06

Field Sample #: 19-02-CR-IN-226-T (29)

Sample ID: 23L1416-20

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	18	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	12/12/23	12/12/23 17:37	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-02-CR-IN-227-B (30)

Sampled: 12/5/2023 07:09

Sample ID: 23L1416-21

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	4.2	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	12/12/23	12/12/23 17:40	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-02-CR-IN-227-T (31)

Sampled: 12/5/2023 07:09

Sample ID: 23L1416-22

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	2.8	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	12/12/23	12/12/23 17:42	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-02-CR-IN-228-B (32)

Sampled: 12/5/2023 07:12

Sample ID: 23L1416-23

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	35	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	12/12/23	12/12/23 17:44	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Sampled: 12/5/2023 07:12

Field Sample #: 19-02-CR-IN-228-T (33)

Sample ID: 23L1416-24

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	22	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	12/12/23	12/12/23 17:47	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-02-KL-IN-200A-T (35)

Sampled: 12/5/2023 06:56

Sample ID: 23L1416-25

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	2.6	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	12/12/23	12/12/23 17:49	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-02-KL-IN-200A-TL (36)

Sampled: 12/5/2023 06:56

Sample ID: 23L1416-26

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	9.2	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	12/12/23	12/12/23 17:52	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-02-KL-IN-200A-TM (37)

Sampled: 12/5/2023 06:57

Sample ID: 23L1416-27

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	3.0	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	12/12/23	12/12/23 17:54	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-02-KL-IN-200B-T (38)

Sampled: 12/5/2023 06:57

Sample ID: 23L1416-28

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	2.8	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	12/12/23	12/12/23 17:57	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-02-TC-IN-211-T (39)

Sampled: 12/5/2023 06:53

Sample ID: 23L1416-29

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	13	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	12/13/23	12/13/23 18:02	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-03-CR-IN-305B-T (41)

Sampled: 12/5/2023 06:15

Sample ID: 23L1416-30

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	100	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	12/13/23	12/13/23 18:05	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Sampled: 12/5/2023 06:37

Field Sample #: 19-03-CR-IN-316-B (49)

Sample ID: 23L1416-31

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	33	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	12/13/23	12/13/23 18:07	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Sampled: 12/5/2023 09:38

Field Sample #: 19-03-CR-IN-316-T (50)

Sample ID: 23L1416-32

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	40	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	12/13/23	12/13/23 18:14	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-03-CR-IN-317-B (51)

Sampled: 12/5/2023 09:34

Sample ID: 23L1416-33

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	100	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	12/13/23	12/13/23 18:17	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-03-CR-IN-317-T (52)

Sampled: 12/5/2023 06:34

Sample ID: 23L1416-34

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	23	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	12/13/23	12/13/23 18:19	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-03-CR-IN-318-T (54)

Sampled: 12/5/2023 06:33

Sample ID: 23L1416-36

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	16	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	12/13/23	12/13/23 18:22	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-03-CR-IN-319-B (55)

Sampled: 12/5/2023 06:34

Sample ID: 23L1416-37

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	47	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	12/13/23	12/13/23 18:24	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Sampled: 12/5/2023 06:33

Field Sample #: 19-03-CR-IN-319-T (56)

Sample ID: 23L1416-38

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	23	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	12/13/23	12/13/23 18:26	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-03-CR-IN-325-B (57)

Sampled: 12/5/2023 06:26

Sample ID: 23L1416-39

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	8.1	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	12/13/23	12/13/23 18:29	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-03-CR-IN-325-T (58)

Sampled: 12/5/2023 06:27

Sample ID: 23L1416-40

Sample Matrix: Drinking Water

Metals Analyses (Total)											
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL							Prepared	Analyzed	
Lead	2.5	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	12/13/23	12/13/23 18:34	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-03-CR-IN-326-B (59)

Sampled: 12/5/2023 06:27

Sample ID: 23L1416-41

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	15	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	12/13/23	12/13/23 18:36	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-03-CR-IN-326-T (60)

Sampled: 12/5/2023 06:28

Sample ID: 23L1416-42

Sample Matrix: Drinking Water

Metals Analyses (Total)											
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL							Prepared	Analyzed	
Lead	3.6	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	12/13/23	12/13/23 18:43	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Sampled: 12/5/2023 06:24

Field Sample #: 19-03-CR-IN-327-B (61)

Sample ID: 23L1416-43

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL			Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL		Units				Prepared	Analyzed	
Lead	13	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	12/13/23	12/13/23 18:46	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-03-CR-IN-327-T (62)

Sampled: 12/5/2023 06:25

Sample ID: 23L1416-44

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	4.6	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	12/13/23	12/13/23 18:48	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Sampled: 12/5/2023 06:23

Field Sample #: 19-03-CR-IN-328-B (63)

Sample ID: 23L1416-45

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	37	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	12/13/23	12/13/23 18:51	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-03-CR-IN-328-T (64)

Sampled: 12/5/2023 06:23

Sample ID: 23L1416-46

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	34	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	12/13/23	12/13/23 18:53	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-03-HA-BY-302-F (65)

Sampled: 12/5/2023 06:10

Sample ID: 23L1416-47

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	2.5	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	12/13/23	12/13/23 18:56	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-03-HA-BY-322-F (66)

Sampled: 12/5/2023 06:18

Sample ID: 23L1416-48

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	12/13/23	12/13/23 18:58	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-03-NO-IN-329-BBACK (67)

Sampled: 12/5/2023 06:20

Sample ID: 23L1416-49

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	20	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	12/13/23	12/13/23 19:00	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Sampled: 12/5/2023 06:19

Field Sample #: 19-03-NO-IN-329-BFRONT (68)

Sample ID: 23L1416-50

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	20	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	12/13/23	12/13/23 19:15	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-03-HA-BY-302-FL (70)

Sampled: 12/5/2023 06:12

Sample ID: 23L1416-51

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	12/13/23	12/13/23 19:17	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-03-HA-BY-302-BF (71)

Sampled: 12/5/2023 06:14

Sample ID: 23L1416-52

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	12/13/23	12/13/23 19:20	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-03-HA-BY-327-BF (72)

Sampled: 12/5/2023 06:18

Sample ID: 23L1416-53

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	12/13/23	12/13/23 19:22	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-03-NO-IN-329-B1 (73)

Sampled: 12/5/2023 06:19

Sample ID: 23L1416-54

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	25	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	12/13/23	12/13/23 19:25	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-03-NO-IN-329-B2 (74)

Sampled: 12/5/2023 06:21

Sample ID: 23L1416-55

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	11	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	12/13/23	12/13/23 19:27	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-03-CR-IN-321-B (75)

Sampled: 12/5/2023 06:29

Sample ID: 23L1416-56

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	58	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	12/13/23	12/13/23 19:30	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Sampled: 12/5/2023 06:29

Field Sample #: 19-03-CR-IN-321-T (76)

Sample ID: 23L1416-57

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	40	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	12/13/23	12/13/23 19:32	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-02-HA-BY-200-F (77)

Sampled: 12/5/2023 06:45

Sample ID: 23L1416-58

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	12/13/23	12/13/23 19:34	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-02-HA-BY-300-BF (78)

Sampled: 12/5/2023 06:45

Sample ID: 23L1416-59

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	12/13/23	12/13/23 19:42	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-02-KI-200A-TM-S (79)

Sampled: 12/5/2023 06:57

Sample ID: 23L1416-60

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	2.6	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	12/13/23	12/13/23 19:47	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-02-CAFE-IN-205-F (80)

Sampled: 12/5/2023 06:58

Sample ID: 23L1416-61

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	12/13/23	12/13/23 19:49	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-02-CAFE-IN-205-BF (81)

Sampled: 12/5/2023 06:59

Sample ID: 23L1416-62

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	12/13/23	12/13/23 19:52	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Sampled: 12/5/2023 07:17

Field Sample #: 19-01-HA-BY-102-F (82)

Sample ID: 23L1416-63

Sample Matrix: Drinking Water

Metals Analyses (Total)										
Analyte	Results	MCL/SMCL		Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL						Prepared	Analyzed	
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	12/13/23	12/13/23 19:54	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-01-HA-BY-102-BF (83)

Sampled: 12/5/2023 07:17

Sample ID: 23L1416-64

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	ND	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	12/13/23	12/13/23 19:56	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Sampled: 12/5/2023 07:25

Field Sample #: 19-01-CR-IN-116-T2 (84)

Sample ID: 23L1416-65

Sample Matrix: Drinking Water

Metals Analyses (Total)											
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time	Analyst
		RL							Prepared	Analyzed	
Lead	2.9	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	12/13/23	12/13/23 19:59	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-01-CR-IN-108-T2 (84)

Sampled: 12/5/2023 07:30

Sample ID: 23L1416-66

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	20	1.0	15	µg/L	1	Z-01	EPA 200.8 Rev 5.4	12/13/23	12/13/23 20:01	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Sampled: 12/5/2023 07:34

Field Sample #: 19-01-CR-IN-107-B (86)

Sample ID: 23L1416-67

Sample Matrix: Drinking Water

Metals Analyses (Total)											
Analyte	Results	MCL/SMCL			Units	Dilution	Flag/Qual	Method	Date	Date/Time	
		RL							Prepared	Analyzed	Analyst
Lead	6.6	1.0	15		µg/L	1		EPA 200.8 Rev 5.4	12/13/23	12/13/23 20:04	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-01-CR-IN-106-T1 (87)

Sampled: 12/5/2023 07:38

Sample ID: 23L1416-68

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	3.5	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	12/13/23	12/13/23 20:11	AR3



315 Fullerton Avenue * Newburgh, NY 12550 * TEL. (845) 562-0890

Project Location: RCSD Dr. CTL School 19

Sample Description:

Work Order: 23L1416

Date Received: 12/11/2023

Field Sample #: 19-01-CR-IN-106-T2 (88)

Sampled: 12/5/2023 07:38

Sample ID: 23L1416-69

Sample Matrix: Drinking Water

Metals Analyses (Total)

Analyte	Results	RL	MCL/SMCL	Units	Dilution	Flag/Qual	Method	Date Prepared	Date/Time Analyzed	Analyst
Lead	8.0	1.0	15	µg/L	1		EPA 200.8 Rev 5.4	12/13/23	12/13/23 20:13	AR3

FLAG/QUALIFIER SUMMARY

*	QC result is outside of established limits.
†	Wide recovery limits established for difficult compound.
‡	Wide RPD limits established for difficult compound.
#	Data exceeded client recommended or regulatory level
ND	Not Detected
RL	Reporting Limit is at the level of quantitation (LOQ)
DL	Detection Limit is the lower limit of detection determined by the MDL study
MCL	Maximum Contaminant Level
	Percent recoveries and relative percent differences (RPDs) are determined by the software using values in the calculation which have not been rounded.
	No results have been blank subtracted unless specified in the case narrative section.
Z-01	#

CERTIFICATIONS

Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 200.8 Rev 5.4 in Drinking Water</i>	

Lead NB-CT,NB-NJ,NB-NY

Pace Analytical Services, LCC operates under the following certifications and accreditations:

Code	Description	Number	Expires
NB-CT	Connecticut Department of Public Health	PH-0823	09/30/2024
NB-NJ	New Jersey DEP	NY015 NELAP	06/30/2023
NB-NY	New York State Department of Health	10142 NELAP	04/1/2024



LAB ID: M33568	REPORT TO:	INVOICE TO:
PROJECT NAME: RCSD Dr. CTL School 19	Company: Lozier Environmental Consulting, Inc.	Company: SAME
TURNAROUND TIME: Standard Rush	Address: 2011 East Main Street	Address:
Other:	City/State Zip: Rochester, New York 14609	City/State Zip:
	Phone:	Phone:
	E-Mail: vkaptein@lozierenv.com	E-Mail:
	Fax:	Fax:
	Purchase Order #	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	LEAD	REQUESTED ANALYSIS			
1	19-01-CR-IN-106-B	12/5/2023	738		DW				X				
2	19-01-CR-IN-107-T1	12/5/2023	735		DW				X				
3	19-01-CR-IN-107-T2	12/5/2023	732		DW				X				
5	19-01-CR-IN-108-T	12/5/2023	728		DW				X				
6	19-01-CR-IN-116-B	12/5/2023	723		DW				X				
7	19-01-CR-IN-116-T	12/5/2023	724		DW				X				
8	19-01-CR-IN-117-B	12/5/2023	716		DW				X				
9	19-01-CR-IN-117-T	12/5/2023	717		DW				X				
10	19-01-CR-IN-118-T2	12/5/2023	718		DW				X				
11	19-01-CR-IN-118-T	12/5/2023	719		DW				X				



FE05668 7743 9351 6845
4 THROUGH PAGE 14

Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

SAMPLED BY*: J. Savoie	DATE: 12/7/23	TIME: 1000
RELINQUISHED BY*: V. Kaptein	DATE: 12/17/23	TIME: 1050
RECEIVED BY*: <i>[Signature]</i>	DATE: 12/17/23	TIME: 1050
RELINQUISHED BY*	DATE:	TIME:
RECEIVED BY*	DATE:	TIME:
RELINQUISHED BY*	DATE:	TIME:
RECEIVED BY*	DATE:	TIME:

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDES: HNO3	FOR POTABLE WATER ON COLIFORM BACTERIA:
TOTAL NUMBER OF CONTAINERS: 68	Present Absent
CUSTODY SEAL INTACT? YES NO	If Present, Date Client is contacted with result:
SAMPLE ON ICE? YES (NO)	Date: _____
TEMPERATURE: 13.3	Contacted By: _____
SAMPLE IN COMPLIANCE: YES NO	

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 2 of 7
2361416

Page 76 of 84

REPORT TO:		INVOICE TO:	
Company: Lozier Environmental Consulting, Inc.	Address: 2011 East Main Street	Company: SAME	Address:
City/State Zip: Rochester, New York 14609	City/State Zip:	Phone:	Phone:
Turnaround Time: Standard Rush	Phone:	Fax:	Fax:
Other:	E-Mail: vkaptein@lozierenv.com	Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	LEAD	REQUESTED ANALYSIS			
12	19-01-CR-IN-122A-T	12/5/2023	719		DW				X				
19	19-02-CR-IN-216-T	12/5/2023	647		DW				X				
21	19-02-CR-IN-217-T	12/5/2023	648		DW				X				
23	19-02-CR-IN-218-T	12/5/2023	651		DW				X				
24	19-02-CR-IN-219-B	12/5/2023	649		DW				X				
25	19-02-CR-IN-219-T	12/5/2023	619		DW				X				
26	19-02-CR-IN-225-B	12/5/2023	704		DW				X				
27	19-02-CR-IN-225-T	12/5/2023	705		DW				X				
28	19-02-CR-IN-226-B	12/5/2023	705		DW				X				
29	19-02-CR-IN-226-T	12/5/2023	706		DW				X				

Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

SAMPLED BY*: J. Savoie

RELINQUISHED BY*: Y. Kaptein DATE: 12/7/23 TIME: 1000

RECEIVED BY: *[Signature]* DATE: 12/17/23 TIME: 1050

RELINQUISHED BY*: DATE: TIME:

RECEIVED BY: DATE: TIME:

RELINQUISHED BY*: DATE: TIME:

RECEIVED BY: DATE: TIME:

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDES: HNO3	FOR POTABLE WATER ON
TOTAL NUMBER OF CONTAINERS: 68	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES NO	Present Absent
SAMPLE ON ICE? YES NO	If Present, Date Client is
TEMPERATURE: 13.3 C	contacted with result:
SAMPLE IN COMPLIANCE: YES NO	Date: _____
	Contacted By: _____



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 3 of 7

2321416

LAB ID: M33568		REPORT TO:		INVOICE TO:	
PROJECT NAME: RCSD Dr. CTL School 19		Company: Lozier Environmental Consulting, Inc.		Company: SAME	
TURNAROUND TIME: Standard Rush		Address: 2011 East Main Street		Address:	
Other:		City/State Zip: Rochester, New York 14609		City/State Zip:	
		Phone:		Phone:	
		Fax:		Fax:	
		E-Mail: vkaptein@lozierenv.com		Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS			
									LEAD			
30	19-02-CR-IN-227-B	12/5/2023	709		DW				X			
31	19-02-CR-IN-227-T	12/5/2023	709		DW				X			
32	19-02-CR-IN-228-B	12/5/2023	712		DW				X			
33	19-02-CR-IN-228-T	12/5/2023	712		DW				X			
35	19-02-KI-IN-200A-T	12/5/2023	656		DW				X			
36	19-02-KI-IN-200A-TL	12/5/2023	656		DW				X			
37	19-02-KI-IN-200A-TM	12/5/2023	657		DW				X			
38	19-02-KI-IN-200B-T	12/5/2023	657		DW				X			
39	19-02-TG-IN-211-T	12/5/2023	653		DW				X			
41	19-03-CR-IN-305B-T	12/5/2023	615		DW				X			

Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

SAMPLED BY*: J. Savoie

RELINQUISHED BY*: V. Kaptein

RECEIVED BY: *[Signature]*

RELINQUISHED BY: *[Signature]*

RECEIVED BY: _____

RECEIVED BY: _____

RECEIVED BY: _____

FOR LAB USE ONLY		FOR POTABLE WATER ON COLIFORM BACTERIA:	
PRESERVATIVE/BIOCIDES: HNO3		Present	Absent
TOTAL NUMBER OF CONTAINERS: 60			
CUSTODY SEAL INTACT? YES NO			
SAMPLE ON ICE? YES (NO)			
TEMPERATURE: 3-5 C			
SAMPLE IN COMPLIANCE: YES NO			
Date: _____			
Contacted By: _____			



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 4 of 7
9361416

LAB ID: M33568	REPORT TO:		INVOICE TO:	
PROJECT NAME: RCSD Dr. CTL School 19	Company: Lozier Environmental Consulting, Inc.	Company:	SAME	
TURNAROUND TIME: Standard Rush	Address: 2011 East Main Street	Address:		
Other:	City/State Zip: Rochester, New York 14609	City/State Zip:		
	Phone:	Fax:		
	E-Mail: vkaptein@lozierenv.com	Purchase Order #:		

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	LEAD	REQUESTED ANALYSIS		
49	19-03-CR-IN-316-B	12/5/2023	637		DW				X			
50	19-03-CR-IN-316-T	12/5/2023	638		DW				X			
51	19-03-CR-IN-317-B	12/5/2023	634		DW				X			
52	19-03-CR-IN-317-T	12/5/2023	634		DW				X			
53	19-03-CR-IN-318-B	12/5/2023	635		DW				X			
54	19-03-CR-IN-318-T	12/5/2023	633		DW				X			
55	19-03-CR-IN-319-B	12/5/2023	634		DW				X			
56	19-03-CR-IN-319-T	12/5/2023	633		DW				X			
57	19-03-CR-IN-325-B	12/5/2023	626		DW				X			
58	19-03-CR-IN-325-T	12/5/2023	627		DW				X			

* Denotes a sample that has NOT been received!

Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

SAMPLED BY*: J. Savoie	DATE: 12/7/23	TIME: 1000
RELINQUISHED BY*: Y. Kaptein	DATE: 12/14/23	TIME: 1050
RECEIVED BY:	DATE:	TIME:
RELINQUISHED BY:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:

FOR LAB USE ONLY		FOR POTABLE WATER ON COLIFORM BACTERIA:	
PRESERVATIVE/BIOCIDES: HNO3		Present	Absent
TOTAL NUMBER OF CONTAINERS: 68		If Present, Date Client is contacted with result:	
CUSTODY SEAL INTACT? YES NO		Date:	Contacted By:
SAMPLE ON ICE? YES NO			
TEMPERATURE: 13.3 C			
SAMPLE IN COMPLIANCE: YES NO			



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 5 of 7
2321416

Page 79 of 84

LAB ID: M33568	Address: 2011 East Main Street	Company: Lozier Environmental Consulting, Inc.	REPORT TO:	Company:	INVOICE TO:
PROJECT NAME: RCSD Dr. CTL School 19	City/State Zip: Rochester, New York 14609			Address:	SAME
TURNAROUND TIME: Standard Rush	Phone:	Fax:		City/State Zip:	
Other:	E-Mail: vkaptein@lozierenv.com			Phone:	Fax:
				Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	LEAD	REQUESTED ANALYSIS			
59	19-03-CR-IN-326-B	12/5/2023	627		DW				X				
60	19-03-CR-IN-326-T	12/5/2023	628		DW				X				
61	19-03-CR-IN-327-B	12/5/2023	624		DW				X				
62	19-03-CR-IN-327-T	12/5/2023	625		DW				X				
63	19-03-CR-IN-328-B	12/5/2023	623		DW				X				
64	19-03-CR-IN-328-T	12/5/2023	623		DW				X				
65	19-03-HA-BY-302-F	12/5/2023	610		DW				X				
66	19-03-HA-BY-322-F	12/5/2023	618		DW				X				
67	19-03-NO-IN-329-BBACK	12/5/2023	620		DW				X				
68	19-03-NO-IN-329-BFRONT	12/5/2023	619		DW				X				

PER EX GRD 7743 93515974

by THROUGH PAGE 7

Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

SAMPLED BY*: J. Savoie

RELINQUISHED BY*: Y. Kaptein DATE: 12/7/23 TIME: 1000

RECEIVED BY: *[Signature]* DATE: 12/14/23 TIME: 1050

RELINQUISHED BY*: DATE: TIME:

RECEIVED BY: DATE: TIME:

RELINQUISHED BY*: DATE: TIME:

RECEIVED BY: DATE: TIME:

FOR LAB USE ONLY				FOR POTABLE WATER ON COLIFORM BACTERIA:			
PRESERVATIVE/BIOCIDES: HNO3	TOTAL NUMBER OF CONTAINERS: 108	CUSTODY SEAL INTACT? YES NO	SAMPLE ON ICE? YES NO	TEMPERATURE: 3.3C	SAMPLE IN COMPLIANCE: YES NO	Date:	Contacted By:



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 10 of 7
2311411

Page 80 of 84

LAB ID: M33568	REPORT TO:		Company:	Lozier Environmental Consulting, Inc.	Address:	2011 East Main Street	City/State Zip:	Rochester, New York 14609	Phone:		Fax:		Invoice TO:	SAME
PROJECT NAME: RCSD Dr. CTL School 19			Company:		Address:		City/State Zip:		Phone:		Fax:		Invoice TO:	
TURNAROUND TIME: Standard Rush			Company:		Address:		City/State Zip:		Phone:		Fax:		Invoice TO:	
Other:			Company:		Address:		City/State Zip:		Phone:		Fax:		Invoice TO:	
E-Mail: vkaptein@lozierenv.com			Purchase Order #											

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	LEAD	REQUESTED ANALYSIS			
70	19-03-HA-BY-302-FL	12/5/2023	612	DW					X				
71	19-03-HA-BY-302-BF	12/5/2023	614	DW					X				
72	19-03-HA-BY-327-BF	12/5/2023	618	DW					X				
73	19-03-NO-IN-329-B1	12/5/2023	619	DW					X				
74	19-03-NO-IN-329-B2	12/5/2023	621	DW					X				
75	19-03-CR-IN-321-B	12/5/2023	629	DW					X				
76	19-03-CR-IN-321-T	12/5/2023	629	DW					X				
77	19-02-HA-BY-200-F	12/5/2023	645	DW					X				
78	19-02-HA-BY-200-BF	12/5/2023	645	DW					X				
79	19-02-KI-IN-200A-TM-S	12/5/2023	657	DW					X				

Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

SAMPLED BY*: J. Savoie	DATE: 12/7/23	TIME: 1000
RELINQUISHED BY*: V. Kaptein	DATE: 12/14/23	TIME: 1050
RECEIVED BY:	DATE:	TIME:
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:

FOR LAB USE ONLY		FOR POTABLE WATER ON COLIFORM BACTERIA:	
PRESERVATIVE/BIOCIDES: HNO3		Present	Absent
TOTAL NUMBER OF CONTAINERS: 108		Present	Absent
CUSTODY SEAL INTACT? YES NO		Present	Absent
SAMPLE ON ICE? YES NO		Present	Absent
TEMPERATURE: 3-3 C		Present	Absent
SAMPLE IN COMPLIANCE: YES NO		Present	Absent
Date:		Present	Absent
Contacted By:		Present	Absent



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 7 of 7

Page 81 of 84

LAB ID: M33568	Company: Lozier Environmental Consulting, Inc.	REPORT TO:	Company:	INVOICE TO: SAME
PROJECT NAME: RCSD Dr. CTL School 19	Address: 2011 East Main Street		Address:	
TURNAROUND TIME: Standard Rush	City, State Zip: Rochester, New York 14609		City, State Zip:	
Other:	Phone:	Fax:	Phone:	Fax:
	E-Mail: vkaptein@lozierenv.com		Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	LEAD	REQUESTED ANALYSIS			
80	19-02-CAFÉ-IN-205-F	12/5/2023	658		DW				X				
81	19-02-CAFÉ-IN-205-BF	12/5/2023	659		DW				X				
82	19-01-HA-BY-102-F	12/5/2023	717		DW				X				
83	19-01-HA-BY-102-BF	12/5/2023	717		DW				X				
84	19-01-CR-IN-116-T2	12/5/2023	725		DW				X				
85	19-01-CR-IN-108-T2	12/5/2023	730		DW				X				
86	19-01-CR-IN-107-B	12/5/2023	734		DW				X				
87	19-01-CR-IN-106-T1	12/5/2023	738		DW				X				
88	19-01-CR-IN-106-T2	12/5/2023	739		DW				X				

Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

SAMPLED BY*: J. Savoie

RELINQUISHED BY*: V. Kaptein DATE: 12/7/23 TIME: 1000

RECEIVED BY: DATE: 12/14/23 TIME: 1050

RELINQUISHED BY*: DATE: TIME:

RECEIVED BY: DATE: TIME:

RELINQUISHED BY*: DATE: TIME:

RECEIVED BY: DATE: TIME:

FOR LAB USE ONLY

PRESERVATIVE/BIOCIDE: HNO3

TOTAL NUMBER OF CONTAINERS: 100

CUSTODY SEAL INTACT? YES NO

SAMPLE ON ICE? YES (NO) 3.3 C

TEMPERATURE: 3.3 C

SAMPLE IN COMPLIANCE: YES NO

FOR POTABLE WATER ON COLIFORM BACTERIA: Present Absent

If Present, Date Client is contacted with result: Date: Contacted By:

Sample Condition Upon Receipt Form (SCUR)

Project # 23L1416
Client: LOZPER

Date and Initials of person:
Examining contents: _____
Label: _____
Deliver to location: _____
pH: _____

Thermometer Used: IRG4

Date: 12/11

Time: 1050

Initials: _____

State of Origin: NY

Cooler #1 Temp. °C 13.3 (Visual) 0.2 @ 0.0°C, -0.5 @ 20.0°C (Correction Factor) _____ (Actual) ☒ Samples on ice, cooling process has begun

Courier: ☒ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☐ Pace ☐ Other _____

Shipping Method: ☐ First Overnight ☐ Priority Overnight ☐ Standard Overnight ☐ Ground
☐ Other _____

Tracking # 7743 9351 6845, 7743 9351 5974

Custody Seal on Cooler/Box Present: ☐ Yes ☐ No

Seals intact: ☐ Yes ☐ No

Ice: ☒ Wet ☐ Blue ☐ Melted ☐ None

Packing Material: ☐ Bubble Wrap ☐ Bubble Bags ☐ None ☐ Other _____

Samples were collected by Pace employee ☐ Yes ☐ No ☐ N/A

Comments:

Chain of Custody Present	☒ Yes ☐ No ☐ N/A	
Chain of Custody Filled Out	☒ Yes ☐ No ☐ N/A	
Relinquished Signature on COC	☒ Yes ☐ No ☐ N/A	
Sampler Name and Signature on COC	☒ Yes ☐ No ☐ N/A	
Samples Arrived within Hold Time	☒ Yes ☐ No ☐ N/A	
Rush TAT requested on COC	☐ Yes ☐ No ☐ N/A	
Sufficient Volume	☒ Yes ☐ No ☐ N/A	
Correct Containers Used	☒ Yes ☐ No ☐ N/A	
Containers Intact	☒ Yes ☐ No ☐ N/A	
Sample Labels match COC (sample IDs & date/time of collection)	☒ Yes ☐ No ☐ N/A	
All containers needing acid/base preservation have been checked.	☐ Yes ☐ No ☐ N/A	Preservation Information: Preservative: _____ Lot #/Trace #: _____ Date: _____ Time: _____ Initials: _____
All Containers needing preservation are found to be in compliance with EPA recommendation:	☐ Yes ☐ No ☐ N/A	
Exceptions: Vials, Microbiology, O&G, Metals		
Headspace in VOA Vials? (>6mm):	☐ Yes ☐ No ☐ N/A	
Trip Blank Present:	☐ Yes ☐ No ☐ N/A	

Additional Login Comments:

Client notification/ Resolution

Person Contacted:

Date/Time:

Comments/Resolution:

Sample Condition Upon Receipt Form (SCUR)

Project # 23L1424
Client: Env. Labworks

Date and Initials of person:

Examining contents: _____

Label: _____

Deliver to location: _____

pH: _____

Thermometer Used: IRG4

Date: 12/11

Time: 1150

Initials: _____

State of Origin: NY

Cooler #1 Temp. °C 0.1 (Visual) 0.2 @ 0.0°C, -0.5 @ 20.0°C (Correction Factor) _____ (Actual) ☒ Samples on ice, cooling process has begun

Courier: ☐ Fed Ex ☐ UPS ☐ USPS ☒ Client ☐ Commercial ☐ Pace ☐ Other _____

Shipping Method: ☐ First Overnight ☐ Priority Overnight ☐ Standard Overnight ☐ Ground

☐ Other _____

Tracking # _____

Custody Seal on Cooler/Box Present: ☐ Yes ☐ No

Seals intact: ☐ Yes ☐ No

Ice: ☒ Wet ☐ Blue ☐ Melted ☐ None

Packing Material: ☐ Bubble Wrap ☐ Bubble Bags ☐ None ☐ Other _____

Samples were collected by Pace employee ☐ Yes ☐ No ☐ N/A

Comments:

Chain of Custody Present	☒ Yes ☐ No ☐ N/A	
Chain of Custody Filled Out	☒ Yes ☐ No ☐ N/A	
Relinquished Signature on COC	☒ Yes ☐ No ☐ N/A	
Sampler Name and Signature on COC	☒ Yes ☐ No ☐ N/A	
Samples Arrived within Hold Time	☒ Yes ☐ No ☐ N/A	
Rush TAT requested on COC	☐ Yes ☐ No ☐ N/A	
Sufficient Volume	☒ Yes ☐ No ☐ N/A	
Correct Containers Used	☒ Yes ☐ No ☐ N/A	
Containers Intact	☒ Yes ☐ No ☐ N/A	
Sample Labels match COC (sample IDs & date/time of collection)	☒ Yes ☐ No ☐ N/A	
All containers needing acid/base preservation have been checked.	☐ Yes ☐ No ☐ N/A	Preservation Information:
All Containers needing preservation are found to be in compliance with EPA recommendation:	☐ Yes ☐ No ☐ N/A	Preservative: _____
Exceptions: Vials, Microbiology, O&G, Metals		Lot #/Trace #: _____
		Date: _____ Time: _____
		Initials: _____
Headspace in VOA Vials? (>6mm):	☐ Yes ☐ No ☐ N/A	
Trip Blank Present:	☐ Yes ☐ No ☐ N/A	

Additional Login Comments:

Client notification/ Resolution

Person Contacted: _____

Date/Time: _____

Comments/Resolution: _____