



March 28, 2025

Amy Kaptein
Lozier Environmental Consulting, Inc
2011 E. Main St.
Rochester, NY 14609

RE: Project: RCSD-School No.15
Pace Project No.: 70343405

Dear Amy Kaptein:

Enclosed are the analytical results for sample(s) received by the laboratory on March 17, 2025. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Newburgh

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in cursive script that reads "Renee Cusack".

Renee Cusack
renee.cusack@pacelabs.com
(845)562-0890
Project Manager

Enclosures

cc: Amy Pusateri, Lozier Environmental Consulting Inc.



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



CERTIFICATIONS

Project: RCSD-School No.15

Pace Project No.: 70343405

Pace Analytical Services, LLC- Newburgh, NY

315 Fullerton Avenue, Newburgh, NY 12550

New York Certification #: 10142 Primary Accrediting Body

New Jersey Certification #: NY015

Connecticut Certification #: PH-0823

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE SUMMARY

Project: RCSD-School No.15
Pace Project No.: 70343405

Lab ID	Sample ID	Matrix	Date Collected	Date Received
70343405001	15-01-RM-IN-154-TL	Drinking Water	03/12/25 06:09	03/17/25 13:00
70343405002	15-01-RM-IN-154-TR	Drinking Water	03/12/25 06:09	03/17/25 13:00
70343405003	15-01-RM-IN-157-T1	Drinking Water	03/12/25 06:10	03/17/25 13:00
70343405004	15-01-RM-IN-157-T2	Drinking Water	03/12/25 06:11	03/17/25 13:00
70343405005	15-01-RM-IN-157A-T	Drinking Water	03/12/25 06:12	03/17/25 13:00
70343405006	15-01-RM-IN-157B-T1	Drinking Water	03/12/25 06:13	03/17/25 13:00
70343405007	15-01-RM-IN-157B-T2	Drinking Water	03/12/25 06:13	03/17/25 13:00
70343405008	15-01-CR-IN-127-B	Drinking Water	03/12/25 06:16	03/17/25 13:00
70343405009	15-01-CR-IN-127-T	Drinking Water	03/12/25 06:16	03/17/25 13:00
70343405010	15-01-CR-IN-126-B	Drinking Water	03/12/25 06:18	03/17/25 13:00
70343405011	15-01-CR-IN-126-T	Drinking Water	03/12/25 06:18	03/17/25 13:00
70343405012	15-01-HA-BY-125-FL	Drinking Water	03/12/25 06:19	03/17/25 13:00
70343405013	15-01-HA-BY-125-FR	Drinking Water	03/12/25 06:19	03/17/25 13:00
70343405014	15-01-HA-BY-125-BF	Drinking Water	03/12/25 06:19	03/17/25 13:00
70343405015	15-01-HA-BY-132-FL	Drinking Water	03/12/25 06:21	03/17/25 13:00
70343405016	15-01-HA-BY-132-FR	Drinking Water	03/12/25 06:21	03/17/25 13:00
70343405017	15-01-HA-BY-132-BF	Drinking Water	03/12/25 06:21	03/17/25 13:00
70343405018	15-01-HA-BY-165-FL	Drinking Water	03/12/25 06:23	03/17/25 13:00
70343405019	15-01-HA-BY-165-FR	Drinking Water	03/12/25 06:23	03/17/25 13:00
70343405020	15-01-HA-BY-165-BF	Drinking Water	03/12/25 06:23	03/17/25 13:00
70343405021	15-01-NO-IN-164-T	Drinking Water	03/12/25 06:26	03/17/25 13:00
70343405022	15-01-CR-IN-137-B	Drinking Water	03/12/25 06:28	03/17/25 13:00
70343405023	15-01-CR-IN-137-T	Drinking Water	03/12/25 06:28	03/17/25 13:00
70343405024	15-01-CR-IN-139-B	Drinking Water	03/12/25 06:29	03/17/25 13:00
70343405025	15-01-CR-IN-139-T	Drinking Water	03/12/25 06:33	03/17/25 13:00
70343405026	15-01-CR-IN-142-B	Drinking Water	03/12/25 06:35	03/17/25 13:00
70343405027	15-01-CR-IN-142-T	Drinking Water	03/12/25 06:35	03/17/25 13:00
70343405028	15-01-CR-IN-146-B	Drinking Water	03/12/25 06:37	03/17/25 13:00
70343405029	15-01-CR-IN-146-T	Drinking Water	03/12/25 06:37	03/17/25 13:00
70343405030	15-01-CR-IN-149-B	Drinking Water	03/12/25 06:39	03/17/25 13:00
70343405031	15-01-CR-IN-149-T	Drinking Water	03/12/25 06:39	03/17/25 13:00
70343405032	15-01-CR-IN-151-B	Drinking Water	03/12/25 06:41	03/17/25 13:00
70343405033	15-01-CR-IN-151-T	Drinking Water	03/12/25 06:41	03/17/25 13:00
70343405034	15-01-CR-IN-150-B	Drinking Water	03/12/25 06:42	03/17/25 13:00
70343405035	15-01-CR-IN-150-T	Drinking Water	03/12/25 06:42	03/17/25 13:00
70343405036	15-01-CR-IN-138-B	Drinking Water	03/12/25 06:45	03/17/25 13:00
70343405037	15-01-CR-IN-138-T	Drinking Water	03/12/25 06:45	03/17/25 13:00

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE SUMMARY

Project: RCSD-School No.15

Pace Project No.: 70343405

Lab ID	Sample ID	Matrix	Date Collected	Date Received
70343405038	15-01-RM-IN-167A-T	Drinking Water	03/12/25 06:48	03/17/25 13:00
70343405039	15-01-CR-IN-109-B	Drinking Water	03/12/25 06:53	03/17/25 13:00
70343405040	15-01-CR-IN-109-T	Drinking Water	03/12/25 06:53	03/17/25 13:00
70343405041	15-01-CR-IN-111-B	Drinking Water	03/12/25 06:55	03/17/25 13:00
70343405042	15-01-CR-IN-111-T	Drinking Water	03/12/25 06:55	03/17/25 13:00
70343405043	15-01-CR-IN-112-B	Drinking Water	03/12/25 06:56	03/17/25 13:00
70343405044	15-01-CR-IN-112-T	Drinking Water	03/12/25 06:56	03/17/25 13:00
70343405045	15-01-CR-IN-110-B	Drinking Water	03/12/25 06:58	03/17/25 13:00
70343405046	15-01-CR-IN-110-T	Drinking Water	03/12/25 06:58	03/17/25 13:00
70343405047	15-01-RM-IN-104-T	Drinking Water	03/12/25 07:06	03/17/25 13:00
70343405048	15-01-CR-IN-114-B	Drinking Water	03/12/25 07:11	03/17/25 13:00
70343405049	15-01-CR-IN-114-T	Drinking Water	03/12/25 07:11	03/17/25 13:00
70343405050	15-01-CR-IN-117-B	Drinking Water	03/12/25 07:13	03/17/25 13:00
70343405051	15-01-CR-IN-117-T	Drinking Water	03/12/25 07:13	03/17/25 13:00
70343405052	15-01-CR-IN-120-B	Drinking Water	03/12/25 07:14	03/17/25 13:00
70343405053	15-01-CR-IN-120-T	Drinking Water	03/12/25 07:14	03/17/25 13:00
70343405054	15-01-CR-IN-119-B	Drinking Water	03/12/25 07:16	03/17/25 13:00
70343405055	15-01-CR-IN-119-T	Drinking Water	03/12/25 07:16	03/17/25 13:00
70343405056	15-01-CR-IN-118-B	Drinking Water	03/12/25 07:17	03/17/25 13:00
70343405057	15-01-CR-IN-118-T	Drinking Water	03/12/25 07:17	03/17/25 13:00
70343405058	15-01-HA-BY-116-FL	Drinking Water	03/12/25 07:18	03/17/25 13:00
70343405059	15-01-HA-BY-116-FR	Drinking Water	03/12/25 07:18	03/17/25 13:00
70343405060	15-01-HA-BY-116-BF	Drinking Water	03/12/25 07:19	03/17/25 13:00
70343405061	15-01-CR-IN-121-T	Drinking Water	03/12/25 07:20	03/17/25 13:00
70343405062	15-01-CR-IN-123-B	Drinking Water	03/12/25 07:22	03/17/25 13:00
70343405063	15-01-CR-IN-123-T	Drinking Water	03/12/25 07:22	03/17/25 13:00
70343405064	15-01-CR-IN-124-TL	Drinking Water	03/12/25 07:24	03/17/25 13:00
70343405065	15-01-CR-IN-124-TR	Drinking Water	03/12/25 07:24	03/17/25 13:00

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE ANALYTE COUNT

Project: RCSD-School No.15

Pace Project No.: 70343405

Lab ID	Sample ID	Method	Analysts	Analytes Reported
70343405001	15-01-RM-IN-154-TL	EPA 200.8, Rev. 5.4	JC1	1
70343405002	15-01-RM-IN-154-TR	EPA 200.8, Rev. 5.4	JC1	1
70343405003	15-01-RM-IN-157-T1	EPA 200.8, Rev. 5.4	JC1	1
70343405004	15-01-RM-IN-157-T2	EPA 200.8, Rev. 5.4	JC1	1
70343405005	15-01-RM-IN-157A-T	EPA 200.8, Rev. 5.4	JC1	1
70343405006	15-01-RM-IN-157B-T1	EPA 200.8, Rev. 5.4	JC1	1
70343405007	15-01-RM-IN-157B-T2	EPA 200.8, Rev. 5.4	JC1	1
70343405008	15-01-CR-IN-127-B	EPA 200.8, Rev. 5.4	JC1	1
70343405009	15-01-CR-IN-127-T	EPA 200.8, Rev. 5.4	JC1	1
70343405010	15-01-CR-IN-126-B	EPA 200.8, Rev. 5.4	JC1	1
70343405011	15-01-CR-IN-126-T	EPA 200.8, Rev. 5.4	JC1	1
70343405012	15-01-HA-BY-125-FL	EPA 200.8, Rev. 5.4	JC1	1
70343405013	15-01-HA-BY-125-FR	EPA 200.8, Rev. 5.4	JC1	1
70343405014	15-01-HA-BY-125-BF	EPA 200.8, Rev. 5.4	JC1	1
70343405015	15-01-HA-BY-132-FL	EPA 200.8, Rev. 5.4	JC1	1
70343405016	15-01-HA-BY-132-FR	EPA 200.8, Rev. 5.4	JC1	1
70343405017	15-01-HA-BY-132-BF	EPA 200.8, Rev. 5.4	JC1	1
70343405018	15-01-HA-BY-165-FL	EPA 200.8, Rev. 5.4	JC1	1
70343405019	15-01-HA-BY-165-FR	EPA 200.8, Rev. 5.4	JC1	1
70343405020	15-01-HA-BY-165-BF	EPA 200.8, Rev. 5.4	JC1	1
70343405021	15-01-NO-IN-164-T	EPA 200.8, Rev. 5.4	JC1	1
70343405022	15-01-CR-IN-137-B	EPA 200.8, Rev. 5.4	JC1	1
70343405023	15-01-CR-IN-137-T	EPA 200.8, Rev. 5.4	JC1	1
70343405024	15-01-CR-IN-139-B	EPA 200.8, Rev. 5.4	JC1	1
70343405025	15-01-CR-IN-139-T	EPA 200.8, Rev. 5.4	JC1	1
70343405026	15-01-CR-IN-142-B	EPA 200.8, Rev. 5.4	JC1	1
70343405027	15-01-CR-IN-142-T	EPA 200.8, Rev. 5.4	JC1	1
70343405028	15-01-CR-IN-146-B	EPA 200.8, Rev. 5.4	JC1	1
70343405029	15-01-CR-IN-146-T	EPA 200.8, Rev. 5.4	JC1	1
70343405030	15-01-CR-IN-149-B	EPA 200.8, Rev. 5.4	JC1	1
70343405031	15-01-CR-IN-149-T	EPA 200.8, Rev. 5.4	JC1	1
70343405032	15-01-CR-IN-151-B	EPA 200.8, Rev. 5.4	JC1	1
70343405033	15-01-CR-IN-151-T	EPA 200.8, Rev. 5.4	JC1	1
70343405034	15-01-CR-IN-150-B	EPA 200.8, Rev. 5.4	JC1	1
70343405035	15-01-CR-IN-150-T	EPA 200.8, Rev. 5.4	JC1	1
70343405036	15-01-CR-IN-138-B	EPA 200.8, Rev. 5.4	JC1	1
70343405037	15-01-CR-IN-138-T	EPA 200.8, Rev. 5.4	JC1	1

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE ANALYTE COUNT

Project: RCSD-School No.15

Pace Project No.: 70343405

Lab ID	Sample ID	Method	Analysts	Analytes Reported
70343405038	15-01-RM-IN-167A-T	EPA 200.8, Rev. 5.4	JC1	1
70343405039	15-01-CR-IN-109-B	EPA 200.8, Rev. 5.4	JC1	1
70343405040	15-01-CR-IN-109-T	EPA 200.8, Rev. 5.4	JC1	1
70343405041	15-01-CR-IN-111-B	EPA 200.8, Rev. 5.4	JC1	1
70343405042	15-01-CR-IN-111-T	EPA 200.8, Rev. 5.4	JC1	1
70343405043	15-01-CR-IN-112-B	EPA 200.8, Rev. 5.4	JC1	1
70343405044	15-01-CR-IN-112-T	EPA 200.8, Rev. 5.4	JC1	1
70343405045	15-01-CR-IN-110-B	EPA 200.8, Rev. 5.4	JC1	1
70343405046	15-01-CR-IN-110-T	EPA 200.8, Rev. 5.4	JC1	1
70343405047	15-01-RM-IN-104-T	EPA 200.8, Rev. 5.4	JC1	1
70343405048	15-01-CR-IN-114-B	EPA 200.8, Rev. 5.4	JC1	1
70343405049	15-01-CR-IN-114-T	EPA 200.8, Rev. 5.4	JC1	1
70343405050	15-01-CR-IN-117-B	EPA 200.8, Rev. 5.4	JC1	1
70343405051	15-01-CR-IN-117-T	EPA 200.8, Rev. 5.4	JC1	1
70343405052	15-01-CR-IN-120-B	EPA 200.8, Rev. 5.4	JC1	1
70343405053	15-01-CR-IN-120-T	EPA 200.8, Rev. 5.4	JC1	1
70343405054	15-01-CR-IN-119-B	EPA 200.8, Rev. 5.4	JC1	1
70343405055	15-01-CR-IN-119-T	EPA 200.8, Rev. 5.4	JC1	1
70343405056	15-01-CR-IN-118-B	EPA 200.8, Rev. 5.4	JC1	1
70343405057	15-01-CR-IN-118-T	EPA 200.8, Rev. 5.4	JC1	1
70343405058	15-01-HA-BY-116-FL	EPA 200.8, Rev. 5.4	JC1	1
70343405059	15-01-HA-BY-116-FR	EPA 200.8, Rev. 5.4	JC1	1
70343405060	15-01-HA-BY-116-BF	EPA 200.8, Rev. 5.4	JC1	1
70343405061	15-01-CR-IN-121-T	EPA 200.8, Rev. 5.4	JC1	1
70343405062	15-01-CR-IN-123-B	EPA 200.8, Rev. 5.4	JC1	1
70343405063	15-01-CR-IN-123-T	EPA 200.8, Rev. 5.4	JC1	1
70343405064	15-01-CR-IN-124-TL	EPA 200.8, Rev. 5.4	JC1	1
70343405065	15-01-CR-IN-124-TR	EPA 200.8, Rev. 5.4	JC1	1

PASI-NB = Pace Analytical Services - Newburgh

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



PROJECT NARRATIVE

Project: RCSD-School No.15

Pace Project No.: 70343405

Method: EPA 200.8, Rev. 5.4

Description: NB 200.8 ICPMS DW No Prep

Client: Lozier Environmental Consulting, Inc.

Date: March 28, 2025

General Information:

65 samples were analyzed for EPA 200.8, Rev. 5.4 by Pace Analytical Services Newburgh. All samples were received in acceptable condition with any exceptions noted below or on the chain-of custody and/or the sample condition upon receipt form (SCUR) attached at the end of this report.

Hold Time:

The samples were analyzed within the method required hold times with any exceptions noted below.

Initial Calibrations (including MS Tune as applicable):

All criteria were within method requirements with any exceptions noted below.

Continuing Calibration:

All criteria were within method requirements with any exceptions noted below.

Internal Standards:

All internal standards were within QC limits with any exceptions noted below.

Surrogates:

All surrogates were within QC limits with any exceptions noted below.

Method Blank:

All analytes were below the report limit in the method blank, where applicable, with any exceptions noted below.

Laboratory Control Spike:

All laboratory control spike compounds were within QC limits with any exceptions noted below.

Matrix Spikes:

All percent recoveries and relative percent differences (RPDs) were within acceptance criteria with any exceptions noted below.

Duplicate Sample:

All duplicate sample results were within method acceptance criteria with any exceptions noted below.

Additional Comments:

This data package has been reviewed for quality and completeness and is approved for release.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD-School No.15

Pace Project No.: 70343405

Sample: 15-01-RM-IN-154-TL		Lab ID: 70343405001		Collected: 03/12/25 06:09		Received: 03/17/25 13:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 16:58	7439-92-1	
Sample: 15-01-RM-IN-154-TR		Lab ID: 70343405002		Collected: 03/12/25 06:09		Received: 03/17/25 13:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 17:00	7439-92-1	
Sample: 15-01-RM-IN-157-T1		Lab ID: 70343405003		Collected: 03/12/25 06:10		Received: 03/17/25 13:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 17:02	7439-92-1	
Sample: 15-01-RM-IN-157-T2		Lab ID: 70343405004		Collected: 03/12/25 06:11		Received: 03/17/25 13:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 17:04	7439-92-1	
Sample: 15-01-RM-IN-157A-T		Lab ID: 70343405005		Collected: 03/12/25 06:12		Received: 03/17/25 13:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 17:05	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD-School No.15

Pace Project No.: 70343405

Sample: 15-01-RM-IN-157B-T1 Lab ID: 70343405006 Collected: 03/12/25 06:13 Received: 03/17/25 13:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 17:07	7439-92-1	

Sample: 15-01-RM-IN-157B-T2 Lab ID: 70343405007 Collected: 03/12/25 06:13 Received: 03/17/25 13:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 17:09	7439-92-1	

Sample: 15-01-CR-IN-127-B Lab ID: 70343405008 Collected: 03/12/25 06:16 Received: 03/17/25 13:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 17:11	7439-92-1	

Sample: 15-01-CR-IN-127-T Lab ID: 70343405009 Collected: 03/12/25 06:16 Received: 03/17/25 13:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 17:13	7439-92-1	

Sample: 15-01-CR-IN-126-B Lab ID: 70343405010 Collected: 03/12/25 06:18 Received: 03/17/25 13:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 17:23	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD-School No.15

Pace Project No.: 70343405

Sample: 15-01-CR-IN-126-T Lab ID: 70343405011 Collected: 03/12/25 06:18 Received: 03/17/25 13:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 17:31	7439-92-1	

Sample: 15-01-HA-BY-125-FL Lab ID: 70343405012 Collected: 03/12/25 06:19 Received: 03/17/25 13:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 17:33	7439-92-1	

Sample: 15-01-HA-BY-125-FR Lab ID: 70343405013 Collected: 03/12/25 06:19 Received: 03/17/25 13:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 17:35	7439-92-1	

Sample: 15-01-HA-BY-125-BF Lab ID: 70343405014 Collected: 03/12/25 06:19 Received: 03/17/25 13:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 17:37	7439-92-1	

Sample: 15-01-HA-BY-132-FL Lab ID: 70343405015 Collected: 03/12/25 06:21 Received: 03/17/25 13:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 17:43	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD-School No.15

Pace Project No.: 70343405

Sample: 15-01-HA-BY-132-FR		Lab ID: 70343405016		Collected: 03/12/25 06:21		Received: 03/17/25 13:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 17:45	7439-92-1	
Sample: 15-01-HA-BY-132-BF		Lab ID: 70343405017		Collected: 03/12/25 06:21		Received: 03/17/25 13:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 17:47	7439-92-1	
Sample: 15-01-HA-BY-165-FL		Lab ID: 70343405018		Collected: 03/12/25 06:23		Received: 03/17/25 13:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 17:49	7439-92-1	
Sample: 15-01-HA-BY-165-FR		Lab ID: 70343405019		Collected: 03/12/25 06:23		Received: 03/17/25 13:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 17:51	7439-92-1	
Sample: 15-01-HA-BY-165-BF		Lab ID: 70343405020		Collected: 03/12/25 06:23		Received: 03/17/25 13:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 17:52	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD-School No.15

Pace Project No.: 70343405

Sample: 15-01-NO-IN-164-T **Lab ID:** 70343405021 **Collected:** 03/12/25 06:26 **Received:** 03/17/25 13:00 **Matrix:** Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 17:56	7439-92-1	

Sample: 15-01-CR-IN-137-B **Lab ID:** 70343405022 **Collected:** 03/12/25 06:28 **Received:** 03/17/25 13:00 **Matrix:** Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 17:58	7439-92-1	

Sample: 15-01-CR-IN-137-T **Lab ID:** 70343405023 **Collected:** 03/12/25 06:28 **Received:** 03/17/25 13:00 **Matrix:** Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 18:00	7439-92-1	

Sample: 15-01-CR-IN-139-B **Lab ID:** 70343405024 **Collected:** 03/12/25 06:29 **Received:** 03/17/25 13:00 **Matrix:** Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 18:06	7439-92-1	

Sample: 15-01-CR-IN-139-T **Lab ID:** 70343405025 **Collected:** 03/12/25 06:33 **Received:** 03/17/25 13:00 **Matrix:** Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 18:08	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD-School No.15

Pace Project No.: 70343405

Sample: 15-01-CR-IN-142-B		Lab ID: 70343405026		Collected: 03/12/25 06:35		Received: 03/17/25 13:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 18:10	7439-92-1	
Sample: 15-01-CR-IN-142-T		Lab ID: 70343405027		Collected: 03/12/25 06:35		Received: 03/17/25 13:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 18:12	7439-92-1	
Sample: 15-01-CR-IN-146-B		Lab ID: 70343405028		Collected: 03/12/25 06:37		Received: 03/17/25 13:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 18:14	7439-92-1	
Sample: 15-01-CR-IN-146-T		Lab ID: 70343405029		Collected: 03/12/25 06:37		Received: 03/17/25 13:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 18:16	7439-92-1	
Sample: 15-01-CR-IN-149-B		Lab ID: 70343405030		Collected: 03/12/25 06:39		Received: 03/17/25 13:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 18:22	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD-School No.15

Pace Project No.: 70343405

Sample: 15-01-CR-IN-149-T Lab ID: 70343405031 Collected: 03/12/25 06:39 Received: 03/17/25 13:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 18:34	7439-92-1	

Sample: 15-01-CR-IN-151-B Lab ID: 70343405032 Collected: 03/12/25 06:41 Received: 03/17/25 13:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 18:36	7439-92-1	

Sample: 15-01-CR-IN-151-T Lab ID: 70343405033 Collected: 03/12/25 06:41 Received: 03/17/25 13:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 18:38	7439-92-1	

Sample: 15-01-CR-IN-150-B Lab ID: 70343405034 Collected: 03/12/25 06:42 Received: 03/17/25 13:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 18:40	7439-92-1	

Sample: 15-01-CR-IN-150-T Lab ID: 70343405035 Collected: 03/12/25 06:42 Received: 03/17/25 13:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 18:41	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD-School No.15

Pace Project No.: 70343405

Sample: 15-01-CR-IN-138-B		Lab ID: 70343405036		Collected: 03/12/25 06:45		Received: 03/17/25 13:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 18:43	7439-92-1	
Sample: 15-01-CR-IN-138-T		Lab ID: 70343405037		Collected: 03/12/25 06:45		Received: 03/17/25 13:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 18:45	7439-92-1	
Sample: 15-01-RM-IN-167A-T		Lab ID: 70343405038		Collected: 03/12/25 06:48		Received: 03/17/25 13:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	2.1	ug/L	1.0	15	1		03/26/25 18:47	7439-92-1	
Sample: 15-01-CR-IN-109-B		Lab ID: 70343405039		Collected: 03/12/25 06:53		Received: 03/17/25 13:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 18:53	7439-92-1	
Sample: 15-01-CR-IN-109-T		Lab ID: 70343405040		Collected: 03/12/25 06:53		Received: 03/17/25 13:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 18:55	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD-School No.15

Pace Project No.: 70343405

Sample: 15-01-CR-IN-111-B		Lab ID: 70343405041		Collected: 03/12/25 06:55		Received: 03/17/25 13:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 18:59	7439-92-1	
Sample: 15-01-CR-IN-111-T		Lab ID: 70343405042		Collected: 03/12/25 06:55		Received: 03/17/25 13:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 19:01	7439-92-1	
Sample: 15-01-CR-IN-112-B		Lab ID: 70343405043		Collected: 03/12/25 06:56		Received: 03/17/25 13:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 19:03	7439-92-1	
Sample: 15-01-CR-IN-112-T		Lab ID: 70343405044		Collected: 03/12/25 06:56		Received: 03/17/25 13:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 19:05	7439-92-1	
Sample: 15-01-CR-IN-110-B		Lab ID: 70343405045		Collected: 03/12/25 06:58		Received: 03/17/25 13:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 19:07	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD-School No.15

Pace Project No.: 70343405

Sample: 15-01-CR-IN-110-T		Lab ID: 70343405046		Collected: 03/12/25 06:58		Received: 03/17/25 13:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 19:09	7439-92-1	
Sample: 15-01-RM-IN-104-T		Lab ID: 70343405047		Collected: 03/12/25 07:06		Received: 03/17/25 13:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 19:11	7439-92-1	
Sample: 15-01-CR-IN-114-B		Lab ID: 70343405048		Collected: 03/12/25 07:11		Received: 03/17/25 13:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 19:17	7439-92-1	
Sample: 15-01-CR-IN-114-T		Lab ID: 70343405049		Collected: 03/12/25 07:11		Received: 03/17/25 13:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 19:19	7439-92-1	
Sample: 15-01-CR-IN-117-B		Lab ID: 70343405050		Collected: 03/12/25 07:13		Received: 03/17/25 13:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 19:25	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD-School No.15

Pace Project No.: 70343405

Sample: 15-01-CR-IN-117-T **Lab ID: 70343405051** Collected: 03/12/25 07:13 Received: 03/17/25 13:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 19:32	7439-92-1	

Sample: 15-01-CR-IN-120-B **Lab ID: 70343405052** Collected: 03/12/25 07:14 Received: 03/17/25 13:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 19:34	7439-92-1	

Sample: 15-01-CR-IN-120-T **Lab ID: 70343405053** Collected: 03/12/25 07:14 Received: 03/17/25 13:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 19:40	7439-92-1	

Sample: 15-01-CR-IN-119-B **Lab ID: 70343405054** Collected: 03/12/25 07:16 Received: 03/17/25 13:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 19:42	7439-92-1	

Sample: 15-01-CR-IN-119-T **Lab ID: 70343405055** Collected: 03/12/25 07:16 Received: 03/17/25 13:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 19:44	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD-School No.15

Pace Project No.: 70343405

Sample: 15-01-CR-IN-118-B		Lab ID: 70343405056		Collected: 03/12/25 07:17		Received: 03/17/25 13:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 19:46	7439-92-1	
Sample: 15-01-CR-IN-118-T		Lab ID: 70343405057		Collected: 03/12/25 07:17		Received: 03/17/25 13:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 19:48	7439-92-1	
Sample: 15-01-HA-BY-116-FL		Lab ID: 70343405058		Collected: 03/12/25 07:18		Received: 03/17/25 13:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 19:50	7439-92-1	
Sample: 15-01-HA-BY-116-FR		Lab ID: 70343405059		Collected: 03/12/25 07:18		Received: 03/17/25 13:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 19:52	7439-92-1	
Sample: 15-01-HA-BY-116-BF		Lab ID: 70343405060		Collected: 03/12/25 07:19		Received: 03/17/25 13:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 19:54	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD-School No.15

Pace Project No.: 70343405

Sample: 15-01-CR-IN-121-T		Lab ID: 70343405061		Collected: 03/12/25 07:20		Received: 03/17/25 13:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	1.1	ug/L	1.0	15	1		03/26/25 19:58	7439-92-1	
Sample: 15-01-CR-IN-123-B		Lab ID: 70343405062		Collected: 03/12/25 07:22		Received: 03/17/25 13:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 20:04	7439-92-1	
Sample: 15-01-CR-IN-123-T		Lab ID: 70343405063		Collected: 03/12/25 07:22		Received: 03/17/25 13:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 20:06	7439-92-1	
Sample: 15-01-CR-IN-124-TL		Lab ID: 70343405064		Collected: 03/12/25 07:24		Received: 03/17/25 13:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 20:08	7439-92-1	
Sample: 15-01-CR-IN-124-TR		Lab ID: 70343405065		Collected: 03/12/25 07:24		Received: 03/17/25 13:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 20:10	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: RCSD-School No.15

Pace Project No.: 70343405

QC Batch:	390300	Analysis Method:	EPA 200.8, Rev. 5.4
QC Batch Method:	EPA 200.8, Rev. 5.4	Analysis Description:	NB 200.8 ICPMS DW No Prep
		Laboratory:	Pace Analytical Services - Newburgh
Associated Lab Samples:	70343405001, 70343405002, 70343405003, 70343405004, 70343405005, 70343405006, 70343405007, 70343405008, 70343405009		

METHOD BLANK:	2051895	Matrix:	Water
Associated Lab Samples:	70343405001, 70343405002, 70343405003, 70343405004, 70343405005, 70343405006, 70343405007, 70343405008, 70343405009		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	03/26/25 16:17	

LABORATORY CONTROL SAMPLE:	2051896					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	43.7	87	85-115	

MATRIX SPIKE SAMPLE:		2051898					
		70342737081	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	47.5	95	70-130	

MATRIX SPIKE SAMPLE:		2051900					
		70342737091	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	48.0	96	70-130	

SAMPLE DUPLICATE:	2051897					
Parameter	Units	70342737081 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: RCSD-School No.15

Pace Project No.: 70343405

QC Batch:	390301	Analysis Method:	EPA 200.8, Rev. 5.4
QC Batch Method:	EPA 200.8, Rev. 5.4	Analysis Description:	NB 200.8 ICPMS DW No Prep
		Laboratory:	Pace Analytical Services - Newburgh
Associated Lab Samples:	70343405010, 70343405011, 70343405012, 70343405013, 70343405014, 70343405015, 70343405016, 70343405017, 70343405018, 70343405019, 70343405020, 70343405021, 70343405022, 70343405023, 70343405024, 70343405025, 70343405026, 70343405027, 70343405028, 70343405029		

METHOD BLANK:	2051901	Matrix:	Water
Associated Lab Samples:	70343405010, 70343405011, 70343405012, 70343405013, 70343405014, 70343405015, 70343405016, 70343405017, 70343405018, 70343405019, 70343405020, 70343405021, 70343405022, 70343405023, 70343405024, 70343405025, 70343405026, 70343405027, 70343405028, 70343405029		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	03/26/25 17:19	

LABORATORY CONTROL SAMPLE:	2051902					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	44.3	89	85-115	

MATRIX SPIKE SAMPLE:		2051904					
		70343405010	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	47.4	94	70-130	

MATRIX SPIKE SAMPLE:		2051906					
		70343405020	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	47.6	95	70-130	

SAMPLE DUPLICATE:	2051903					
Parameter	Units	70343405010 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: RCSD-School No.15
Pace Project No.: 70343405

QC Batch:	390626	Analysis Method:	EPA 200.8, Rev. 5.4
QC Batch Method:	EPA 200.8, Rev. 5.4	Analysis Description:	NB 200.8 ICPMS DW No Prep
		Laboratory:	Pace Analytical Services - Newburgh
Associated Lab Samples:	70343405030, 70343405031, 70343405032, 70343405033, 70343405034, 70343405035, 70343405036, 70343405037, 70343405038, 70343405039, 70343405040, 70343405041, 70343405042, 70343405043, 70343405044, 70343405045, 70343405046, 70343405047, 70343405048, 70343405049		

METHOD BLANK:	2053939	Matrix:	Water
Associated Lab Samples:	70343405030, 70343405031, 70343405032, 70343405033, 70343405034, 70343405035, 70343405036, 70343405037, 70343405038, 70343405039, 70343405040, 70343405041, 70343405042, 70343405043, 70343405044, 70343405045, 70343405046, 70343405047, 70343405048, 70343405049		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	03/26/25 18:18	

LABORATORY CONTROL SAMPLE:	2053940					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	43.9	88	85-115	

MATRIX SPIKE SAMPLE:		2053942					
		70343405030	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	46.2	92	70-130	

MATRIX SPIKE SAMPLE:		2053944					
		70343405040	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	46.7	93	70-130	

SAMPLE DUPLICATE:	2053941					
Parameter	Units	70343405030 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: RCSD-School No.15
Pace Project No.: 70343405

QC Batch:	390627	Analysis Method:	EPA 200.8, Rev. 5.4
QC Batch Method:	EPA 200.8, Rev. 5.4	Analysis Description:	NB 200.8 ICPMS DW No Prep
		Laboratory:	Pace Analytical Services - Newburgh
Associated Lab Samples:	70343405050, 70343405051, 70343405052, 70343405053, 70343405054, 70343405055, 70343405056, 70343405057, 70343405058, 70343405059, 70343405060, 70343405061, 70343405062, 70343405063, 70343405064, 70343405065		

METHOD BLANK:	2053945	Matrix:	Water
Associated Lab Samples:	70343405050, 70343405051, 70343405052, 70343405053, 70343405054, 70343405055, 70343405056, 70343405057, 70343405058, 70343405059, 70343405060, 70343405061, 70343405062, 70343405063, 70343405064, 70343405065		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	03/26/25 19:21	

LABORATORY CONTROL SAMPLE:	2053946					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	43.6	87	85-115	

MATRIX SPIKE SAMPLE:		2053948					
		70343405050	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	46.5	92	70-130	

MATRIX SPIKE SAMPLE:		2053950					
		70343405060	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	46.0	92	70-130	

SAMPLE DUPLICATE:	2053947					
Parameter	Units	70343405050 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALIFIERS

Project: RCSD-School No.15
Pace Project No.: 70343405

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: RCSD-School No.15

Pace Project No.: 70343405

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70343405001	15-01-RM-IN-154-TL	EPA 200.8, Rev. 5.4	390300		
70343405002	15-01-RM-IN-154-TR	EPA 200.8, Rev. 5.4	390300		
70343405003	15-01-RM-IN-157-T1	EPA 200.8, Rev. 5.4	390300		
70343405004	15-01-RM-IN-157-T2	EPA 200.8, Rev. 5.4	390300		
70343405005	15-01-RM-IN-157A-T	EPA 200.8, Rev. 5.4	390300		
70343405006	15-01-RM-IN-157B-T1	EPA 200.8, Rev. 5.4	390300		
70343405007	15-01-RM-IN-157B-T2	EPA 200.8, Rev. 5.4	390300		
70343405008	15-01-CR-IN-127-B	EPA 200.8, Rev. 5.4	390300		
70343405009	15-01-CR-IN-127-T	EPA 200.8, Rev. 5.4	390300		
70343405010	15-01-CR-IN-126-B	EPA 200.8, Rev. 5.4	390301		
70343405011	15-01-CR-IN-126-T	EPA 200.8, Rev. 5.4	390301		
70343405012	15-01-HA-BY-125-FL	EPA 200.8, Rev. 5.4	390301		
70343405013	15-01-HA-BY-125-FR	EPA 200.8, Rev. 5.4	390301		
70343405014	15-01-HA-BY-125-BF	EPA 200.8, Rev. 5.4	390301		
70343405015	15-01-HA-BY-132-FL	EPA 200.8, Rev. 5.4	390301		
70343405016	15-01-HA-BY-132-FR	EPA 200.8, Rev. 5.4	390301		
70343405017	15-01-HA-BY-132-BF	EPA 200.8, Rev. 5.4	390301		
70343405018	15-01-HA-BY-165-FL	EPA 200.8, Rev. 5.4	390301		
70343405019	15-01-HA-BY-165-FR	EPA 200.8, Rev. 5.4	390301		
70343405020	15-01-HA-BY-165-BF	EPA 200.8, Rev. 5.4	390301		
70343405021	15-01-NO-IN-164-T	EPA 200.8, Rev. 5.4	390301		
70343405022	15-01-CR-IN-137-B	EPA 200.8, Rev. 5.4	390301		
70343405023	15-01-CR-IN-137-T	EPA 200.8, Rev. 5.4	390301		
70343405024	15-01-CR-IN-139-B	EPA 200.8, Rev. 5.4	390301		
70343405025	15-01-CR-IN-139-T	EPA 200.8, Rev. 5.4	390301		
70343405026	15-01-CR-IN-142-B	EPA 200.8, Rev. 5.4	390301		
70343405027	15-01-CR-IN-142-T	EPA 200.8, Rev. 5.4	390301		
70343405028	15-01-CR-IN-146-B	EPA 200.8, Rev. 5.4	390301		
70343405029	15-01-CR-IN-146-T	EPA 200.8, Rev. 5.4	390301		
70343405030	15-01-CR-IN-149-B	EPA 200.8, Rev. 5.4	390626		
70343405031	15-01-CR-IN-149-T	EPA 200.8, Rev. 5.4	390626		
70343405032	15-01-CR-IN-151-B	EPA 200.8, Rev. 5.4	390626		
70343405033	15-01-CR-IN-151-T	EPA 200.8, Rev. 5.4	390626		
70343405034	15-01-CR-IN-150-B	EPA 200.8, Rev. 5.4	390626		
70343405035	15-01-CR-IN-150-T	EPA 200.8, Rev. 5.4	390626		
70343405036	15-01-CR-IN-138-B	EPA 200.8, Rev. 5.4	390626		
70343405037	15-01-CR-IN-138-T	EPA 200.8, Rev. 5.4	390626		
70343405038	15-01-RM-IN-167A-T	EPA 200.8, Rev. 5.4	390626		
70343405039	15-01-CR-IN-109-B	EPA 200.8, Rev. 5.4	390626		
70343405040	15-01-CR-IN-109-T	EPA 200.8, Rev. 5.4	390626		
70343405041	15-01-CR-IN-111-B	EPA 200.8, Rev. 5.4	390626		
70343405042	15-01-CR-IN-111-T	EPA 200.8, Rev. 5.4	390626		
70343405043	15-01-CR-IN-112-B	EPA 200.8, Rev. 5.4	390626		
70343405044	15-01-CR-IN-112-T	EPA 200.8, Rev. 5.4	390626		
70343405045	15-01-CR-IN-110-B	EPA 200.8, Rev. 5.4	390626		
70343405046	15-01-CR-IN-110-T	EPA 200.8, Rev. 5.4	390626		
70343405047	15-01-RM-IN-104-T	EPA 200.8, Rev. 5.4	390626		
70343405048	15-01-CR-IN-114-B	EPA 200.8, Rev. 5.4	390626		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: RCSD-School No.15

Pace Project No.: 70343405

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70343405049	15-01-CR-IN-114-T	EPA 200.8, Rev. 5.4	390626		
70343405050	15-01-CR-IN-117-B	EPA 200.8, Rev. 5.4	390627		
70343405051	15-01-CR-IN-117-T	EPA 200.8, Rev. 5.4	390627		
70343405052	15-01-CR-IN-120-B	EPA 200.8, Rev. 5.4	390627		
70343405053	15-01-CR-IN-120-T	EPA 200.8, Rev. 5.4	390627		
70343405054	15-01-CR-IN-119-B	EPA 200.8, Rev. 5.4	390627		
70343405055	15-01-CR-IN-119-T	EPA 200.8, Rev. 5.4	390627		
70343405056	15-01-CR-IN-118-B	EPA 200.8, Rev. 5.4	390627		
70343405057	15-01-CR-IN-118-T	EPA 200.8, Rev. 5.4	390627		
70343405058	15-01-HA-BY-116-FL	EPA 200.8, Rev. 5.4	390627		
70343405059	15-01-HA-BY-116-FR	EPA 200.8, Rev. 5.4	390627		
70343405060	15-01-HA-BY-116-BF	EPA 200.8, Rev. 5.4	390627		
70343405061	15-01-CR-IN-121-T	EPA 200.8, Rev. 5.4	390627		
70343405062	15-01-CR-IN-123-B	EPA 200.8, Rev. 5.4	390627		
70343405063	15-01-CR-IN-123-T	EPA 200.8, Rev. 5.4	390627		
70343405064	15-01-CR-IN-124-TL	EPA 200.8, Rev. 5.4	390627		
70343405065	15-01-CR-IN-124-TR	EPA 200.8, Rev. 5.4	390627		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 1 of 7

Page 28 of 35

LAB ID: M37316		REPORT TO:		INVOICE TO:	
PROJECT NAME: RCSD - School No. 15		Company: Lozier Environmental Consulting, Inc.		Company: (SAME)	
TURNAROUND TIME: Standard Rush		Address: 2011 East Main Street		Address:	
City/State Zip: Rochester NY 14609		City/State Zip:		City/State Zip:	
Phone: 585-654-9080		Fax: 585-654-9662		Phone: Fax:	
E-Mail: support@lozierenv.com		Purchase Order #:			

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS			
1	15-01-RM-IN-154-TL	3/12/2025	6:09		DW			hand wash	x			
2	15-01-RM-IN-154-TR	3/12/2025	6:09		DW			island prep	x			
3	15-01-RM-IN-157-T1	3/12/2025	6:10		DW			hand wash	x			
4	15-01-RM-IN-157-T2	3/12/2025	6:11		DW			island prep	x			
5	15-01-RM-IN-157-A-T	3/12/2025	6:12		DW			hand wash	x			
6	15-01-RM-IN-157-B-T1	3/12/2025	6:13		DW			dish wash	x			
7	15-01-RM-IN-157-B-T2	3/12/2025	6:13		DW			dish wash	x			
8	15-01-CR-IN-127-B	3/12/2025	6:16		DW				x			
9	15-01-CR-IN-127-T	3/12/2025	6:16		DW				x			
10	15-01-CR-IN-126-B	3/12/2025	6:18		DW				x			

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

SAMPLED BY*: Joe Savioe

REINQUISHED BY*: Joe Savioe DATE: 3/13/2025 TIME: 8:00

RECEIVED BY: *John Atwood* DATE: 3/12/25 TIME: 1:30

REINQUISHED BY: DATE: TIME:

RECEIVED BY: DATE: TIME:

REINQUISHED BY*: DATE: TIME:

RECEIVED BY: DATE: TIME:

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FSD & ERD

7726 9549 2040, 7726 9549 1559

FOR LAB USE ONLY		FOR POTABLE WATER ONLY:	
PRESERVATIVE/BIOCIDES: HNO3-		COLIFORM BACTERIA:	
TOTAL NUMBER OF CONTAINERS: 65		Present Absent	
CUSTODY SEAL INTACT? YES		If Present, Date Client is contacted with result:	
SAMPLE ON ICE? NO		Date: _____	
TEMPERATURE: 15.0C		Contacted By: _____	
SAMPLE IN COMPLIANCE: YES			

MO#: 70343405

70343405



2011 East Main Street, Rochester, NY 14609 Phone (585) 654-9080 Fax (585) 654-9662
Web: LozierEnv.com E-Mail: support@lozierenv.com

Page 2 of 7
70343405

REPORT TO:		INVOICE TO:	
Company:	Lozier Environmental Consulting, Inc.	Company: (SAME)	
Address:	2011 East Main Street	Address:	
City/State Zip:	Rochester NY 14609	City/State Zip:	
Phone:	585-654-9080	Phone:	
Fax:	585-654-9662	Fax:	
E-Mail:	support@lozierenv.com	Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS			
11	15-01-CR-IN-126-T	3/12/2025	6:18		DW				x			
12	15-01-HA-BY-125-FL	3/12/2025	6:19		DW				x			
13	15-01-HA-BY-125-FR	3/12/2025	6:19		DW				x			
14	15-01-HA-BY-125-BF	3/12/2025	6:19		DW				x			
15	15-01-HA-BY-132-FL	3/12/2025	6:21		DW				x			
16	15-01-HA-BY-132-FR	3/12/2025	6:21		DW				x			
17	15-01-HA-BY-132-BF	3/12/2025	6:21		DW				x			
18	15-01-HA-BY-165-FL	3/12/2025	6:23		DW				x			
19	15-01-HA-BY-165-FR	3/12/2025	6:23		DW				x			
20	15-01-HA-BY-165-BF	3/12/2025	6:23		DW				x			

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

SAMPLED BY: Joe Savioe

RELINQUISHED BY: Joe Savioe DATE: 3/13/2025 TIME: 8:00

RECEIVED BY: *Alba Istan* DATE: 3/17/25 TIME: 1300

RELINQUISHED BY: DATE: TIME:

RECEIVED BY: DATE: TIME:

RELINQUISHED BY: DATE: TIME:

RECEIVED BY: DATE: TIME:

FOR LAB USE ONLY		FOR POTABLE WATER ONLY:	
PRESERVATIVE/BIOCIDES: HNO3-		COLIFORM BACTERIA:	
TOTAL NUMBER OF CONTAINERS: 65		Present	Absent
CUSTODY SEAL INTACT? YES		If Present, Date Client is contacted with result:	
SAMPLE ON ICE? NO		Date: _____	
TEMPERATURE: 15.00C		Contacted By: _____	
SAMPLE IN COMPLIANCE: YES			

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 3 of 7
70343405

Page 30 of 35

LAB ID: M37316		Company: Lozier Environmental Consulting, Inc.		REPORT TO:		INVOICE TO:	
PROJECT NAME: RCSD - School No. 15		Address: 2011 East Main Street		Company: (SAME)			
TURNAROUND TIME: Standard Rush		City/State Zip: Rochester NY 14609		City/State Zip:			
Other:		Phone: 585-654-9080		Fax: 585-654-9662		Phone: Fax:	
		E-Mail: support@lozierenv.com		Purchase Order #:			

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS				
21	15-01-NO-IN-164-T	3/12/2025	6:26		DW				Lead				
22	15-01-CR-IN-137-B	3/12/2025	6:28		DW				X				
23	15-01-CR-IN-137-T	3/12/2025	6:28		DW				X				
24	15-01-CR-IN-139-B	3/12/2025	6:29		DW				X				
25	15-01-CR-IN-139-T	3/12/2025	6:33		DW				X				
26	15-01-CR-IN-142-B	3/12/2025	6:35		DW				X				
27	15-01-CR-IN-142-T	3/12/2025	6:35		DW				X				
28	15-01-CR-IN-146-B	3/12/2025	6:37		DW				X				
29	15-01-CR-IN-146-T	3/12/2025	6:37		DW				X				
30	15-01-CR-IN-149-B	3/12/2025	6:39		DW				X				

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

SAMPLED BY: Joe Savioe	DATE: 3/13/2025	TIME: 8:00
RELINQUISHED BY: Joe Savioe	DATE: 3/17/25	TIME: 1300
RECEIVED BY: <i>William Hanna</i>	DATE: 3/17/25	TIME: 1300
RELINQUISHED BY:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:
RELINQUISHED BY:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:

FOR LAB USE ONLY		FOR POTABLE WATER ONLY:	
PRESERVATIVE/BIOCIDES: HNO3-		COLIFORM BACTERIA:	
TOTAL NUMBER OF CONTAINERS: 65		Present	Absent
CUSTODY SEAL INTACT? YES		If Present, Date Client is contacted with result:	
SAMPLE ON ICE? NO		Date: _____	Contacted By: _____
TEMPERATURE: 15-20C			
SAMPLE IN COMPLIANCE: YES			

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 4 of 7
70343465

LAB ID: M37316		Company: Lozier Environmental Consulting, Inc.		REPORT TO:		INVOICE TO:	
PROJECT NAME: RCSD - School No. 15		Address: 2011 East Main Street		City/State Zip: Rochester NY 14609		Address: (SAME)	
TURNAROUND TIME: Standard Rush		Phone: 585-654-9080		Fax: 585-654-9662		City/State Zip:	
Other:		E-Mail: support@lozierenv.com		Purchase Order #:		Fax:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS				
31	15-01-CR-IN-149-T	3/12/2025	6:39		DW				Lead				
32	15-01-CR-IN-151-B	3/12/2025	6:41		DW								
33	15-01-CR-IN-151-T	3/12/2025	6:41		DW								
34	15-01-CR-IN-150-B	3/12/2025	6:42		DW								
35	15-01-CR-IN-150-T	3/12/2025	6:42		DW								
36	15-01-CR-IN-138-B	3/12/2025	6:45		DW								
37	15-01-CR-IN-138-T	3/12/2025	6:45		DW								
38	15-01-RM-IN-167A-T	3/12/2025	6:48		DW								
39	15-01-CR-IN-109-B	3/12/2025	6:53		DW								
40	15-01-CR-IN-109-T	3/12/2025	6:53		DW								

Container Type (Circle One): Plastic Glass Sterile Other _____
Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

SAMPLED BY* Joe Savioe

RECEIVED BY* Joe Savioe DATE: 3/13/2025 TIME: 8:00

RECEIVED BY* *Michael* DATE: 3/12/25 TIME: 1300

RECEIVED BY* DATE: TIME:

RECEIVED BY* DATE: TIME:

RECEIVED BY* DATE: TIME:

FOR LAB USE ONLY		FOR POTABLE WATER ONLY:	
PRESERVATIVE/BIOCIDE: HNO3-		COLIFORM BACTERIA:	
TOTAL NUMBER OF CONTAINERS: 65		Present Absent	
CUSTODY SEAL INTACT? YES		If Present, Date Client is contacted with result:	
SAMPLE ON ICE? NO		Date: _____	
TEMPERATURE: 15-0 C		Contacted By: _____	
SAMPLE IN COMPLIANCE: YES			

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 5 of 7
70343405

LAB ID: M37316		Company: Lozier Environmental Consulting, Inc.		REPORT TO:		Company: (SAME)		INVOICE TO:	
PROJECT NAME: RCSD - School No. 15		Address: 2011 East Main Street				Address:			
TURNAROUND TIME: Standard Rush		City/State Zip: Rochester NY 14609				City/State Zip:			
Other:		Phone: 585-654-9080		Fax: 585-654-9662		Phone:		Fax:	
		E-Mail: support@lozierenv.com				Purchase Order #:			

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS				
41	15-01-CR-IN-111-B	3/12/2025	6:55		DW				X				
42	15-01-CR-IN-111-T	3/12/2025	6:55		DW				X				
43	15-01-CR-IN-112-B	3/12/2025	6:56		DW				X				
44	15-01-CR-IN-112-T	3/12/2025	6:56		DW				X				
45	15-01-CR-IN-110-B	3/12/2025	6:58		DW				X				
46	15-01-CR-IN-110-T	3/12/2025	6:58		DW				X				
47	15-01-RM-IN-104-T	3/12/2025	7:06		DW				X				
48	15-01-CR-IN-114-B	3/12/2025	7:11		DW				X				
49	15-01-CR-IN-114-T	3/12/2025	7:11		DW				X				
50	15-01-CR-IN-117-B	3/12/2025	7:13		DW				X				

Container Type (Circle One): Plastic Glass Sterile Other _____ Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

SAMPLED BY*: Joe Savioe

RELINQUISHED BY*: Joe Savioe DATE: 3/13/2025 TIME: 8:00

RECEIVED BY: Joe Savioe DATE: 3/12/25 TIME: 1300

RELINQUISHED BY*: DATE: TIME:

RECEIVED BY: DATE: TIME:

RELINQUISHED BY*: DATE: TIME:

RECEIVED BY: DATE: TIME:

FOR LAB USE ONLY		FOR POTABLE WATER ONLY:	
PRESERVATIVE/BIOCIDE: HNO3-		COLIFORM BACTERIA:	
TOTAL NUMBER OF CONTAINERS: 65		Present	Absent
CUSTODY SEAL INTACT? YES		If Present, Date Client is contacted with result:	
SAMPLE ON ICE? NO		Date: _____	
TEMPERATURE: 50C		Contacted By: _____	
SAMPLE IN COMPLIANCE: YES			

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 6 of 7
70343405

LAB ID: M37316		Company: Lozier Environmental Consulting, Inc.		REPORT TO:		INVOICE TO:	
PROJECT NAME: RCSD - School No. 15		Address: 2011 East Main Street		City/State Zip: Rochester NY 14609		Company: (SAME)	
TURNAROUND TIME: Standard Rush		Phone: 585-654-9080 Fax: 585-654-9662		City/State Zip:		Address:	
Other:		E-Mail: support@lozierenv.com		Purchase Order #:		Fax:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS				
51	15-01-CR-IN-117-T	3/12/2025	7:13		DW			Lead					
52	15-01-CR-IN-120-B	3/12/2025	7:14		DW								
53	15-01-CR-IN-120-T	3/12/2025	7:14		DW								
54	15-01-CR-IN-119-B	3/12/2025	7:16		DW								
55	15-01-CR-IN-119-T	3/12/2025	7:16		DW								
56	15-01-CR-IN-118-B	3/12/2025	7:17		DW								
57	15-01-CR-IN-118-T	3/12/2025	7:17		DW								
58	15-01-HA-BY-116-FL	3/12/2025	7:18		DW								
59	15-01-HA-BY-116-FR	3/12/2025	7:18		DW								
60	15-01-HA-BY-116-BF	3/12/2025	7:19		DW								

Container Type (Circle One): Plastic Glass Sterile Other _____ Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

SAMPLED BY: Joe Savioe	DATE: 3/13/2025	TIME: 8:00
RECEIVED BY: Joe Savioe	DATE: 3/17/25	TIME: 13:00
RELINQUISHED BY: <i>Albert</i>	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:
RELINQUISHED BY:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:

FOR LAB USE ONLY		FOR POTABLE WATER ONLY:	
PRESERVATIVE/BIOCIDE: HNO3-	TOTAL NUMBER OF CONTAINERS: 66	COLIFORM BACTERIA:	
CUSTODY SEAL INTACT? YES	SAMPLE ON ICE? NO	Present	Absent
TEMPERATURE: 50.0 C	SAMPLE IN COMPLIANCE: YES	If Present, Date Client is contacted with result:	
		Date:	Contacted By:

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

		REPORT TO:		INVOICE TO:	
LAB ID: M37316		Company: Lozier Environmental Consulting, Inc.		Company: (SAME)	
PROJECT NAME: RCSD - School No. 15		Address: 2011 East Main Street		Address:	
TURNAROUND TIME: Standard Rush		City, State Zip: Rochester NY 14609		City, State Zip:	
Other:		Phone: 585-654-9080 Fax: 585-654-9662		Phone: Fax:	
E-Mail: support@lozierenv.com		Purchase Order #:			

Page 34

[illegible]

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

SAMPLED BY* Joe Savioe	
RELINQUISHED BY*	Joe Savioe
RECEIVED BY:	
RELINQUISHED BY*	
RECEIVED BY:	
RELINQUISHED BY*	
RECEIVED BY:	
RELINQUISHED BY*	
RECEIVED BY:	

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDES: HNO ₃	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINERS: 65	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES	Present Absent
SAMPLE ON ICE? NO	If Present, Date Client is
TEMPERATURE: 15.0°C	contacted with result:
SAMPLE IN COMPLIANCE: YES	Date: _____
	Contacted By: _____

***The above signatures hereby authorize subcontracting of samples as required for laboratory analysis**

WO#: 70343405

Project #

PM: RC1

Due Date: 03/31/25

Client:

CLIENT: NB-LOZIER

Date and Initials of person:

Examining contents: _____

Label: _____

Deliver to location: _____

pH: _____

Thermometer Used: IRG4

Date: 3/17

Time: 1300

Initials: _____

State of Origin: NY

Cooler #1 Temp. °C: 15.0 (Visual) 0.2 @ 0.0°C, -0.5 @ 20.0°C (Correction Factor) _____ (Actual) ☒ Samples on ice, cooling process has begun

Courier: ☒ Fed Ex ☐ UPS ☐ USPS ☐ Commercial ☐ Pace ☐ Other _____

Shipping Method: ☐ First Overnight ☐ Priority Overnight ☐ Standard Overnight ☒ Ground

☐ Other _____

Tracking # SEE COC

Custody Seal on Cooler/Box Present: ☐ Yes ☐ No Seals intact: ☐ Yes ☐ No Ice: ☒ Wet ☐ Blue ☐ Melted ☐ None

Packing Material: ☐ Bubble Wrap ☐ Bubble Bags ☐ None ☐ Other _____

Samples were collected by Pace employee ☐ Yes ☐ No ☐ N/A

Comments:

Chain of Custody Present	☒ Yes ☐ No ☐ N/A	
Chain of Custody Filled Out	☒ Yes ☐ No ☐ N/A	
Relinquished Signature on COC	☒ Yes ☐ No ☐ N/A	
Sampler Name and Signature on COC	☒ Yes ☐ No ☐ N/A	
Samples Arrived within Hold Time	☒ Yes ☐ No ☐ N/A	
Rush TAT requested on COC	☐ Yes ☐ No ☐ N/A	
Sufficient Volume	☒ Yes ☐ No ☐ N/A	
Correct Containers Used	☒ Yes ☐ No ☐ N/A	
Containers Intact	☒ Yes ☐ No ☐ N/A	
Sample Labels match COC (sample IDs & date/time of collection)	☒ Yes ☐ No ☐ N/A	
All containers needing acid/base preservation have been checked.	☐ Yes ☐ No ☐ N/A	Preservation Information:
All Containers needing preservation are found to be in compliance with EPA recommendation:	☐ Yes ☐ No ☐ N/A	Preservative: _____
Exceptions: Vials, Microbiology, O&G, Metals		Lot #/Trace #: _____
		Date: _____ Time: _____
		Initials: _____
Headspace in VOA Vials? (>6mm):	☐ Yes ☐ No ☐ N/A	
Trip Blank Present:	☐ Yes ☐ No ☐ N/A	

Additional Login Comments:

Client notification/ Resolution

Person Contacted:

Date/Time:

Comments/Resolution: