



March 28, 2025

Amy Kaptein
Lozier Environmental Consulting, Inc
2011 E. Main St.
Rochester, NY 14609

RE: Project: RCSD-School No.28(Henry Hudson
Pace Project No.: 70342737

Dear Amy Kaptein:

Enclosed are the analytical results for sample(s) received by the laboratory on March 13, 2025. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Newburgh

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in cursive script that reads 'Renee Cusack'.

Renee Cusack
renee.cusack@pacelabs.com
(845)562-0890
Project Manager

Enclosures

cc: Amy Pusateri, Lozier Environmental Consulting Inc.



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



CERTIFICATIONS

Project: RCSD-School No.28(Henry Hudson

Pace Project No.: 70342737

Pace Analytical Services, LLC- Newburgh, NY

315 Fullerton Avenue, Newburgh, NY 12550

New York Certification #: 10142 Primary Accrediting Body

New Jersey Certification #: NY015

Connecticut Certification #: PH-0823

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE SUMMARY

Project: RCSD-School No.28(Henry Hudson)

Pace Project No.: 70342737

Lab ID	Sample ID	Matrix	Date Collected	Date Received
70342737001	28-01-CR-IN-106-T	Drinking Water	03/04/25 06:10	03/13/25 10:00
70342737002	28-01-CR-IN-123-T	Drinking Water	03/04/25 06:11	03/13/25 10:00
70342737003	28-01-CR-IN-123-B	Drinking Water	03/04/25 06:12	03/13/25 10:00
70342737004	28-01-CR-IN-124-T	Drinking Water	03/04/25 06:12	03/13/25 10:00
70342737005	28-01-CR-IN-124-B	Drinking Water	03/04/25 06:13	03/13/25 10:00
70342737006	28-01-CR-IN-128-T	Drinking Water	03/04/25 06:15	03/13/25 10:00
70342737007	28-01-CR-IN-128-B	Drinking Water	03/04/25 06:15	03/13/25 10:00
70342737008	28-01-CR-IN-129-T	Drinking Water	03/04/25 06:17	03/13/25 10:00
70342737009	28-01-CR-IN-129-B	Drinking Water	03/04/25 06:18	03/13/25 10:00
70342737010	28-01-HA-BY-103-F	Drinking Water	03/04/25 06:20	03/13/25 10:00
70342737011	28-01-HA-BY-103-BF	Drinking Water	03/04/25 06:20	03/13/25 10:00
70342737012	28-01-HA-BY-131-FL	Drinking Water	03/04/25 06:23	03/13/25 10:00
70342737013	28-01-HA-BY-131-FR	Drinking Water	03/04/25 06:24	03/13/25 10:00
70342737014	28-01-HA-BY-131-BF	Drinking Water	03/04/25 06:24	03/13/25 10:00
70342737015	28-01-CR-IN-133-TL	Drinking Water	03/04/25 06:30	03/13/25 10:00
70342737016	28-01-CR-IN-133-TR	Drinking Water	03/04/25 06:30	03/13/25 10:00
70342737017	28-01-CR-IN-151-T	Drinking Water	03/04/25 06:32	03/13/25 10:00
70342737018	28-01-CR-IN-151-B	Drinking Water	03/04/25 06:32	03/13/25 10:00
70342737019	28-01-CR-IN-152-T	Drinking Water	03/04/25 06:34	03/13/25 10:00
70342737020	28-01-CR-IN-152-B	Drinking Water	03/04/25 06:35	03/13/25 10:00
70342737021	28-01-CR-IN-154-T	Drinking Water	03/04/25 06:36	03/13/25 10:00
70342737022	28-01-CR-IN-154-B	Drinking Water	03/04/25 06:37	03/13/25 10:00
70342737023	28-01-CR-IN-155-T	Drinking Water	03/04/25 06:38	03/13/25 10:00
70342737024	28-01-CR-IN-155-B	Drinking Water	03/04/25 06:39	03/13/25 10:00
70342737025	28-01-CR-IN-156-T	Drinking Water	03/04/25 06:41	03/13/25 10:00
70342737026	28-01-CR-IN-156-B	Drinking Water	03/04/25 06:41	03/13/25 10:00
70342737027	28-01-CR-IN-157-T	Drinking Water	03/04/25 06:41	03/13/25 10:00
70342737028	28-01-CR-IN-157-B	Drinking Water	03/04/25 06:42	03/13/25 10:00
70342737029	28-01-CR-IN-158-T	Drinking Water	03/04/25 06:43	03/13/25 10:00
70342737030	28-01-CR-IN-158-B	Drinking Water	03/04/25 06:43	03/13/25 10:00
70342737031	28-01-CR-IN-159-B	Drinking Water	03/04/25 06:45	03/13/25 10:00
70342737032	28-01-CR-IN-159-T	Drinking Water	03/04/25 06:45	03/13/25 10:00
70342737033	28-01-CR-IN-165-T	Drinking Water	03/04/25 06:47	03/13/25 10:00
70342737034	28-01-CR-IN-165-B	Drinking Water	03/04/25 06:47	03/13/25 10:00
70342737035	28-01-HA-BY-169-FL	Drinking Water	03/04/25 06:48	03/13/25 10:00
70342737036	28-01-HA-BY-169-FR	Drinking Water	03/04/25 06:49	03/13/25 10:00
70342737037	28-01-HA-BY-169-BF	Drinking Water	03/04/25 06:49	03/13/25 10:00

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE SUMMARY

Project: RCSD-School No.28(Henry Hudson)

Pace Project No.: 70342737

Lab ID	Sample ID	Matrix	Date Collected	Date Received
70342737038	28-01-CR-IN-168-T	Drinking Water	03/04/25 06:50	03/13/25 10:00
70342737039	28-01-CR-IN-168-B	Drinking Water	03/04/25 06:51	03/13/25 10:00
70342737040	28-01-CR-IN-169-T	Drinking Water	03/04/25 06:53	03/13/25 10:00
70342737041	28-01-CR-IN-169-B	Drinking Water	03/04/25 06:53	03/13/25 10:00
70342737042	28-01-KI-IN-110-T1	Drinking Water	03/04/25 06:56	03/13/25 10:00
70342737043	28-01-KI-IN-110-T2	Drinking Water	03/04/25 06:56	03/13/25 10:00
70342737044	28-01-KI-IN-110-T3	Drinking Water	03/04/25 06:57	03/13/25 10:00
70342737045	28-01-KI-IN-110-T4	Drinking Water	03/04/25 06:58	03/13/25 10:00
70342737046	28-01-KI-IN-110-T5	Drinking Water	03/04/25 06:58	03/13/25 10:00
70342737047	28-01-KI-IN-110-T6	Drinking Water	03/04/25 07:01	03/13/25 10:00
70342737048	28-01-KI-IN-110-T7	Drinking Water	03/04/25 07:01	03/13/25 10:00
70342737049	28-01-CF-IN-101-FL	Drinking Water	03/04/25 07:01	03/13/25 10:00
70342737050	28-01-CF-IN-101-FR	Drinking Water	03/04/25 07:02	03/13/25 10:00
70342737051	28-01-CF-IN-101-BF	Drinking Water	03/04/25 07:04	03/13/25 10:00
70342737052	28-02-CR-IN-225-T	Drinking Water	03/04/25 07:10	03/13/25 10:00
70342737053	28-02-CR-IN-232-T	Drinking Water	03/04/25 07:11	03/13/25 10:00
70342737054	28-02-CR-IN-232-B	Drinking Water	03/04/25 07:11	03/13/25 10:00
70342737055	28-02-CR-IN-233-T	Drinking Water	03/04/25 07:12	03/13/25 10:00
70342737056	28-02-CR-IN-233-B	Drinking Water	03/04/25 07:13	03/13/25 10:00
70342737057	28-02-RM-IN-234A-T	Drinking Water	03/04/25 07:15	03/13/25 10:00
70342737058	28-02-CR-IN-235-T	Drinking Water	03/04/25 07:16	03/13/25 10:00
70342737059	28-02-CR-IN-235-B	Drinking Water	03/04/25 07:16	03/13/25 10:00
70342737060	28-02-CR-IN-236-T	Drinking Water	03/04/25 07:18	03/13/25 10:00
70342737061	28-02-CR-IN-237-T	Drinking Water	03/04/25 07:20	03/13/25 10:00
70342737062	28-02-CR-IN-237-B	Drinking Water	03/04/25 07:21	03/13/25 10:00
70342737063	28-02-CR-IN-238-T	Drinking Water	03/04/25 07:21	03/13/25 10:00
70342737064	28-02-CR-IN-238-B	Drinking Water	03/04/25 07:22	03/13/25 10:00
70342737065	28-02-CR-IN-239-T	Drinking Water	03/04/25 07:22	03/13/25 10:00
70342737066	28-02-CR-IN-239-B	Drinking Water	03/04/25 07:24	03/13/25 10:00
70342737067	28-02-CR-IN-240-T	Drinking Water	03/04/25 07:24	03/13/25 10:00
70342737068	28-02-CR-IN-240-B	Drinking Water	03/04/25 07:25	03/13/25 10:00
70342737069	28-02-CR-IN-241-T	Drinking Water	03/04/25 07:25	03/13/25 10:00
70342737070	28-02-CR-IN-241B	Drinking Water	03/04/25 07:25	03/13/25 10:00
70342737071	28-02-CR-IN-242-T	Drinking Water	03/04/25 07:26	03/13/25 10:00
70342737072	28-02-CR-IN-242-B	Drinking Water	03/04/25 07:26	03/13/25 10:00
70342737073	28-02-CR-IN-245-T	Drinking Water	03/04/25 07:28	03/13/25 10:00
70342737074	28-02-CR-IN-245-B	Drinking Water	03/04/25 07:28	03/13/25 10:00

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE SUMMARY

Project: RCSD-School No.28(Henry Hudson)

Pace Project No.: 70342737

Lab ID	Sample ID	Matrix	Date Collected	Date Received
70342737075	28-02-HA-BY-247-F	Drinking Water	03/04/25 07:29	03/13/25 10:00
70342737076	28-02-HA-BY-247-BF	Drinking Water	03/04/25 07:29	03/13/25 10:00
70342737077	28-02-CR-IN-204A-T1	Drinking Water	03/04/25 07:30	03/13/25 10:00
70342737078	28-02-CR-IN-204A-T2	Drinking Water	03/04/25 07:30	03/13/25 10:00
70342737079	28-02-CR-IN-205-T	Drinking Water	03/04/25 07:31	03/13/25 10:00
70342737080	28-02-TC-IN-203-T	Drinking Water	03/04/25 07:32	03/13/25 10:00
70342737081	28-02-HA-BY-211-FL	Drinking Water	03/04/25 07:32	03/13/25 10:00
70342737082	28-02-HA-BY-211-FR	Drinking Water	03/04/25 07:33	03/13/25 10:00
70342737083	28-02-HA-BY-211-BF	Drinking Water	03/04/25 07:33	03/13/25 10:00
70342737084	28-02-CR-IN-212-T1	Drinking Water	03/04/25 07:34	03/13/25 10:00
70342737085	28-02-CR-IN-212-T2	Drinking Water	03/04/25 07:34	03/13/25 10:00
70342737086	28-02-CR-IN-212-T3	Drinking Water	03/04/25 07:35	03/13/25 10:00
70342737087	28-02-RM-IN-212A-T	Drinking Water	03/04/25 07:32	03/13/25 10:00
70342737088	28-02-CR-IN-214-T1	Drinking Water	03/04/25 07:38	03/13/25 10:00
70342737089	28-02-CR-IN-214-T2	Drinking Water	03/04/25 07:39	03/13/25 10:00
70342737090	28-02-CR-IN-214-T3	Drinking Water	03/04/25 07:39	03/13/25 10:00
70342737091	28-01-NO-IN-103-T	Drinking Water	03/04/25 07:48	03/13/25 10:00

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE ANALYTE COUNT

Project: RCSD-School No.28(Henry Hudson)

Pace Project No.: 70342737

Lab ID	Sample ID	Method	Analysts	Analytes Reported
70342737001	28-01-CR-IN-106-T	EPA 200.8, Rev. 5.4	JC1	1
70342737002	28-01-CR-IN-123-T	EPA 200.8, Rev. 5.4	JC1	1
70342737003	28-01-CR-IN-123-B	EPA 200.8, Rev. 5.4	JC1	1
70342737004	28-01-CR-IN-124-T	EPA 200.8, Rev. 5.4	JC1	1
70342737005	28-01-CR-IN-124-B	EPA 200.8, Rev. 5.4	JC1	1
70342737006	28-01-CR-IN-128-T	EPA 200.8, Rev. 5.4	JC1	1
70342737007	28-01-CR-IN-128-B	EPA 200.8, Rev. 5.4	JC1	1
70342737008	28-01-CR-IN-129-T	EPA 200.8, Rev. 5.4	JC1	1
70342737009	28-01-CR-IN-129-B	EPA 200.8, Rev. 5.4	JC1	1
70342737010	28-01-HA-BY-103-F	EPA 200.8, Rev. 5.4	JC1	1
70342737011	28-01-HA-BY-103-BF	EPA 200.8, Rev. 5.4	JC1	1
70342737012	28-01-HA-BY-131-FL	EPA 200.8, Rev. 5.4	JC1	1
70342737013	28-01-HA-BY-131-FR	EPA 200.8, Rev. 5.4	JC1	1
70342737014	28-01-HA-BY-131-BF	EPA 200.8, Rev. 5.4	JC1	1
70342737015	28-01-CR-IN-133-TL	EPA 200.8, Rev. 5.4	JC1	1
70342737016	28-01-CR-IN-133-TR	EPA 200.8, Rev. 5.4	JC1	1
70342737017	28-01-CR-IN-151-T	EPA 200.8, Rev. 5.4	JC1	1
70342737018	28-01-CR-IN-151-B	EPA 200.8, Rev. 5.4	JC1	1
70342737019	28-01-CR-IN-152-T	EPA 200.8, Rev. 5.4	JC1	1
70342737020	28-01-CR-IN-152-B	EPA 200.8, Rev. 5.4	JC1	1
70342737021	28-01-CR-IN-154-T	EPA 200.8, Rev. 5.4	JC1	1
70342737022	28-01-CR-IN-154-B	EPA 200.8, Rev. 5.4	JC1	1
70342737023	28-01-CR-IN-155-T	EPA 200.8, Rev. 5.4	JC1	1
70342737024	28-01-CR-IN-155-B	EPA 200.8, Rev. 5.4	JC1	1
70342737025	28-01-CR-IN-156-T	EPA 200.8, Rev. 5.4	JC1	1
70342737026	28-01-CR-IN-156-B	EPA 200.8, Rev. 5.4	JC1	1
70342737027	28-01-CR-IN-157-T	EPA 200.8, Rev. 5.4	JC1	1
70342737028	28-01-CR-IN-157-B	EPA 200.8, Rev. 5.4	JC1	1
70342737029	28-01-CR-IN-158-T	EPA 200.8, Rev. 5.4	JC1	1
70342737030	28-01-CR-IN-158-B	EPA 200.8, Rev. 5.4	JC1	1
70342737031	28-01-CR-IN-159-B	EPA 200.8, Rev. 5.4	JC1	1
70342737032	28-01-CR-IN-159-T	EPA 200.8, Rev. 5.4	JC1	1
70342737033	28-01-CR-IN-165-T	EPA 200.8, Rev. 5.4	JC1	1
70342737034	28-01-CR-IN-165-B	EPA 200.8, Rev. 5.4	JC1	1
70342737035	28-01-HA-BY-169-FL	EPA 200.8, Rev. 5.4	JC1	1
70342737036	28-01-HA-BY-169-FR	EPA 200.8, Rev. 5.4	JC1	1
70342737037	28-01-HA-BY-169-BF	EPA 200.8, Rev. 5.4	JC1	1

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE ANALYTE COUNT

Project: RCSD-School No.28(Henry Hudson)

Pace Project No.: 70342737

Lab ID	Sample ID	Method	Analysts	Analytes Reported
70342737038	28-01-CR-IN-168-T	EPA 200.8, Rev. 5.4	JC1	1
70342737039	28-01-CR-IN-168-B	EPA 200.8, Rev. 5.4	JC1	1
70342737040	28-01-CR-IN-169-T	EPA 200.8, Rev. 5.4	JC1	1
70342737041	28-01-CR-IN-169-B	EPA 200.8, Rev. 5.4	JC1	1
70342737042	28-01-KI-IN-110-T1	EPA 200.8, Rev. 5.4	JC1	1
70342737043	28-01-KI-IN-110-T2	EPA 200.8, Rev. 5.4	JC1	1
70342737044	28-01-KI-IN-110-T3	EPA 200.8, Rev. 5.4	JC1	1
70342737045	28-01-KI-IN-110-T4	EPA 200.8, Rev. 5.4	JC1	1
70342737046	28-01-KI-IN-110-T5	EPA 200.8, Rev. 5.4	JC1	1
70342737047	28-01-KI-IN-110-T6	EPA 200.8, Rev. 5.4	JC1	1
70342737048	28-01-KI-IN-110-T7	EPA 200.8, Rev. 5.4	JC1	1
70342737049	28-01-CF-IN-101-FL	EPA 200.8, Rev. 5.4	JC1	1
70342737050	28-01-CF-IN-101-FR	EPA 200.8, Rev. 5.4	JC1	1
70342737051	28-01-CF-IN-101-BF	EPA 200.8, Rev. 5.4	JC1	1
70342737052	28-02-CR-IN-225-T	EPA 200.8, Rev. 5.4	JC1	1
70342737053	28-02-CR-IN-232-T	EPA 200.8, Rev. 5.4	JC1	1
70342737054	28-02-CR-IN-232-B	EPA 200.8, Rev. 5.4	JC1	1
70342737055	28-02-CR-IN-233-T	EPA 200.8, Rev. 5.4	JC1	1
70342737056	28-02-CR-IN-233-B	EPA 200.8, Rev. 5.4	JC1	1
70342737057	28-02-RM-IN-234A-T	EPA 200.8, Rev. 5.4	JC1	1
70342737058	28-02-CR-IN-235-T	EPA 200.8, Rev. 5.4	JC1	1
70342737059	28-02-CR-IN-235-B	EPA 200.8, Rev. 5.4	JC1	1
70342737060	28-02-CR-IN-236-T	EPA 200.8, Rev. 5.4	JC1	1
70342737061	28-02-CR-IN-237-T	EPA 200.8, Rev. 5.4	JC1	1
70342737062	28-02-CR-IN-237-B	EPA 200.8, Rev. 5.4	JC1	1
70342737063	28-02-CR-IN-238-T	EPA 200.8, Rev. 5.4	JC1	1
70342737064	28-02-CR-IN-238-B	EPA 200.8, Rev. 5.4	JC1	1
70342737065	28-02-CR-IN-239-T	EPA 200.8, Rev. 5.4	JC1	1
70342737066	28-02-CR-IN-239-B	EPA 200.8, Rev. 5.4	JC1	1
70342737067	28-02-CR-IN-240-T	EPA 200.8, Rev. 5.4	JC1	1
70342737068	28-02-CR-IN-240-B	EPA 200.8, Rev. 5.4	JC1	1
70342737069	28-02-CR-IN-241-T	EPA 200.8, Rev. 5.4	JC1	1
70342737070	28-02-CR-IN-241B	EPA 200.8, Rev. 5.4	JC1	1
70342737071	28-02-CR-IN-242-T	EPA 200.8, Rev. 5.4	JC1	1
70342737072	28-02-CR-IN-242-B	EPA 200.8, Rev. 5.4	JC1	1
70342737073	28-02-CR-IN-245-T	EPA 200.8, Rev. 5.4	JC1	1
70342737074	28-02-CR-IN-245-B	EPA 200.8, Rev. 5.4	JC1	1

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE ANALYTE COUNT

Project: RCSD-School No.28(Henry Hudson)

Pace Project No.: 70342737

Lab ID	Sample ID	Method	Analysts	Analytes Reported
70342737075	28-02-HA-BY-247-F	EPA 200.8, Rev. 5.4	JC1	1
70342737076	28-02-HA-BY-247-BF	EPA 200.8, Rev. 5.4	JC1	1
70342737077	28-02-CR-IN-204A-T1	EPA 200.8, Rev. 5.4	JC1	1
70342737078	28-02-CR-IN-204A-T2	EPA 200.8, Rev. 5.4	JC1	1
70342737079	28-02-CR-IN-205-T	EPA 200.8, Rev. 5.4	JC1	1
70342737080	28-02-TC-IN-203-T	EPA 200.8, Rev. 5.4	JC1	1
70342737081	28-02-HA-BY-211-FL	EPA 200.8, Rev. 5.4	JC1	1
70342737082	28-02-HA-BY-211-FR	EPA 200.8, Rev. 5.4	JC1	1
70342737083	28-02-HA-BY-211-BF	EPA 200.8, Rev. 5.4	JC1	1
70342737084	28-02-CR-IN-212-T1	EPA 200.8, Rev. 5.4	JC1	1
70342737085	28-02-CR-IN-212-T2	EPA 200.8, Rev. 5.4	JC1	1
70342737086	28-02-CR-IN-212-T3	EPA 200.8, Rev. 5.4	JC1	1
70342737087	28-02-RM-IN-212A-T	EPA 200.8, Rev. 5.4	JC1	1
70342737088	28-02-CR-IN-214-T1	EPA 200.8, Rev. 5.4	JC1	1
70342737089	28-02-CR-IN-214-T2	EPA 200.8, Rev. 5.4	JC1	1
70342737090	28-02-CR-IN-214-T3	EPA 200.8, Rev. 5.4	JC1	1
70342737091	28-01-NO-IN-103-T	EPA 200.8, Rev. 5.4	JC1	1

PASI-NB = Pace Analytical Services - Newburgh

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



PROJECT NARRATIVE

Project: RCSD-School No.28(Henry Hudson)
Pace Project No.: 70342737

Method: EPA 200.8, Rev. 5.4
Description: NB 200.8 ICPMS DW No Prep
Client: Lozier Environmental Consulting, Inc.
Date: March 28, 2025

General Information:

91 samples were analyzed for EPA 200.8, Rev. 5.4 by Pace Analytical Services Newburgh. All samples were received in acceptable condition with any exceptions noted below or on the chain-of custody and/or the sample condition upon receipt form (SCUR) attached at the end of this report.

Hold Time:

The samples were analyzed within the method required hold times with any exceptions noted below.

Initial Calibrations (including MS Tune as applicable):

All criteria were within method requirements with any exceptions noted below.

Continuing Calibration:

All criteria were within method requirements with any exceptions noted below.

Internal Standards:

All internal standards were within QC limits with any exceptions noted below.

Surrogates:

All surrogates were within QC limits with any exceptions noted below.

Method Blank:

All analytes were below the report limit in the method blank, where applicable, with any exceptions noted below.

Laboratory Control Spike:

All laboratory control spike compounds were within QC limits with any exceptions noted below.

Matrix Spikes:

All percent recoveries and relative percent differences (RPDs) were within acceptance criteria with any exceptions noted below.

Duplicate Sample:

All duplicate sample results were within method acceptance criteria with any exceptions noted below.

Additional Comments:

This data package has been reviewed for quality and completeness and is approved for release.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD-School No.28(Henry Hudson)

Pace Project No.: 70342737

Sample: 28-01-CR-IN-106-T		Lab ID: 70342737001		Collected: 03/04/25 06:10		Received: 03/13/25 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 12:13	7439-92-1	
Sample: 28-01-CR-IN-123-T		Lab ID: 70342737002		Collected: 03/04/25 06:11		Received: 03/13/25 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 12:26	7439-92-1	
Sample: 28-01-CR-IN-123-B		Lab ID: 70342737003		Collected: 03/04/25 06:12		Received: 03/13/25 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 12:28	7439-92-1	
Sample: 28-01-CR-IN-124-T		Lab ID: 70342737004		Collected: 03/04/25 06:12		Received: 03/13/25 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 12:30	7439-92-1	
Sample: 28-01-CR-IN-124-B		Lab ID: 70342737005		Collected: 03/04/25 06:13		Received: 03/13/25 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	1.3	ug/L	1.0	15	1		03/26/25 12:32	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD-School No.28(Henry Hudson)

Pace Project No.: 70342737

Sample: 28-01-CR-IN-128-T		Lab ID: 70342737006		Collected: 03/04/25 06:15		Received: 03/13/25 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 12:38	7439-92-1	
Sample: 28-01-CR-IN-128-B		Lab ID: 70342737007		Collected: 03/04/25 06:15		Received: 03/13/25 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 12:40	7439-92-1	
Sample: 28-01-CR-IN-129-T		Lab ID: 70342737008		Collected: 03/04/25 06:17		Received: 03/13/25 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 12:42	7439-92-1	
Sample: 28-01-CR-IN-129-B		Lab ID: 70342737009		Collected: 03/04/25 06:18		Received: 03/13/25 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 12:44	7439-92-1	
Sample: 28-01-HA-BY-103-F		Lab ID: 70342737010		Collected: 03/04/25 06:20		Received: 03/13/25 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 12:46	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD-School No.28(Henry Hudson)

Pace Project No.: 70342737

Sample: 28-01-HA-BY-103-BF Lab ID: 70342737011 Collected: 03/04/25 06:20 Received: 03/13/25 10:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 12:48	7439-92-1	

Sample: 28-01-HA-BY-131-FL Lab ID: 70342737012 Collected: 03/04/25 06:23 Received: 03/13/25 10:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 12:51	7439-92-1	

Sample: 28-01-HA-BY-131-FR Lab ID: 70342737013 Collected: 03/04/25 06:24 Received: 03/13/25 10:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 12:53	7439-92-1	

Sample: 28-01-HA-BY-131-BF Lab ID: 70342737014 Collected: 03/04/25 06:24 Received: 03/13/25 10:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 12:55	7439-92-1	

Sample: 28-01-CR-IN-133-TL Lab ID: 70342737015 Collected: 03/04/25 06:30 Received: 03/13/25 10:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 13:01	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD-School No.28(Henry Hudson)

Pace Project No.: 70342737

Sample: 28-01-CR-IN-133-TR		Lab ID: 70342737016		Collected: 03/04/25 06:30		Received: 03/13/25 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 13:03	7439-92-1	
Sample: 28-01-CR-IN-151-T		Lab ID: 70342737017		Collected: 03/04/25 06:32		Received: 03/13/25 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 13:05	7439-92-1	
Sample: 28-01-CR-IN-151-B		Lab ID: 70342737018		Collected: 03/04/25 06:32		Received: 03/13/25 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 13:07	7439-92-1	
Sample: 28-01-CR-IN-152-T		Lab ID: 70342737019		Collected: 03/04/25 06:34		Received: 03/13/25 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 13:09	7439-92-1	
Sample: 28-01-CR-IN-152-B		Lab ID: 70342737020		Collected: 03/04/25 06:35		Received: 03/13/25 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	1.6	ug/L	1.0	15	1		03/26/25 13:11	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD-School No.28(Henry Hudson)

Pace Project No.: 70342737

Sample: 28-01-CR-IN-154-T Lab ID: 70342737021 Collected: 03/04/25 06:36 Received: 03/13/25 10:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 13:17	7439-92-1	

Sample: 28-01-CR-IN-154-B Lab ID: 70342737022 Collected: 03/04/25 06:37 Received: 03/13/25 10:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	1.6	ug/L	1.0	15	1		03/26/25 13:29	7439-92-1	

Sample: 28-01-CR-IN-155-T Lab ID: 70342737023 Collected: 03/04/25 06:38 Received: 03/13/25 10:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 13:31	7439-92-1	

Sample: 28-01-CR-IN-155-B Lab ID: 70342737024 Collected: 03/04/25 06:39 Received: 03/13/25 10:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 13:33	7439-92-1	

Sample: 28-01-CR-IN-156-T Lab ID: 70342737025 Collected: 03/04/25 06:41 Received: 03/13/25 10:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 13:35	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD-School No.28(Henry Hudson)

Pace Project No.: 70342737

Sample: 28-01-CR-IN-156-B **Lab ID: 70342737026** Collected: 03/04/25 06:41 Received: 03/13/25 10:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 13:37	7439-92-1	

Sample: 28-01-CR-IN-157-T **Lab ID: 70342737027** Collected: 03/04/25 06:41 Received: 03/13/25 10:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 13:38	7439-92-1	

Sample: 28-01-CR-IN-157-B **Lab ID: 70342737028** Collected: 03/04/25 06:42 Received: 03/13/25 10:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 13:40	7439-92-1	

Sample: 28-01-CR-IN-158-T **Lab ID: 70342737029** Collected: 03/04/25 06:43 Received: 03/13/25 10:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 13:42	7439-92-1	

Sample: 28-01-CR-IN-158-B **Lab ID: 70342737030** Collected: 03/04/25 06:43 Received: 03/13/25 10:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 13:48	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD-School No.28(Henry Hudson)

Pace Project No.: 70342737

Sample: 28-01-CR-IN-159-B		Lab ID: 70342737031		Collected: 03/04/25 06:45		Received: 03/13/25 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 13:50	7439-92-1	
Sample: 28-01-CR-IN-159-T		Lab ID: 70342737032		Collected: 03/04/25 06:45		Received: 03/13/25 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	1.2	ug/L	1.0	15	1		03/26/25 13:54	7439-92-1	
Sample: 28-01-CR-IN-165-T		Lab ID: 70342737033		Collected: 03/04/25 06:47		Received: 03/13/25 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 13:56	7439-92-1	
Sample: 28-01-CR-IN-165-B		Lab ID: 70342737034		Collected: 03/04/25 06:47		Received: 03/13/25 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 13:58	7439-92-1	
Sample: 28-01-HA-BY-169-FL		Lab ID: 70342737035		Collected: 03/04/25 06:48		Received: 03/13/25 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 14:00	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD-School No.28(Henry Hudson)

Pace Project No.: 70342737

Sample: 28-01-HA-BY-169-FR Lab ID: 70342737036 Collected: 03/04/25 06:49 Received: 03/13/25 10:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 14:02	7439-92-1	

Sample: 28-01-HA-BY-169-BF Lab ID: 70342737037 Collected: 03/04/25 06:49 Received: 03/13/25 10:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 14:04	7439-92-1	

Sample: 28-01-CR-IN-168-T Lab ID: 70342737038 Collected: 03/04/25 06:50 Received: 03/13/25 10:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 14:06	7439-92-1	

Sample: 28-01-CR-IN-168-B Lab ID: 70342737039 Collected: 03/04/25 06:51 Received: 03/13/25 10:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 14:12	7439-92-1	

Sample: 28-01-CR-IN-169-T Lab ID: 70342737040 Collected: 03/04/25 06:53 Received: 03/13/25 10:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 14:14	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD-School No.28(Henry Hudson)

Pace Project No.: 70342737

Sample: 28-01-CR-IN-169-B Lab ID: 70342737041 Collected: 03/04/25 06:53 Received: 03/13/25 10:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 14:20	7439-92-1	

Sample: 28-01-KI-IN-110-T1 Lab ID: 70342737042 Collected: 03/04/25 06:56 Received: 03/13/25 10:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 14:27	7439-92-1	

Sample: 28-01-KI-IN-110-T2 Lab ID: 70342737043 Collected: 03/04/25 06:56 Received: 03/13/25 10:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 14:29	7439-92-1	

Sample: 28-01-KI-IN-110-T3 Lab ID: 70342737044 Collected: 03/04/25 06:57 Received: 03/13/25 10:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 14:35	7439-92-1	

Sample: 28-01-KI-IN-110-T4 Lab ID: 70342737045 Collected: 03/04/25 06:58 Received: 03/13/25 10:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 14:37	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD-School No.28(Henry Hudson)

Pace Project No.: 70342737

Sample: 28-01-KI-IN-110-T5		Lab ID: 70342737046		Collected: 03/04/25 06:58		Received: 03/13/25 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 14:39	7439-92-1	
Sample: 28-01-KI-IN-110-T6		Lab ID: 70342737047		Collected: 03/04/25 07:01		Received: 03/13/25 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 14:41	7439-92-1	
Sample: 28-01-KI-IN-110-T7		Lab ID: 70342737048		Collected: 03/04/25 07:01		Received: 03/13/25 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 14:43	7439-92-1	
Sample: 28-01-CF-IN-101-FL		Lab ID: 70342737049		Collected: 03/04/25 07:01		Received: 03/13/25 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 14:45	7439-92-1	
Sample: 28-01-CF-IN-101-FR		Lab ID: 70342737050		Collected: 03/04/25 07:02		Received: 03/13/25 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 14:47	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD-School No.28(Henry Hudson)

Pace Project No.: 70342737

Sample: 28-01-CF-IN-101-BF		Lab ID: 70342737051		Collected: 03/04/25 07:04		Received: 03/13/25 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 14:49	7439-92-1	
Sample: 28-02-CR-IN-225-T		Lab ID: 70342737052		Collected: 03/04/25 07:10		Received: 03/13/25 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 14:53	7439-92-1	
Sample: 28-02-CR-IN-232-T		Lab ID: 70342737053		Collected: 03/04/25 07:11		Received: 03/13/25 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 14:59	7439-92-1	
Sample: 28-02-CR-IN-232-B		Lab ID: 70342737054		Collected: 03/04/25 07:11		Received: 03/13/25 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 15:01	7439-92-1	
Sample: 28-02-CR-IN-233-T		Lab ID: 70342737055		Collected: 03/04/25 07:12		Received: 03/13/25 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 15:02	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD-School No.28(Henry Hudson)

Pace Project No.: 70342737

Sample: 28-02-CR-IN-233-B		Lab ID: 70342737056		Collected: 03/04/25 07:13		Received: 03/13/25 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	2.6	ug/L	1.0	15	1		03/26/25 15:04	7439-92-1	
Sample: 28-02-RM-IN-234A-T		Lab ID: 70342737057		Collected: 03/04/25 07:15		Received: 03/13/25 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 15:06	7439-92-1	
Sample: 28-02-CR-IN-235-T		Lab ID: 70342737058		Collected: 03/04/25 07:16		Received: 03/13/25 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 15:08	7439-92-1	
Sample: 28-02-CR-IN-235-B		Lab ID: 70342737059		Collected: 03/04/25 07:16		Received: 03/13/25 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	1.2	ug/L	1.0	15	1		03/26/25 15:10	7439-92-1	
Sample: 28-02-CR-IN-236-T		Lab ID: 70342737060		Collected: 03/04/25 07:18		Received: 03/13/25 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 15:12	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD-School No.28(Henry Hudson)

Pace Project No.: 70342737

Sample: 28-02-CR-IN-237-T		Lab ID: 70342737061		Collected: 03/04/25 07:20		Received: 03/13/25 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 15:22	7439-92-1	
Sample: 28-02-CR-IN-237-B		Lab ID: 70342737062		Collected: 03/04/25 07:21		Received: 03/13/25 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 15:30	7439-92-1	
Sample: 28-02-CR-IN-238-T		Lab ID: 70342737063		Collected: 03/04/25 07:21		Received: 03/13/25 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	2.0	ug/L	1.0	15	1		03/26/25 15:32	7439-92-1	
Sample: 28-02-CR-IN-238-B		Lab ID: 70342737064		Collected: 03/04/25 07:22		Received: 03/13/25 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	1.0	ug/L	1.0	15	1		03/26/25 15:34	7439-92-1	
Sample: 28-02-CR-IN-239-T		Lab ID: 70342737065		Collected: 03/04/25 07:22		Received: 03/13/25 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 15:36	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD-School No.28(Henry Hudson)

Pace Project No.: 70342737

Sample: 28-02-CR-IN-239-B Lab ID: 70342737066 Collected: 03/04/25 07:24 Received: 03/13/25 10:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 15:38	7439-92-1	

Sample: 28-02-CR-IN-240-T Lab ID: 70342737067 Collected: 03/04/25 07:24 Received: 03/13/25 10:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 15:40	7439-92-1	

Sample: 28-02-CR-IN-240-B Lab ID: 70342737068 Collected: 03/04/25 07:25 Received: 03/13/25 10:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 15:45	7439-92-1	

Sample: 28-02-CR-IN-241-T Lab ID: 70342737069 Collected: 03/04/25 07:25 Received: 03/13/25 10:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 15:47	7439-92-1	

Sample: 28-02-CR-IN-241B Lab ID: 70342737070 Collected: 03/04/25 07:25 Received: 03/13/25 10:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 15:49	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD-School No.28(Henry Hudson)

Pace Project No.: 70342737

Sample: 28-02-CR-IN-242-T		Lab ID: 70342737071		Collected: 03/04/25 07:26		Received: 03/13/25 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 15:51	7439-92-1	
Sample: 28-02-CR-IN-242-B		Lab ID: 70342737072		Collected: 03/04/25 07:26		Received: 03/13/25 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 15:55	7439-92-1	
Sample: 28-02-CR-IN-245-T		Lab ID: 70342737073		Collected: 03/04/25 07:28		Received: 03/13/25 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 15:57	7439-92-1	
Sample: 28-02-CR-IN-245-B		Lab ID: 70342737074		Collected: 03/04/25 07:28		Received: 03/13/25 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 15:59	7439-92-1	
Sample: 28-02-HA-BY-247-F		Lab ID: 70342737075		Collected: 03/04/25 07:29		Received: 03/13/25 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 16:01	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD-School No.28(Henry Hudson)

Pace Project No.: 70342737

Sample: 28-02-HA-BY-247-BF Lab ID: 70342737076 Collected: 03/04/25 07:29 Received: 03/13/25 10:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 16:03	7439-92-1	

Sample: 28-02-CR-IN-204A-T1 Lab ID: 70342737077 Collected: 03/04/25 07:30 Received: 03/13/25 10:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 16:09	7439-92-1	

Sample: 28-02-CR-IN-204A-T2 Lab ID: 70342737078 Collected: 03/04/25 07:30 Received: 03/13/25 10:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 16:11	7439-92-1	

Sample: 28-02-CR-IN-205-T Lab ID: 70342737079 Collected: 03/04/25 07:31 Received: 03/13/25 10:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 16:13	7439-92-1	

Sample: 28-02-TC-IN-203-T Lab ID: 70342737080 Collected: 03/04/25 07:32 Received: 03/13/25 10:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 16:15	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD-School No.28(Henry Hudson)

Pace Project No.: 70342737

Sample: 28-02-HA-BY-211-FL Lab ID: 70342737081 Collected: 03/04/25 07:32 Received: 03/13/25 10:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 16:21	7439-92-1	

Sample: 28-02-HA-BY-211-FR Lab ID: 70342737082 Collected: 03/04/25 07:33 Received: 03/13/25 10:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 16:32	7439-92-1	

Sample: 28-02-HA-BY-211-BF Lab ID: 70342737083 Collected: 03/04/25 07:33 Received: 03/13/25 10:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	<1.0	ug/L	1.0	15	1		03/26/25 16:34	7439-92-1	

Sample: 28-02-CR-IN-212-T1 Lab ID: 70342737084 Collected: 03/04/25 07:34 Received: 03/13/25 10:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	5.2	ug/L	1.0	15	1		03/26/25 16:36	7439-92-1	

Sample: 28-02-CR-IN-212-T2 Lab ID: 70342737085 Collected: 03/04/25 07:34 Received: 03/13/25 10:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4									
Pace Analytical Services - Newburgh									
Lead	1.2	ug/L	1.0	15	1		03/26/25 16:38	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD-School No.28(Henry Hudson)

Pace Project No.: 70342737

Sample: 28-02-CR-IN-212-T3 **Lab ID:** 70342737086 **Collected:** 03/04/25 07:35 **Received:** 03/13/25 10:00 **Matrix:** Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh									
Lead	2.7	ug/L	1.0	15	1		03/26/25 16:40	7439-92-1	

Sample: 28-02-RM-IN-212A-T **Lab ID:** 70342737087 **Collected:** 03/04/25 07:32 **Received:** 03/13/25 10:00 **Matrix:** Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh									
Lead	1.7	ug/L	1.0	15	1		03/26/25 16:42	7439-92-1	

Sample: 28-02-CR-IN-214-T1 **Lab ID:** 70342737088 **Collected:** 03/04/25 07:38 **Received:** 03/13/25 10:00 **Matrix:** Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh									
Lead	3.2	ug/L	1.0	15	1		03/26/25 16:44	7439-92-1	

Sample: 28-02-CR-IN-214-T2 **Lab ID:** 70342737089 **Collected:** 03/04/25 07:39 **Received:** 03/13/25 10:00 **Matrix:** Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh									
Lead	8.9	ug/L	1.0	15	1		03/26/25 16:46	7439-92-1	

Sample: 28-02-CR-IN-214-T3 **Lab ID:** 70342737090 **Collected:** 03/04/25 07:39 **Received:** 03/13/25 10:00 **Matrix:** Drinking Water

Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep									
Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh									
Lead	22.1	ug/L	1.0	15	1		03/26/25 16:48	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: RCSD-School No.28(Henry Hudson

Pace Project No.: 70342737

Sample: 28-01-NO-IN-103-T		Lab ID: 70342737091		Collected: 03/04/25 07:48		Received: 03/13/25 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
NB 200.8 ICPMS DW No Prep		Analytical Method: EPA 200.8, Rev. 5.4 Pace Analytical Services - Newburgh							
Lead	<1.0	ug/L	1.0	15	1		03/26/25 16:50	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: RCSD-School No.28(Henry Hudson)
Pace Project No.: 70342737

QC Batch:	389974	Analysis Method:	EPA 200.8, Rev. 5.4
QC Batch Method:	EPA 200.8, Rev. 5.4	Analysis Description:	NB 200.8 ICPMS DW No Prep
		Laboratory:	Pace Analytical Services - Newburgh
Associated Lab Samples:	70342737001, 70342737002, 70342737003, 70342737004, 70342737005, 70342737006, 70342737007, 70342737008, 70342737009, 70342737010, 70342737011, 70342737012, 70342737013, 70342737014, 70342737015, 70342737016, 70342737017, 70342737018, 70342737019, 70342737020		

METHOD BLANK:	2050186	Matrix:	Water
Associated Lab Samples:	70342737001, 70342737002, 70342737003, 70342737004, 70342737005, 70342737006, 70342737007, 70342737008, 70342737009, 70342737010, 70342737011, 70342737012, 70342737013, 70342737014, 70342737015, 70342737016, 70342737017, 70342737018, 70342737019, 70342737020		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	03/26/25 12:09	

LABORATORY CONTROL SAMPLE:	2050187					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	46.2	92	85-115	

MATRIX SPIKE SAMPLE:		2050189					
		70342737001	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	42.0	83	70-130	

MATRIX SPIKE SAMPLE:		2050191					
		70342737011	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	48.4	97	70-130	

SAMPLE DUPLICATE:	2050188					
Parameter	Units	70342737001 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: RCSD-School No.28(Henry Hudson)
Pace Project No.: 70342737

QC Batch:	389976	Analysis Method:	EPA 200.8, Rev. 5.4
QC Batch Method:	EPA 200.8, Rev. 5.4	Analysis Description:	NB 200.8 ICPMS DW No Prep
		Laboratory:	Pace Analytical Services - Newburgh
Associated Lab Samples:	70342737021, 70342737022, 70342737023, 70342737024, 70342737025, 70342737026, 70342737027, 70342737028, 70342737029, 70342737030, 70342737031, 70342737032, 70342737033, 70342737034, 70342737035, 70342737036, 70342737037, 70342737038, 70342737039, 70342737040		

METHOD BLANK:	2050196	Matrix:	Water
Associated Lab Samples:	70342737021, 70342737022, 70342737023, 70342737024, 70342737025, 70342737026, 70342737027, 70342737028, 70342737029, 70342737030, 70342737031, 70342737032, 70342737033, 70342737034, 70342737035, 70342737036, 70342737037, 70342737038, 70342737039, 70342737040		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	03/26/25 13:13	

LABORATORY CONTROL SAMPLE:	2050197					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	43.9	88	85-115	

MATRIX SPIKE SAMPLE:		2050199					
		70342737021	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	48.4	96	70-130	

MATRIX SPIKE SAMPLE:	2050201						
		70342737031	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	48.7	97	70-130	

SAMPLE DUPLICATE:	2050198					
Parameter	Units	70342737021 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: RCSD-School No.28(Henry Hudson)

Pace Project No.: 70342737

QC Batch:	389977	Analysis Method:	EPA 200.8, Rev. 5.4
QC Batch Method:	EPA 200.8, Rev. 5.4	Analysis Description:	NB 200.8 ICPMS DW No Prep
		Laboratory:	Pace Analytical Services - Newburgh
Associated Lab Samples:	70342737041, 70342737042, 70342737043, 70342737044, 70342737045, 70342737046, 70342737047, 70342737048, 70342737049, 70342737050, 70342737051, 70342737052, 70342737053, 70342737054, 70342737055, 70342737056, 70342737057, 70342737058, 70342737059, 70342737060		

METHOD BLANK:	2050203	Matrix:	Water
Associated Lab Samples:	70342737041, 70342737042, 70342737043, 70342737044, 70342737045, 70342737046, 70342737047, 70342737048, 70342737049, 70342737050, 70342737051, 70342737052, 70342737053, 70342737054, 70342737055, 70342737056, 70342737057, 70342737058, 70342737059, 70342737060		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	03/26/25 14:16	

LABORATORY CONTROL SAMPLE:	2050204					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	44.2	88	85-115	

MATRIX SPIKE SAMPLE:		2050206					
		70342737041	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	48.4	96	70-130	

MATRIX SPIKE SAMPLE:		2050208					
		70342737051	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	<1.0	50	47.5	95	70-130	

SAMPLE DUPLICATE:	2050205					
Parameter	Units	70342737041 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: RCSD-School No.28(Henry Hudson)
Pace Project No.: 70342737

QC Batch: 390298 Analysis Method: EPA 200.8, Rev. 5.4
QC Batch Method: EPA 200.8, Rev. 5.4 Analysis Description: NB 200.8 ICPMS DW No Prep
Laboratory: Pace Analytical Services - Newburgh
Associated Lab Samples: 70342737061, 70342737062, 70342737063, 70342737064, 70342737065, 70342737066, 70342737067, 70342737068, 70342737069, 70342737070, 70342737071, 70342737072, 70342737073, 70342737074, 70342737075, 70342737076, 70342737077, 70342737078, 70342737079, 70342737080

METHOD BLANK: 2051888 Matrix: Water
Associated Lab Samples: 70342737061, 70342737062, 70342737063, 70342737064, 70342737065, 70342737066, 70342737067, 70342737068, 70342737069, 70342737070, 70342737071, 70342737072, 70342737073, 70342737074, 70342737075, 70342737076, 70342737077, 70342737078, 70342737079, 70342737080

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	03/26/25 15:14	

LABORATORY CONTROL SAMPLE: 2051889

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	43.5	87	85-115	

MATRIX SPIKE SAMPLE: 2051891

Parameter	Units	70342737061 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	47.5	94	70-130	

MATRIX SPIKE SAMPLE: 2051893

Parameter	Units	70342737071 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	47.4	94	70-130	

SAMPLE DUPLICATE: 2051890

Parameter	Units	70342737061 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: RCSD-School No.28(Henry Hudson)
Pace Project No.: 70342737

QC Batch:	390300	Analysis Method:	EPA 200.8, Rev. 5.4
QC Batch Method:	EPA 200.8, Rev. 5.4	Analysis Description:	NB 200.8 ICPMS DW No Prep
		Laboratory:	Pace Analytical Services - Newburgh
Associated Lab Samples:	70342737081, 70342737082, 70342737083, 70342737084, 70342737085, 70342737086, 70342737087, 70342737088, 70342737089, 70342737090, 70342737091		

METHOD BLANK: 2051895 Matrix: Water
Associated Lab Samples: 70342737081, 70342737082, 70342737083, 70342737084, 70342737085, 70342737086, 70342737087, 70342737088, 70342737089, 70342737090, 70342737091

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	03/26/25 16:17	

LABORATORY CONTROL SAMPLE: 2051896

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	43.7	87	85-115	

MATRIX SPIKE SAMPLE: 2051898

Parameter	Units	70342737081 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	47.5	95	70-130	

MATRIX SPIKE SAMPLE: 2051900

Parameter	Units	70342737091 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	48.0	96	70-130	

SAMPLE DUPLICATE: 2051897

Parameter	Units	70342737081 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALIFIERS

Project: RCSD-School No.28(Henry Hudson)
Pace Project No.: 70342737

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: RCSD-School No.28(Henry Hudson)

Pace Project No.: 70342737

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70342737001	28-01-CR-IN-106-T	EPA 200.8, Rev. 5.4	389974		
70342737002	28-01-CR-IN-123-T	EPA 200.8, Rev. 5.4	389974		
70342737003	28-01-CR-IN-123-B	EPA 200.8, Rev. 5.4	389974		
70342737004	28-01-CR-IN-124-T	EPA 200.8, Rev. 5.4	389974		
70342737005	28-01-CR-IN-124-B	EPA 200.8, Rev. 5.4	389974		
70342737006	28-01-CR-IN-128-T	EPA 200.8, Rev. 5.4	389974		
70342737007	28-01-CR-IN-128-B	EPA 200.8, Rev. 5.4	389974		
70342737008	28-01-CR-IN-129-T	EPA 200.8, Rev. 5.4	389974		
70342737009	28-01-CR-IN-129-B	EPA 200.8, Rev. 5.4	389974		
70342737010	28-01-HA-BY-103-F	EPA 200.8, Rev. 5.4	389974		
70342737011	28-01-HA-BY-103-BF	EPA 200.8, Rev. 5.4	389974		
70342737012	28-01-HA-BY-131-FL	EPA 200.8, Rev. 5.4	389974		
70342737013	28-01-HA-BY-131-FR	EPA 200.8, Rev. 5.4	389974		
70342737014	28-01-HA-BY-131-BF	EPA 200.8, Rev. 5.4	389974		
70342737015	28-01-CR-IN-133-TL	EPA 200.8, Rev. 5.4	389974		
70342737016	28-01-CR-IN-133-TR	EPA 200.8, Rev. 5.4	389974		
70342737017	28-01-CR-IN-151-T	EPA 200.8, Rev. 5.4	389974		
70342737018	28-01-CR-IN-151-B	EPA 200.8, Rev. 5.4	389974		
70342737019	28-01-CR-IN-152-T	EPA 200.8, Rev. 5.4	389974		
70342737020	28-01-CR-IN-152-B	EPA 200.8, Rev. 5.4	389974		
70342737021	28-01-CR-IN-154-T	EPA 200.8, Rev. 5.4	389976		
70342737022	28-01-CR-IN-154-B	EPA 200.8, Rev. 5.4	389976		
70342737023	28-01-CR-IN-155-T	EPA 200.8, Rev. 5.4	389976		
70342737024	28-01-CR-IN-155-B	EPA 200.8, Rev. 5.4	389976		
70342737025	28-01-CR-IN-156-T	EPA 200.8, Rev. 5.4	389976		
70342737026	28-01-CR-IN-156-B	EPA 200.8, Rev. 5.4	389976		
70342737027	28-01-CR-IN-157-T	EPA 200.8, Rev. 5.4	389976		
70342737028	28-01-CR-IN-157-B	EPA 200.8, Rev. 5.4	389976		
70342737029	28-01-CR-IN-158-T	EPA 200.8, Rev. 5.4	389976		
70342737030	28-01-CR-IN-158-B	EPA 200.8, Rev. 5.4	389976		
70342737031	28-01-CR-IN-159-B	EPA 200.8, Rev. 5.4	389976		
70342737032	28-01-CR-IN-159-T	EPA 200.8, Rev. 5.4	389976		
70342737033	28-01-CR-IN-165-T	EPA 200.8, Rev. 5.4	389976		
70342737034	28-01-CR-IN-165-B	EPA 200.8, Rev. 5.4	389976		
70342737035	28-01-HA-BY-169-FL	EPA 200.8, Rev. 5.4	389976		
70342737036	28-01-HA-BY-169-FR	EPA 200.8, Rev. 5.4	389976		
70342737037	28-01-HA-BY-169-BF	EPA 200.8, Rev. 5.4	389976		
70342737038	28-01-CR-IN-168-T	EPA 200.8, Rev. 5.4	389976		
70342737039	28-01-CR-IN-168-B	EPA 200.8, Rev. 5.4	389976		
70342737040	28-01-CR-IN-169-T	EPA 200.8, Rev. 5.4	389976		
70342737041	28-01-CR-IN-169-B	EPA 200.8, Rev. 5.4	389977		
70342737042	28-01-KI-IN-110-T1	EPA 200.8, Rev. 5.4	389977		
70342737043	28-01-KI-IN-110-T2	EPA 200.8, Rev. 5.4	389977		
70342737044	28-01-KI-IN-110-T3	EPA 200.8, Rev. 5.4	389977		
70342737045	28-01-KI-IN-110-T4	EPA 200.8, Rev. 5.4	389977		
70342737046	28-01-KI-IN-110-T5	EPA 200.8, Rev. 5.4	389977		
70342737047	28-01-KI-IN-110-T6	EPA 200.8, Rev. 5.4	389977		
70342737048	28-01-KI-IN-110-T7	EPA 200.8, Rev. 5.4	389977		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: RCSD-School No.28(Henry Hudson)

Pace Project No.: 70342737

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70342737049	28-01-CF-IN-101-FL	EPA 200.8, Rev. 5.4	389977		
70342737050	28-01-CF-IN-101-FR	EPA 200.8, Rev. 5.4	389977		
70342737051	28-01-CF-IN-101-BF	EPA 200.8, Rev. 5.4	389977		
70342737052	28-02-CR-IN-225-T	EPA 200.8, Rev. 5.4	389977		
70342737053	28-02-CR-IN-232-T	EPA 200.8, Rev. 5.4	389977		
70342737054	28-02-CR-IN-232-B	EPA 200.8, Rev. 5.4	389977		
70342737055	28-02-CR-IN-233-T	EPA 200.8, Rev. 5.4	389977		
70342737056	28-02-CR-IN-233-B	EPA 200.8, Rev. 5.4	389977		
70342737057	28-02-RM-IN-234A-T	EPA 200.8, Rev. 5.4	389977		
70342737058	28-02-CR-IN-235-T	EPA 200.8, Rev. 5.4	389977		
70342737059	28-02-CR-IN-235-B	EPA 200.8, Rev. 5.4	389977		
70342737060	28-02-CR-IN-236-T	EPA 200.8, Rev. 5.4	389977		
70342737061	28-02-CR-IN-237-T	EPA 200.8, Rev. 5.4	390298		
70342737062	28-02-CR-IN-237-B	EPA 200.8, Rev. 5.4	390298		
70342737063	28-02-CR-IN-238-T	EPA 200.8, Rev. 5.4	390298		
70342737064	28-02-CR-IN-238-B	EPA 200.8, Rev. 5.4	390298		
70342737065	28-02-CR-IN-239-T	EPA 200.8, Rev. 5.4	390298		
70342737066	28-02-CR-IN-239-B	EPA 200.8, Rev. 5.4	390298		
70342737067	28-02-CR-IN-240-T	EPA 200.8, Rev. 5.4	390298		
70342737068	28-02-CR-IN-240-B	EPA 200.8, Rev. 5.4	390298		
70342737069	28-02-CR-IN-241-T	EPA 200.8, Rev. 5.4	390298		
70342737070	28-02-CR-IN-241B	EPA 200.8, Rev. 5.4	390298		
70342737071	28-02-CR-IN-242-T	EPA 200.8, Rev. 5.4	390298		
70342737072	28-02-CR-IN-242-B	EPA 200.8, Rev. 5.4	390298		
70342737073	28-02-CR-IN-245-T	EPA 200.8, Rev. 5.4	390298		
70342737074	28-02-CR-IN-245-B	EPA 200.8, Rev. 5.4	390298		
70342737075	28-02-HA-BY-247-F	EPA 200.8, Rev. 5.4	390298		
70342737076	28-02-HA-BY-247-BF	EPA 200.8, Rev. 5.4	390298		
70342737077	28-02-CR-IN-204A-T1	EPA 200.8, Rev. 5.4	390298		
70342737078	28-02-CR-IN-204A-T2	EPA 200.8, Rev. 5.4	390298		
70342737079	28-02-CR-IN-205-T	EPA 200.8, Rev. 5.4	390298		
70342737080	28-02-TC-IN-203-T	EPA 200.8, Rev. 5.4	390298		
70342737081	28-02-HA-BY-211-FL	EPA 200.8, Rev. 5.4	390300		
70342737082	28-02-HA-BY-211-FR	EPA 200.8, Rev. 5.4	390300		
70342737083	28-02-HA-BY-211-BF	EPA 200.8, Rev. 5.4	390300		
70342737084	28-02-CR-IN-212-T1	EPA 200.8, Rev. 5.4	390300		
70342737085	28-02-CR-IN-212-T2	EPA 200.8, Rev. 5.4	390300		
70342737086	28-02-CR-IN-212-T3	EPA 200.8, Rev. 5.4	390300		
70342737087	28-02-RM-IN-212A-T	EPA 200.8, Rev. 5.4	390300		
70342737088	28-02-CR-IN-214-T1	EPA 200.8, Rev. 5.4	390300		
70342737089	28-02-CR-IN-214-T2	EPA 200.8, Rev. 5.4	390300		
70342737090	28-02-CR-IN-214-T3	EPA 200.8, Rev. 5.4	390300		
70342737091	28-01-NO-IN-103-T	EPA 200.8, Rev. 5.4	390300		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 1 of 10

Page 37 of 47

LAB ID: M37287		REPORT TO:		INVOICE TO:	
PROJECT NAME: RCSD - School No. 28 (Henry Hudson)		Company: Lozier Environmental Consulting, Inc.		Company: (SAME)	
TURNAROUND TIME: Standard Rush		Address: 2011 East Main Street		Address:	
Other:		City/State Zip: Rochester NY 14609		City/State Zip:	
		Phone: 585-654-9080		Phone:	
		Fax: 585-654-9662		Fax:	
		E-Mail: support@lozierenv.com		Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS
1	28-01-CR-IN-106-T	3/4/2025	6:10		DW				Lead
2	28-01-CR-IN-123-T	3/4/2025	6:11		DW				
3	28-01-CR-IN-123-B	3/4/2025	6:12		DW				
4	28-01-CR-IN-124-T	3/4/2025	6:12		DW				
5	28-01-CR-IN-124-B	3/4/2025	6:13		DW				
6	28-01-CR-IN-128-T	3/4/2025	6:15		DW				
7	28-01-CR-IN-128-B	3/4/2025	6:15		DW				
8	28-01-CR-IN-129-T	3/4/2025	6:17		DW				
9	28-01-CR-IN-129-B	3/4/2025	6:18		DW				
10	28-01-HA-BY-103-F	3/4/2025	6:20		DW				

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

SAMPLED BY*: Joe Savice	DATE: 3/6/2025	TIME: 15:30
RELINQUISHED BY*: Joe Savice	DATE: 3/13/25	TIME: 1000
RECEIVED BY:	DATE:	TIME:
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FOR LAB USE ONLY		FOR POTABLE WATER ONLY:	
PRESERVATIVE/BIOCIDES: HNO3-	TOTAL NUMBER OF CONTAINERS: 91	COLIFORM BACTERIA:	
CUSTODY SEAL INTACT? YES		Present Absent	
SAMPLE ON ICE? NO		If Present, Date Client is	
TEMPERATURE: 13.1 C		contacted with result:	
SAMPLE IN COMPLIANCE: YES		Date: _____	
		Contacted By: _____	

FED EX GROUND
7726 3005 8448
7018 3 BOXES



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 2 of 10
70342737

Page 38 of 47

LAB ID: M37287		REPORT TO:		INVOICE TO:	
PROJECT NAME: RCSD - School No. 28 (Henry Hudson)		Company: Lozier Environmental Consulting, Inc.		Company: (SAME)	
TURNAROUND TIME: Standard Rush		Address: 2011 East Main Street		Address:	
Other:		City/State/Zip: Rochester NY 14609		City/State/Zip:	
Phone: 585-654-9080		Fax: 585-654-9662		Phone: Fax:	
E-Mail: support@lozierenv.com		Purchase Order #:			

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS				
11	28-01-HA-BY-103-BF	3/4/2025	6:20		DW				X				
12	28-01-HA-BY-131-FL	3/4/2025	6:23		DW				X				
13	28-01-HA-BY-131-FR	3/4/2025	6:24		DW				X				
14	28-01-HA-BY-131-BF	3/4/2025	6:24		DW				X				
15	28-01-CR-IN-133-TL	3/4/2025	6:30		DW				X				
16	28-01-CR-IN-133-TR	3/4/2025	6:30		DW				X				
17	28-01-CR-IN-151-T	3/4/2025	6:32		DW				X				
18	28-01-CR-IN-151-B	3/4/2025	6:32		DW				X				
19	28-01-CR-IN-152-T	3/4/2025	6:34		DW				X				
20	28-01-CR-IN-152-B	3/4/2025	6:35		DW				X				

Container Type (Circle One): Plastic Glass Sterile Other _____ Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

SAMPLED BY*: Joe Savioe

RELINQUISHED BY*: Joe Savioe DATE: 3/6/2025 TIME: 15:30

RECEIVED BY: Mark DATE: 3/6/25 TIME: 1000

RELINQUISHED BY*: DATE: TIME:

RECEIVED BY: DATE: TIME:

RELINQUISHED BY*: DATE: TIME:

RECEIVED BY: DATE: TIME:

FOR LAB USE ONLY		FOR POTABLE WATER ONLY:	
PRESERVATIVE/BIOCIDES: HNO3-		COLIFORM BACTERIA:	
TOTAL NUMBER OF CONTAINERS 91		Present	Absent
CUSTODY SEAL INTACT? YES		If Present, Date Client is contacted with result:	
SAMPLE ON ICE? NO		Date: _____	
TEMPERATURE: 15.1 C		Contacted By: _____	
SAMPLE IN COMPLIANCE: YES			

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis



LAB ID: M37287		Company: Lozier Environmental Consulting, Inc.		REPORT TO:		Company: (SAME)		INVOICE TO:	
PROJECT NAME: RCSD - School No. 28 (Henry Hudson)		Address: 2011 East Main Street				Address:			
TURNAROUND TIME: Standard Rush		City/State Zip: Rochester NY 14609				City/State Zip:			
Other:		Phone: 585-654-9080		Fax: 585-654-9662		Phone:		Fax:	
		E-Mail: support@lozierenv.com				Purchase Order #:			

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS				
21	28-01-CR-IN-154-T	3/4/2025	6:36		DW				X				
22	28-01-CR-IN-154-B	3/4/2025	6:37		DW				X				
23	28-01-CR-IN-155-T	3/4/2025	6:38		DW				X				
24	28-01-CR-IN-155-B	3/4/2025	6:39		DW				X				
25	28-01-CR-IN-156-T	3/4/2025	6:41		DW				X				
26	28-01-CR-IN-156-B	3/4/2025	6:41		DW				X				
27	28-01-CR-IN-157-T	3/4/2025	6:41		DW				X				
28	28-01-CR-IN-157-B	3/4/2025	6:42		DW				X				
29	28-01-CR-IN-158-T	3/4/2025	6:43		DW				X				
30	28-01-CR-IN-158-B	3/4/2025	6:43		DW				X				

Container Type (Circle One): Plastic Glass Sterile Other _____ Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

SAMPLED BY*: Joe Savio

RELINQUISHED BY*: Joe Savio

RECEIVED BY*: John

RELINQUISHED BY*:

RECEIVED BY:

RELINQUISHED BY*:

RECEIVED BY:

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDE: HNO3-	FOR POTABLE WATER ONLY:
TOTAL NUMBER OF CONTAINERS: 91	COLIFORM BACTERIA:
CUSTODY SEAL INTACT? YES	Present Absent
SAMPLE ON ICE? NO	If Present, Date Client is
TEMPERATURE: 13 C	contacted with result:
SAMPLE IN COMPLIANCE: YES	Date: _____
	Contacted By: _____

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis



70342737

LAB ID: M37287		REPORT TO:		INVOICE TO:	
PROJECT NAME: RCSD - School No. 28 (Henry Hudson)		Company: Lozier Environmental Consulting, Inc.		Company: (SAME)	
TURNAROUND TIME: Standard Rush		Address: 2011 East Main Street		Address:	
Other:		City/State Zip: Rochester NY 14609		City/State Zip:	
		Phone: 585-654-9080		Phone:	
		Fax: 585-654-9662		Fax:	
		E-Mail: support@lozierenv.com		Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS				
31	28-01-CR-IN-159-B	3/4/2025	6:45		DW				Lead				
32	28-01-CR-IN-159-T	3/4/2025	6:45		DW				X				
33	28-01-CR-IN-165-T	3/4/2025	6:47		DW				X				
34	28-01-CR-IN-165-B	3/4/2025	6:47		DW				X				
35	28-01-HA-BY-169-FL	3/4/2025	6:48		DW				X				
36	28-01-HA-BY-169-FR	3/4/2025	6:49		DW				X				
37	28-01-HA-BY-169-BF	3/4/2025	6:49		DW				X				
38	28-01-CR-IN-168-T	3/4/2025	6:50		DW				X				
39	28-01-CR-IN-168-B	3/4/2025	6:51		DW				X				
40	28-01-CR-IN-169-T	3/4/2025	6:53		DW				X				

Container Type (Circle One): Plastic Glass Sterile Other _____
Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

SAMPLED BY*: Joe Savio	DATE: 3/6/2025	TIME: 15:30
RELINQUISHED BY*: Joe Savio	DATE: 3/13/25	TIME: 10:00
RECEIVED BY*: <i>Alia H...</i>	DATE: 3/13/25	TIME: 10:00
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:

FOR LAB USE ONLY		FOR POTABLE WATER ONLY:	
PRESERVATIVE/BIOCIDE: HNO3-		COLIFORM BACTERIA:	
TOTAL NUMBER OF CONTAINERS 91		Present	Absent
CUSTODY SEAL INTACT? YES		If Present, Date Client is contacted with result:	
SAMPLE ON ICE? NO		Date: _____	Contacted By: _____
TEMPERATURE: 3.1 C			
SAMPLE IN COMPLIANCE: YES			

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 5 of 10
70342737

LAB ID: M37287		REPORT TO:		INVOICE TO:	
PROJECT NAME: RCSD - School No. 28 (Henry Hudson)		Company: Lozier Environmental Consulting, Inc.		Company: (SAME)	
TURNAROUND TIME: Standard Rush		Address: 2011 East Main Street		Address:	
Other:		City/State Zip: Rochester NY 14609		City/State Zip:	
		Phone: 585-654-9080		Phone:	
		Fax: 585-654-9662		Fax:	
		E-Mail: support@lozierenv.com		Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS				
41	28-01-CR-IN-169-B	3/4/2025	6:53					island prep sink	X				
42	28-01-KI-IN-110-T1	3/4/2025	6:56					hand wash sink	X				
43	28-01-KI-IN-110-T2	3/4/2025	6:56					island prep sink	X				
44	28-01-KI-IN-110-T3	3/4/2025	6:57					hand wash sink	X				
45	28-01-KI-IN-110-T4	3/4/2025	6:58					hand wash sink	X				
46	28-01-KI-IN-110-T5	3/4/2025	6:58					hand wash sink	X				
47	28-01-KI-IN-110-T6	3/4/2025	7:01					hand wash sink	X				
48	28-01-KI-IN-110-T7	3/4/2025	7:01					hand wash sink	X				
49	28-01-CF-IN-101-FL	3/4/2025	7:01					hand wash sink	X				
50	28-01-CF-IN-101-FR	3/4/2025	7:02					hand wash sink	X				

Container Type (Circle One): Plastic Glass Sterile Other _____ Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

SAMPLED BY*: Joe Savio	DATE: 3/6/2025	TIME: 15:30
RELINQUISHED BY*: Joe Savio	DATE: 3/13/25	TIME: 10:00
RECEIVED BY*: <i>[Signature]</i>	DATE: 3/13/25	TIME: 10:00
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FOR LAB USE ONLY		FOR POTABLE WATER ONLY:	
PRESERVATIVE/BIOCIDE: HNO3-	TOTAL NUMBER OF CONTAINERS 91	COLIFORM BACTERIA:	
CUSTODY SEAL INTACT? YES	SAMPLE ON ICE? NO	Present	Absent
TEMPERATURE: 35.6 C	SAMPLE IN COMPLIANCE: YES	If Present, Date Client is contacted with result:	
		Date: _____	
		Contacted By: _____	



2011 East Main Street, Rochester, NY 14609
Web: LozierEnv.com

Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 6 of 10
70342737

LAB ID: M37287		REPORT TO:		INVOICE TO:	
PROJECT NAME: RCSD - School No. 28 (Henry Hudson)		Company: Lozier Environmental Consulting, Inc.		Company: (SAME)	
TURNAROUND TIME: Standard Rush		Address: 2011 East Main Street		Address:	
Other:		City, State Zip: Rochester NY 14609		City, State Zip:	
		Phone: 585-654-9080		Phone:	
		Fax: 585-654-9662		Fax:	
		E-Mail: support@lozierenv.com		Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	Lead	REQUESTED ANALYSIS			
51	28-01-CF-IN-101-BF	3/4/2025	7:04		DW				x				
52	28-02-CR-IN-225-T	3/4/2025	7:10		DW				x				
53	28-02-CR-IN-232-T	3/4/2025	7:11		DW				x				
54	28-02-CR-IN-232-B	3/4/2025	7:11		DW				x				
55	28-02-CR-IN-233-T	3/4/2025	7:12		DW				x				
56	28-02-CR-IN-233-B	3/4/2025	7:13		DW				x				
57	28-02-RM-IN-234A-T	3/4/2025	7:15		DW				x				
58	28-02-CR-IN-235-T	3/4/2025	7:16		DW				x				
59	28-02-CR-IN-235-B	3/4/2025	7:16		DW				x				
60	28-02-CR-IN-236-T	3/4/2025	7:18		DW				x				

Container Type (Circle One): Plastic Glass Sterile Other _____ Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

SAMPLED BY*: Joe Savio	DATE: 3/6/2025	TIME: 15:30
RELINQUISHED BY*: Joe Savio	DATE: 3/13/25	TIME: 1000
RECEIVED BY: <i>[Signature]</i>	DATE: 3/13/25	TIME: 1000
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:
RELINQUISHED BY*:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

FOR LAB USE ONLY		FOR POTABLE WATER ONLY:	
PRESERVATIVE/BIOCIDES: HNO3	TOTAL NUMBER OF CONTAINERS: 91	COLIFORM BACTERIA:	Present Absent
CUSTODY SEAL INTACT? YES	SAMPLE ON ICE? NO	If Present, Date Client is contacted with result:	
TEMPERATURE: 3.2 C	SAMPLE IN COMPLIANCE: YES	Date:	
		Contacted By:	



2011 East Main Street, Rochester, NY 14609 Phone (585) 654-9080 Fax (585) 654-9662
Web: LozierEnv.com E-Mail: support@lozierenv.com

Page 1 of 10
70342737

LAB ID: M37287		REPORT TO:		INVOICE TO:	
PROJECT NAME: RCSD - School No. 28 (Henry Hudson)		Company: Lozier Environmental Consulting, Inc.		Company: (SAME)	
TURNAROUND TIME: Standard Rush		Address: 2011 East Main Street		Address:	
Other:		City/State/Zip: Rochester NY 14609		City/State/Zip:	
		Phone: 585-654-9080		Phone:	
		Fax: 585-654-9662		Fax:	
		E-Mail: support@lozierenv.com		Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS			
61	28-02-CR-IN-237-T	3/4/2025	7:20		DW				Lead			
62	28-02-CR-IN-237-B	3/4/2025	7:21		DW				X			
63	28-02-CR-IN-238-T	3/4/2025	7:21		DW				X			
64	28-02-CR-IN-238-B	3/4/2025	7:22		DW				X			
65	28-02-CR-IN-239-T	3/4/2025	7:22		DW				X			
66	28-02-CR-IN-239-B	3/4/2025	7:24		DW				X			
67	28-02-CR-IN-240-T	3/4/2025	7:24		DW				X			
68	28-02-CR-IN-240-B	3/4/2025	7:25		DW				X			
69	28-02-CR-IN-241-T	3/4/2025	7:25		DW				X			
70	28-02-CR-IN-241B	3/4/2025	7:25		DW				X			

Container Type (Circle One): Plastic Glass Sterile Other _____
Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

SAMPLED BY*: Joe Savioe
RELINQUISHED BY*: Joe Savioe
RECEIVED BY*: Joe Savioe
RELINQUISHED BY*:
RECEIVED BY*:
RELINQUISHED BY*:
RECEIVED BY*:
DATE: 3/6/2025 TIME: 15:30
DATE: 3/3/25 TIME: 1000
DATE: TIME:
DATE: TIME:
DATE: TIME:
DATE: TIME:

FOR LAB USE ONLY		FOR POTABLE WATER ONLY:	
PRESERVATIVE/BIOCIDES: HNO3-		COLIFORM BACTERIA:	
TOTAL NUMBER OF CONTAINERS: 91		Present Absent	
CUSTODY SEAL INTACT? YES		If Present, Date Client is contacted with result:	
SAMPLE ON ICE? NO		Date: _____	
TEMPERATURE: 32 C		Contacted By: _____	
SAMPLE IN COMPLIANCE: YES			

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis



2011 East Main Street, Rochester, NY 14609 Phone (585) 654-9080 Fax (585) 654-9662
Web: LozierEnv.com E-Mail: support@lozierenv.com

Page 8 of 10
70342737

LAB ID: M37287	Company: Lozier Environmental Consulting, Inc.	Address: 2011 East Main Street	City/State/Zip: Rochester NY 14609	Phone: 585-654-9080	Fax: 585-654-9662	City/State/Zip:	Phone:	Fax:
PROJECT NAME: RCSD - School No. 28 (Henry Hudson)	REPORT TO:			INVOICE TO:		Purchase Order #:		
TURNAROUND TIME: Standard Rush	E-Mail: support@lozierenv.com							

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS			
71	28-02-CR-IN-242-T	3/4/2025	7:26		DW				Lead			
72	28-02-CR-IN-242-B	3/4/2025	7:26		DW							
73	28-02-CR-IN-245-T	3/4/2025	7:28		DW							
74	28-02-CR-IN-245-B	3/4/2025	7:28		DW							
75	28-02-HA-BY-247-F	3/4/2025	7:29		DW							
76	28-02-HA-BY-247-BF	3/4/2025	7:29		DW							
77	28-02-CR-IN-204A-T1	3/4/2025	7:30		DW							
78	28-02-CR-IN-204A-T2	3/4/2025	7:30		DW							
79	28-02-CR-IN-205-T	3/4/2025	7:31		DW							
80	28-02-TC-IN-203-T	3/4/2025	7:32		DW							

Container Type (Circle One): Plastic Glass Sterile Other _____ Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

SAMPLED BY: Joe Savioe	DATE: 3/6/2025	TIME: 15:30
RELINQUISHED BY: Joe Savioe	DATE: 3/13/25	TIME: 1000
RECEIVED BY: <i>Mike</i>	DATE:	TIME:
RELINQUISHED BY:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:
RELINQUISHED BY:	DATE:	TIME:
RECEIVED BY:	DATE:	TIME:

FOR LAB USE ONLY		FOR POTABLE WATER ONLY:	
PRESERVATIVE/BIOCIDE: HNO3-		COLIFORM BACTERIA:	
TOTAL NUMBER OF CONTAINERS: 91		Present	Absent
CUSTODY SEAL INTACT? YES		If Present, Date Client is contacted with result:	
SAMPLE ON ICE? NO		Date: _____	
TEMPERATURE: 3.1 C		Contacted By: _____	
SAMPLE IN COMPLIANCE: YES			

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis



2011 East Main Street, Rochester, NY 14609 Phone (585) 654-9080 Fax (585) 654-9662
Web: LozierEnv.com E-Mail: support@lozierenv.com

Page 9 of 10
70342737

LAB ID: M37287
PROJECT NAME: RCSD - School No. 28 (Henry Hudson)
TURNAROUND TIME: Standard Rush
Other:

REPORT TO:		INVOICE TO:	
Company:	Lozier Environmental Consulting, Inc.	Company: (SAME)	
Address:	2011 East Main Street	Address:	
City/State Zip:	Rochester NY 14609	City/State Zip:	
Phone:	585-654-9080	Phone:	
Fax:	585-654-9662	Fax:	
E-Mail:	support@lozierenv.com	Purchase Order #:	

LAB ID (Lab Use Only)	SAMPLE DESCRIPTION / LOCATION	DATE	TIME	AIR	WATER: P=Potable NP=Non-Potable	SOIL / SOLID	WIPE / SWAB / TAPE LIFT	SAMPLE COMMENTS	REQUESTED ANALYSIS				
81	28-02-HA-BY-211-FL	3/4/2025	7:32		DW				Lead				
82	28-02-HA-BY-211-FR	3/4/2025	7:33		DW				X				
83	28-02-HA-BY-211-BF	3/4/2025	7:33		DW				X				
84	28-02-CR-IN-212-T1	3/4/2025	7:34		DW				X				
85	28-02-CR-IN-212-T2	3/4/2025	7:34		DW				X				
86	28-02-CR-IN-212-T3	3/4/2025	7:35		DW				X				
87	28-02-RM-IN-212A-T	3/4/2025	7:32		DW				X				
88	28-02-CR-IN-214-T1	3/4/2025	7:38		DW				X				
89	28-02-CR-IN-214-T2	3/4/2025	7:39		DW				X				
90	28-02-CR-IN-214-T3	3/4/2025	7:39		DW				X				

Container Type (Circle One): Plastic Glass Sterile Other _____
Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

SAMPLED BY*: Joe Savio
RELINQUISHED BY*: Joe Savio
RECEIVED BY*: *John*
RELINQUISHED BY*:
RECEIVED BY: DATE: 3/6/2025 TIME: 15:30
RELINQUISHED BY*: DATE: 3/4/25 TIME: 1000
RECEIVED BY: DATE: TIME:
RELINQUISHED BY*: DATE: TIME:
RECEIVED BY: DATE: TIME:

FOR LAB USE ONLY		FOR POTABLE WATER ONLY:	
PRESERVATIVE/BIOCIDE: HNO3-		COLIFORM BACTERIA:	
TOTAL NUMBER OF CONTAINERS: 91		Present	Absent
CUSTODY SEAL INTACT? YES		If Present, Date Client is contacted with result:	
SAMPLE ON ICE? NO		Date: _____	Contacted By: _____
TEMPERATURE: 51 C			
SAMPLE IN COMPLIANCE: YES			

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis



Phone (585) 654-9080 Fax (585) 654-9662
E-Mail: support@lozierenv.com

Page 10 of 10
7034273-46 of 47

	
Environmental Consulting, Inc.	
REPORT TO:	
Company:	Lozier Environmental Consulting, Inc.
Address: 2011 East Main Street	
City/State Zip:	Rochester NY 14609
Phone:	585-654-9080
Fax:	585-654-9662
E-Mail:	support@lozierenv.com
INVOICE TO:	
Company: (SAME)	
Address:	
City/State Zip:	
Phone:	
Fax:	
Purchase Order #:	

[illegible]

Container Type (Circle One): Plastic Glass Sterile Other _____

Delivery (Circle One): Client Drop-Off / Courier (Tracking # _____)

SAMPLED BY* Joe Savio

RELINQUISHED BY*: Joe Sayoe
DATE: 3/6/2025 TIME: 15:30

RECEIVED BY: Wm DATE: 3/3/75 TIME: 1000

RELINQUISHED BY*: _____ DATE: _____ TIME: _____

RECEIVED BY: _____ DATE: _____ TIME: _____

RELINQUISHED BY: _____ DATE: _____ TIME: _____

RECEIVED BY: _____ DATE: _____ TIME: _____

FOR LAB USE ONLY	
PRESERVATIVE/BIOCIDES: HNO ₃ TOTAL NUMBER OF CONTAINERS: 91 CUSTODY SEAL INTACT? YES SAMPLE ON ICE? NO TEMPERATURE: 3.1 °C SAMPLE IN COMPLIANCE: YES	FOR POTABLE WATER ONLY: COLIFORM BACTERIA: Present Absent If Present, Date Client is contacted with result: Date: _____ Contacted By: _____

*The above signatures hereby authorize subcontracting of samples as required for laboratory analysis

WO#: 70342737

CUR)

Project #

PM: RC1

Due Date: 03/27/25

Client:

CLIENT: NB-LOZIER

Date and Initials of person:

Examining contents: _____

Label: _____

Deliver to location: _____

pH: _____

Thermometer Used: IRG4

Date: 3/13

Time: 1000

Initials: _____

State of Origin: NY

Cooler #1 Temp. °C 13.1 (Visual) 0.2 @ 0.0°C, -0.5 @ 20.0°C (Correction Factor) (Actual) ☒ Samples on ice, cooling process has begun

Courier: ☒ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☐ Pace ☐ Other _____

Shipping Method: ☐ First Overnight ☐ Priority Overnight ☐ Standard Overnight ☐ Ground

☐ Other _____

Tracking # _____

Custody Seal on Cooler/Box Present: ☐ Yes ☐ No

Seals intact: ☐ Yes ☐ No

Ice: ☒ Wet ☐ Blue ☐ Melted ☐ None

Packing Material: ☐ Bubble Wrap ☐ Bubble Bags ☐ None ☐ Other _____

Samples were collected by Pace employee ☐ Yes ☐ No ☐ N/A

Comments:

Chain of Custody Present	☒ Yes ☐ No ☐ N/A	
Chain of Custody Filled Out	☒ Yes ☐ No ☐ N/A	
Relinquished Signature on COC	☒ Yes ☐ No ☐ N/A	
Sampler Name and Signature on COC	☒ Yes ☐ No ☐ N/A	
Samples Arrived within Hold Time	☒ Yes ☐ No ☐ N/A	
Rush TAT requested on COC	☐ Yes ☐ No ☐ N/A	
Sufficient Volume	☒ Yes ☐ No ☐ N/A	
Correct Containers Used	☒ Yes ☐ No ☐ N/A	
Containers Intact	☒ Yes ☐ No ☐ N/A	
Sample Labels match COC (sample IDs & date/time of collection)	☒ Yes ☐ No ☐ N/A	
All containers needing acid/base preservation have been checked.	☐ Yes ☐ No ☐ N/A	Preservation Information:
All Containers needing preservation are found to be in compliance with EPA recommendation:	☐ Yes ☐ No ☐ N/A	Preservative: _____
Exceptions: Vials, Microbiology, O&G, Metals		Lot #/Trace #: _____
		Date: _____ Time: _____
		Initials: _____
Headspace in VOA Vials? (>6mm):	☐ Yes ☐ No ☐ N/A	
Trip Blank Present:	☐ Yes ☐ No ☐ N/A	

Additional Login Comments:

Client notification/ Resolution

Person Contacted: _____ Date/Time: _____

Comments/Resolution: _____