



1515 80th St. E.
Tacoma, WA 98404
(253) 531-3121

Lead and Copper Distribution System - Report of Analyses

Lead and Copper Analysis (LCR)	System Group Type: (circle one) A B <u>Other</u>
Water System ID Number: NA	System Name: PASD
Source: S93 (standing distribution samples)	County: Clallam
	Consecutive System? YES NO
Sample Purpose: (check appropriate box) ☒ RC - Routine/Compliance (satisfies monitoring requirements) ☐ C - Confirmation (confirmation of chemical result)* ☐ I - Investigative (does not satisfy monitoring requirements) ☐ O - Other (specify - does not satisfy monitoring requirements)	Date Received: 09-09-2026 Date Analyzed: 09-14-2026 Date Reported: 09-23-2026 Supervisor Initials: <i>amb</i>
Sample Composition: (check appropriate box) ☐ S - Single Source ☐ B - Blended (list sources in "Source Number" field) ☐ C - Composite (list sources in "Source Number" field) ☒ D - Distribution Sample	Sample Type: (check one) ☐ Pre-treatment/Untreated (Raw) ☒ Post-treatment (Finished) ☐ Unknown or Other Contact Name: Amy Costello Phone Number: 360-478-6897
Send Report & Bill to: Olympic Educational Service District 114 105 National Avenue N, Bremerton WA 98312	Comments:

ANALYTICAL RESULTS

(DOH #) Analyte	(0009) Lead	(0023) Copper
State Detection Reporting Level (SDRL) (mg/L)	0.001	0.02
Regulatory Action Level (mg/L)**	0.015	1.3
Analytical Method / Analyst's Initials	200.8/CP	200.8/NA

Lab Number / Sample Number ____/____	Date Collected	Sample Location:	Lead (mg/L)	Copper (mg/L)
089 / 08073	09-04-2026	RES, 418614	<0.0010	NA
089 / 08074	09-04-2026	RES, Monroe Athletic Portable	<0.0010	NA
089 / 08075	09-04-2026	HS Concessions, 418699	<0.0010	NA
089 / 08076	09-04-2026	HS, 418680	0.0066	NA
089 / 08077	09-04-2026	HS, 418679	0.0049	NA
089 / 08078	09-04-2026	HS, 418689	<0.0010	NA
089 / 08079	09-04-2026	HS, 418690	<0.0010	NA
089 / 08080	09-04-2026	HS, 418685	<0.0010	NA
089 / 08081	09-04-2026	DES, 418647	0.0010	NA
089 / 08082	09-04-2026	DES, 418644	0.0014	NA
089 / 08083	09-09-2026	HS Girls Locker Rm	0.0104	NA

NOTES:

***Regulatory Action Level for schools and daycare facilities is 0.020 mg/L for Lead**

Confirmation: Include the original lab number, sample number, and collection date of original sample in either comment section

mg/L: milligrams per liter or parts per million

Regulatory Action level: The concentraion against which the 90th percentile of all distribution samples collected during the monitoring period that, if exceeded, signals the system is in violation.

SDRL (State Detection Reporting Level): The minimum reporting level established by the department.

LAB COMMENTS AND DATA QUALIFIERNote data qualifiers next to the individual result. Note the definition of the qualifiers here: