



Environmental Laboratories, Inc.
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045
Tel. (860) 645-1102



Analysis Report

September 10, 2026

FOR: Attn: Roy Barticciotto
CEMCO Water & Wastewater Specialists Inc
122 Grapehollow Rd
Holmes, NY 12531

Sample Information

Matrix: DRINKING WATER
Location Code: CEMCO
Rush Request: Standard
P.O.#: NY-5907717

Custody Information

Collected by:
Received by: CP
Analyzed by: see "By" below

Date	Time
09/01/26	8:00
09/02/26	17:19

Laboratory Data

SDG ID: GCW98079
Phoenix ID: CW98079

Project ID: PQ SCHOOLS PB
Client ID: ES-008

Parameter	Result	RL/ PQL	DIL	Units	AL	MCL	MCLG	Date/Time	By	Reference
Copper	0.008	0.002	1	mg/L	1.3		1	09/10/26	TH	E200.7
Lead	< 0.0010	0.0010	1	mg/L	0.015			09/10/26	TH	E200.5
Total Metal Digestion	Completed							09/08/26	BF	E200.5/E200.7

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected
BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)
AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Action Level (AL): (Lower of): 40 CFR Part 141.80 Lead & Copper ALs; New York State Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): 40 CFR Part 143 Secondary Goals. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If you are the client above and have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext.200. The contents of this report cannot be discussed with anyone other than the client listed above without their written consent.

Phyllis Shiller, Laboratory Director

September 10, 2026

Reviewed and Released by: Anil Makol, Project Manager